

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9902180079      DOC. DATE: ~~99/01/31~~ NOTARIZED: NO      DOCKET #  
FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina      05000400  
AUTH. NAME      AUTHOR AFFILIATION  
ROGERS, S.      Carolina Power & Light Co.  
ALEXANDER, D.B.      Carolina Power & Light Co.,  
RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1999 for Shearon Harris Nuclear Power Plant. With 990211 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
TITLE: Monthly Operating Report (per Tech Specs)

NOTES: Application for permit renewal filed.      05000400E

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	FLANDERS, S	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RRAB	1 1
	<u>ELLE CENTER 01</u>	1 1	OC/DBA/PAD	1 1
	RGN2	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

**MICROFILMED**

NOTE TO ALL "RIDS" RECIPIENTS:  
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR



Carolina Power & Light Company  
Harris Nuclear Plant  
P.O. Box 165  
New Hill NC 27562

FEB 11 1999

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

Serial: HNP-99-020

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
MONTHLY OPERATING REPORT

Dear Sir or Madam:

In accordance with Carolina Power & Light Company's Harris Nuclear Plant Technical Specification 6.9.1.5, the report of operating statistics and shutdown experience for the month of January 1999 is provided.

Sincerely,

D. B. Alexander  
Manager, Regulatory Affairs  
Harris Plant

SGR

Enclosure

- c: Mr. J. B. Brady - NRC Senior Resident Inspector
- Mr. S. C. Flanders - NRC Project Manager
- Mr. L. A. Reyes - NRC Regional Administrator

9902180079 990131  
PDR ADDCK 05000400  
R PDR

170085

CP&L CO.  
RUN DATE 02/03/99  
RUN TIME 11:37:33

PLANT PERFORMANCE DATA SYSTEM  
OPERATING DATA REPORT  
HARRIS UNIT 1

PAGE 1  
RPD36-000

DOCKET NO. 050-400  
COMPLETED BY SHEILA ROGERS  
TELEPHONE (919) 362-2573

OPERATING STATUS

1. UNIT NAME: HARRIS UNIT 1
2. REPORTING PERIOD: JANUARY 99
3. LICENSED THERMAL POWER (MWT): 2775
4. NAMEPLATE RATING (GROSS MWE): 950.9
5. DESIGN ELECTRICAL RATING (NET MWE): 900.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 920.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 860.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS:
  
9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE):
10. REASONS FOR RESTRICTION IF ANY:

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	744.00	103033.00
12. NUMBER OF HOURS REACTOR CRITICAL	719.68	719.68	86945.29
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	.00
14. HOURS GENERATOR ON LINE	700.43	700.43	86086.04
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	.00
16. GROSS THERMAL ENERGY GEN. (MWH)	1906265.16	1906265.16	231325989.12
17. GROSS ELEC. ENERGY GEN (MWH)	639389.00	639389.00	76983426.00
18. NET ELEC. ENERGY GENERATED (MWH)	598552.00	598552.00	71835424.00
19. UNIT SERVICE FACTOR	94.14	94.14	83.55
20. UNIT AVAILABILITY FACTOR	94.14	94.14	83.55
21. UNIT CAP. FACTOR (USING MDC NET)	93.55	93.55	81.07
22. UNIT CAP. FACTOR (USING DER NET)	89.39	89.39	77.47
23. UNIT FORCED OUTAGE RATE	5.86	5.86	3.12
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY

\_\_\_\_\_

INITIAL ELECTRICITY

\_\_\_\_\_

COMMERCIAL OPERATION

\_\_\_\_\_

Faint, illegible text at the top of the page, possibly a header or title area.

Second section of faint, illegible text in the upper middle portion of the page.

Third section of faint, illegible text in the middle portion of the page.

Fourth section of faint, illegible text in the lower middle portion of the page.

Fifth section of faint, illegible text at the bottom of the page.

CP&L CO.  
RUN DATE 02/03/99  
RUN TIME 11:37:32

PLANT PERFORMANCE DATA SYSTEM  
APPENDIX B - AVERAGE DAILY POWER LEVEL  
HARRIS UNIT 1

PAGE 1  
RPD39-000

DOCKET NO. 050-400  
COMPLETED BY SHEILA ROGERS  
TELEPHONE (919) 362-2573

JANUARY 1999

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	883	17	859
2	858	18	861
3	857	19	872
4	884	20	871
5	884	21	870
6	881	22	866
7	880	23	834
8	880	24	867
9	875	25	876
10	883	26	878
11	880	27	873
12	877	28	871
13	874	29	876
14	318	30	880
15	-40	31	882
16	231		

UNIT SHUTDOWNS AND POWER REDUCTION

UNIT NAME: Harris  
 DATE: 01/31/99  
 COMPLETED BY: S. G. Rogers  
 TELEPHONE: (919) 362-2573

REPORT MONTH: January 1999

NUMBER	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
99-001	01/14/99	F	43.57	B	3	99-02	ED	RELAYX	Plant trip occurred 1/14/99 when workers were performing preventive maintenance on 'A' Auxiliary bus. Ramp-up began 1/16/99 @ 04:52 and the plant was returned to 100% power on 1/17/99 @ 04:00.

1  
 F: Forced  
 S: Scheduled

2  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Continued  
 5-Reduced Load  
 6-Other

4  
 Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)  
 5  
 Exhibit 1 - Same Source

