

ENCLOSURE 5 TO SERIAL: HNP-99-082

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
REQUEST FOR LICENSE AMENDMENT
REVISION TO TECHNICAL SPECIFICATION 6.2.2.e - OPERATIONS MANAGEMENT
LICENSE REQUIREMENTS

TECHNICAL SPECIFICATION PAGE

Page E5-1

9908060229 990802
PDR ADOCK 05000400
P PDR



UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on-duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1;
- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3, or 4, at least one licensed Senior Operator shall be in the control room;
- c. An individual qualified as a Radiation Control Technician shall be on site when fuel is in the reactor;

d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Operator or licensed Senior Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation;

or an off-shift operations superintendent Add

e. The Manager-Operations shall either hold a Senior Reactor Operator License or have at one time held a Senior Reactor Operator License Delete for a similar unit If the Manager-Operations does not hold a Senior Reactor Operator License, an off-shift Operations superintendent who reports directly to the Manager-Operations and holds a Senior Reactor Operator License shall be designated to supervise shift work and licensed activities.

The Radiation Control Technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.



11

11

11

11

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on-duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1;
- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3, or 4, at least one licensed Senior Operator shall be in the control room;
- c. An individual qualified as a Radiation Control Technician* shall be on site when fuel is in the reactor;
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Operator or licensed Senior Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation;
- e. The Manager-Operations or an off-shift Operations superintendent shall hold a Senior Reactor Operator License. If the Manager-Operations does not hold a Senior Reactor Operator License, an off-shift Operations superintendent who reports directly to the Manager-Operations and holds a Senior Reactor Operator License shall be designated to supervise shift work and licensed activities.

The Radiation Control Technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.