

# PRIORITY 1

(ACCELERATED RIDS PROCESSING)

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9507170334      DOC. DATE: 95/07/10      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv      05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388

AUTH. NAME      AUTHOR AFFILIATION  
 BYRAM, R.G.      Pennsylvania Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Documents response to verbal questions from NRC on util move of EOF to Northeast Division Headquarters.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0      SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: 05000387

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	1		PD1-2 PD		1	1
	POSLUSNY, C		1	1					
INTERNAL:	ACRS		6	6		FILE CENTER 01		1	1
	NRR/DE/EMCB		1	1		NRR/DRCH/HICB		1	1
	NRR/DSSA/SPLB		1	1		NRR/DSSA/SRXB		1	1
	NUDOCS-ABSTRACT		1	1		OGC/HDS2		1	0
EXTERNAL:	NOAC		1	1		NRC PDR		1	1
NOTES:			1	1					

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
 DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL ~~18~~ 0



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 610/774-5151

Robert G. Byram  
Senior Vice President-Nuclear  
610/774-7502  
Fax: 610/774-5019

JUL 10 1995

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**RESPONSE TO NRC QUESTIONS ON EOF MOVE**  
**PLA-4334** **FILE R41-2**

Docket Nos. 50-387  
and 50-388

This letter documents the response to verbal questions from the NRC Staff on Pennsylvania Power & Light Company's move of the EOF to its Northeast Division Headquarters.

- 1) ERDS for both units will continue to be activated from the existing EOF (near site) until the completion of the installation of PICSY on Unit 2. At that time the ERDS for Unit 2 will be activated from the TSC and ERDS for Unit 1 will continue to be activated from the existing EOF (near site). After the completion of the installation of PICSY on Unit 1, ERDS for both units will be activated from the TSC.
- 2) The timing of the move to the new EOF is contingent upon NRC approval. Therefore if the move to the new EOF takes place before or after the Unit 2 Refueling and Inspection Outage, ERDS for both units will be fully available during the move. If the EOF is moved during the Unit 2 Refueling and Inspection Outage, the ERDS for Unit 1 will be fully available and except for the points for the ERDS for Unit 2 which are generated in the Plant Computer (23 of 70 points) the ERDS for Unit 2 will be available.
- 3) Existing ERDS data is not changed due to either the PICSY project or the EOF move.
- 4) ERDS will remain compatible with the NRC computer system.
- 5) As discussed in the meeting held on June 13, 1995, with our Licensing personnel, we will be setting up a meeting in a couple of weeks to discuss the time to man the EOF.
- 6) The 2 1/2 hour EOF manning time addresses both off hours and normal work hours.

9507170334 950710  
PDR ADDCK 05000387  
P PDR


Aool  
1/0

- 7) The State and local officials have been involved in the relocation effort. All have agreed in principle to the relocation. Only Luzerne County has agreed in writing. The counties and State will be invited to participate in the validation and verification of the new facility.

The host county has signed saying they are aware of the move and are involved in efforts to coordinate the move. We expect State and local officials to sign letters of agreement after EOF validation and verification.

If you any questions, please contact Mr. C. T. Coddington at (610) 774-7531.

Very truly yours,



R. G. Byram

copy: NRC Region I  
Ms. M. Banerjee, NRC Sr. Resident Inspector  
Mr. C. Poslusny, NRC Sr. Project Manager

