

- REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8003180521      DOC. DATE: 80/03/13      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv      05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388  
 AUTH. NAME      AUTHOR AFFILIATION  
 CURTIS, N.W.      Pennsylvania Power & Light Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
 PARR, O.D.      Light Water Reactors Branch 3

SUBJECT: Discusses use of N-234 & N-235 Code cases during preservice exam of reactor pressure vessel scheduled during Aug 1980. Requests response if objection are raised to use of codes.

DISTRIBUTION CODE: B001B      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: PSAR/FSAR AMDS and Related Correspondence

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
ACTION:	05 PM <u>MINER</u>	1		AD <u>LWR</u>	1	
	8C <u>LWR 3</u>	1		LA <u>LWR 3</u>	1	
INTERNAL:	01 REG FILE	1		02 NRC PDR	1	
	06 I & E	3		08 OPERA LIC BR	1	
	09 GEOSCIEN BR	4		10 QAB	1	
	11 MECH ENG BR	1		12 STRUC ENG BR	1	
	13 MATL ENG BR	2	2	15 REAC SYS BR	1	
	16 ANALYSIS BR	1	1	17 CORE PERF BR	1	
	18 AUX SYS BR	1	1	19 CONTAIN SYS	1	
	20 I & C SYS BR	1	1	21 POWER SYS BR	1	
	22 AD SITE TECH	1		26 ACCDNT ANLYS	1	
	27 EFFL TRT SYS	1		28 RAD ASMT BR	1	
	29 KIRKWOOD	1		AD FOR ENG	1	
	AD PLANT SYS	1		AD REAC SAFETY	1	
	AD SITE ANLYSIS	1		DIRECTOR NRR	1	
	HYDRO-METEOR BR	2	2	MPA	1	
OELD	1					
EXTERNAL:	03 LPDR	1		04 NSIC	1	
	30 ACRS	10	1			

LTR  
 MOORE  
 EPB 2 BC  
 LEECH  
 EPB 2 LA

MAR 20 1980



TOTAL NUMBER OF COPIES REQUIRED: LTR 56 ENCL 0  
~~52~~ 44

MAA

**PP&L**

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101    PHONE: (215) 821-5151

March 13, 1980

Mr. Olan D. Parr, Chief  
Light Water Reactors Branch No. 3  
Division of Project Management  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Docket Nos. 50-387  
50-388

SUSQUEHANNA STEAM ELECTRIC STATION  
APPROVAL TO USE CODE CASES  
ER 100450                      FILE 899-M-166  
PLA - 459

Dear Mr. Parr:

During the preservice examination of the reactor pressure vessel, Pennsylvania Power and Light Company intends to use the following code cases which have not been accepted by you:

- N-234 - Time Between Ultrasonic Calibration Checks
- N-235 - Ultrasonic Calibration Checks per Section V

The automatic examinations of the reactor pressure vessel are presently scheduled for August 1980.

If you have objections to either of these code cases, please inform us as soon as possible.

Very truly yours,

*N.W. Curtis* *NW*  
N. W. Curtis  
Vice President - Engineering and Construction

*Boo  
SE  
/10*

CTC/psb