

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9908170166      DOC. DATE: ~~99/07/31~~ NOTARIZED: NO      DOCKET #  
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina      05000400  
 AUTH. NAME      AUTHOR AFFILIATION  
 ROGER, S.      Carolina Power & Light Co.  
 ALEXANDER, D.B.      Carolina Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for July 1999 for Shearon Harris Nuclear Power Plant. With 990811 ltr

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: Application for permit renewal filed.      05000400

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
	LAUFER, R.		1	1					
INTERNAL:	ACRS		1	1	<u>FILE CENTER</u> 01		1	1	
	OC/DBA/PAD		1	1	RES/DRAA/OERAB		1	1	
	RGN2		1	1					
EXTERNAL:	LIMITCO MARSHALL		1	1	NOAC		1	1	
	NRC PDR		1	1					

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 9 ENCL 9

MR



Carolina Power & Light Company  
Harris Nuclear Plant  
P.O. Box 165  
New Hill NC 27562

Serial: HNP-99-126

**AUG 11 1999**

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
MONTHLY OPERATING REPORT

Dear Sir or Madam:

In accordance with Carolina Power & Light Company's Harris Nuclear Plant Technical Specification 6.9.1.5, the report of operating statistics and shutdown experience for the month of July 1999 is provided.

Sincerely,

D. B. Alexander  
Manager, Regulatory Affairs  
Harris Plant

SGR

Enclosure

c: Mr. J. B. Brady - NRC Senior Resident Inspector  
Mr. R. J. Laufer - NRC Project Manager  
Mr. L. A. Reyes - NRC Regional Administrator

5413 Shearon Harris Road New Hill NC

9908170166 990731  
PDR ADOCK 05000400  
R PDR

IE24/1

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

CP&L CO.  
RUN DATE 08/06/99  
RUN TIME 12:23:04

PLANT PERFORMANCE DATA SYSTEM  
OPERATING DATA REPORT  
HARRIS UNIT 1

PAGE 1  
RPD36-000

DOCKET NO. 050-400  
COMPLETED BY SHEILA ROGERS  
TELEPHONE (919)362-2573

OPERATING STATUS

1. UNIT NAME: HARRIS UNIT 1
2. REPORTING PERIOD: JULY 99
3. LICENSED THERMAL POWER (MWT): 2775
4. NAMEPLATE RATING (GROSS MWE): 950.9
5. DESIGN ELECTRICAL RATING (NET MWE): 900.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 920.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 860.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE):
10. REASONS FOR RESTRICTION IF ANY:

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	5087.00	107376.00
12. NUMBER OF HOURS REACTOR CRITICAL	744.00	4925.60	91151.21
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	.00
14. HOURS GENERATOR ON LINE	744.00	4851.11	90236.72
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	.00
16. GROSS THERMAL ENERGY GEN. (MWH)	2060091.18	13252993.74	242672717.70
17. GROSS ELEC. ENERGY GEN (MWH)	673755.00	4402034.00	80746071.00
18. NET ELEC. ENERGY GENERATED (MWH)	632165.00	4126640.00	75363512.00
19. UNIT SERVICE FACTOR	100.00	95.36	84.04
20. UNIT AVAILABILITY FACTOR	100.00	95.36	84.04
21. UNIT CAP. FACTOR (USING MDC NET)	98.80	94.33	81.61
22. UNIT CAP. FACTOR (USING DER NET)	94.41	90.13	77.99
23. UNIT FORCED OUTAGE RATE	.00	4.64	3.18

24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY \_\_\_\_\_

INITIAL ELECTRICITY \_\_\_\_\_

COMMERCIAL OPERATION \_\_\_\_\_

CP&L CO.  
RUN DATE 08/06/99  
RUN TIME 12:23:03

PLANT PERFORMANCE DATA SYSTEM  
APPENDIX B - AVERAGE DAILY POWER LEVEL  
HARRIS UNIT 1

PAGE 1  
RPD39-000

DOCKET NO. 050-400  
COMPLETED BY SHEILA ROGERS  
TELEPHONE (919) 362-2573

JULY 1999

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	852	17	850
2	853	18	848
3	850	19	847
4	847	20	847
5	843	21	847
6	843	22	845
7	850	23	842
8	850	24	845
9	844	25	849
10	847	26	846
11	860	27	848
12	866	28	846
13	865	29	849
14	861	30	846
15	858	31	844
16	854		