



Carolina Power & Light Company

Central File
50-400
401
402
403

USNRC REGION II
ATLANTA, GEORGIA

February 6, 1980

FEB 11 AM 10:24
AD/2

Mr. James P. O'Reilly
Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT UNIT NOS. 1, 2, 3, AND 4
DOCKET NOS. 50-400, 50-401, 50-402, AND 50-403
IE BULLETIN 79-28

Dear Mr. O'Reilly:

Carolina Power & Light Company (CP&L) has determined that the Namco Model EA180 limit switches identified in the subject IE Bulletin are not used in safety-related equipment provided by our NSSS vendor (Westinghouse) for the Shearon Harris Nuclear Power Plant (SHNPP). However, due to the time required for equipment vendors to respond, we have not yet completed our investigation of the use of these switches in non-NSSS equipment. We will inform you when this investigation is completed and identify our plans for completing any required corrective action.

Yours very truly,

M A M Duffie
M. A. McDuffie
Senior Vice President
Engineering & Construction

MAM/jc

cc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

D

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

Q 8003210 163

