

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

MA/4

ACCESSION NBR: 8007150535 DOC. DATE: 80/07/09 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 50-401 Shearon Harris Nuclear Power Plant, Unit 2, Carolina 05000401
 50-402 Shearon Harris Nuclear Power Plant, Unit 3, Carolina 05000402
 AUTH. NAME AUTHOR AFFILIATION 05000403
 MCDUFFIE, M.A. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Requests clarification of ANSI N45.2.10 as invoked by Reg Guide 1.74, as to whether or not certificates of conformance, certificates of compliance & certified test repts must contain longhand signature.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
ACTION:	ADA/D LICENSING	1		BC YOUNGBLOOD, B.	1	
	LARUSHBROOK, M.	1		PM WILSON, J. 05	1	
INTERNAL:	ACCID EVAL BR	1		AUX SYS BR 18	1	
	CHEM ENG BR	1		CONT SYS BR	1	
	CORE PERF BR 17	1		DIR, HUM FAC SFY	1	
	DIR, SFTY TECH	1		EFF TR SYS BR	1	
	EMERG PREP 22	1		ENV ENG BR	1	
	EQUIP QUAL BR	1		GEOSCIEN BR 09	4	
	HYD/GEO BR 11	1		I&C SYS BR 20	1	
	I&E 06	3		MATL ENG BR	1	
	MECH ENG BR	1		MPA	1	
	NRC PDR 02	1		OELD	1	
	POWER SYS BR	1		PROC/TST REV BR	1	
	QA BR 10	1		RAD ASSESS BR12	1	
	REAC SYS BR	1		<u>REG FILE</u> 01	1	
SIT ANAL BR 27	1		STRUCT ENG BR	1		
EXTERNAL:	ACRS 30	10	10	LPDR 03	1	
	NSIC 04	1				

JUL 17 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 49 ENCL 0 ~~43~~

0000000000

Faint, illegible text scattered across the upper half of the page, possibly representing a list or a set of data points.

0000000000
0000000000

0000000000
0000000000

Vertical line of text on the left side of the page, possibly a page number or a reference code.

Vertical line of text on the right side of the page, possibly a page number or a reference code.

0000000000



Carolina Power & Light Company

File: G R-1/2

July 9, 1980

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NOS. 1, 2, 3, AND 4
DOCKET NOS. 50-400, 50-401, 50-402, and 50-403
SIGNATURE REQUIREMENTS FOR MATERIAL DOCUMENTATION

Dear Mr. Denton:

It has been brought to CP&L's attention recently by several suppliers that the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section III, does not contain a specific requirement that material test reports or other documentation be provided with a longhand signature. On this basis, several of the suppliers provide initialed, stamped or similarly annotated documentation, particularly when the supplier has a large volume of documentation to process. ANSI N45.2.10-73 requires Certificates of Conformance, Certificates of Compliance, and Certified Test Reports to be written and signed. Due to this situation, CP&L has recently experienced problems in procurement of affected items, primarily steel.

In view of the above, CP&L requests an interpretation of ANSI N45.2.10, as invoked by Regulatory Guide 1.74, as to whether or not Certificates of Conformance, Certificates of Compliance, and Certified Test Reports must contain a longhand signature. Since this matter is currently impacting our procurement program, it is respectfully requested that a response to this question be provided as soon as practicable.

If the NRC's response is that ANSI N45.2.10 requires a longhand signature (above and beyond the ASME Section III requirements), it is recommended that action be initiated to make the ASME and NRC requirements consistent in this area. This would greatly reduce current problems and misunderstandings that may now exist.

CP&L will appreciate your assistance with regard to clarification of this matter.

NJC/gea (5052)

cc: Mr. V. Stello
Mr. J. P. O'Reilly

Yours very truly,

M. A. McDuffie
Senior Vice President
Engineering and Construction

Boo 5/10

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8007150535



[The body of the document contains extremely faint and illegible text, likely bleed-through from the reverse side of the page. The text is scattered across the page and cannot be transcribed accurately.]



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555


June 30, 1980

MA/1

TO ALL APPLICANTS FOR CONSTRUCTION PERMITS, POWER REACTOR LICENSEES,
ARCHITECT/ENGINEERS AND REACTOR VENDORS

I am enclosing for your information a notice which has been forwarded to the Office of the Federal Register for publication. This notice relates to regional meetings which will be held, beginning July 14, 1980, to address the portion of the Commission's Memorandum and Order dated May 23, 1980, which describes requirements pertaining to environmental qualification of electrical equipment installed in safety systems.

Sincerely,


Darrell G. Eisenhower, Director
Division of Licensing

Enclosure:
Notice

cc w/encl:
Service Lists



FEDERAL REGISTER NOTICE
IMPLEMENTATION OF REQUIREMENTS FOR ENVIRONMENTAL QUALIFICATION
OF ELECTRICAL EQUIPMENT

AGENCY: U. S. Nuclear Regulatory Commission
ACTION: NOTICE OF MEETING
SUMMARY: On May 23, 1980, the NRC issued a Memorandum and Order that defines Commission's requirements with respect to the environmental qualification of electrical equipment at nuclear power plants. In connection with these new requirements, the NRC will hold regional meetings to explain in more detail each of the requirements.

Dates and Locations of Regional Meetings

to be Held from 8:30 A.M. to 3:00 P.M.

July 14, 1980 - Region I	- Holiday Inn 260 Goodard Boulevard King of Prussia, Pennsylvania
July 15, 1980 - Region II	- Hyatt Regency Lancaster Room 265 Peachtree Street, N.E. Atlanta, Georgia
July 16, 1980 - Region III	- Marriott O'Hare Motel 8535 W. Higgins Road Chicago, Illinois
July 17, 1980 - Region IV & V	Holiday Inn North Irving, Texas

- 2 -

FOR FURTHER INFORMATION CONTACT:

Robert A. Purple, Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
(301) 492-7672

SUPPLEMENTAL INFORMATION:


The primary purpose of these meetings will be to: (1) provide a more detailed technical explanation of the new NRC requirements; (2) provide a description of the NRC approach, schedule, and administrative procedures to be followed in implementing these requirements; and (3) provide a forum for discussion of the requirements.

Persons other than the NRC staff and licensee representatives may observe the proceedings but will be permitted to participate in the discussions only as time will allow.

Registration of attendees will be conducted prior to each meeting at the designated locations.

Dated at Bethesda, Maryland, this 27th day of June 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation