

MAR 24 1983 -

DISTRIBUTION  
Document Control 50-400/401  
NRC PDR  
L PDR  
NSIC  
PRC System

Docket Nos.: 50-400  
and 50-401

Mr. E. E. Utley  
Executive Vice President  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

LB#3 Reading  
JLee  
NPKadambi  
HRichings  
Jordan, IE  
Taylor, IE  
Attorney, OELD  
TMNovak

Dear Mr. Utley:

Subject: Discrepancy in the LOCA Peaking Factor for Shearon Harris

It has recently come to our attention that there is a discrepancy in the Shearon Harris (SH) FSAR between the power distribution peaking factor, FQ, described in Section 4.3, Nuclear Design, and that used in Section 15.6, LOCA Analysis. The Standard Format, Regulatory Guide 170, requires that any value of FQ to be used in a Chapter 15 analysis should be fully discussed and justified in Section 4.3. Chapter 4 of the SH FSAR lists and describes the derivation and surveillance of only the "standard" Westinghouse FQ value of 2.32. No other value is discussed or mentioned. However, Section 15.6 uses a value of 2.11. This occurs without explanation or any mention other than the value listed in Table 15.6.5-2.

Given only the information presently available in the FSAR and its references a derating to about 91 percent power would be required for SH to meet LOCA requirements using the peaking factor (and resulting  $k_i/ft$ ) from the analyses and surveillance described in Section 4.3.

Informal investigation has indicated that Westinghouse and SH intend to use a new excore "Axial Power Distribution Monitoring System" to demonstrate, via active surveillance, that the LOCA peaking factor (2.11) can be met in operation. However, this is not mentioned in the FSAR. They evidently intend to submit a topical report on this subject. A previous report (WCAP-9105) on the (possibly same) subject was submitted in 1977 and reviewed, with approval for referencing (discriptions of the system and techniques). However, it was incomplete, e.g., not dealing with uncertainties, and thus no approved system presently exists.

In view of this newly discovered discrepancy in peaking factors and the absence of information in the FSAR, the subject of peaking factor control, analysis and surveillance (or power reduction) must be considered an open issue which could be resolved by responding satisfactorily to the following:

OFFICE	.....	.....	.....	.....	.....	.....	.....
SURNAME	.....	.....	.....	.....	.....	.....	.....
DATE	.....	.....	.....	.....	.....	.....	.....



1000

Mr. E. E. Utley

- 2 -

Table 15.6.5-2 of the FSAR gives a value of 2.11 for the FQ used in LOCA analysis. Section 4.3 of the FSAR (which should discuss all aspects of all power distributions used in Chapter 15 analyses, including in particular the power peaking factors used to satisfy LQCA analysis requirements) does not mention such a value. Instead Section 4.3 presents only the standard Westinghouse discussions demonstrating that an FQ value of 2.32 can be maintained, using the standard Westinghouse CAOC (with improved load follow) analysis, control and excite (split detector) surveillance. The only conclusion that one can draw from this information, as it stands, is that it will be necessary to derate the reactor to 91 percent power. If there is an alternate power distribution analysis, control scheme or surveillance system to be used with your reactor operations which will demonstrate that an FQ of 2.11 can be maintained, please modify Section 4.3 (and other indications of FQ and peak kW/ft such as Table 4.1) to present this new limit, and a discussion in detail of the modifications involved to hardware, analyses and operations, including a full uncertainty analysis. Topical reports may be submitted and referenced, but modifications to Chapter 4 (and possibly Chapter 7) are required.

Please direct any questions to Dr. Prasad Kadambi at (301)492-8423.


Sincerely,

Original signed by:  
George W. Knighton

George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

cc: See next page

OFFICE	DL:LB#3, NPK	DL (B#3)					
SURNAME	NPKadambi/yt	Gwknighton					
DATE	3/23/83	3/29/83					



Mr. E. E. Utley  
Executive Vice President  
Power Supply and Engineering and  
Construction  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

cc: George F. Trowbridge, Esq.  
Shaw, Pittman, Potts &  
Trowbridge  
1800 M Street, NW  
Washington, DC 20036

Richard E. Jones, Esq.  
Associate General Counsel  
Carolina Power & Light Company  
411 Fayetteville Street Mall  
Raleigh, North Carolina 27602

M. David Gordon, Esq.  
Attorney Associate General  
State of North Carolina  
P. O. Box 629  
Raleigh, North Carolina 27602

Thomas S. Erwin, Esq.  
115 W. Morgan Street  
Raleigh, North Carolina 27602

Mr. George Maxwell  
Resident Inspector/ Harris NPS  
c/o U.S. Nuclear Regulatory Commission  
Route 1, Box 315B  
New Hill, North Carolina 27562

Charles D. Barham, Jr., Esq.  
Vice President & Senior Counsel  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

Mr. John Runkle, Executive Coordinator  
Conservation Council of North Carolina  
307 Granville Road  
Chapel Hill, North Carolina 27514

Mr. Wells Eddleman  
718-A Iredell Street  
Durham, North Carolina 27705

Mr. George Jackson, Secretary  
Environmental Law Project  
School of Law, 064-A  
University of North Carolina  
Chapel Hill, North Carolina 27514

Dr. Phyllis Lotchin  
108 Bridle Run  
Chapel Hill, North Carolina 27514

Mr. Travis Payne, Esq.  
723 W. Johnson Street  
P. O. Box 12643  
Raleigh, North Carolina 27605

Mr. Daniel F. Read, President  
CHANGE  
P. O. Box 524  
Chapel Hill, North Carolina 27514

Ms. Patricia T. Newman, Co-Coordinator  
Mr. Slater E. Newman, Co-Coordinator  
Citizens Against Nuclear Power  
2309 Weymouth Ct.  
Raleigh, North Carolina 27612

Richard D. Wilson, M.D.  
725 Hunter Street  
Apex, North Carolina 27502

Regional Administrator - Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street  
Suite 3100  
Atlanta, Georgia 30303



100

100