

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDIS)

ACCESSION NBR:8307060302 DOC.DATE: 83/06/30 NOTARIZED: NO DOCKET #
FACIL:50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 5000400
 50-401 Shearon Harris Nuclear Power Plant, Unit 2, Carolina 05000401

~~DOCKET #~~
05000400
05000401


AUTH.NAME	AUTHOR AFFILIATION
MCDUFFIE,M.A.	Carolina Power & Light Co.
RECIP.NAME	RECIPIENT AFFILIATION
DENTON,H.R.	Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards responses to Auxiliary Sys Branch draft SER Open Items 134,135 & 224, re removal of barrier in fuel cask pool, crane load block & protection of circulating water sys.

DISTRIBUTION CODE: 8030S COPIES RECEIVED: LTR ENCL SIZE: /
TITLE: Licensing Submittal: Control of Heavy Loads Near Spent Fuel (USI A-36)

NOTES:

RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL	
NRR/DL/ADL		1	0	NRR LB3 BC		1	0
NRR LB3 LA		1	0	KADAMBI,P		1	1
INTERNAL: ELD/HDS1		1	0	NRR REQUA,G		1	1
NRR SINGH,A 01		4	4	NRR/DL/SSPB		1	1
NRR/DSI/AEB 26		1	1	NRR/DSI/CPB 10		1	1
NRR/DST/METB 12		1	1	NRR/DSI/RSB 23		1	1
<u>REG FILE</u> 04		1	1	RGN2		1	1
RM/DDAMI/MIB		1	0				
EXTERNAL: ACRS 41		6	6	LPDR 03		1	1
NRC PDR 02		1	1	NSIC 05		1	1
NTIS		1	1				





SERIAL: LAP-83-224

Carolina Power & Light Company
JUN 30 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NOS. 1 AND 2
DOCKET NOS. 50-400 AND 50-401
DRAFT SAFETY EVALUATION REPORT RESPONSES
AUXILIARY SYSTEMS BRANCH

Dear Mr. Denton:

Carolina Power & Light Company (CP&L) hereby transmits one original and forty copies of responses to Shearon Harris Nuclear Power Plant Draft Safety Evaluation Report Open Items. These responses are for the Auxiliary Systems Branch, and are CP&L Open Item Numbers 13⁴, 135, and 224.

We will be providing responses to other Open Items in the Draft Safety Evaluation Report shortly.

Yours very truly,

M. A. McDuffie
Senior Vice President
Engineering & Construction

JDK/pgp (7036JDK)

cc: Mr. N. Prasad Kadambi (NRC)
Mr. N. Wagner (NRC)
Mr. G. F. Maxwell (NRC-SHNPP)
Mr. J. P. O'Reilly (NRC-RII)
Mr. Travis Payne (KUDZU)
Mr. Daniel F. Read (CHANGE/ELP)
Chapel Hill Public Library
Wake County Public Library

Mr. Wells Eddleman
Dr. Phyllis Lotchin
Mr. John D. Runkle
Dr. Richard D. Wilson
Mr. G. O. Bright (ASLB)
Dr. J. H. Carpenter (ASLB)
Mr. J. L. Kelley (ASLB)

8307060302 830630
PDR ADOCK 05000400
E PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

B300
11

Foreign Bill

1. The following countries have been granted the right to issue foreign currency notes:

2. The following countries have been granted the right to issue foreign currency notes:

EXTRADITION AGREEMENTS

DEBT IN U.S. DOLLARS:

3. The following countries have been granted the right to issue foreign currency notes:

4. The following countries have been granted the right to issue foreign currency notes:

5. The following countries have been granted the right to issue foreign currency notes:

6. The following countries have been granted the right to issue foreign currency notes:

7. The following countries have been granted the right to issue foreign currency notes:

8. The following countries have been granted the right to issue foreign currency notes:

Open Item 134 (ASB/NW-7), Question 410.11

Question

Provide additional information indicating how the removal barrier placed between the cask loading pool and the new fuel pool will prevent the spent fuel cask-handling crane from being inadvertently moved over the new fuel pool. We are concerned that since the new fuel pools may be flooded and used for storage of spent fuel, only administrative controls could prevent a heavy load on the spent fuel cask crane from moving over this spent fuel. Describe the design of the removal barrier, its stability against side thrust of the spent fuel cask, its resting position should it be toppled by the spent fuel cask and clearance around the in-place removable barrier to the new fuel pool.

It is our position, based on NUREG-0612, Section 5.1.2, that mechanical or electrical stops be provided to restrict travel to the east from the cask loading area, and we are concerned that the removable barrier is an inadequate mechanical stop.

Response

The removable barrier is not designed to prevent the cask crane from being inadvertently moved over the new fuel pool. The function of the removable barrier is to prevent the cask, in the remote chance of being dropped on top of the dividing wall between the cask loading pool and cask head and yoke storage area, from toppling over and falling into the new fuel pool. The dropping cask, after landing on the dividing wall, may start to topple over and strike the barrier. The barrier is designed to withstand the striking force, thus, preventing the cask from falling into the new fuel pool. The removable barrier is 21 feet 6 inches in overall height. It is set in place by being lowered into a 4 feet deep recess in the concrete floor; therefore, the installed height is 17 feet 6 inches measured from the operating floor.

Travel of the center line of the main hook on the cask crane is restricted to the shaded area as shown on Figure 9.1.4-7 by a combination of limit switches and mechanical stops. Figure 9.1.4-7 has been marked to show additional information and is attached. During cask handling, the center line of the main hook is further restricted under administrative control to the path cross hatched on the figure.

Therefore, a combination of limit switches and mechanical stops do restrict the crane from the new fuel pool area, and the removable barrier is not used as a mechanical stop. Refer to FSAR Section 9.1.4.2.2.7 for further details on the spent fuel cask handling crane and the auxiliary crane.

1940


and from 1940 to 1950 there was a significant shift in the age and gender composition of the population. The median age increased from 25.5 years in 1940 to 30.5 years in 1950. The median age in 1950 was the highest recorded in the twentieth century. The median age declined to 28.5 years in 1960, 26.5 years in 1970, 25.5 years in 1980, 24.5 years in 1990, and 23.5 years in 2000. The median age in 2000 was the lowest recorded in the twentieth century.

The age distribution of the population in 1940 was relatively uniform, with a median age of 25.5 years. The median age increased to 30.5 years in 1950, and then declined to 28.5 years in 1960, 26.5 years in 1970, 25.5 years in 1980, 24.5 years in 1990, and 23.5 years in 2000.

The median age in 1940 was 25.5 years. The median age increased to 30.5 years in 1950, and then declined to 28.5 years in 1960, 26.5 years in 1970, 25.5 years in 1980, 24.5 years in 1990, and 23.5 years in 2000. The median age in 2000 was the lowest recorded in the twentieth century.

The median age in 1940 was 25.5 years. The median age increased to 30.5 years in 1950, and then declined to 28.5 years in 1960, 26.5 years in 1970, 25.5 years in 1980, 24.5 years in 1990, and 23.5 years in 2000. The median age in 2000 was the lowest recorded in the twentieth century.

The median age in 1940 was 25.5 years. The median age increased to 30.5 years in 1950, and then declined to 28.5 years in 1960, 26.5 years in 1970, 25.5 years in 1980, 24.5 years in 1990, and 23.5 years in 2000. The median age in 2000 was the lowest recorded in the twentieth century.



PLAN AT EL. 286.00'

SHEARON HARRIS NUCLEAR POWER PLANT
Carolina Power & Light Company

**SPENT FUEL CASK CRANE
MAIN HOOK AND CASK TRAVEL
ENVELOPES - SHEET 1**

REF DWG: CAR2165-G-022 (REV 7, 09/11)

Open Item 135

Describe how movement of the spent fuel cask-handling crane load block is prevented from going within a 15 foot horizontal distance of the new fuel pool during the time spent fuel is stored therein. Indicate how you will meet the recommendations of NUREG-0612 to prevent raising the spent fuel cask greater than 6 inches above the operating floor.

Response

Please reference FSAR Section 9.1.4.2.2.7 and the response to Open Item 134. The center of the main hook of the cask crane is prevented from coming within 15 feet of the north edge and 10 feet 6 inches of the west edge of the new fuel pool by limit switches. During the cask handling, the entire operation will also be under administrative control.

In case of a cask drop while the cask is being transported between the cask loading pool and cask decontamination area, the cask will either drop into a pit (cask loading pool, cask head and yoke storage area, or cask decontamination area) or be prevented from toppling over and falling into the new fuel pool by the removable barrier. (See response to Open Item 134)

Cask handling procedures will require additional links to be added to the lifting yoke to prevent the cask from being raised higher than 6 inches above the operating floor. The cask handling procedures will be in place 90 days prior to initial fuel load.

卷之三

and the other two foundations are 200' x 100' x 10' high
at a cost of \$1000 each and 10' thick. The top of the
foundation is 10' above the ground level.
The foundation is built of concrete and the walls are
concrete and the roof is made of wood and the floor is
wooden beams and joists. The walls are 10' thick and
the roof is 10' thick and the floor is 10' thick.

On 10 July 1944, I had to fly back to the USA to take part in the 1944-45
flying season. I was given a choice of planes to take, so chose the
Spitfire Mk Vb. It was a very good aircraft, but I did not like the
feel of the controls. The engine was a Merlin 61, which was not
as powerful as the Griffon, but it was more reliable.

Shearon Harris Nuclear Power Plant
Draft SER Open Item No. 224 (FSAR Section 10.4.5)

Demonstrate that the circulating water system meets the requirements of GDC 4 with respect to protection of safety related systems from failures in non-safety related systems. Postulated seismic failure of the circulating water piping allows water flow by gravity and siphoning to a common elevation in the cooling tower basin and turbine building basement. Water may reach several safety related areas via access from turbine building walls and doors not identified as seismic Category I and water proof for flooding.

Response

The areas of the Turbine Building containing circulating water pipes are separated from the buildings with safety related areas by continuous reinforced concrete walls as shown by shading in Figures 224-1 and 224-2. These walls are seismically designed to resist the seismic forces of the SSE and hydrostatic pressure that would be associated with flooding up to elevation 262 feet.

The seismic gap between Turbine Building number 1 and number 2 is provided with waterstops in locations as required to isolate the area from the effects of flooding.

As shown in Figure 224-1, the Unit 1 Turbine Building walls that isolate the circulating water pipe areas from safety related areas of the Reactor Auxiliary Building are the walls at column coordinates 7/Aa to 7Ak, 7/Ak to 9/Ap, 9/Ap to 42/Ap, 42/Ap to 42/Aa, 42/Aa to 43/Aa, 43/Aa to 43/Ap.

As shown on Figure 224-2, the Unit 2 Turbine Building walls that isolate the circulating water pipe areas from safety related areas of the Reactor Auxiliary Building are the walls at column coordinates 43/Aa to 43/Ap, 43/Ap to 75/Ap, 75/Ap to 75/Aa, 75/Aa to 76/Aa.

FSAR Section 10.4.3.5 will be revised to reflect this response in a future amendment.

Documentos Históricos
(c. f. 91, sección 2, folio 175v, recto)

Inda oír estes pedras na sua apariencia em que separam os
cavados de terra de outras de terra comum. A terra do
cavado é sempre de menor espessura e tem menor resistencia
que a terra comum. O terreno é de um só tipo e não tem
variações de altura ou profundidade. A terra do cavado
é sempre mais dura e resistente que a terra comum. A
terra do cavado é sempre mais dura e resistente que a terra comum.


220000

As pedras que se acham no fundo das minas são de granito e
não de basalto. As pedras de granito são sempre de maior
espessura que as de basalto. As pedras de granito são
também mais duras e resistentes que as de basalto. As
pedras de granito são sempre de maior espessura que as de basalto.
As pedras de granito são sempre de maior espessura que as de basalto.

As pedras de granito são sempre de maior espessura que as de basalto.
As pedras de granito são sempre de maior espessura que as de basalto.
As pedras de granito são sempre de maior espessura que as de basalto.

As pedras de granito são sempre de maior espessura que as de basalto.
As pedras de granito são sempre de maior espessura que as de basalto.
As pedras de granito são sempre de maior espessura que as de basalto.

As pedras de granito são sempre de maior espessura que as de basalto.




ISOLATION WALL

SHEARON HARRIS NUCLEAR POWER PLANT
Carolina Power & Light Company
FINAL SAFETY ANALYSIS REPORT


**GENERAL ARRANGEMENT - TURBINE
BUILDING - PLAN EL 240.00'
UNIT 1**

REF DWG: CAR 2165-G-004 (REV 3)

FIGURE 224-1



PLAN AT EL. 240.00"



SHEARON HARRIS NUCLEAR POWER PLANT
Carolina Power & Light Company
FINAL SAFETY ANALYSIS REPORT

**GENERAL ARRANGEMENT - TURBINE
BUILDING - PLAN EL 240.00'
UNIT 2**

REF DWG: CAR 216S-G-274 (REV 3)

FIGURE 224-2

