

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST  
SYRACUSE, N. Y. 13202

April 12, 1978

Mr. Edson G. Case, Acting Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Nine Mile Point Unit 2  
Docket No. 50-410

US NRC  
DISTRIBUTION SERVICES  
BRANCH

1978 APR 18 AM 11:53

RECEIVED DISTRIBUTION  
SERVICES UNIT

REGULATOR DOCKET FILE COPY

Dear Mr. Case:


Pursuant to Section 50.55a(a)(2)(ii), Niagara Mohawk Power Corporation requests approval to invoke ASME Code Case 1644-7.

It is intended to apply Code Case 1644-7 to the bolting material used in the concrete anchors for equipment to be installed at Nine Mile Point Unit 2. Niagara Mohawk will apply the additional limitations recommended by the Nuclear Regulatory Commission Staff for Code Case 1644-6 in Revision 11 to Regulatory Guide 1.85.

We have evaluated the safety significance of applying Code Case 1644-7 and found that the level of safety for Unit 2 is not degraded.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Gerald K. Rhode, Vice President  
System Project Management

PEF/szd

781090021

Boo  
5/10

1950

1950