

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO: Mr. James G. Keppler

FROM: Commonwealth Edison
Morris, Illinois 60450
B. B. Stephenson

DATE OF DOCUMENT
03-24-77

DATE RECEIVED
03-31-77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP INPUT FORM

NUMBER OF COPIES RECEIVED
100

DESCRIPTION
Ltr. Trans The Following:

(1 page)

ACKNOWLEDGED

PLANT NAME: DRESDEN UNIT # 2

jcm

DO NOT REMOVE

ENCLOSURE Licensee Event Report (RO-50-237/197-8) on 02-25-77 concerning Main steam line low pressure isolation switch 2-261-30C tripped below Tech Spec Limits due to instrument setpoint drift.....

(1 page)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

BRANCH CHIEF:	Ziemann
W/3 CYS FOR ACTION	
LIC. ASST.:	
W/1 CYS	
ACRS 10 CYS HOLDING/SENT	A: C A T B

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE	
<input checked="" type="checkbox"/> NRC PDR	
I & E (2)	
MIPC	
SCHROEDER/IPPOLITO	
HOUSTON	
NOVAK/CHECK	
GRIMES	
CASE	
BUTLER	
HANAUER	
TEDESCO/MACCARY	
EISENHUT	
BAER	
SHAO	
VOLLMER/BUNCH	
KREGER/J. COLLINS	

EXTERNAL DISTRIBUTION

LPDR: Morris, J. J.	
TIC:	
NSIC:	

CONTROL NUMBER

770910323

CONFIDENTIAL


CONFIDENTIAL



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

BBS Ltr. #77-255

March 24, 1977



Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

REGULATORY DOCKET FILE COPY

Enclosed please find Reportable Occurrence report number 50-237/1977-8.
This report is being submitted to your office in accordance with the Dresden
Nuclear Power Station Technical Specifications, Section 6.6.B.

A handwritten signature in dark ink, appearing to read 'B. B. Stephenson'.

B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC

770910323

WESTERN UNION TELEPHONE COMPANY

LICENSE EVENT REPORT

CONTROL BLOCK: 1 6

PLEASE PRINT ALL REQUIRED INFORMATION

LICENSEE NAME: 01 | I | L | D | R | S | 2 | LICENSE NUMBER: 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | LICENSE TYPE: 4 | 1 | 1 | 1 | 1 | EVENT TYPE: 0 | 3 |

01 CONT CATEGORY: 57 | 58 | REPORT TYPE: L | REPORT SOURCE: L | DOCKET NUMBER: 0 | 5 | 3 | 0 | - | 0 | 2 | 3 | 7 | EVENT DATE: 0 | 2 | 2 | 5 | 7 | 7 | REPORT DATE: 0 | 3 | 2 | 5 | 7 | 7 |

EVENT DESCRIPTION

02 | During routine surveillance testing, main steam line low pressure isolation switch
03 | 2-261-30C was found to trip at 853 psi (Tech Specs require a trip point greater
04 | than or equal to 855 psi, including a 5-psi head correction). Redundant instrumenta-
05 | tion would have provided the required isolation signal had a low pressure condi-
06 | tion occurred. A similar event involving PS 2-261-30C occurred in March, 1975.

(50-237/1977-8)

07 | SYSTEM CODE: C | D | CAUSE CODE: E | COMPONENT CODE: I | N | S | T | R | U | PRIME COMPONENT SUPPLIER: N | COMPONENT MANUFACTURER: B | O | 8 | 0 | VIOLATION: Y |

CAUSE DESCRIPTION

08 | The event was attributed to instrument setpoint drift. PS 2-261-30C was reset to
09 | trip at the correct setpoint. The switch will continue to be tested monthly to
10 | ensure that reportable setpoint variations are identified and corrected in a timely

(Continued)

11 | FACILITY STATUS: E | % POWER: 0 | 9 | 5 | OTHER STATUS: NA | METHOD OF DISCOVERY: B | DISCOVERY DESCRIPTION: NA |

12 | FORM OF ACTIVITY RELEASED: Z | CONTENT OF RELEASE: Z | AMOUNT OF ACTIVITY: NA | LOCATION OF RELEASE: NA |

PERSONNEL EXPOSURES

13 | NUMBER: 0 | 0 | 0 | TYPE: Z | DESCRIPTION: NA |

PERSONNEL INJURIES

14 | NUMBER: 0 | 0 | 0 | DESCRIPTION: NA |

OFFSITE CONSEQUENCES

15 | NA |

LOSS OR DAMAGE TO FACILITY

16 | TYPE: Z | DESCRIPTION: NA |

PUBLICITY

17 | NA |

ADDITIONAL FACTORS

18 | CAUSE DESCRIPTION (Continued) manner. PS 2-261-30C is a Barksdale
19 | pre-cycled pressure switch, type B2T-A1255.

NAME: T. E. Lang PHONE: Ext. 222

RECEIVED DOCUMENT
PROCESSING UNIT

1977 MAR 31 PM 12 17