

B 8/7/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-220

REC: GRIER B H
NRC

ORG: SCHNEIDER R R
NIAGARA MOHAWK PWR

DOCDATE: 07/28/78
DATE RCVD: 08/02/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-220/78-029) ON 07/22/78 CONCERNING
PERFORMANCE OF SURVEILLANCE TEST N1-ISP-RE04, FOUND RE04A, RE04B & RE04C WITH
SETPOINTS LESS CONSERVATIVE THAN ALLOWED BY TS 3.6.2, RESULTING IN BOTH
SENSORS IN CHANNEL 11 OPERATING IN A DEGRADED MODE

PLANT NAME: NINE MILE PT - UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ORB#3 BC**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL:

LPDR'S
OSWEGO, NY**W/ENCL
TIC, LIZ CARTER**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

1704

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 782160002

***** THE END *****

cap



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. No specific words or phrases can be discerned.]

July 28, 1978

Mr. Boyce H. Grier
Director
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

RE: Docket No. 50-220

Dear Mr. Grier:

In accordance with Nine Mile Point Nuclear Station Unit #1
Technical Specifications, we hereby submit Licensee Event Report,
LER 78-29 which is in violation of Section 3.6.2 of the Technical
Specifications.

This report was completed in the format designated in
NUREG-0161, dated July 1977.

Sincerely,

Original Signed by R.R. Schneider

R.R. Schneider
Vice President -
Electric Production

mtm

Attachments (3 copies each)

xc: Director, Office of I&E (30 copies)
Director, Office of MIPC (3 copies)

REGULATORY DOCKET FILE COPY

782160002

1002
5/11

RECEIVED
REGULATORY SERVICES
JUL 29 1978
U.S. NUCLEAR REGULATORY COMMISSION



11

.

.

.

.

.

.

.

.

11

.

July 28, 1978

Mr. Boyce H. Grier
 Director
 United States Nuclear Regulatory Commission
 Region I
 631 Park Avenue
 King of Prussia, PA. 19406

RE: Docket No. 50-220
 LER 78-029/01T-0

Dear Mr. Grier:

During normal operation, performance of Surveillance Test N1-ISP-RE04, found RE04A with a setpoint of 3.80 psig, RE04B with a setpoint of 3.70 psig, and RE04C with a setpoint of 3.80 psig. This condition resulted in three of four High Drywell Pressure Switches having setpoint values less conservative than those allowed by Technical Specification 3.6.2. Technical Specification 3.6.2 allows 3.5 psig +/- 0.053 psig.

All three switches were reset to within allowable limits and retested. Current Surveillance testing schedules are adequate to insure early detection of these instrument drifts. In addition, we are planning to change out these Barton Model 289 pressure indicating switches during our next refueling outage and replace them with a GE analog transmitter trip system.

This condition did not present an unresolved safety question and had minimal safety implications.

Very truly yours,

ORIGINAL SIGNED BY R.R. SCHNEIDER

R.R. Schneider
 Vice President -
 Electric Production

DKM/mtm

