

A 05/09/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-220

REC: GRIER B H
NRC

ORG: SCHNEIDER R R
NIAGARA MOHAWK PWR

DOC DATE: 04/24/78
DATE RCVD: 05/08/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-220/78-018) ON 04/07/78 CONCERNING
SURVEILLANCE TEST N1-ISP-RE22 FOUND A MAIN STEAM HIGH FLOW SWITCH WITH A
SETPOINT OF 106.2 PSI, EXCEEDING TECH SPEC LIMIT, CAUSED BY SETPOINT DRIFT.

PLANT NAME: NINE MILE PT - UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *m*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF LEAD ~~4~~ ENCL

INTERNAL:

- REG FILE**W/ENCL
- ~~IA-E**W/2 ENCL~~
- SCHROEDER/IPPOLITO**W/ENCL
- NOVAK/CHECK**W/ENCL
- KNIGHT**W/ENCL
- HANAUER**W/ENCL
- EISENHUT**W/ENCL
- SHAO**W/ENCL
- KREGER/J. COLLINS**W/ENCL
- K SEYFRIT/IE**W/ENCL

- NRC PDR**W/ENCL
- MIPC**W/3 ENCL
- HOUSTON**W/ENCL
- EEB**W/ENCL
- BUTLER**W/ENCL
- TEDESCO**W/ENCL
- BAER**W/ENCL
- VOLLMER/BUNCH**W/ENCL
- ROSA**W/ENCL

EXTERNAL:

- LPDR'S
- OSWEGO, NY**W/ENCL
- TIC**W/ENCL
- NSIC**W/ENCL
- ACRS CAT B**W/16 ENCL

COPIES NOT SUBMITTED PER
REGULATORY GUIDE 10.1

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 781280044

***** THE END *****

D



REGULATORY DOCKET FILE COPY

NMP-0150

NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

RECEIVED DISTRIBUTION SERVICES UNIT

1978 MAY 8 PM 12 44

US NRC
DISTRIBUTION SERVICES
BRANCH

April 24, 1978

Mr. Boyce H. Grier
Director
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406


RE: Docket No. 50-220

Dear Mr. Grier:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specifications, we hereby submit Licensee Event Report, LER 78-18, which is in violation of Section 3.6.2 of the Technical Specifications.

This report was completed in the format designated in NUREG-0161, dated July 1977.

Very truly yours,



R.R. Schneider
Vice President -
Electric Production

mtm

Attachments (3 copies)

cc: Director, Office of I&E (30 copies)
Director, Office of MIPC (3 copies)

781280044

A002
S
111

