

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8310280014 DOC. DATE: 83/10/21 NOTARIZED: NO DOCKET #  
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400  
 50-401 Shearon Harris Nuclear Power Plant, Unit 2, Carolina 05000401  
 AUTH. NAME: MCDUFFIE, M.A. AUTHOR AFFILIATION: Carolina Power & Light Co.  
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards nonproprietary & proprietary responses to request for addl info re criticality analyses for spent fuel racks. Draft SER Open Item 360 completed. Proprietary response withheld (ref 10CFR2.790).

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 4  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

## NOTES:

| RECIPIENT<br>ID CODE/NAME | COPIES<br>LTTR ENCL | RECIPIENT<br>ID CODE/NAME | COPIES<br>LTTR ENCL |
|---------------------------|---------------------|---------------------------|---------------------|
| NRR/DL/ADL                | 1 0                 | NRR LB3 BC                | 1 0                 |
| NRR LB3 LA                | 1 0                 | BUCKLEY, B 01             | 1 1                 |
| INTERNAL: ELD/HDS1        | 1 0                 | IE FILE                   | 1 1                 |
| IE/DEPER/EPB 36           | 3 3                 | IE/DEPER/IRB 35           | 1 1                 |
| IE/DEQA/QAB 21            | 1 1                 | NRR/DE/AEAB               | 1 0                 |
| NRR/DE/CEB 11             | 1 1                 | NRR/DE/EHEB               | 1 1                 |
| NRR/DE/eqB 13             | 2 2                 | NRR/DE/GB 28              | 2 2                 |
| NRR/DE/MEB 18             | 1 1                 | NRR/DE/MTEB 17            | 1 1                 |
| NRR/DE/SAB 24             | 1 1                 | NRR/DE/SGEB 25            | 1 1                 |
| NRR/DHFS/HFEB40           | 1 1                 | NRR/DHFS/LQB 32           | 1 1                 |
| NRR/DHFS/PSRB             | 1 1                 | NRR/DL/SSPB               | 1 0                 |
| NRR/DSI/AEB 26            | 1 1                 | NRR/DSI/ASB               | 1 1                 |
| NRR/DSI/CPB 10            | 1 1                 | NRR/DSI/CSB 09            | 1 1                 |
| NRR/DSI/ICSB 16           | 1 1                 | NRR/DSI/METB 12           | 1 1                 |
| NRR/DSI/PSB 19            | 1 1                 | NRR/DSI/RAB 22            | 1 1                 |
| NRR/DSI/RSB 23            | 1 1                 | REG FILE 04               | 1 1                 |
| RGN2                      | 3 3                 | RM/DDAM1/MIB              | 1 0                 |
| EXTERNAL: ACRS 41         | 6 6                 | BNL (AMDTS ONLY)          | 1 1                 |
| DMB/DSS (AMDTS)           | 1 1                 | FEMA-REP DIV 39           | 1 1                 |
| LPDR 03                   | 1 1                 | NRC PDR 02                | 1 1                 |
| NSIC 05                   | 1 1                 | NTIS                      | 1 1                 |

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 46

SECTION: 83105001      DATE: 83105011      TIME: 1400  
 FACILITY: 50-000      SPECIAL: Harris nuclear power plant, Unit 1, Carolina  
 50-001      SPECIAL: Harris nuclear power plant, Unit 2, Carolina  
 AUTH. NAME:      ALTRAK AFFILIATION  
 INDUSTRY: M.A.      Carolina Power & Light Co.  
 CIP. NAME:      RECIPROCAL AFFILIATION  
 DIVISION: M.A.      Office of Nuclear Reactor Regulation, Director

withheld (see 10C.R.S. 130).  
Draft SR upon item 200 completed, proprietary response  
for and info re criticality analyses for spent fuel racks.  
SUBJECT: Forwards nonproprietary & proprietary responses to request.

FILE: Legislation submitted; 42ARAFBAR Amts & Related Correspondence  
DISTRIBUTION CODE: 80018 COPIES RECEIVED:LTR -- ENCL -- SIZE:-----

2311

[illegible]

SERIAL: LAP-83-483

OCT 21 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
UNIT NOS. 1 AND 2  
DOCKET NOS. 50-400 AND 50-401  
DRAFT SAFETY EVALUATION REPORT OPEN ITEMS  
AUXILIARY SYSTEMS BRANCH

Dear Mr. Denton:

This submittal is in response to an NRC reviewer's request for additional information addressing the criticality analyses for the spent fuel racks referred to in CP&L's letter dated October 11, 1983, Serial No. LAP-83-472 and completes all requested information for draft SER Open Item 360.

Enclosed are:

1. One (1) copy of Westinghouse "Shearon Harris Spent Fuel Rack Criticality Analysis" (Proprietary).
2. Forty (40) copies of Westinghouse "Shearon Harris Spent Fuel Rack Criticality Analysis" (Non-Proprietary).
3. One (1) copy of Application for Withholding (CAW-83-86) (Non-Proprietary).
4. One (1) copy of Affidavit (CAW-83-16) (Non-Proprietary).

This submittal contains proprietary information of Westinghouse Electric Corporation. In conformance with the requirements of 10CFR Section 2.790, as amended, of the Commission's regulations, we are enclosing with this submittal an application for withholding from public disclosure and an affidavit. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission.


8310280014

Harold R. Denton

-2-

Correspondence with respect to the affidavit or application for withholding should reference CAW-83-86 and should be addressed to R. A. Wiesemann, Manager, Regulatory & Legislative Affairs, Westinghouse Electric Corporation, P. O. Box 355, Pittsburgh, Pennsylvania 15230.

Yours very truly,



M. A. McDuffie  
Senior Vice President  
Nuclear Generation

MAM/pgp (8205NLU)  
Enclosures

|                                 |                            |
|---------------------------------|----------------------------|
| cc: Mr. B. C. Buckley (NRC)*    | Mr. Wells Eddleman         |
| Mr. G. F. Maxwell (NRC-SHNPP)   | Dr. Phyllis Lotchin        |
| Mr. J. P. O'Reilly (NRC-RII)    | Mr. John D. Runkle         |
| Mr. Travis Payne (KUDZU)        | Dr. Richard D. Wilson      |
| Mr. Daniel F. Read (CHANGE/ELP) | Mr. G. O. Bright (ASLB)    |
| Mr. R. P. Gruber (NCUC)         | Dr. J. H. Carpenter (ASLB) |
| Chapel Hill Public Library      | Mr. J. L. Kelley (ASLB)    |
| Wake County Public Library      |                            |

\* Denotes parties which have received the proprietary information.

Shearon Harris Nuclear Power Plant  
Draft SER Open Item 360  
ASB Question 9.1.2

In order to permit us to evaluate  $K_{eff}$  for spent fuel pools, provide further information regarding all fuel to be stored, fuel distribution within the pool(s), a detailed description of the storage racks, a description of the calculational methods used in the determination of  $K_{eff}$  by CP&L together with a discussion of the calculation and mechanical uncertainties considered in the calculation. Describe how control will be maintained over the location of the fuel in the spent fuel pools.

Response

The maximum U-235 enrichment is 3.9 for the Westinghouse 17x17 fuel. The rack parameters are shown in Table 1. This table will be included in FSAR Section 9.1.2 in a future amendment.

The previously mentioned proprietary submittal addressing criticality analyses for the Shearon Harris spent fuel racks is attached.

TABLE 1

SHEARON HARRIS SPENT FUEL RACK DIMENSIONS

Fuel Type: W 17x17 and GE 8x8

| <u>RACK TYPE</u>      | <u>POISON</u> | <u>BWR</u> |
|-----------------------|---------------|------------|
| C-C SPACING           | 10.500        | 6.250      |
| CELL I.D.             | 8.750         | 6.050      |
| POISON CAVITY         | 0.090         | 0.060      |
| POISON WIDTH          | 7.500         | 5.100      |
| CELL GAP (NOMINAL)    | 1.330         | ---        |
| POISON THICKNESS      | 0.075         | 0.045      |
| WALL THICKNESS        | 0.075         | 0.075      |
| WRAPPER THICKNESS     | 0.035         | 0.035      |
| POISON (GM-B10/SQ.CM) | 0.020         | 0.0103     |

---

All Dimensions in Inches

### 3.4 CRITICALITY ANALYSIS

#### 3.4.1 NEUTRON MULTIPLICATION FACTOR

Criticality of fuel assemblies in the spent fuel storage rack is prevented by the design of the racks which limits fuel assembly interaction. This is done by fixing the minimum separation between assemblies and inserting neutron poison between assemblies.

The design basis for preventing criticality outside the reactor is that, including uncertainties, there is a 95 percent probability at a 95 percent confidence level that the effective multiplication factor ( $K_{eff}$ ) of the fuel assembly array will be less than 0.95 as recommended in ANSI N210-1976 and in "NRC Position for Review and Acceptance of Spent Fuel Storage and Handling Applications".

The following are the conditions that are assumed in meeting this design basis for the Shearon Harris spent fuel storage racks.

#### 3.4.2 NORMAL STORAGE

##### 3.4.2.1 PWR FUEL

- a. The fuel assembly contains the highest enrichment authorized without any control rods or any noncontained burnable poison and is at its most reactive point in life. The enrichment of the 17 x 17 Westinghouse optimized fuel assembly is 3.9 w/o U-235 with no depletion or fission product buildup. The following assembly parameters were modeled:

##### WESTINGHOUSE FUEL ASSEMBLY (17 X 17 OFA)

|                               |           |
|-------------------------------|-----------|
| Number of Fuel Rods per assy. | = 264     |
| Zirc-4 Rod Clad O.D.          | = 0.36"   |
| Clad Thickness                | = 0.0225" |
| Fuel Pellet O.D.              | = 0.3088" |

|                           |   |                              |
|---------------------------|---|------------------------------|
| Fuel Pellet Density       | = | 95 $\frac{1}{2}$ Theoretical |
| Fuel Pellet Dishing       | = | 1.20%                        |
| Rod Pitch                 | = | 0.496" Square                |
| Number Zirc-4 Guide Tubes | = | 25                           |
| Guide Tube O.D.           | = | 0.474"                       |
| Guide Tube Thickness      | = | 0.016"                       |

The assembly is conservatively modeled with water replacing the assembly grid volume and no U-234 or U-236 in the fuel pellet. No U-235 burnup is assumed.

- b. The storage cell nominal geometry is shown on Figure 3.4-1.
- c. The moderator is pure water at the temperature within the design limits of the pool which yields the largest reactivity. A conservative value of 1.0 gm/cm<sup>3</sup> is used for the density of water. No dissolved boron is included in the water.
- d. The array is either infinite in lateral extent or is surrounded by a conservatively chosen reflector, whichever is appropriate for the analytical model. The nominal case calculation is infinite in lateral and axial extent. Poison plates are not necessary on the periphery of the rack module except for the sides of the module adjacent to another rack module (either a PWR rack or a BWR rack). However for the Shearon Harris PWR racks, poison plates are used on all module peripheries except for one module in each pool. Poison plates are omitted from one side of the module (6 cells) for compatibility with the surveillance inspection program.

Calculations for those racks with the poison removed indicate a less reactive configuration than the nominal case of an infinite rack. Therefore, the nominal case of an infinite array of poison cells is a conservative assumption.





e. Mechanical uncertainties and biases due to mechanical tolerances during construction are treated by either using "worst case" conditions or by performing sensitivity studies to obtain the appropriate values. The items included in the analysis are:

- poison pocket thickness
- stainless steel thickness
- can ID
- center-to-center spacing
- can bowing

The calculation method uncertainty and bias is discussed in Section 3.4.4.

f. Credit is taken for the neutron absorption in full length structural materials and in solid materials added specifically for neutron absorption. The minimum poison loading ( $0.02 \text{ gm B10/cm}^2$ ) is assumed in the poison plates and  $\text{B}_4\text{C}$  particle self shielding is included as a bias in the reactivity calculation.

#### 3.4.2.2 BWR FUEL

a. The fuel assembly contains the highest enrichment authorized without any burnable poison and is at its most reactive point in life. The enrichment of the fuel assembly is 3.20 w/o U-235 with no depletion or fission product buildup. The fuel assembly is modeled using the following parameters:

##### GENERAL ELECTRIC FUEL ASSEMBLY (EWR 8 x 8R)

Lattice Pitch - 0.640" square

No. Fuel Rods/Assembly - 62

No. Water Rods/Assembly - 2

Location of Water Rods - Positions #29 & #36

Fuel Rod Pellet O.D. - 0.410"

Fuel Rod Pellet Immersion Density - 95% Theoretical

Active Fuel Length -

6" Natural  $\text{UO}_2$ , 138" enriched (3.2 w/o U-235), 6" Natural  $\text{UO}_2$   
Fuel Rod Clad O.D. - 0.483"  
Fuel Rod Clad Thickness - 0.032"  
Fuel Rod Clad Material - Zircaloy - 2  
Water Rod O.D. - 0.591"  
Water Rod Thickness - 0.030"  
Water Rod Material - Zircaloy - 2

FUEL - CHANNEL

Material - Zircaloy - 2  
Thickness - 0.080"  
Inside Square Dim. - 5.268" (min.)  
Outside Square Dim. - 5.454" (max.)  
Inside Square Dim. - 5.281" (avg.)  
Outside Square Dim. - 5.441" (avg.)

The assembly is conservatively modeled with water replacing the assembly grid volume and no U-234 or U-236 in the fuel pellet. No U-235 burnup is assumed, nor is any credit taken for gadolinium burnable poison.

- b. Figure 3.4-2 shows a schematic of the spent fuel storage racks illustrating the checkerboard arrangement of cell modules. Figure 3.4-3 shows the nominal dimensions of individual cell modules and indicates the unit cell modeled in the KENO analysis.
- c. The moderator is pure water at the temperature within the design limits of the pool which yields the largest reactivity. A conservative value of  $1.0 \text{ gm/cm}^3$  is used for the density of water.



- d. The array is either infinite in lateral extent or is surrounded by a conservatively chosen reflector, whichever is appropriate for the analytical model. The nominal case analytical model is infinite in lateral extent. The following dimensions were modeled in the axial direction:

Rod Clad = 159.5"

Fuel =  $\left\{ \begin{array}{l} 6" \text{ natural } \text{UO}_2 \text{ (top)} \\ 138" \text{ enriched (3.2 w/o U-235)} \\ 6" \text{ natural } \text{UO}_2 \text{ (bottom)} \end{array} \right.$

Channels = 164"

Boraflex = 151"

Storage Cell Can = 164"

Poison plates are not necessary on the periphery of the rack modules since adjacent BWR racks are located far enough apart to preclude an increase in reactivity relative to the infinite array model of poison cells. Furthermore, the BWR rack modules with no poison on the periphery are also located far enough from the PWR modules to preclude an increase in reactivity relative to the infinite array model of PWR or BWR poison cells.

- e. Mechanical uncertainties and biases due to mechanical tolerances during construction are treated by either using "worst case" conditions or by performing sensitivity studies to obtain the appropriate values. The items included in the analysis are:

- rack assembly tolerances
- material thickness tolerances
- center-to-center spacing
- fuel channel effects
- poison loading

The calculational method uncertainty and bias is discussed in Section 3.4.4.

- f. Credit is taken for the neutron absorption in full length structural materials and in solid materials added specifically for neutron absorption. The minimum poison loading ( $0.0103 \text{ gm-B}^{10}/\text{cm}^2$ ) is assumed in the poison plates and  $\text{B}_4\text{C}$  particle self shielding is included as a bias in the reactivity calculation.

### 3.4.3 POSTULATED ACCIDENTS

The following postulated accidents were analyzed:

- a. Drop of fuel assembly on top of racks.
- b. Drop of fuel assembly next to the unpoisoned periphery of the racks.
- c. Inadvertent loading of wrong type of fuel into a storage cell.
- d. Loss of cooling systems
- e. Water injection into racks when used for dry storage.

Each of these accidents are discussed in the sections which follow.

#### 3.4.3.1 Drop of Fuel Assembly on Top of Racks

Four possible accident scenarios can be postulated as follows:

- 1) drop of a PWR assembly on either a PWR or a EWR rack, and,
- 2) drop of a EWR assembly on either a PWR or a EWR rack.

A fuel assembly dropped on top of the racks will be prevented by the rack structure from interacting with the active fuel stored in the rack. The top of the active fuel stored in the EWR racks is approximately 13 inches from the top of the rack structure; the top of the active fuel stored in the PWR racks is approximately 8.5 inches from



the top of the rack structure. Furthermore, calculations show that a single isolated FWR assembly in water is more reactive ( $K_{eff} \approx 0.9$ ) than a single isolated EWR assembly in water ( $K_{eff} \approx 0.7$ ). Consequently, the worst case condition is the drop of a FWR assembly on top of a FWR rack.

Calculations show that even for an infinite array of FWR assemblies separated from each other by as little as 7 inches of water will have a nominal  $K_{eff}$  of less than 0.9 which clearly demonstrates that an assembly 8.5 inches from active fuel is essentially isolated.

#### 3.4.3.2 Drop of Fuel Assembly Next to the Unpoisoned Periphery of the Racks

The "worst case" conditions for this accident would be the drop of a FWR fuel assembly next to an unpoisoned peripheral storage cell of a FWR storage rack. This situation could lead to an increase in  $K_{eff}$  for the array of stored fuel. Therefore, the double contingency principle of ANS N16.1-1975 is applied for this accident. This principle states that it is unnecessary to assume two unlikely, independent, concurrent events to ensure protection against a criticality accident. Thus, for accident conditions, the presence of soluble boron ( $\sim 2000$  ppm) in the storage pool water can be assumed as a realistic initial condition since not assuming its presence would be a second unlikely event.

In the case of Westinghouse 17 x 17 OFA fuel, the presence of approximately 2000 ppm boron in pool water will decrease reactivity by more than 30%  $\Delta K$ . Thus  $K_{eff} < 0.95$  can be easily met for this postulated accident since any reactivity increase would be less than the negative worth of the dissolved boron.





#### 3.4.3.3 Inadvertent Loading of the Wrong Type of Fuel Into a Storage Cell

The design of the storage racks is such that a PWR fuel assembly (because of its physical size) cannot be inadvertently loaded into a BWR storage cell. If a BWR fuel assembly is inadvertently loaded into a PWR storage cell, the design basis  $K_{eff}$  is not exceeded since the single BWR fuel assembly is less reactive than the PWR assembly.

#### 3.4.3.4 Loss of Cooling Systems/Water Injection Into Racks When Used for Dry Storage

For the loss of cooling accident the effect would be a decrease in the water moderator density. This accident can be grouped with the accident in which the storage racks are used as a new fuel dry storage facility and water is introduced for fire fighting or some other abnormal situation. Both accidents involve moderator densities less than 1 gm/cc and suggest the "optimum moderation" condition. However, the "optimum moderation" accident is not a problem in poisoned fuel storage racks. The presence of poison plates removes the conditions necessary for "optimum moderation" so that  $K_{eff}$  continually decreases as moderator density decreases from 1.0 gm/cm<sup>3</sup> to 0.0 gm/cm<sup>3</sup> in poison rack designs.

Figure 3.4-4 shows the behavior of  $K_{eff}$  as a function of moderator density for a BWR poisoned spent fuel rack and Figure 3.4-5 shows a similar behavior for a PWR spent fuel rack.

#### 3.4.4 CRITICALITY ANALYTICAL METHOD

The design method which ensures the criticality safety of fuel assemblies in the PWR and BWR spent fuel storage racks uses the AMFX system of codes<sup>(1,2)</sup> for cross-section generation and KENO IV<sup>(3)</sup> for reactivity determination.

The 218 energy group cross-section library<sup>(1)</sup> that is the common starting point for all cross-sections used for the storage rack analyses was generated from ENDF/B-IV data. The NITAWL program<sup>(2)</sup> adds to this library the self-shielded resonance cross-sections that are appropriate for each particular geometry. The Nordheim Integral Treatment is used in the NITAWL program. Energy and spatial weighting of cross-sections is performed by the XSDRNPM program<sup>(2)</sup> which is a one-dimensional  $S_n$  transport theory code. These multigroup cross-section sets are then used as input to KENO IV<sup>(3)</sup>, which is a three dimensional Monte Carlo theory program designed for reactivity calculations.

The calculation method and cross-section values are verified by comparison with critical experiment data for assemblies similar to those for which the racks are designed. This benchmarking data is sufficiently diverse to establish that the method bias and uncertainty will apply to rack conditions which include strong neutron absorbers, large water gaps and low moderator densities.

A set of 27 critical experiments has been analyzed using the above method to demonstrate its applicability to criticality analysis and to establish the method bias and variability. The experiments range from water moderated, oxide fuel arrays separated by various materials (Boral, steel, water) that simulate LWR fuel shipping and storage conditions,<sup>(4,5)</sup> to dry, harder spectrum uranium metal cylinder arrays with various interspersed materials<sup>(6)</sup> (Plexiglas, steel and air) that demonstrate the wide range of applicability of the method.

The results and some descriptive facts about each of the 27 benchmark critical experiments are given in Table 3.4-1. The average  $K_{eff}$  of the benchmarks is 0.9998 which demonstrates that there is no bias associated with the method. The standard deviation of the  $K_{eff}$  values is 0.0057  $\Delta K$ . The 95/95 one-sided tolerance limit factor for 27 values is 2.26. Thus, there is a 95 percent probability with a

95 percent confidence level that the uncertainty in reactivity, due to the method, is not greater than  $0.013 \Delta K$ .

These methods conform with ANSI N18.2-1973, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants", Section 5.7, Fuel Handling System; ANSI N210-1976, "Design Objective for LWR Spent Fuel Storage Facilities at Nuclear Power Stations", Section 5.1.12; ANSI N16.9-175, "Validation of Computational Methods for Nuclear Criticality Safety"; NRC Standard Review Plan, Section 9.1.2, "Spent Fuel Storage"; and the NRC Guidance, "NRC Position for Review and Acceptance of Spent Fuel Storage and Handling Applications".

#### 3.4.5 CRITICALITY ANALYSIS

This section presents the neutron multiplication factor  $K_{eff}$  calculated using the above method for the nominal designs of both the PWR and BWR racks. Biases and uncertainties are developed for both rack types and include consideration of the following variables: poison loading, poison particle size, rack construction tolerances, rack material thickness tolerances, water density and calculation method uncertainty. This section also combines the nominal  $K_{eff}$  with biases and uncertainties to develop a final  $K_{eff}$  for each type of storage rack (i.e. BWR or PWR) at a 95 percent probability with a 95 percent confidence level.

This section also presents the results of sensitivity studies which show how the  $K_{eff}$  for the array varies as a function of cell center-to-center spacing, fuel enrichment, and poison loading of the poison plates. Finally, this section discusses the combination of BWR fuel racks loaded in the same pool with PWR fuel racks and the possibility of interaction between the two fuel types.



### 3.4.5.1 FWR Fuel Storage Racks

#### a. Nominal KENO $K_{eff}$

The  $K_{eff}$  for the nominal design of the FWR fuel storage racks was computed by the KENO code to be  $0.8968 \pm .0050$  (95/95). The KENO model was based on the nominal dimensions of the unit cell shown on figure 3.4-1. The minimum boron loading of 0.02 grams of  $B^{10}$  per square centimeter was incorporated in the model and the water density was 1 gram per cubic centimeter. The fuel parameters modeled for the nominal KENO are given in section 3.4.2.1.

#### b. Biases and Uncertainties

As discussed in section 3.4.4 the KENO method had a 0.0 bias with a 95/95 uncertainty of  $0.013 \Delta k$ .

Calculations have shown that when the boron in the poison plates is modeled as a homogenized mixture of elements, the results are biased by a positive  $0.0025 \Delta k$  relative to models which discretely define the  $B_4C$  particles.

The mechanical tolerances of the individual storage cells and the construction tolerances of the FWR fuel storage rack will allow storage cells to be closer together than the  $\left[ \quad \right]_{a,b,c,e}$  inches shown on Figure 3.4-1. For the Shearon Harris FWR racks the worst combination of mechanical tolerances (i.e., sheet metal thickness, cell I.D. maximum, rack grid assembly, and cell bowing) will result in a reduction of the water gap between adjacent cells by  $\left[ \quad \right]_{a,b,c,e}$ . Furthermore, a "GO-NOGO" gauge will be employed during construction to ensure that the nominal gap of  $\left[ \quad \right]_{a,b,c,e}$  (see Figure 3.4-1) between the wrapper plates of adjacent cells will not be less than  $\left[ \quad \right]_{a,b,c,e}$  inches. For a single can it is calculated that reactivity does not increase significantly because the increase in reactivity due to the water gap reduction on one side of the can is offset by the decrease in reactivity due to the increased water gap on the opposite side of

this can. The analysis, for the effect of mechanical tolerances, however, assumes a worst case of a rack composed of an array of groups of four cans where the water gap between the four cans is reduced to  $\left[ \quad \right]_{a,b,c,e}^{\text{inch}}$ . The reactivity increase of this configuration is found to be  $0.011 \Delta k$  and is included as a bias term in calculating the final  $K_{\text{eff}}$  of the rack:

Some mechanical tolerances are not included in the analysis because worst case assumptions are used in the nominal case analysis. An example of this is eccentric assembly position.. Calculations were performed which show that the most reactive condition is the assembly centered in the can which is assumed in the nominal case.

#### c. Final $K_{\text{eff}}$ for PWR Fuel Storage Racks

For normal operation and using the method described in the above sections, the final  $K_{\text{eff}}$  for the rack is determined in the following manner:

$$K_{\text{eff}} = K_{\text{nominal}} + B_{\text{mech}} + B_{\text{method}} + B_{\text{part}} + [(K_{\text{s nominal}})^2 + (K_{\text{s method}})^2]^{1/2}$$

where:

$K_{\text{nominal}}$  = nominal case KENO  $K_{\text{eff}}$

$B_{\text{mech}}$  = bias to account for the fact that mechanical tolerances can result in water gaps between poison plates less than nominal.

$B_{\text{method}}$  = method bias determined from benchmark critical comparisons.

$B_{\text{part}}$  = bias to account for poison particle self-shielding.

$K_{\text{eff}}^{\text{nominal}} = 95/95$  uncertainty in the nominal case KENO  $K_{\text{eff}}$

$K_{\text{method}} = 95/95$  uncertainty in the method bias.

Substituting calculated values as developed in items a and b, the result is:

$$\begin{aligned} K_{\text{eff}} &= 0.8968 + 0.011 + 0.0 + 0.0025 + [(0.0050)^2 + (0.013)^2]^{1/2} \\ &= 0.9242. \end{aligned}$$

Since  $K_{\text{eff}}$  is less than 0.95 including uncertainties at a 95/95 probability/confidence level, the acceptance criteria for criticality is met.

#### d. Sensitivity Studies for FWR Racks

To show the dependence of  $K_{\text{eff}}$  on fuel and storage cell parameters as requested by the NRC, sensitivity studies were performed relative to the nominal model in which the boron loading of the poison plates, the fuel enrichment, and the storage cell center-to-center spacing were varied. Figure 3.4-6 shows the results of the calculations of the sensitivity studies for the Shearon Harris FWR fuel storage racks.

#### 3.4.5.2 EWR Fuel Storage Racks

##### a. Nominal KENO $K_{\text{eff}}$

The  $K_{\text{eff}}$  for the nominal design of the EWR fuel storage racks was computed by the KENO computer code to be  $0.9274 \pm .0031$  (95/95). The KENO model was based on the nominal dimensions of the unit cell shown on Figure 3.4-3. The minimum boron loading of 0.0103 grams of  $B^{10}$  per square centimeter was incorporated in the model and the water density was 1 gram per cubic centimeter. The fuel parameters modeled for the nominal KENO are given in section 3.4.2.2.



## b. Biases and Uncertainties

As discussed in section 3.4.4, the KENO method had a 0.0 bias with a 95/95 uncertainty of  $.013 \Delta k$ .

Calculations have shown that when the boron in the poison plates is modeled as a homogenized mixture of elements, the results are biased by a positive  $0.006 \Delta k$  relative to models which discretely define the  $B_4C$  particles.

The construction tolerances for BWR racks allow for the nominal center-to-center spacing of storage cells of  $\left[ \begin{smallmatrix} a, b, c, e \\ a, b, c, e \end{smallmatrix} \right]$  inches to be randomly reduced to  $\left[ \begin{smallmatrix} a, b, c, e \\ a, b, c, e \end{smallmatrix} \right]$  inches for individual cells. It was calculated that the increase in  $K_{eff}$  due to the random reduction in cell center-to-center would be less than  $0.032 \Delta k$  with a (95% confidence/95% probability) level. Calculations for material thicknesses tolerances of the cell sheet metal and the poison plates indicated that the increase in  $\Delta k$  would be less than  $0.0079$  with a (95% confidence/95% probability) level.

In addition to the uncertainty in the final  $K_{eff}$  associated with the various parameters discussed above, there are other physical variables that may affect  $K_{eff}$ . Analysis showed that the infinite poisoned array was more reactive with fuel channels included than it was without the channels. It was also determined that the reactivity was higher for the fuel (either channeled or unchanneled) when the assemblies were located exactly in the center of the storage cells. The boraflex poison is specified to contain a minimum loading of  $.0103$  grams of  $B^{10}$  per square centimeter and that value was employed throughout the analysis for the sake of conservatism. The "nominal" case KENO (see Item a) then has already incorporated three "worst case" conditions (i.e. centered fuel, channels included, and minimum poison loading).

c. Final  $K_{eff}$  For EWR Fuel Storage Racks

For normal operation and using the method described in the above sections, the final  $K_{eff}$  for the rack is determined in the following manner.

$$K_{eff} = K_{nominal} + B_{method} + B_{part} + [(ks_{nominal})^2 + (ks_{mech})^2 + (ks_{method})^2 + (ks_{mat})^2]^{1/2}$$

where:

$K_{nominal}$  = nominal case KENO  $K_{eff}$

$B_{method}$  = method bias determined from benchmark critical comparisons.

$B_{part}$  = bias to account for poison particle self-shielding.

$ks_{nominal}$  = 95/95 uncertainty in the nominal case KENO  $K_{eff}$ .

$ks_{mech}$  = 95/95 uncertainty in the calculation of the bias due to construction tolerances.

$ks_{method}$  = 95/95 uncertainty in the method bias.

$ks_{mat}$  = 95/95 uncertainty associated with material thickness tolerances.

Substituting calculated values given in items a and b in the order listed above, the result is:

$$K_{eff} = 0.9274 + 0.0 + 0.006 + [(.0031)^2 + (.0032)^2 + (.013)^2 + (.0079)^2]^{1/2} = 0.9493$$

Since  $K_{eff}$  is less than 0.95 including uncertainties at a 95/95 probability/confidence level, the acceptance criteria for criticality is met.

#### d. Sensitivity Studies for BWR Racks

To show the dependence of  $K_{eff}$  on fuel and storage cell parameters as requested by the NRC, sensitivity studies were performed relative to the nominal model in which the boron loading of the poison plates, the fuel enrichment, and the storage cell center-to-center spacing were varied. Figures 3.4-7 and 3.4-8 show the results of the calculations of the sensitivity studies.

#### 3.4.5.3 PWR/BWR Racks in Same Pool

In the Shearon Harris spent fuel pools both PWR and BWR fuel storage racks may be placed in the same pool. In sections 3.4.5.1 and 3.4.5.2 it was determined that the maximum neutron multiplication factor,  $K_{eff}$ , for an infinite array of stored fuel, including uncertainties was 0.9242 for PWR fuel and 0.9493 for BWR fuel. Calculations were performed which showed that, if the cell centerline plane of the peripheral cells of a BWR rack were maintained at a distance equal to or greater than 9.0 inches from the cell centerline plane of the peripheral cells of a PWR rack, the resulting  $K_{eff}$  for the combined configuration was less than 0.94. Since the pool layouts indicate that the 9 inch minimum is not violated, the acceptance criteria is met for pools containing both BWR and PWR storage racks.

#### 3.4.6 ACCEPTANCE CRITERIA FOR CRITICALITY

The neutron multiplication factor in the spent fuel pool shall be less than or equal to 0.95, including all uncertainties, under all conditions.

Generally, the acceptance criteria for postulated accident conditions can be  $K_{eff} \leq 0.98$  because of the accuracy of the methods used coupled with the low probability of occurrence. For instance, in ANSI N210-1976 the acceptance criteria for the "optimum moderation" condition is  $K_{eff} \leq 0.98$ . However, for simplicity, the acceptance criteria for all conditions will be  $K_{eff} \leq 0.95$  including accidents.

#### REFERENCES


1. W.E. Ford III, et al, "A 218-Group Neutron Cross-Section Library in the AMPX Master Interface Format for Criticality Safety Studies," ORNL/CSD/TM-4 (July 1976).
2. N.M. Greene, et al, "AMPX: A Modular Code System for Generating Coupled Multigroup Neutron-Gamma Libraries from ENDF/B," ORNL/TM-3706 (March 1976).
3. L.M. Petrie and N.F. Cross, "KENO IV" - An Improved Monte Carlo Criticality Program," ORNL-4938 (November 1975).
4. S.R. Bierman, et al, "Critical Separation Between Subcritical Clusters of 2.35 wt %  $^{235}\text{U}$  Enriched  $\text{UO}_2$  Rods in Water with Fixed Neutron Poisons," Battelle Pacific Northwest Laboratories PNL-2438 (October 1977).
5. S.R. Bierman, et al, "Critical Separation Between Subcritical Clusters of 4.29 wt %  $^{235}\text{U}$  Enriched  $\text{UO}_2$  Rods in Water with Fixed Neutron Poisons," Battelle Pacific Northwest Laboratories PNL-2614 (March 1978).
6. J.T. Thomas, "Critical Three-Dimensional Arrays of U (93.2) - Metal Cylinders," Nuclear Science and Engineering, Volume 52, pages 350-359 (1973).


## BENCHMARK CRITICAL EXPERIMENTS [4, 5, 6]

| <u>General Description</u>  | <u>Enrichment w/o U235</u> | <u>Reflector</u> | <u>Separating Material</u> | <u>Characterizing Separation (cm)</u> | <u>K<sub>eff</sub></u> |
|-----------------------------|----------------------------|------------------|----------------------------|---------------------------------------|------------------------|
| UO <sub>2</sub> rod lattice | 2.35                       | water            | water                      | 11.92                                 | 1.004 ± .004           |
| "                           | "                          | "                | "                          | 8.39                                  | 0.993 ± .004           |
| "                           | "                          | "                | "                          | 6.39                                  | 1.005 ± .004           |
| "                           | "                          | "                | "                          | 4.46                                  | 0.994 ± .004           |
| "                           | "                          | "                | stainless steel            | 10.44                                 | 1.005 ± .004           |
| "                           | "                          | "                | "                          | 11.47                                 | 0.992 ± .004           |
| "                           | "                          | "                | "                          | 7.76                                  | 0.992 ± .004           |
| "                           | "                          | "                | "                          | 7.42                                  | 1.004 ± .004           |
| "                           | "                          | "                | boral                      | 6.34                                  | 1.005 ± .004           |
| "                           | "                          | "                | "                          | 9.03                                  | 0.992 ± .004           |
| "                           | "                          | "                | "                          | 5.05                                  | 1.001 ± .004           |
| "                           | 4.29                       | "                | water                      | 10.64                                 | 0.999 ± .005           |
| "                           | "                          | "                | stainless steel            | 9.76                                  | 0.999 ± .005           |
| "                           | "                          | "                | "                          | 8.08                                  | 0.998 ± .006           |
| "                           | "                          | "                | boral                      | 6.72                                  | 0.998 ± .005           |
| U metal cylinders           | 93.2                       | bare             | air                        | 15.43                                 | 0.998 ± .003           |
| "                           | "                          | paraffin         | air                        | 23.84                                 | 1.006 ± .005           |
| "                           | "                          | bare             | air                        | 19.97                                 | 1.005 ± .003           |
| "                           | "                          | paraffin         | air                        | 36.47                                 | 1.001 ± .004           |
| "                           | "                          | bare             | air                        | 13.74                                 | 1.005 ± .003           |
| "                           | "                          | paraffin         | air                        | 23.48                                 | 1.005 ± .004           |
| "                           | "                          | bare             | plexiglass                 | 15.74                                 | 1.010 ± .003           |
| "                           | "                          | paraffin         | plexiglass                 | 24.43                                 | 1.006 ± .004           |
| "                           | "                          | bare             | plexiglass                 | 21.74                                 | 0.999 ± .003           |
| "                           | "                          | paraffin         | plexiglass                 | 27.94                                 | 0.994 ± .005           |
| "                           | "                          | bare             | steel                      | 14.74                                 | 1.000 ± .003           |



FIGURE 3.4-1 STORAGE CELL NOMINAL DIMENSIONS  
IN THE PWR STORAGE RACKS





\*SEE FIGURE 3.4-3 FOR DETAIL DESCRIPTION OF MODULE.

ILLUSTRATION OF SPENT FUEL STORAGE ARRANGEMENT

SHOWING "CHECKERBOARD" ALIGNMENT OF STORAGE

MODULES IN THE BWR STORAGE RACKS

(NOT DRAWN TO ACTUAL SCALE)

FIGURE 3.4-2






FIGURE 3.4-3. NOMINAL DIMENSIONS FOR TYPICAL  
SPENT FUEL STORAGE CELL

FIGURE 3.4.4

EFFECT OF WATER DENSITY ON NEUTRON  
MULTIPLICATION FACTOR FOR A TYPICAL BWR

POISONED FUEL RACK

1.0

0.9

0.8

0.7

0.6

0.5

$k_{eff}$

NOTES: FUEL ENRICHMENT = 3.04 W/O U<sup>235</sup>

POISON LOADING = 0.01 GM-B<sup>10</sup>/CM<sup>2</sup>

FUEL LATTICE = E } CENTER-TO-CENTER

0 0.2 0.4 0.6 0.8 1.0

WATER DENSITY (GM/CC)




FIGURE 3.4-5  $K_{eff}$  VS. WATER MODERATOR DENSITY

FOR A TYPICAL "POISONED" PWR SPENT FUEL STORAGE RACK






FIGURE 3.4-6

$k_{eff}$  AS A FUNCTION OF C-C SPACING,  
POISON LOADING AND ENRICHMENT  
FOR PWR SPENT FUEL RACK



NOTES: FOR ENRICHMENT CURVE, C-C = [ ],  $a, b, c, e$  LOADING = 0.02  
 " SPACING CURVE, W/O = 3.9, LOADING = 0.02  
 " LOADING " , W/O = 3.9, C-C = 10.5"

FIGURE 3.4-7  
NEUTRON MULTIPLICATION FACTOR,  $k_{eff}$   
AS A FUNCTION OF FUEL ENRICHMENT  
AND POISON 8-10 LOADING  
FOR BWR SPENT FUEL RACK




NOTES: FOR ENRICHMENT CURVE, 8-10 LOADING = 0.0103  
FOR POISON LOADING CURVE, ENRICHMENT = 3.20  
FOR BOTH CURVES, THE CENTER-TO-CENTER SPACING  
OF FUEL ASSEMBLIES =  $\left[ \begin{matrix} 26.52 \\ 26.52 \end{matrix} \right]$  INCHES



11-1-74

FIGURE 3.4-8  
NEUTRON MULTIPLICATION FACTOR ( $k_{eff}$ )  
AS A FUNCTION OF STORAGE CELL CENTER-  
TO-CENTER SPACING  
FOR BWR SPENT FUEL RACK



CELL CENTER-TO-CENTER SPACING (INCHES)

NOTES: FUEL ENRICHMENT = 3.20 W/O  $U^{235}$

POISON LOADING = 0.0103 gm- $B^{10}$ /CM<sup>2</sup>

\*DUE TO "CHECKERBOARD" DESIGN MINIMUM CELL  
SPACING = [ ] INCHES