

**ANALYSIS OF HABITABILITY
OF THE
SHEARON HARRIS NUCLEAR POWER PLANT
EMERGENCY OPERATIONS FACILITY**

Prepared for
CAROLINA POWER & LIGHT COMPANY

EBASCO
EBASCO SERVICES INCORPORATED

SEPTEMBER 1983

8311020118 831025
PDR ADCK 05000400
F PDR



Small, faint, illegible marks or characters in the top right corner.

Faint, illegible text or markings at the bottom right of the page.

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 INTRODUCTION	1
2.0 EXPOSURES TO RADIONUCLIDES AIRBORNE INSIDE FACILITY	1
2.1 Methodology	1
2.2 Assumptions and Parameters	2
2.3 Results	2
3.0 PROTECTION FACTOR ESTIMATE	3
3.1 Methodology	3
3.2 Assumptions and Parameters	3
3.3 Results	3
4.0 CONCLUSIONS	4
PROTECTION FACTOR ESTIMATOR SOLUTION FORM	
REFERENCES	
APPENDIX A	

LIST OF TABLES

<u>TITLE</u>	<u>TABLE NO.</u>
30-Day Inhalation and Submersion doses at the Emergency Operations Facility	1
Emergency Operations Facility Protection Factors for Outdoor Contamination	2



LIST OF FIGURES

<u>TITLE</u>	<u>FIGURE NO.</u>
Ventilation System of the SHNPP Emergency Operations Facility	1
Emergency Operations Facility	2
Emergency Operations Facility Building Key	3

1.0 INTRODUCTION

The Emergency Operations Facility (EOF) will be operated by Carolina Power and Light Company for the management of overall licensee emergency response, coordination of radiological and environmental assessment, development of recommendations for public protective actions and coordination of emergency response activities with Federal, State and Local supporting agencies. The EOF for the Shearon Harris Nuclear Power Plant is located 3,429 meters from the plant site.

The Nuclear Regulatory Commission has provided guidance on acceptable design features for EOFs. Supplement 1 to NUREG-0737 indicates that an EOF should have a protection factor of 5, ventilation isolation and HEPA filters. Habitability requirements are only for the part of the EOF in which dose assessments, communications and decision making take place.

This habitability study consists of an assessment of exposures to individuals in the EOF from radionuclides airborne inside the facility and an analysis of the building protection factors for outside contamination.

2.0 EXPOSURES TO RADIONUCLIDES AIRBORNE INSIDE FACILITY

The EOF ventilation system is designed to draw in 720 CFM outside air. In the event of an incident at SHNPP, the outside air whether drawn in by the air handling unit or injected into the system by the emergency fan serves to pressurize the system and will leave the system by infiltration. (See Figure 1)

The 30-day thyroid, whole body and skin doses to individuals inside the EOF were evaluated for a design basis loss-of-coolant accident (LOCA).

2.1 Methodology

A design basis LOCA provides the radionuclide release rate from the containment using the guidance given in Regulatory Guide 1.4. Atmospheric dispersion factors at the EOF were calculated in accordance with Regulatory Guide 1.145. The detailed description of the activity release and dose evaluation models are given in Appendix 15.0.A of the SHNPP FSAR.

2.2 Assumptions and Parameters

The following lists the assumptions and parameters used in the analysis of inhalation and submersion doses:

- 1) design basis assumptions presented in FSAR 15.6.5.4.1 are applied,
- 2) accident duration is assumed to be 30 days,
- 3) the net free volume of EOF is estimated to be 31,716 ft³ (898 M³), allowing 10% of the volume for equipment and furniture. This volume represents the first floor of the EOF where management and coordination of emergency activities, dose assessment, communications and decision making takes place (See Figure 2),
- 4) radionuclides are uniformly distributed throughout the EOF net free volume,
- 5) EOF atmospheric dispersion factors are:

<u>Time Period</u>	<u>X/Q in sec/m³</u>
0 - 8 hrs	1.1 X 10 ⁻⁴
8 - 24 hrs	8.1 X 10 ⁻⁵
1 - 4 days	2.9 X 10 ⁻⁵
4 - 30 days	7.1 X 10 ⁻⁶

- 6) occupancy of the EOF is based on the following:

<u>Time Period</u>	<u>Occupancy Factor</u>
0 - 24 hours	1.0
1 - 4 days	0.6
4 - 30 days	0.4

- 7) a finite cloud correction is used,
- 8) filter efficiency of EOF emergency cleanup system for iodine is 99%,
- 9) a breathing rate of the occupants of 3.47 X 10⁻⁴ cubic meters per second for the duration of the accident,
- 10) the EOF air intake flow rate is 720 CFM (with no recirculation), and
- 11) the assumed unfiltered in-leakage into the pressurized EOF is 3 CFM with air locks as a result of opening and closing of doors.

2.3 Results

The doses to an EOF occupant are presented in Table 1. These doses are well within the GDC-19 limit of 5 rems to the whole body and the corresponding SRP 6.4 limits of 30 rem to the skin and thyroid.

3.0 PROTECTION FACTORS ESTIMATE

An individual in the EOF would also receive exposure from outdoor contamination which is 1) airborne and 2) deposited on the ground and roof. Building protection factors have been calculated separately for each type of contamination.

3.1 Methodology

The models used in the calculation of protection factors for outdoor airborne contamination are included in Appendix A. Methodology included in Reference 1 was used in the calculation of protection factors for outdoor ground and roof contamination.

The analysis has been performed by dividing the first and second floors into six azimuthal sectors as indicated in Figure 2. Figure 3 indicates that the contribution to exposure through walls in sectors E and F is small due to presence of the building complex and therefore has been ignored in the analysis. The parameters used in the evaluation and results for outdoor surface contamination are included on the PFE solution forms. The chart numbers refer to those included in Reference 1.

3.2 Assumptions and Parameters

The following assumptions and parameters are used in the evaluation of the protection factors for the EOF:

- 1) interior walls of the building, in which the EOF is located, are 8.0 inches thick.
- 2) walls enclosing the EOF are 8.0 inches thick.
- 3) each floor thickness is 8.0 inches.
- 4) the ceiling heights of the first floor, second floor and mezzanine are 9.7 ft., 8.2 ft. and 8 ft., respectively.
- 5) density of concrete is 140 lbs/cu. ft.

3.3 Results

Protection factors calculated for the first and second floors of the EOF are included in Table-2. The values for both outdoor surface and airborne contaminations are above 5 and hence exceed the requirements of NUREG-0737.

4.0 CONCLUSIONS

The analysis of the inhalation and submersion (skin, whole body and thyroid) doses to an EOF occupant has shown that the 30-day exposures will be well within the GDC-19 and SRP 5.4 limits. Consequently, the EOF location and design of its emergency air filtration system have been demonstrated to be appropriately chosen to ensure more than adequate protection of personnel during relatively long periods of occupancy following even the most severe design-basis accident.

In addition, the structural aspects of the EOF have been analyzed with regards to the protection level it affords against outside airborne and deposited radioactive contaminants. The resultant protection factors, prove that there is sufficient shielding between the critical areas of the EOF to be occupied and the outside contamination carried in and deposited by a radioactive plume.

TABLE 1

30-Day Inhalation and Submersion Doses
At The Emergency Operations Facility
(Rem)

	<u>Dose</u>
Whole Body	0.02
Skin	0.60
Thyroid	1.60

TABLE 2

Emergency Operations Facility
Protection Factors for Outdoor Contamination

	<u>Radioactive Plume</u>	<u>Protection Factors</u> <u>Surface Contamination</u>
First Floor	18.5	50
Second Floor	5.1	33



PFE SOLUTION FORM

Project SHNPP - EMERGENCY OPERATIONS FACILITY - FIRST FLOOR

Parameters	Factor	SECTOR OR BUILDING SIDE				Chart
		A	B	C	D	

$W = \frac{0}{52.7}$ 66 40 70 70

ROOF MASS THICKNESS:

$L = \frac{90.5}{4769}$	$X'_o (A, Z, X_o) =$					Chart 1
$A = \frac{4769}{22.83}$	$C_o (A, Z, X_o) =$.0018	Chart 1

$Z = \frac{22.83}{3}$

$H = \frac{3}{0}$

WALL MASS THICKNESS:

$A_p = \frac{0}{187.2}$	$X'_e (X_e, A_p) =$	93.6	93.6	93.6	93.6	Chart 2
$W_c = \frac{187.2}{93.6}$	$X_i =$	0	93.6	93.6	0	-
$X_o = \frac{93.6}{0, 93.6, 93.6, 0}$	$\Delta X_w (H, W_c) =$					Chart 3
$X_e = \frac{93.6}{187.2}$	$\Delta X_w (A) =$					
$X_i = \frac{0}{187.2}$	$\Delta X_w (E_x) =$					
$X_t = \frac{187.2}{0}$	$\Delta X_w (X_c) =$	6.7	6.7	6.7	6.7	WALL HEIGHT RULE
$X_r = \frac{0}{0}$	$X'_w =$	100.3	193.9	193.9	100.3	

WALL-BY-WALL ANALYSIS:

$y = \frac{0}{h}$	$X'_w =$	100.3	193.9	193.9	100.3	Leave out $\Delta X_w (A)$
$h = \frac{0}{h}$	$r =$	32	48	130	42.5	-
$E_x = \frac{y}{h}$	$C'_o (X'_w, r) =$.012	.0012	.0005	.0098	Chart 8

PROTECTION FACTOR:

$C'_o (X'_w, r) =$.009	.0005	.0004	.008	.018
$RF = C_o + C'_o =$.02
$PF =$.50



Project SHNPP - EMERGENCY OPERATIONS FACILITY - SECOND FLOOR

Parameters	Factor	SECTOR OR BUILDING SIDE				Chart
		A	B	C	D	

W = 52.7 66 40 70 70

ROOF MASS THICKNESS:

L = <u>90.5</u>	$X'_o(A, Z, X_o) =$					Chart 1
A = <u>4769</u>	$C_o(A, Z, X_o) =$.018	Chart 1

Z = 13.17

H = 12.66

WALL MASS THICKNESS:

$A_p =$ <u>0</u>	$X'_e(X_e, A_p) =$	93.6	93.6	93.6	93.6	Chart 2
$W_c =$ _____	$X_i =$	0	93.6	93.6	0	-
$X_o =$ <u>93.6</u>	$\Delta X_w(H, W_c) =$	17	17	17	17	Chart 3
$X_e =$ <u>93.6</u>	$\Delta X_w(A) =$					
$X_i =$ <u>$\frac{A}{0}, \frac{B}{93.6}, \frac{C}{93.6}, \frac{D}{0}$</u>	$\Delta X_w(E_x) =$					
$X_r =$ <u>93.6</u>	$\Delta X_w(X_c) =$	9.7	9.7	9.7	9.7	Wall Height Rule
$X_r =$ <u>0</u>	$X'_w =$	120.3	213.9	213.9	120.3	

WALL-BY-WALL ANALYSIS:

$y =$ _____	$X'_w =$	120.3	213.9	213.9	120.3	Leave out $\Delta X_w(A)$
$h =$ _____	$r =$	32	48	130	42.5	-
$E_x = \frac{y}{h} =$ _____	$C'_o(X'_w, r) =$.008	.0008	.00033	.005	Chart 8

PROTECTION FACTOR:

$\frac{0}{90} C'_o(X'_w, r) =$.006	.0004	.0003	.004	0.11
$RF = C_o + C'_o =$.03
$PF =$					33

P F E SOLUTION FORM

LIST OF SYMBOLS

θ	=	Azimuthal Angle, $^{\circ}$
W	=	Width, ft
L	=	Length, ft
A	=	The Plan Area of the Building or the Contributing Roof Area, sq ft
Z	=	Distance from Detector Location to Roof, ft
H	=	Height of Detector Location Above Ground Contamination, ft
A_p	=	Percent of Apertures in Exterior Wall.
W_c	=	Width of Ground Contaminated Field, ft
X_o	=	Total Mass Thickness between a Detector Location and Roof, psf $X_f + X_r$
X_e	=	Exterior Wall Mass Thickness, psf
X_i	=	Interior Partition Mass Thickness, psf
X_f	=	Floor Mass Thickness, psf
X_r	=	Roof Mass Thickness, psf
X_c	=	Basement Ceiling Mass Thickness, psf
y	=	The Exposed Portion of a Partially Exposed Basement Wall, ft
h	=	The Ceiling Height of an Exposed Basement, ft
E_x	=	y/h the Exposed Fraction of a Basement Wall
X'_e	=	Adjusted Wall Mass Thickness (Corrected for Apertures) psf
C_o	=	Total Overhead Contribution
X'_o	=	Equivalent Overhead Mass Thickness, psf
ΔX_w	=	An Incremental Increase (or Decrease) in the Exterior Wall Mass Thickness Used to Equate the Real Building to an Equivalent Building, psf
X'_w	=	Equivalent Wall Mass Thickness, psf
C_g	=	Total Ground Contribution
PF	=	Protection Factor

References:

1. "Shelter Design And Analysis", TR-20 (Vol. 2), February 1976, Defense Civil Preparedness Agency.
2. Meteorology and Atomic Energy, 1968. U.S. Atomic Energy Commission.
3. "The Effectiveness of Sheltering as a Protective Action Against Nuclear Accidents Involving Gaseous Releases", Protective Action Evaluation Part 1, April 1978. George H. Anno and Michael A. Dore, U. S. Environmental Protection Agency.




FIGURE 2

EMERGENCY OPERATIONS FACILITY



Small, faint, illegible markings or characters in the top right corner.

Small, faint, illegible markings or characters near the bottom center of the page.




FIGURE 3
EMERGENCY OPERATIONS FACILITY
BUILDING KEY



APPENDIX A

PROTECTION FACTOR CALCULATION MODELS

Protection Factors (PF) for the buildings due to outdoor ground and roof contaminations were calculated using the methodology presented in Ref. 1, which should be referred to for this purpose.

PF for outdoor plume were calculated using the models presented as follows:

A structure provides protection by the geometrical effect of limiting the distance of approach of the cloud and by shielding afforded by walls. PF is obtained by assuming the plume to be hemispherical in shape and applying equation 7.77 of Ref. 2 .

$$\begin{aligned}
 PF = & (1+Kx.Ux.W) \exp (-Ux.W) \\
 & \times \left\{ \left[\exp (-u.a) - \exp (-u.r1) - K (1+u.r1) \right. \right. \\
 & \times \left. \left. \exp (-u.r1) + K (1+u.a) \exp (-u.a) \right] \right. \\
 & \times \left. \left[1 - \exp (-u.r1) - K (1+u.r1) \exp (-u.r1) + K \right]^{-1} \right\}
 \end{aligned}$$

Where,

- U_x = total absorption coefficient for building material; cm^2/g or cm^{-1}
- u = total absorption coefficient for air; cm^2/g or cm^{-1}
- $u = U_a + U_s$
- U_a = energy absorption coefficient; cm^2/g or cm^{-1}
- U_s = scattering absorption coefficient; cm^2/g or cm^{-1}
- W = thickness of shield afforded by building material; g/cm^2
- K_x = component in the buildup factor = $(U_x - U_a)/U_a$



K = component in the buildup factor for air = 1.25 @ 1.0 MeV.*

a = effective building radius, cm
 $= \sqrt[3]{V \times \frac{3}{2\pi}}$

V = volume of building; cm^3

r_1 = radioactive plume radius, cm

Assuming the plume size is very large and substituting infinity for r_1 in the above equation;

$$\text{PF} = (1+Kx.Ux.W) \exp(-Ux.W) \times \left\{ \frac{[1+K(1+u.a)] \exp(-u.a)}{1+K} \right\}$$

= A X B — (i)

The term represented by B expresses the PF from the geometrical considerations, whereas that represented by A expresses the shielding factor.

The shielding provided through the roof is different from that provided by walls. Also, walls have windows and doors which do not provide any protection. Therefore, the above equation has been modified as follows:

$$\text{PF} = B \times \left[F_w \{ A_p + (1-A_p) \times A_w \} + F_r \times A_r \right] \text{ — (ii)}$$

Where, F_r^{**} = fraction of gamma radiation through roof
 F_w = fraction of gamma radiation through walls
 A_p = fraction representing aperture (windows, doors, etc.) in walls.

* 1.0 MEV gamma energy used in the calculation is close to the value indicated in Ref.3 .

** F_r is obtained by using Figure 7.33 of Ref. 2 or hand calculation.

A_w = shielding factor for walls

A_r = shielding factor for roof