

**ANALYSIS OF HABITABILITY  
OF THE  
SHEARON HARRIS NUCLEAR POWER PLANT  
TECHNICAL SUPPORT CENTER**

*Prepared for*  
**CAROLINA POWER & LIGHT COMPANY**

**EBASCO**  
**EBASCO SERVICES INCORPORATED**

**SEPTEMBER 1983.**

8311020126 831025  
PDR ADOCK 05000400  
F PDR

TABLE OF CONTENTS

	<u>Page No.</u>
1. INTRODUCTION	1
2. DIRECT RADIATION EXPOSURE ANALYSIS	1
3. EXPOSURE TO RADIONUCLIDES AIRBORNE INSIDE THE TSC	2
3.1 Methodology	2
3.2 Assumptions and Parameters	2
3.3 Results and Conclusion	3

REFERENCES



LIST OF TABLES AND FIGURE

TABLE 1 - Direct Shine Doses to TSC Personnel From  
Radioactivity on Emergency Ventilation  
System Filters

TABLE 2 - Inhalation and Submersion Doses to TSC  
Personnel Following a Design-Basis  
Loss-of-Coolant Accident

FIGURE 1 - Technical Support Center  
Emergency Ventilation System  
Air Flow Diagram



Small, faint, illegible marks or characters in the top right corner.


## 1. INTRODUCTION

This study is performed to determine the habitability of the Technical Support Center (TSC), after a radiological accident at the Shearon Harris Nuclear Power Plant (SHNPP). General Design Criterion 19 (GDC-19) (Ref. 1) Appendix A to 10CFR50 specifies a radiation exposure limit of 5 rem whole body, or its equivalent to any part of the body of personnel within the facility for the duration of the accident. The analyses presented in this report are provided in two sections. The first section, entitled Direct Radiation Exposure Analysis, addresses direct radiation exposure from 1) local sources of radiation, 2) radionuclides in containment, 3) airborne radionuclides which may leak from containment and are transported to areas adjacent to the TSC and 4) buildup of radionuclides on emergency filtration systems located within the facility. The second section of the report, entitled Exposure to Radionuclides Airborne Inside the TSC, addresses the whole body, thyroid and skin doses to occupants due to intake of airborne radionuclides into the facility. A major loss-of-coolant accident (LOCA) is the design basis event which provides the emergency condition for habitability.

## 2. DIRECT RADIATION EXPOSURE ANALYSIS

The shielding analysis for the TSC has been performed in accordance with the assumptions stated in Section 12.3.2.16 of the SHNPP FSAR. The source term used in the calculations is described in Section 12.2.1.12.

The TSC is located in the Fuel Handling Building at Elevation 324' and is separated from the containment by an additional six feet of concrete and a minimum distance of 88 feet. Dose rates near the containment due to direct shine are shown on page 12.3A-10 of the FSAR for Region R 27 (area immediately outside containment). All radioactive piping of interest is located below Elevation 261' in the Reactor Auxiliary Building and is separated from the TSC by six feet of concrete and a distance of 110 feet. These sources do not make a significant contribution to dose rates in the TSC. The emergency ventilation system filters, located in the mechanical room of the facility, have been postulated to be the most relatively significant source of direct exposure. Dose rates due to this source at various time intervals in different areas of the facility are shown in Table 1. These dose rates are within the limits for continuous occupancy of the facility.



### 3. EXPOSURE TO RADIONUCLIDES AIRBORNE INSIDE THE TSC

The TSC is designed with one outside air intake at Elevation 336' (MSL) in the southwest corner of the Fuel Handling Building along the west wall. The room containing the ventilation equipment (charcoal filters, etc.) is in the southwest quadrant separated from the rest of the facility by a 12" block wall.

In an emergency condition or when radiation is detected in the air stream, outside air will be drawn for ventilation and pressurization through the emergency ventilation filtration system (HEPA filter and charcoal adsorber) before it is distributed to the ceiling cavity. A radiation detector at the outside air intake is used for automatic operation of the filtration system. There are low leakage dampers to be used for isolation of air streams, arranged such that untreated air will not infiltrate through the closed dampers.

#### 3.1 Methodology

The habitability of the TSC is assessed against its capability to maintain doses to its occupants below the limits of GDC-19 and SRP 6.4 (Ref. 2) following a design-basis LOCA. Gaseous radionuclides leaking from the containment are the source of the radioactivity reaching the TSC outside air intake (OAI). The radioactivity concentration at the OAI is calculated based on the guidance given in Reference 3. Airborne radionuclides enter the facility as a result of the pressurization makeup air and uncontrolled air in-leakage from opening and closing of the TSC doors. (It should be noted, however, that the latter source of contaminated air into the TSC has been included for conservatism since the TSC design calls for the use of air-locks.) The TSC radionuclide concentration is calculated based on the design values of the filtered air makeup and recirculation flow rates. The dose calculation models are given in Appendix 15.0.A of the FSAR. A conceptual presentation of the emergency ventilation system and air flows is given in Figure 1.

#### 3.2 Assumptions and Parameters

The following assumptions and parameters are used in the habitability analysis:

- 1) design basis assumptions presented in FSAR Section 15.6.5.4.1 are applied,
- 2) an accident duration of 30 days,



- 3) a net free TSC volume of  $88,096 \text{ ft}^3$  ( $2,495 \text{ M}^3$ ) which allows 10% of the TSC volume for furniture and equipment,
- 4) radionuclides are uniformly distributed throughout the TSC volume,
- 5) the TSC outside air intake is located at Elevation 336'; 106 ft. below the containment dome,
- 6) filter efficiency of TSC emergency ventilation filters for iodine is 99%, representing 4" or greater of charcoal beds,
- 7) finite cloud correction is applied,
- 8) a breathing rate of the TSC occupants of  $3.47 \times 10^{-4}$  cubic meters per second for the duration of the accident,
- 9) occupancy of the TSC is based on the following:

<u>Time Period</u>	<u>Occupancy Factor</u>
0 to 24 hrs.	1.0
1 to 4 days	0.6
4 to 30 days	0.4

- 10) post accident atmospheric dispersion factors are calculated using recommendations in Reference 3. These X/Qs are then adjusted by applying an overall reduction factor to account for the effects of changes in wind speed, wind direction and occupancy factor. The adjusted X/Qs are:

<u>Time Period</u>	<u>Adjusted X/Q (sec/m<sup>3</sup>)</u>
0 to 8 hrs.	$3.68 \times 10^{-3}$
8 to 24 hrs.	$2.17 \times 10^{-3}$
1 to 4 days	$8.46 \times 10^{-4}$
4 to 30 days	$2.43 \times 10^{-4}$

- 11) pressurization makeup air flow rates of 800 cfm (minimum) and 1200 cfm (maximum),
- 12) the fan capacity for air recirculation is 2,400 cfm, and
- 13) an unfiltered inleakage into the pressurized TSC of 3 cfm.

### 3.3 Results and Conclusion

The inhalation and submersion doses to the whole body, skin and thyroid of a TSC occupant are presented in Table 2. The direct shine doses are not

included because of their negligible contribution. The results indicate that the doses are within the GDC-19 and SRP 6.4 guidelines of 5 rem for whole body and 30 rem for skin and thyroid. The Technical Support Center is therefore designed to be habitable in the event of a design-basis LOCA.

References:

1. 10CFR50, Appendix A, GDC 19
2. Standard Review Plan (NUREG-0800), Section 6.4 .
3. Nuclear Power Plant Control Room Ventilation System Design for Meeting General Criterion 19, K G Murphy and K M Campe, 13th AEC Air Cleaning Conference, 1973

TABLE 1

Direct Shine Doses to TSC Personnel From  
Radioactivity on Emergency Ventilation System Filters  
(MREM/HR)


AREA	1 HR	1 DAY	1 MONTH
Decon Facility	5.1	13.2	0.07
NRC Team	0.5	1.2	0.006
Outside Agencies	0.4	1.0	0.005
Accident Assessment	0.1	0.4	0.002
Command Team	1.1	2.8	0.014

TABLE 2

Inhalation and Submersion Doses to TSC  
Personnel Following a Design-Basis  
Loss-of-Coolant Accident  
(REM)

Pressurization Makeup Air Flow Rate (CFM)	30-Day Doses		
	Whole Body	Skin	Thyroid
800	0.8	19	19
1200	0.9	20	26

**FIGURE 1**  
**TECHNICAL SUPPORT CENTER**  
**EMERGENCY VENTILATION SYSTEM**  
**AIR FLOW DIAGRAM**



**NOTES:**

OAI : OUTSIDE AIR INTAKE

P : PRE-FILTER

H : HEPA FILTER

C : CHARCOAL ADSORBER

