

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412060052 DOC. DATE: 84/11/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400  
 AUTH. NAME AUTHOR AFFILIATION  
 ZIMMERMAN, S.R. Carolina Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Informs that util pursuing changes to structural design basis, including eliminating postulated pipe breaks in primary main loop & arbitrary intermediate pipe breaks in Class 1, 2, & 3 pipes, based on Generic Ltr 84-04.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR/DL/ADL	1	NRR LB3 BC	1
	NRR LB3 LA	1	BUCKLEY, B 01	1
INTERNAL:	ACRS 41	6	ADM/LFMB	1
	ELD/HDS1	1	IE FILE	1
	IE/DEPER/EPB 36	1	IE/DEPER/IRB 35	1
	IE/DQASIP/QAB21	1	NRR ROE, M, L	1
	NRR/DE/AEAB	1	NRR/DE/CEB 11	1
	NRR/DE/EHEB	1	NRR/DE/eqB 13	2
	NRR/DE/GB 28	2	NRR/DE/MEB 18	1
	NRR/DE/MTEB 17	1	NRR/DE/SAB 24	1
	NRR/DE/Sgeb 25	1	NRR/DHFS/HFEB40	1
	NRR/DHFS/LQB 32	1	NRR/DHFS/PSRB	1
	NRR/DL/SSPB	1	NRR/DSI/AEB 26	1
	NRR/DSI/ASB	1	NRR/DSI/CPB 10	1
	NRR/DSI/CSB 09	1	NRR/DSI/ICSB 16	1
	NRR/DSI/METB 12	1	NRR/DSI/PSB 19	1
	NRR/DSI/RAB 22	1	NRR/DSI/RSB 23	1
	<u>REG FILE</u> 04	1	RGN2	3
	RM/DDAMI/MIB	1		
EXTERNAL:	BNL (AMDTs ONLY)	1	DMB/DSS (AMDTs)	1
	FEMA-REP DIV 39	1	LPDR 03	1
	NRC PDR 02	1	NSIC 05	1
	NTIS	1	PNL GRUEL, R	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 54 ENCL 0





Carolina Power & Light Company

NOV 30 1984

SERIAL: NLS-84-460

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
UNIT NO. 1 - DOCKET NO. 50-400  
ELIMINATION OF POSTULATED PIPE BREAKS IN PRIMARY MAIN LOOP AND  
ARBITRARY INTERMEDIATE PIPE BREAKS IN CLASS 1, 2, AND 3 PIPES

- REFERENCES:
- 1) U. S. Nuclear Regulatory Commission. "Safety Evaluation of Westinghouse Topical Reports Dealing with Elimination of Postulated Pipe Breaks in PWR Primary Main Loop (Generic Letter 84-04)," February 1, 1984.
  - 2) U. S. Nuclear Regulatory Commission. "Catawba Nuclear Station Unit 2, Safety Evaluation for the Elimination of Arbitrary Intermediate Pipe Breaks," March 1984.

Dear Mr. Denton:

Carolina Power & Light Company has been following the recent developments related to the postulation of pipe breaks in nuclear power plant piping systems and concurs with the nuclear industry's conclusion that, given the current knowledge and experience, there exists sufficient justification to eliminate certain breaks from the design basis. We are currently pursuing the following changes to the Shearon Harris structural design basis:

1. The elimination of postulated pipe breaks in the reactor coolant system primary loop.
2. The elimination of arbitrary intermediate pipe breaks in ASME Code Class 1, 2, and 3 piping systems.

In order to establish the regulatory basis for the primary loop changes, and in accordance with the provisions of Generic Letter 84-04 (Reference 1), we will request an exemption to the requirements of GDC-4 with respect to asymmetric blowdown loads resulting from discrete breaks in the primary loop. In support of this request, we will submit a report demonstrating that the fracture mechanics studies, previously evaluated and accepted by the Staff, envelope the site-specific parameters of the Shearon Harris design. The exemption request and the supportive documentation will be submitted for your review by January 1985.

8412060052 841130  
PDR ADOCK 05000400  
A PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

Boo1  
1/0



[The text in this section is extremely faint and illegible. It appears to be a multi-paragraph document, possibly a letter or a report, with several lines of text scattered across the page. The characters are too light to be accurately transcribed.]

The Company agrees with the Staff's conclusions (Reference 2) that "The Standard Review Plan (SRP) guidelines in MEB 3-1 (with regard to arbitrary intermediate pipe breaks), were not intended to be absolute requirements but rather represent viable approaches considered to be acceptable by the staff" and that "it has become apparent that the particular criterion requiring the postulation of arbitrary intermediate pipe breaks can be overly restrictive and result in an excessive number of pipe rupture protection devices which do not provide a compensatory level of safety." We will request relief from the existing SRP guidelines regarding the postulation of arbitrary intermediate pipe breaks by January 1985. The request will be accompanied with the supportive technical justification.

The benefits we expect to realize from these design basis changes stem from the elimination of pipe whip restraints and other structural provisions associated with the mitigation of the postulated breaks. Specific benefits will include:

1. Reduced potential for restricted thermal or seismic movement.
2. Reduced design, material, and erection costs.
3. Improved efficiencies in operation, maintenance, and in-service inspection resulting from better access.
4. Improved thermal efficiency, with a corresponding reduction in containment heat load.

The Company requests that a decision be made on each request within three months of submittal to allow realization of design and construction savings.

Should you have any questions with regard to this issue, please contact Mr. Pedro Salas (919) 836-8015.

Yours very truly,




S. R. Zimmerman  
Manager

Nuclear Licensing Section

PS/ccc (786PSA)

cc: Mr. B. C. Buckley (NRC)	Mr. Wells Eddleman
Mr. G. F. Maxwell (NRC-SHNPP)	Mr. John D. Runkle
Mr. J. P. O'Reilly (NRC-RII)	Dr. Richard D. Wilson
Mr. Travis Payne (KUDZU)	Mr. G. O. Bright (ASLB)
Mr. Daniel F. Read (CHANGE/ELP)	Dr. J. H. Carpenter (ASLB)
Chapel Hill Public Library	Mr. J. L. Kelley (ASLB)
Wake County Public Library	



[The page contains several lines of extremely faint, illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and is not readable.]