

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS).

ACCESSION NBR: 8412070220 DOC. DATE: 84/12/03 NOTARIZED: NO DOCKET #: 05000400
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina
 AUTH. NAME: ZIMMERMAN, S.R. AUTHOR AFFILIATION: Carolina Power & Light Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards remaining master list of ^{500 EGTS} Class 1E electrical equipment included in environ qualification program submitted on 840727, in response to NRC 841125 request for addl info re acceptance review for OL application.

DISTRIBUTION CODE: A048D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1050
 TITLE: OR/Licensing Submittal: Equipment Qualification

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTR	ENCL			LTR	ENCL
	NRR LB3 BC	12	1	0	BUCKLEY, B	01	1	1
INTERNAL:	ACRS	15	8	8	ADM/LFMB		1	
	ELD/HDS1	12	1		GC	13	1	
	IE FILE	09	1		NRR KARSCH, R		1	
	NRR/DE/EQB	07	2	2	NRR/DL DIR	14	1	
	NRR/DL/ORAB	06	1		NRR/DSI/AEB		1	
	REG FILE	04	1	1	RGN2		1	
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1	NTIS	31	1	1

Limited list.

6 Encls



Carolina Power & Light Company

SERIAL: NLS-84-476

DEC 03 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NO. 1 - DOCKET NO. 50-400
ENVIRONMENTAL QUALIFICATION OF
ELECTRICAL EQUIPMENT

- REFERENCES:
- 1) Carolina Power & Light Company. "Shearon Harris Nuclear Power Plant Final Safety Analysis Report," June 26, 1980 (as amended).
 - 2) Eisenhut, D. G. "Acceptance Review of Application for Operating Licenses for Shearon Harris Nuclear Power Plant, Unit Nos. 1, 2, 3, and 4," November 25, 1981. Correspondence.
 - 3) Utley, E. E. "Responses to NRC Acceptance Review Items," June 30, 1982. Correspondence.
 - 4) U. S. Nuclear Regulatory Commission. "Safety Evaluation Report Related to the Operation of Shearon Harris Nuclear Power Plant, Unit Nos. 1 and 2," NUREG-1038, November 1983.
 - 5) Zimmerman, S. R. "Partial Master List of Electrical Equipment Located in the Harsh Environments," NLS-84-348, July 27, 1984.

Dear Mr. Denton:

Carolina Power & Light Company hereby submits the remainder of the Master List of Class IE electrical equipment included in the environmental qualification program submitted on July 27, 1984 (Reference 5). With this material, and with the information contained in the Final Safety Analysis Report (Reference 1), we fulfill the request for additional information (References 2 and 4) that you indicated was necessary to establish the acceptability of our program. This submittal contains the following information:

1. The listing of Nuclear Steam Supply System Class IE electrical equipment located in harsh environments; including those environments where the radiation total integrated dose (TID) is greater than 10^4 rads (Attachment I). This supersedes the previous list which included primarily equipment in areas where the TID is greater than 10^5 rads. The component evaluation sheets have been included.

8412070220 841203
PDR ADOCK 05000400
A

PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

*A048
1/11
Limited
Dist*




[Faint, illegible text scattered across the page]

SYSTEM NAME: CS0002-CHEM. & VOLUME CONTROL

I

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG. 1.97	CES #	REV #
1CS-V509SB-1	LIMIT SWITCH	W TAG NO 11A88 RE FAIL CLOSED	WESTINGH	SEBY FIELD	CB21	1523.0 1730.0 241.0	H	(A)	CI		2770	
1CS-V509SB-1	SOLENOID VALVE	W TAG NO 11A88 RE FAIL CLOSED	WESTINGH	SEBY FIELD	CB21	1523.0 1730.0 241.0	H	(A)	CI		2769	
1CS-V510SB-1	LIMIT SWITCH	XCESS LETDN < FROM RCS TO VALVE 1CS-V509	WESTINGH	SEBY FIELD	CB21	1525.0 1730.0 241.0	H	(A)	CI		2768	
1CS-V510SB-1	SOLENOID VALVE	W TAG NO 11A88 RE FAIL CLOSED	WESTINGH	SEBY FIELD	CB21	1525.0 1730.0 241.0	H	(A)	CI		2767	

DH/2070220



SYSTEM # & NAME: CS0002-CHEM. & VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-L520SA-1	MOTOR OPERATOR	W TAG NO 4GM72 FB	WESTINGH	SE BY FIELD	AB31	1543.0 1596.0 263.0	H	A	CI		2858	
2CS-L520SA-1	LIMIT SWITCH	W TAG NO 4GM72 FB	WESTINGH	SE BY FIELD	AB31	1543.0 1596.0 263.0	H	A	CI		2859	
2CS-L520SA-1	LEVEL CONTR 4	FROM VCT 1X-SM OUTLET TO LCV 2CS-L521SB	WESTINGH	SE BY FIELD	AB31	1543.0 1596.0 263.0	H	A	CI		3616	
2CS-L521SB-1	LEVEL CONTR 4	W TAG NO 4GM72 FB	WESTINGH	SE BY FIELD	AB31	1546.0 1596.0 263.0	H	A	CI		3617	
2CS-L521SB-1	MOTOR OPERATOR	FROM VCT 1X-SM OUTLET TO LCV 2CS-L521SB	WESTINGH	SE BY FIELD	AB31	1546.0 1596.0 263.0	H	A	CI		2860	
2CS-L521SB-1	LIMIT SWITCH	W TAG NO 4GM72 FB	WESTINGH	SE BY FIELD	AB31	1546.0 1596.0 263.0	H	A	CI		2861	
2CS-L522SB-1	MOTOR OPERATOR	W TAG NO 8GM72 FB	WESTINGH	SE BY FIELD	AB21	1521.0 1574.0 267.0	H (N)	D	CI		2862	
2CS-L522SB-1	LIMIT SWITCH	W TAG NO 8GM72 FB	WESTINGH	SE BY FIELD	AB21	1521.0 1574.0 267.0	H (N)	D	CI		2863	
2CS-L523SA-1	LIMIT SWITCH H	WST COMM TO CHARG PUMP 1A-SA SUCT	WESTINGH	SE BY FIELD	AB21	1499.0 1573.0 267.0	H (N)	D	CI		2865	
2CS-L523SA-1	MOTOR OPERATOR	W TAG NO 8GM72 FB	WESTINGH	SE BY FIELD	AB21	1499.0 1573.0 267.0	H (N)	D	CI		2864	

TAGS INCLUDED: 2CS-L520.A-1 --- 2CS-L523SA-1
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: CS0022-CHEM. & VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V511SA-1	SOLENOID VALVE	W TAG NO 21A78 RG FAIL CLOSED	WESTINGH	SE BY FIELD	CB21	1459.0 1670.0 248.0	H	A	CI	*	2894	
2CS-V511SA-1	LIMIT SWITCH	W TAG NO 21A78 RG FAIL CLOSED	WESTINGH	SE BY FIELD	CB21	1459.0 1670.0 248.0	H	A	CI	*	2895	
2CS-V512SA-1	LIMIT SWITCH	W TAG NO 21A78 RG FAIL CLOSED	WESTINGH	SE BY FIELD	CB21	1458.0 1669.0 248.0	H	A	CI	*	2897	
2CS-V512SA-1	SOLENOID VALVE	ETDM ORIFICE < LINE DOWN STREAM OF VLV	WESTINGH	SE BY FIELD	CB21	1458.0 1669.0 248.0	H	A	CI	*	2896	
2CS-V513SA-1	SOLENOID VALVE	LETDM ORIFICE LINE DOWN STREAM OF VLV	WESTINGH	SE BY FIELD	CB21	1457.0 1668.0 248.0	H	A	CI	*	2898	
2CS-V513SA-1	LIMIT SWITCH	W TAG NO 21A78 RG FAIL CLOSED	WESTINGH	SE BY FIELD	CB21	1457.0 1668.0 248.0	H	A	CI	*	2899	
2CS-V516SA-1	MOTOR OPERATOR	W TAG NO 21M78 FNN END CONN SCH 1	WESTINGH	SE BY FIELD	CB21	1561.0 1690.0 245.0	H	A	CI	*	2900	
2CS-V516SA-1	LIMIT SWITCH	W TAG NO 21M78 FNN END CONN SCH 1	WESTINGH	SE BY FIELD	CB21	1561.0 1690.0 245.0	H	A	CI	*	2901	
2CS-V516SA-1	GLOBE 2	SEAL WATER RETURN HDR UPSTREAM TO	WESTINGH	SE BY FIELD	CB21	1561.0 1690.0 245.0	H	A	CI		3591	
2CS-V517SB-1	GLOBE 2	W TAG NO 21M78 FN END CONN SCH 1	WESTINGH	SE BY FIELD	AB21	1570.0 1685.0 236.0	H (M)	D	CI		3592	
2CS-V517SB-1	MOTOR OPERATOR	EAL WATER < RETURN HDR UP- STREAM OF VLV	WESTINGH	SE BY FIELD	AB21	1570.0 1685.0 236.0	H (M)	D	CI	*	2902	

TAGS INCLUDED: 2CS-R500SA-1 ---- 2CS-V517SB-1
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail.

2. The second part of the document outlines the various methods used to collect and analyze data. It includes a detailed description of the sampling techniques employed and the statistical tests used to evaluate the results.

3. The third part of the document presents the findings of the study. It shows that there is a significant correlation between the variables being studied, and it discusses the implications of these findings for future research and practice.

4. Finally, the document concludes with a summary of the key points and a list of references. It also includes a section on the limitations of the study and suggestions for further work.



SYSTEM # & NAME: CS0007-CHEM. & VOLUME CONTROL


TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V517SB-1	LIMIT SWITCH	W TAG NO 2TM78 FN END CONN SCH 1	WESTINGH'S	BY FIELD	AB21	1570.0 1685.0 236.0	H (M)	D	CI	.	2903	
2CS-V518SB-1	LIMIT SWITCH	ISOLATION VALV E FAIL CLOSED	WESTINGH'S	BY FIELD	AB21	1445.0 1655.0 245.0	H (M)	D	CI	.	2905	
2CS-V518SB-1	SOLFNOID VALVE	ISOLATION VALV E FAIL CLOSED	WESTINGH'S	BY FIELD	AB21	1445.0 1655.0 245.0	H (M)	D	CI	.	2904	
2CS-V522SB-1	GLOBE 1 1/2	LATER	WESTINGH'S	BY FIELD	AB21	1432.0 1678.0 236.0	H (M)	D	CI		2272	
2CS-V523SB-1	GLOBE 1 1/2	LATER	WESTINGH'S	BY FIELD	AB21	1543.0 1642.0 236.0	H (M)	D	CI		2273	
2CS-V524SB-1	GLOBE 1 1/2	LATER	WESTINGH'S	BY FIELD	AB21	1571.0 1694.0 236.0	H (M)	D	CI		2274	
2CS-V585SA-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1617.0 1586.0 238.0	H (M)	D	CI		2906	
2CS-V585SA-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1617.0 1586.0 238.0	H (M)	D	CI		2907	
2CS-V585SA-1	GATE 3	CHARG PUMPS MINIFLOW HDR UPSTRM OF VLV	WESTINGH'S	BY FIELD	AB21	1617.0 1586.0 238.0	H (M)	D	CI		3631	
2CS-V586SB-1	GLOBE ?	W TAG NO 2TM78 FN END CONN SCH 1	WESTINGH'S	BY FIELD	AB21	1547.0 1595.0 236.0	H (M)	D	CI		3615	
2CS-V586SB-1	LIMIT SWITCH	LT. BA ADDIT-< ION TO CHARG PUMPS SUCT	WESTINGH'S	BY FIELD	AB21	1547.0 1595.0 236.0	H (M)	D	CI		2909	
2CS-V586SB-1	MOTOR OPERATOR	W TAG NO 2TM78 FN END CONN SCH 1	WESTINGH'S	BY FIELD	AB21	1547.0 1595.0 236.0	H (M)	D	CI		2908	

TAGS INCLUDED: 2CS-V517SB-1 ----2CS-V586SB-1
SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/86

SYSTEM # & NAME: CS0097-CHEM. & VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V587SA-1	LIMIT SWITCH	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1495.0 1595.0 247.0	H (M)	D	CI		2911	
2CS-V587SA-1	MOTOR OPERATOR	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1495.0 1595.0 247.0	H (M)	D	CI		2910	
2CS-V587SA-1	GATE 8	VCT OUTLET HDR AT CHARG PUMPS SUCTION	WESTINGH'SE	BY FIELD	AB21	1495.0 1595.0 247.0	H (M)	D	CI		3618	
2CS-V588SB-1	GATE 8	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1502.0 1595.0 247.0	H (M)	D	CI		3619	
2CS-V588SB-1	MOTOR OPERATOR	CT OUTLET HDR AT CHARG PUMPS SUCTION	WESTINGH'SE	BY FIELD	AB21	1502.0 1595.0 247.0	H (M)	D	CI		2912	
2CS-V588SB-1	LIMIT SWITCH	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1502.0 1595.0 247.0	H (M)	D	CI		2913	
2CS-V589SA-1	MOTOR OPERATOR	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1518.0 1576.0 247.0	H (M)	D	CI		2914	
2CS-V589SA-1	LIMIT SWITCH	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1518.0 1576.0 247.0	H (M)	D	CI		2915	
2CS-V590SB-1	LIMIT SWITCH	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	1525.0 1576.0 247.0	H (M)	D	CI		2917	
2CS-V590SB-1	MOTOR OPERATOR	W TAG NO 8GM72 FB	WESTINGH'SE	BY FIELD	AB21	-1525.0 1576.0 247.0	H (M)	D	CI		2916	
2CS-V590SB-1	GATE 8	CHARGING PUMPS SUCTION HDR	WESTINGH'SE	BY FIELD	AB21	1525.0 1576.0 247.0	H (M)	D	CI		3621	

TAGS INCLUDED: 2CS-V587SA-1 ----2CS-V591SA-1
 SORT TYPE: SYSDS, TAG GLOBAL REV#- 0 05/01/84



SYSTEM # & NAME: CS0002-CHEM. & VOLUME CONTROL


TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M CATEG.	FUNCT. H/M CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V600SB-1	GLORE 2	MINIFLOW LINE FROM CHARG PMP 1A-SA DISCH TO	WESTINGH'S	BY FIELD	AB21	1493.0 1592.0 247.0	H (M)	D	CI		3627	
2CS-V600SB-1	MOTOR OPERATOR	W TAG NO 2TM78 FM	WESTINGH'S	BY FIELD	AB21	1493.0 1592.0 247.0	H (M)	D	CI		2918	
2CS-V600SB-1	LIMIT SWITCH	W TAG NO 2TM78 FM	WESTINGH'S	BY FIELD	AB21	1493.0 1592.0 247.0	H (M)	D	CI		2919	
2CS-V601SB-1	MOTOR OPERATOR	W TAG NO 2TM78 FM	WESTINGH'S	BY FIELD	AB21	1516.0 1591.0 247.0	H (M)	D	CI		2920	
2CS-V601SB-1	LIMIT SWITCH H	MINIFLOW LINE FROM CHARG PMP 1C-SAB DISCH	WESTINGH'S	BY FIELD	AB21	1516.0 1591.0 247.0	H (M)	D	CI		2921	
2CS-V601SB-1	GLORE 2	W TAG NO 2TM78 FM	WESTINGH'S	BY FIELD	AB21	1516.0 1591.0 247.0	H (M)	D	CI		3628	
2CS-V602SB-1	GLORE 2	MINIFLOW LINE FROM CHARG PMP 1B-SB DISCH TO	WESTINGH'S	BY FIELD	AB21	1528.0 1592.0 247.0	H (M)	D	CI		3630	

TAGS INCLUDED: 2CS-V592SAB-1 ----2CS-V602SB-1
SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: CS0702-CHEM. B VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V602SB-1	MOTOR OPERATOR	W TAG NO 2TM78 FN	WESTINGH'S	BY FIELD	AB21	1528.0 1592.0 247.0	H (M)	D	CI		2866	
2CS-V602SB-1	LIMIT SWITCH	W TAG NO 2TM78 FN	WESTINGH'S	BY FIELD	AB21	1528.0 1592.0 247.0	H (M)	D	CI		2867	
2CS-V603SA-1	MOTOR OPERATOR	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1495.0 1575.0 247.0	H (M)	D	CI		2868	
2CS-V603SA-1	LIMIT SWITCH	HARG PUMPS DISCH HDR	WESTINGH'S	BY FIELD	AB21	1495.0 1575.0 247.0	H (M)	D	CI		2869	
2CS-V603SA-1	GATE 4	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1495.0 1575.0 247.0	H (M)	D	CI		3632	
2CS-V604SB-1	GATE 4	CHARG PUMPS DISCH HDR	WESTINGH'S	BY FIELD	AB21	1502.0 1575.0 247.0	H (M)	D	CI		3633	
2CS-V604SB-1	MOTOR OPERATOR	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1502.0 1575.0 247.0	H (M)	D	CI		2870	
2CS-V604SB-1	LIMIT SWITCH	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1502.0 1575.0 247.0	H (M)	D	CI		2871	
2CS-V605SA-1	MOTOR OPERATOR	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1518.0 1575.0 247.0	H (M)	D	CI		2872	
2CS-V605SA-1	LIMIT SWITCH	HARG PUMPS DISCH HDR	WESTINGH'S	BY FIELD	AB21	1518.0 1575.0 247.0	H (M)	D	CI		2873	
2CS-V605SA-1	GATE 4	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1518.0 1575.0 247.0	H (M)	D	CI		3634	
2CS-V606SB-1	GATE 4	CHARG PUMPS DISCH HDR	WESTINGH'S	BY FIELD	AB21	1526.0 1575.0 247.0	H (M)	D	CI		3635	

TAGS INCLUDED: 2CS-V602SB-1 ---- 2CS-V606SB-1
 SORT TYPE: SYS0ES, TAG GLOBAL REV#- 0 05/01/84



SYSTEM # & NAME: C50002-CHEM. & VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V606SB-1	LIMIT SWITCH	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1526.0 1575.0 247.0	H (M)	D	CI		2875	
2CS-V606SB-1	MOTOR OPERATOR	W TAG NO 4GM78 FN	WESTINGH'S	BY FIELD	AB21	1526.0 1575.0 247.0	H (M)	D	CI		2874	
2CS-V609SB-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1455.0 1641.0 236.0	H (M)	D	CI		2876	
2CS-V609SB-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1455.0 1641.0 236.0	H (M)	D	CI		2877	
2CS-V610SA-1	LIMIT SWITCH H	2CS-V610SA-1TO 2CS-V515SN-1 INCLUDING PEN-	WESTINGH'S	BY FIELD	AB21	1457.0 1642.0 236.0	H (M)	D	CI	*	2879	
2CS-V610SA-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1457.0 1642.0 236.0	H (M)	D	CI	*	2878	
2CS-V610SA-1	GATE 3	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1457.0 1642.0 236.0	H (M)	D	CI		3590	
2CS-V611SB-1	GLOBE 2	SW INJ FROM CHARG PMP5 DI- SCH HDR TO SW	WESTINGH'S	BY FIELD	AB21	1530.0 1576.0 250.0	H (M)	D	CI		3637	
2CS-V611SB-1	LIMIT SWITCH	W TAG NO 2TM78 FN	WESTINGH'S	BY FIELD	AB21	1530.0 1576.0 250.0	H (M)	D	CI		2881	
2CS-V611SB-1	MOTOR OPERATOR	W TAG NO 2TM78 FN	WESTINGH'S	BY FIELD	AB21	1530.0 1576.0 250.0	H (M)	D	CI		2880	
2CS-V636SA-1	LIMIT SWITCH	W TAG NO 3/8TA 78RL	WESTINGH'S	BY FIELD	AB31	1603.0 1621.0 271.0	H (M)	D	CI		2883	
2CS-V636SA-1	SOLENOID VALVE	W TAG NO 3/8TA 78RL	WESTINGH'S	BY FIELD	AB31	1603.0 1621.0 271.0	H (M)	D	CI		2882	


TAGS INCLUDED: 2CS-V606SB-1 ----2CS-V636SA-1
SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84



SYSTEM # 1 E:CS0072-CHEM. & VOLUME CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CS-V637SN-1 B	SOLENOID VALVE	W TAG NO 3/8TA 78RL	WESTINGH'SE	BY FIELD	AB31	1603.0 1621.0 271.0	H (M)	D	CI		2884	
2CS-V637SN-1 B	LIMIT SWITCH	W TAG NO 3/8TA 78RL	WESTINGH'SE	BY FIELD	AB31	1603.0 1621.0 271.0	H (M)	D	CI		2885	
2CS-V757SA-1	PCKLESS GLO 2	MINIFLOW MODIF ICATION LINE	WESTINGH'SE	BY FIELD	AB21		H	D (A)	CI		4022	
2CS-V758S ³ B-1	PCKLESS GLO 2	MINIFLOW MODIF ICATION LINE	WESTINGH'SE	BY FIELD	AB21		H	D (A)	CI		4023	
2CS-V759SB-1	PCKLESS GLO 2	MINIFLOW MODIF ICATION LINE	WESTINGH'SE	BY FIELD	AB21		H	D (A)	CI		4024	
2CS-V760SA-1	PCKLESS GLO 2	MINIFLOW MODIF ICATION LINE	WESTINGH'SE	BY FIELD	AB21		H	D (A)	CI		4025	

TAGS INCLUDED: 2CS-V637SN-1 ----3CS-B525SN-1
 SORT TYPE:SYSDES,TAG GLOBAL REV#- 0 05/01/86



SHEARON HARRIS 1 - MASTER LIST

STEM # & NAME: CC0014-COMP. COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT (LOCATION)	LOCATION X,Y,Z	ENVIRONM. W/M/CATEG.	FUNCT. D	SAFETY FUNCTION	REG 1.97	RES #	OPV #
1CC 0671	SA TEMPERATURE PRIMARY FL (RTD)	CC PMP 1A DIS (RTD)	MINCE PROD. INC	S7364P1252 12 WSO-325	AB21	1400.01 1535.01 246.0	H (M)	D	CI		0144	
1CC 0672	SB TEMPERATURE PRIMARY FL (RTD)	CC PMP 1B DIS (RTD)	MINCE PROD. INC	S7364P1252 12 WSO-325	AB21	1572.01 1535.01 236.0	H (M)	D	CI		0145	

SYSTEM # & NAME: CC0014-POMP. COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CC-V169SA-1	MOTOR OPERATOR	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1558.0 1654.0 255.0	H (M)	D	CI		2842	
2CC-V169SA-1	LIMIT SWITCH	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1558.0 1654.0 255.0	H (M)	D	CI		2843	
2CC-V169SA-1	GATE 6	RCP 1A-SN SUCTION	WESTINGH'SE	BY FIELD	AB21	1558.0 1654.0 255.0	H (M)	D	CI		3577	
2CC-V170SB-1	GATE 6	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1559.0 1661.0 236.0	H (M)	D	CI		3578	
2CC-V170SB-1	MOTOR OPERATOR	CP 1A-SN SUCTION LINE	WESTINGH'SE	BY FIELD	AB21	1559.0 1661.0 236.0	H (M)	D	CI		2844	
2CC-V170SB-1	LIMIT SWITCH	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1559.0 1661.0 236.0	H (M)	D	CI		2845	
2CC-V172SB-1	LIMIT SWITCH	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB11	1534.0 1637.0 230.0	H (M)	D	CI		2847	
2CC-V172SB-1	MOTOR OPERATOR	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB11	1534.0 1637.0 230.0	H (M)	D	CI		2846	
2CC-V172SB-1	GATE 6	DNSTRM 2CC-V172SN-1 TO LTDN HX	WESTINGH'SE	BY FIELD	AB11	1534.0 1637.0 230.0	H (M)	D	CI		3575	
2CC-V182SB-1	GATE 6	UPSTRM TO 2CC-V182SN-1 TO RETRN HDR	WESTINGH'SE	BY FIELD	AB21	1538.0 1640.0 245.0	H (M)	D	CI		3576	
2CC-V182SB-1	MOTOR OPERATOR	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1538.0 1640.0 245.0	H (M)	D	CI		2848	
2CC-V182SB-1	LIMIT SWITCH	W TAG NO 6GM62 FB	WESTINGH'SE	BY FIELD	AB21	1538.0 1640.0 245.0	H (M)	D	CI		2849	

TAGS INCLUDED: 2CC-V169SA-1 ----2CC-V182SB-1
SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME:CC0014-COMP.COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CC-V183SB-1	MOTOR OPERATOR	W TAG NO 6GM62 FB	WESTINGH'S	BY FIELD	AB21	1562.0 1666.0 245.0	H (M)	D	CI		2850	
2CC-V183SB-1	LIMIT SWITCH	UPSTRM TO VALVE 2CC-V183 SN TO RETN	WESTINGH'S	BY FIELD	AB21	1562.0 1666.0 245.0	H (M)	D	CI		2851	
2CC-V183SB-1	GATE 6	W TAG NO 6GM62 FB	WESTINGH'S	BY FIELD	AB21	1562.0 1666.0 245.0	H (M)	D	CI		3579	
2CC-V184SA-1	GATE 6	UPSTRM TO VALVE 2CC-V183 SN TO RETRN	WESTINGH'S	BY FIELD	CB21	1555.0 1671.0 247.0	H	A	CI		3580	
2CC-V184SA-1	LIMIT SWITCH	W TAG NO 6GM62 FBH	WESTINGH'S	BY FIELD	CB21	1555.0 1671.0 247.0	H	A	CI		2853	
2CC-V184SA-1	MOTOR OPERATOR	W TAG NO 6GM62 FBH	WESTINGH'S	BY FIELD	CB21	1555.0 1671.0 247.0	H	A	CI		2852	
2CC-V190SB-1	LIMIT SWITCH	CP 1A-SN DISCH UPSTRM TO 2CC-F2SN	WESTINGH'S	BY FIELD	AB21	1549.0 1648.0 255.0	H (M)	D	CI		2855	
2CC-V190SB-1	MOTOR OPERATOR	W TAG NO 4GM68 FM	WESTINGH'S	BY FIELD	AB21	1549.0 1648.0 255.0	H (M)	D	CI		2854	
2CC-V190SB-1	GATE 4	W TAG NO 4GM68 FM	WESTINGH'S	BY FIELD	AB21	1549.0 1648.0 255.0	H (M)	D	CI		3581	
2CC-V191SA-1	GATE 4	RCP 1A-SN DISCH UP STRM TO 2CC-F2SN	WESTINGH'S	BY FIELD	CB21	1542.0 1655.0 255.0	H	A	CI		3582	
2CC-V191SA-1	MOTOR OPERATOR	W TAG NO 4GM68 FMH	WESTINGH'S	BY FIELD	CB21	1542.0 1655.0 255.0	H	A	CI		2856	
2CC-V191SA-1	LIMIT SWITCH	W TAG NO 4GM68 FMH	WESTINGH'S	BY FIELD	CB21	1542.0 1655.0 255.0	H	A	CI		2857	

TAGS INCLUDED: 2CC-V183SB-1 ---2CC-V191SA-1
SORT TYPE:SYSDES,TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME:CCOD14-COMP.COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M CATEG.	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CC-B19SA-1	BUTTERFLY 1R	CC HX 1A-SA OUTLET	WESTINGH'SE	BY FIELD	AB21	1479.01 1551.01 251.0	H (M)	D	CI		3570	
3CC-B19SA-1	MOTOR OPERATOR	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1479.01 1551.01 251.0	H (M)	D	CI		3222	
3CC-B19SA-1	LIMIT SWITCH	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1479.01 1551.01 251.0	H (M)	D	CI		3223	
3CC-B20SB-1	MOTOR OPERATOR	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1498.01 1552.01 251.0	H (M)	D	CI		3224	
3CC-B20SB-1	LIMIT SWITCH	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1498.01 1552.01 251.0	H (M)	D	CI		3225	
3CC-B20SB-1	BUTTERFLY 1B	CC HX 1B-SB OUTLET	WESTINGH'SE	BY FIELD	AB21	1498.01 1552.01 251.0	H (M)	D	CI		3572	
3CC-B5SA-1	BUTTERFLY 1R	RTN HDR TO CC PMP 1A-SA SUCTION	WESTINGH'SE	BY FIELD	AB21	1422.01 1547.01 252.0	H (M)	D	CI		3569	
3CC-B5SA-1	MOTOR OPERATOR	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1422.01 1547.01 252.0	H (M)	D	CI		3226	
3CC-B5SA-1	LIMIT SWITCH	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1422.01 1547.01 252.0	H (M)	D	CI		3227	
3CC-B6SB-1	MOTOR OPERATOR	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1556.01 1547.01 249.0	H (M)	D	CI		3228	
3CC-B6SB-1	LIMIT SWITCH	IN HDR TO CC < PMP 1B-SB SUCTION	WESTINGH'SE	BY FIELD	AB21	1556.01 1547.01 249.0	H (M)	D	CI		3229	
3CC-B6SB-1	BUTTERFLY 1B	W TAG NO 18BM3 2	WESTINGH'SE	BY FIELD	AB21	1556.01 1547.01 249.0	H (M)	D	CI		3571	

TAGS INCLUDED: 3CC-B19SA-1 ----3CC-B6SB-1
SORT TYPE:SYSDES,TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: CC0014-COMP. COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CC-L15A-1	SOLENOID VALVE	W TAG NO 3/40A 32R	WESTINGH	SE BY FIELD	AB21	1519.0 1619.0 239.0	H (M)	D	CI		3234	
3CC-L15A-1	LIMIT SWITCH	W TAG NO 3/40A 32R	WESTINGH	SE BY FIELD	AB21	1519.0 1619.0 239.0	H (M)	D	CI		3235	
3CC-L25B-1	LIMIT SWITCH	W TAG NO 3/40A 32R	WESTINGH	SE BY FIELD	AB21	1520.0 1620.0 239.0	H (M)	D	CI		3237	
3CC-L25B-1	SOLENOID VALVE	FFD INLET	WESTINGH	SE BY FIELD	AB21	1520.0 1620.0 239.0	H (M)	D	CI		3236	
3CC-V1655A-1	GATE 12	RH HX 1A-SA OUTLET	WESTINGH	SE BY FIELD	AB21	1428.0 1567.0 238.0	H (M)	D	CI		3573	
3CC-V1655A-1	LIMIT SWITCH	W TAG NO 12GM3 25B	WESTINGH	SE BY FIELD	AB21	1428.0 1567.0 238.0	H (M)	D	CI		3239	
3CC-V1655A-1	MOTOR OPERATOR	W TAG NO 12GM3 25B	WESTINGH	SE BY FIELD	AB21	1428.0 1567.0 238.0	H (M)	D	CI		3238	

TAGS INCLUDED: 3CC-0277SA-1 ---3CC-V1673B-1
SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: HP0075-CONT. HYDROGEN CONTROL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
EH2RMB 1A SA	Hydrogen Re-combiner	LATER ELECTRIC HYDROGEN RECOMB.	WESTINGHOUSE	BY FIELD	CB41	1441.C 1706.0 286.0	H	A	PRRM		2455	
EH2RMB 1B SB	Hydrogen Re-combiner	LATER ELECTRIC HYDROGEN RECOMB.	WESTINGHOUSE	BY FIELD	CB41	1559.C 1706.C 286.0	H	A	PRRM		2456	





12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

SYSTEM # & NAME: CT0007-CONTAINMENT SPRAY

TAG NO	COMPONENT NAME	FUNCTION	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/MICATEG.	FUNCT. D	SAFETY FUNCTION	REG 1.97	CES #	REV #
LT 1CT 0990 I	LEVEL TRANS MITTER	RWST LEVEL PR ST I	ITT- BARTON	752 WSO-32	TA11	1329.0 1615.0 265.0	H (M)	D	CI	*	01601	
LT 1CT 0991 II	LEVEL TRANS MITTER	RWST LEVEL PR ST II	ITT- BARTON	752 WSO-32	TA11	1327.0 1617.0 265.0	H (M)	D	CI	*	01621	

TAGS INCLUDED: FF 1CT 7152 SB---LT 1CT 0991 II
 SORT TYPE: SYSDES, TAG GLOBAL REV# 0 05/01/84


SYSTEM & NAME: CONTAINMENT SPRAY

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTURER	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. HAZ/CLASS.	PROTECT. FUNCTION	SAFETY FUNCTION	REG. 1.97	ICES #	REV. #
PT ICT0950	PRESS. XMTR.	CONT PRES	BARTON	752	A.B.32	261-0	H	D	CI	*		

SYSTEM # 8 NAME: 1FW200-FEEDWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
LT 1FW 0474 I	LEVEL TRANS MITTER	SG 1A NAR RGE LVL PR ST I	ITT- BARTON	MOD 764 WSO-32	CB21	1454.0 1709.0 236.0	H	A	CI	*	0083	
LT 1FW 0475 II	LEVEL TRANS MITTER	SG 1A NAR RGE LVL PR ST II	ITT- BARTON	MOD 764 WSO-32	CB21	1456.0 1717.0 236.0	H	A	CI	*	0088	
LT 1FW 0476 III	LEVEL TRANS MITTER	SG 1A NAR RGE LVL PR ST III	ITT- BARTON	MOD 764 WSO-32	CB21	1460.0 1725.0 236.0	H	A	CI	*	0092	
LT 1FW 0477 I	LEVEL TRANS MITTER	SG 1A WD RGE LVL PR ST I	ITT- BARTON	MOD 764 WSO-32	CB21	1454.0 1709.0 236.0	H	A	CI		0414	
LT 1FW 0484 I	LEVEL TRANS MITTER	SG 1B NAR RGE LVL PR ST I	ITT- BARTON	MOD 764 WSO-32	CB21	1503.0 1646.0 236.0	H	A	CI	*	0415	
LT 1FW 0485 II	LEVEL TRANS MITTER	SG 1B NAR RGE LVL PR ST II	ITT- BARTON	MOD 764 WSO-32	CB21	1490.0 1648.0 236.0	H	A	CI	*	0102	
LT 1FW 0486 III	LEVEL TRANS MITTER	SG 1B NAR RGE LVL PR ST III	ITT- BARTON	MOD 764 WSO-32	CB21	1490.0 1648.0 236.0	H	A	CI	*	0106	
LT 1FW 0487 II	LEVEL TRANS MITTER	SG 1B WD RGE L EV PR ST II	ITT- BARTON	MOD 764 WSO-32	CB21	1496.0 1646.0 236.0	H	A	CI		0110	
LT 1FW 0494 I	LEVEL TRANS MITTER	SG 1C NAR RGE LVL PR ST I (ILT)	ITT- BARTON	MOD 764 WSO-32	CB21	1531.0 1736.0 236.0	H	A	CI	*	0416	
LT 1FW 0495 II	LEVEL TRANS MITTER	SG 1C NAR RGE LEV PR ST II	ITT- BARTON	MOD 764 WSO-32	WP21	1336.0 1730.0 236.0	H	A	CI	*	0117	
LT 1FW 0496 III	LEVEL TRANS MITTER	SG 1C NAR RGE LEV PR ST III	ITT- BARTON	MOD 764 WSO-32	CB21	1544.0 1723.0 236.0	H	A	CI	*	0120	

TAGS INCLUDED: LT 1FW 0474 I ----PI 1FW 2001A SA
 SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/84



SYSTEM # 3 NAME: MAIN STEAM

TAG NO	COMPONENT	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CIS #	REV #
FT IMS 0474	ITT	FLOW TRANSM OM PR ST I	BARTON	MOD 764 WSO-325	CB21	1460.0 1725.0 236.0	H	A	CI		0081	
FT IMS 0475	IV	FLOW TRANSM OM PR ST IV	BARTON	MOD 764 WSO-325	CB31	1468.0 1734.0 263.0	H	A	CI		0086	
FT IMS 0484	ITT	FLOW TRANSM OM PR ST III	BARTON	MOD 764 WSO-325	CB21	1490.0 1648.0 236.0	H	A	CI		0098	
FT IMS 0494	III	FLOW TRANSM OM PR ST III	BARTON	MOD 764 WSO-325	CB21	1544.0 1725.0 236.0	H	A	CI		0112	
FT IMS 0495	IV	FLOW TRANSM OM PR ST IV	BARTON	764 WSO-325	CB21	1544.0 1713.0 236.0	H	A	CI		0115	
FT IMS 0485							H	A	CI			

TAGS INCLUDED
SO 1 19850474 III---PI IMS 0474.2 S
GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: MS000P-MAIN STEAM


TAG NO	COMPONENT NAME	TYPE	MFG	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/R/CATLG.	FUNCI.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2MS-V1SAB-1	SOLENOID VALVE	ISOLATION VAL	WESTINGH'S	BY FIELD	AB32	1492.01 1605.01 279.0	H	A	CI	.	2997	
		W TAG NO 301A6										
2MS-V1SAB-1	LIMIT SWITCH	ISOLATION VAL	WESTINGH'S	BY FIELD	AB32	1492.01 1605.01 279.0	H	A	CI	.	2997	
		W TAG NO 301A6										
2MS-V1SAB-1 DELETE	GLOBE VALVE	FROM PEN M-3 TO ISO VAL 2MS-V1SA1 SPLIC PIPE	WESTINGH'S	BY FIELD	AB32	1492.01 1605.01 279.0	H	A	CI		144	
2MS-V2SAB-1	LIMIT SWITCH	ISOLATION VAL	WESTINGH'S	BY FIELD	AB32	1502.01 1605.01 279.0	H	A	CI	.	3001	
		W TAG NO 301A6										
2MS-V2SAB-1	SOLENOID VALVE	ISOLATION VAL	WESTINGH'S	BY FIELD	AB32	1502.01 1605.01 279.0	H	A	CI	.	3001	
		W TAG NO 301A6										
2MS-V2SAB-1	GLOBE VALVE	FROM PENETRAT-ION M-2 TO ISO VAL 2MS-V2SN-1	WESTINGH'S	BY FIELD	AB32	1502.01 1605.01 279.0	H	A	CI		3701	
2MS-V3SAB-1	GLOBE VALVE	PEN PEN M-1 TO ISO VAL 2MS-13SA1 SPEC PI-	WESTINGH'S	BY FIELD	AB32	1512.01 1605.01 279.0	H	A	CI		3702	

TAGS INCLUDED: PK 1MS 030891 S----2MS-V1SAB-1
 SORT TYPE: SYSDEF, TAG GLOBAL REVR- 0 05/01/84



SYSTEM # & NAME: MS0002-MAIN STEAM

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2MS-V3SA3-1	LIMIT SWITCH	ISOLATION VAL W TAG NO 301A6	WESTINGH'SE	BY FIELD	AB32	1512.0 1605.0 279.0	H	A	CI	*	3003	
2MS-V3SA9-1	SOLENOID VALVE	ISOLATION VAL W TAG NO 301A6	WESTINGH'SE	BY FIELD	AB32	1512.0 1605.0 279.0	H	A	CI	*	3002	



SYSTEM # & NAME: M50008 MAIN STEAM

Tag No.	Component Name	Function & Service	Manufacturer	Model/ Ser.	Plant Loc.	Location X, Y, Z	Environment Categ M/M	Funct. Categ.	Safety Funct.	REG. GUID# 1.97	CEB#	Rev #
PTIMS 474 I	TRANSMITTER	STEAM FLOW PRESS.	BARTON	763	R.A.B.	X: Y: Z: 261.0	H	D	CI			
PTIMS 475 I	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 476 I	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 484 II	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 485 II	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 486 II	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 494 III	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 495 III	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			
PTIMS 496 III	"	"	"	"	"	X: Y: Z: 261.0	H	D	CI			




142



SYSTEM # 4 RC0001-REACTOR COOLANT

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
FT 1RC 0414 I	FLOW TRANSMITTER	RCS FLOW LOOP PR ST I	ITT-BARTON	MOD 752 WSO-325	CB21	1454.0 1709.0 236.0	H	A	ERS		0042	
FT 1RC 0415 II	FLOW TRANSMITTER	RCS FLOW LOOP PR ST II	ITT-BARTON	MOD 752 WSO-325	CB21	1456.0 1717.0 236.0	H	A	ERS		0043	
FT 1RC 0416 III	FLOW TRANSMITTER	RCS FLOW LOOP PR ST III	ITT-BARTON	MOD 752 WSO-325	CB21	1460.0 1725.0 236.0	H	A	ERS		0044	
FT 1RC 0424 I	FLOW TRANSMITTER	RCS FLOW LOOP PR ST I	ITT-BARTON	MOD 752 WSO-325	CB21	1503.0 1646.0 236.0	H	A	ERS		0056	
FT 1RC 0425 II	FLOW TRANSMITTER	RCS FLOW LOOP PR ST II	ITT-BARTON	MOD 752 WSO-325	CB21	1496.0 1646.0 236.0	H	A	ERS		0057	
FT 1RC 0426 III	FLOW TRANSMITTER	RCS FLOW LOOP PR ST III	ITT-BARTON	MOD 752 WSO-325	CB21	1490.0 1648.0 236.0	H	A	ERS		0058	
FT 1RC 0434 I	FLOW TRANSMITTER	RCS FLOW LOOP PR ST I	ITT-BARTON	MOD 752 WSO-325	CB21	1531.0 1736.0 236.0	H	A	ERS		0069	
FT 1RC 0435 II	FLOW TRANSMITTER	RCS FLOW LOOP PR ST II	ITT-BARTON	MOD 752 WSO-325	CB21	1536.0 1730.0 236.0	H	A	ERS		0070	
FT 1RC 0436 III	FLOW TRANSMITTER	RCS FLOW LOOP PR ST III	ITT-BARTON	MOD 752 WSO-325	CB21	1544.0 1723.0 236.0	H	A	ERS		0071	

TAGS INCLUDED: FT 1RC 0414 I ----LI 1RC 0460 88
SORT TYPE:SYSDS,TAG GLOBAL REV# 0 05/01/84




SYSTEM # & NAME: RC0001-REACTOR

COOLANT

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATFG.	SAFETY FUNCTION	REG 1.97	CFS #	REV #
LT 1RC 0459 I	LEVEL TRANS MITTER	PRZR LEVEL PR ST I	ITT- HARTON	764 WSO-32	CB21	236.0	H	A	ERC		0413	
LT 1RC 0460 II	LEVEL TRANS MITTER	PRZR LEVEL PR ST II	ITT- HARTON	MOD 764 WSO-32	CB21	1496.0 1646.0 236.0	H	A	ERC		0077	
LT 1RC 0461 III	LEVEL TRANS MITTER	PRZR LEVEL PR ST III	ITT- BARTON	MOD 764 WSL-32	CB21	1490.0 1645.0 236.0	H	A	ERC		0080	

TAGS INCLUDED: LI 1RC 0461.1 S----PI 1RC 0403.2 S
 SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/R4



SYSTEM # & NAME: RC0001-REACTOR

COOLANT

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
TE 1RC 0410 II	TEMPERATURE PRIMARY EL	LOOP 1 COLD LEG (RTD) PR ST II	WESTINGHOUSE	BY FIELD WSO-32	CB21	1470.0 1703.0 257.0	H	A	ERC	*	0030	
TE 1RC 0412AI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST I		BY FIELD WSO-32	CB21	1477.0 1708.0 236.0	H	A	ERC		0034	
TE 1RC 0412BI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST I		BY FIELD WSO-32	CB21	1476.0 1708.0 236.0	H	A	ERC		0037	
TE 1RC 0412CI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST I		BY FIELD WSO-32	CB21	1470.0 1704.0 257.0	H	A	ERC		0036	
TE 1RC 0412DI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST I		BY FIELD WSO-32	CB21	1469.0 1704.0 257.0	H	A	ERC		0035	
TE 1RC 0415 I	TEMPERATURE PRIMARY EL	LOOP 1 HOT LEG (RTD) PR ST I		BY FIELD WSO-32	CB21	1475.0 1709.0 257.0	H	A	ERC	*	0038	
TE 1RC 0420 II	TEMPERATURE PRIMARY EL	LOOP 2 COLD LEG (RTD) PR ST II		ITE 420 WSO-32	CB21	1511.0 1678.0 257.0	H	A	ERC	*	0045	
TE 1RC 0422AI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST II		BY FIELD WSO-32	CB21	1512.0 1671.0 257.0	H	A	ERC		0049	
TE 1RC 0422BI	TEMPERATURE PRIMARY EL	DT-TAVG PROTECT (RTD) PR ST II		BY FIELD WSO-32	CB21	1512.0 1672.0 257.0	H	A	ERC		0050	

TAGS INCLUDED: PI 1RC 0404 S ----TE 1RC 0422BII
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84



SYSTEM # & NAME: W01001-REACTOR

COOLANT

TAG NO.	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
TE 1RC 0422CII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1511.0 1679.0 257.0	H	A	ERC		0051	
TE 1RC 0422DII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1510.0 1680.0 257.0	H	A	ERC		0052	
TE 1RC 0423 I	TEMPERATURE PRIMARY EL (RTD)	LOOP 2 HOT LEG RDF		BY FIELD WSO-32	CB21	1513.0 1673.0 257.0	H	A	ERC	*	0053	
TE 1RC 0430 III	TEMPERATURE PRIMARY EL	LOOP 3 COLD LEG RDF GRTDPR ST III		BY FIELD WSO325	CB21	1513.0 1724.0 257.0	H	A	ERC	*	0061	
TE 1RC 0432AIII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1516.0 1718.0 257.0	H	A	ERC		0063	
TE 1RC 0432BIII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1517.0 1719.0 257.0	H	A	ERC		0064	
TE 1RC 0432CIII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1513.0 1725.0 257.0	H	A	ERC		0065	
TE 1RC 0432DIII	TEMPERATURE PRIMARY EL I	DT-TAVG. PROTEC RDF PR ST III		BY FIELD WSO-32	CB21	1513.0 1724.0 257.0	H	A	ERC		0066	
TE 1RC 0433 I	TEMPERATURE PRIMARY EL (RTDPR ST I)	LOOP 3 HOT LEG RDF		BY FIELD WSO-32	CB21	1517.0 1719.0 255.0	H	A	ERC	*	0068	

TAGS INCLUDED: TE 1RC 0422CII ----TE 1RC 0433.1 S
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/86



SYSTEM # & NAME: RCP001-REACTOR

COOLANT

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
Z5 1RC R530 SA	POSITION SWITCH	PRZR SFTY RELF VLV POS S 1RC-	CROSBY	RY FIELD EBASCO	CB41	308.0	H	A	ERC		1276	
2RC-0525S9-1	LIMIT SWITCH	W TAG NO 30A92	WESTINGH'S	BY FIELD	AB21	1556.0 1657.0 245.0	H	M	D	ERC		3015
2RC-0525SB-1	SOLENOID VALVE	W TAG NO 30A92	WESTINGH'S	BY FIELD	AB21	1556.0 1657.0 245.0	H	M	D	ERC	*	3014
2RC-0528SA-1	LIMIT SWITCH	W TAG NO 10A92	WESTINGH'S	BY FIELD	CB21	1508.0 1639.0 255.0	H	A	ERC	*	3017	
2RC-0528SA-1	SOLENOID VALVE	PRT CONN LINE FOR SDT&HZ AT C/B PENTR.	WESTINGH'S	BY FIELD	CB21	1508.0 1639.0 255.0	H	A	ERC	*	3016	
2RC-0529SB-1	SOLENOID VALVE	W TAG NO. 10A92R	WESTINGH'S	BY FIELD	AB21	1510.0 1610.0 236.0	H	M	D	ERC	*	3018
2RC-0529SB-1	LIMIT SWITCH	W TAG NO. 10A92R	WESTINGH'S	BY FIELD	AB21	1510.0 1610.0 236.0	H	M	D	ERC	*	3019

SYSTEM # & NAME: RC001 REACTOR COOLANT

Tag No.	Component Name	Function & Service	Manufacturer	Model/Ser.	Plant Loc.	Location X,Y,Z	Environm. Categ M/M	Funct. Categ.	Safety Funct.	1.97	CEB	Rev
PT-IRC402	PRESSURE TRANSMITTER	REACTOR COOLANT SEE ESE-1 TAB "B"	BARTON	763/584	CB	X: 1531.0 Y: 1736.0 Z: 236.0	H	A	ERS			
PT IRC 455	PRESSURE TRANSMITTER	REACTOR COOLANT SEE ESE-1 TAB "B"	BARTON	763/581	CB	X: 1456.0 Y: 1653.0 Z: 236.0	H	A	ERS			
PT IRC 456	PRESSURE TRANSMITTER	REACTOR COOLANT SEE ESE-1 TAB "B"	BARTON	763/582	CB	X: 1490.0 Y: 1648.0 Z: 236.0	H	A	ERS			
PT-IRC 457	PRESSURE TRANSMITTER	REACTOR COOLANT SEE ESE-1 TAB "B"	BARTON	763/583	CB	X: 1490.0 Y: 1648.0 Z: 236.0	H	A	ERS			
PT IRC 403	PRESSURE TRANSMITTER	REACTOR COOLANT LOOP PRESSURE	VERITRAK	76 PH2 / N1250023	CB	X: Y: Z: 236.0	H	A	ERS			
TE-IRC 0411 B	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1478.0 Y: 1708.0 Z: 236.0	H	A	ERS			
TE-IRC 0411 C	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1472.0 Y: 1702.0 Z: 263.0	H	A	ERS			
TE-IRC 0421 B	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1511.0 Y: 1676.0 Z: 257.0	H	A	ERS			
TE-IRC 0421 C	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1509.0 Y: 1681.0 Z: 257.0	H	A	ERS			
TE-IRC 0431 B	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1515.0 Y: 1716.0 Z: 236.0	H	A	ERS			
TE-IRC 0431 C	TEMPERATURE ELEMENT	REACTOR COOLANT	RdF	21204	CB	X: 1513.0 Y: 1724.0 Z: 236.0	H	A	ERS			



SHEARON HARRIS I - MASTER LIST


SYSTEM # & NAME: RC001 REACTOR COOLANT (RVLIS)

Tag No.	Component Name	Function & Service	Manufacturer	Model/ Ser.	Plant Loc.	Location X,Y,Z	Environm. Categ M/M	Funct. Categ.	Safety Funct.	Auth. Ref.	CFR #	Rev #
TE IRC 1313 SA	TEMPERATURE ELEMENT	RVLIS REACTOR HEAD CAP'LRY. INB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1314 SA	TEMPERATURE ELEMENT	RVLIS REACTOR HEAD CAP'LRY. OUTBOARD TEMPERATURE	MINCO		CB		H		ERS			
TE IRC 1315 SA	TEMPERATURE ELEMENT	RVLIS REACTOR HOT LEG CAPILLARY TUB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1316 SA	TEMPERATURE ELEMENT	RVLIS REACTOR HOT LEG CAPILLARY OUTB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1317 SA	TEMPERATURE ELEMENT	RVLIS CAP'LRY. TO SEAL TABLE INB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1318 SA	TEMPERATURE ELEMENT	RVLIS CAP'LRY. TO SEAL TABLE OUTB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1319 SA	TEMPERATURE ELEMENT	RVLIS CAP'LRY. FROM SEAL TABLE TEMPERATURE	MINCO		CB		H		ERS			
TE IRC 1323 SB	TEMPERATURE ELEMENT	RVLIS REACTOR HEAD CAPILLARY INB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1324 SB	TEMPERATURE ELEMENT	RVLIS REACTOR HEAD CAPILLARY OUTB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1325 SB	TEMPERATURE ELEMENT	RVLIS REACTOR HOT LEG CAPILLARY INB'RD. TEMP.	MINCO		CB		H		ERS			
TE IRC 1326 SB	TEMPERATURE ELEMENT	RVLIS REACTOR HOT LEG CAPILLARY OUTB'RD. TEMP.	MINCO		CB		H		ERS			



SYSTEM # & NAME: RC 001 REACTOR COOLANT (RVLIS)

Tag No.	Component Name	Function & Service	Manufacturer	Model/ Ser.	Plant Loc.	Location X,Y,Z'	Environ. Categ M/M	Funct. Categ.	Safety Funct.	Auth. Ref.	CRB #	Rev #
TE IRC 1327 SB	TEMPERATURE ELEMENT	RVLIS CAP'RY. TO SEAL TABLE IN'R'D. TEMPERATURE	BARTON		CB		H		RCS			
TE IRC 1328 SB	TEMPERATURE ELEMENT	RVLIS CAP'RY. TO SEAL TABLE OUTBRD TEMPERATURE	BARTON		CB		H		RCS			
TE IRC 1329 SB	TEMPERATURE ELEMENT	RVLIS CAP'RY. FROM SEAL TABLE TEMPERATURE	BARTON		CB		H		RCS			
LIS IRC 1310 SA	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS REACTOR HOT LEG HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LIS IRC 1311 SA	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS REACTOR HEAD HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LIS IRC 1312 SA	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS SEAL TABLE HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LIS IRC 1320 SB	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS REACTOR HOT LEG HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LIS IRC 1321 SB	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS REACTOR HEAD HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LIS IRC 1322 SB	DIFFERENTIAL PRESSURE INDICATING SWITCH	RVLIS SEAL TABLE HYDRAULIC ISOLATOR	BARTON	581	CB		H		RCS			
LT IRC 1310 SA	LEVEL TRANSMITTERS	RVLIS REACTOR VESSEL PLENUM LEVEL	BARTON	752	CB		H		RCS			
LT IRC 1311 SA	LEVEL TRANSMITTERS	RVLIS REACTOR VESSEL NARROW RANGE LEVEL	BARTON	752	CB		H		RCS			



60

25

71

42

77



SYSTEM NAME: 1RHO003-RESIDUAL HEAT REMOVAL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M/CATIG.	FUNCT. SAFETY FUNCTION	REG 1.27	PCS REV #
SIRHGOZA SA	FLOW SWITCH	RESID HT REM PMP 1A FLOW	ITT-HARTON	288A WSO-325	AB 11	216.0	H. (A)	CRHR		1461
S 1RHO003 SA	FLOW SWITCH	RESID HT REM PMP 1B FLOW	ITT-HARTON	288A WSO-325	AB 11	216.0	H. (A)	CRHR		1462

TAGS INCLUDED: FCV 1RHO002A SA-----11 1RHO 003AAS S
 SORT TYPE: SYSDEF, TAG GLOBAL REV#- 0 0 001/96

SYSTEM # 6 NAME: 4000⁰-RESIDUAL HEAT REMOVAL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CEI #	REV #
10N-V500SB-1	LIMIT SWITCH	M TAG NO 12GR8 BSEH	WESTINGH	SF BY FIELD	CB21	1520.01 1702.01 251.0		M	A			2772

SYSTEM # & NAME: RH0073-RESIDUAL HEAT REMOVAL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
1RH-V500SB-1	MOTOR OPERATOR	W TAG NO 12GM8 8SEH	WESTINGH'SE	BY FIELD	CB21	1520.0 1702.0 251.0	H	A	RHR		2771	
1RH-V500SB-1	GATE 12	RCS LOOP 3 HL TO RHR PUMP SUCTION	WESTINGH'SE	BY FIELD	CB21	1520.0 1702.0 251.0	H	A	CRHR		3719	
1RH-V501SA-1	GATE 12	W TAG NO 12GM8 8SEH W/LS	WESTINGH'SE	BY FIELD	CB11	1548.0 1682.0 230.0	H	A	CRHR		3720	
1RH-V501SA-1	LIMIT SWITCH	RCS LOOP 3 HL TO RHR PUMP SUCTION	WESTINGH'SE	BY FIELD	CB11	1548.0 1682.0 230.0	H	A	CRHR		2773	
1RH-V501SA-1	MOTOR OPERATOR	W TAG NO 12GM8 8SEH W/LS	WESTINGH'SE	BY FIELD	CB11	1548.0 1682.0 230.0	H	A	CRHR		2774	
1RH-V502SB-1	LIMIT SWITCH	W TAG NO 12GM8 8SEH W/LS PER CQL-3146 P	WESTINGH'SE	BY FIELD	CB21	1480.0 1702.0 251.0	H	A	CRHR		2776	
1RH-V502SB-1	MOTOR OPERATOR	W TAG NO 12GM8 8SEH W/LS PER CQL-3146 P	WESTINGH'SE	BY FIELD	CB21	1480.0 1702.0 251.0	H	A	CRHR		2775	
1RH-V502SB-1	GATE 12	RCS LOOP 1 HL TO RHR PUMP SUCTION	WESTINGH'SE	BY FIELD	CB21	1480.0 1702.0 251.0	H	A	CRHR		3717	
1RH-V503SA-1	GATE 12	RCS LOOP 1 HL TO RHR PUMP SUCTION	WESTINGH'SE	BY FIELD	CB11	1457.0 1676.0 230.0	H	A	CRHR		3718	
1RH-V503SA-1	MOTOR OPERATOR	W TAG NO 12GM8 8SEH	WESTINGH'SE	BY FIELD	CB11	1457.0 1676.0 230.0	H	A	CRHR		2777	
1RH-V503SA-1	LIMIT SWITCH	W TAG NO 12GM8 8SEH	WESTINGH'SE	BY FIELD	CB11	1457.0 1676.0 230.0	H	A	CRHR		2778	
2RH-F512SB-1	MOTOR OPERATOR	W TAG NO 2TM 7 8SH	WESTINGH'SE	BY FIELD	AB21	1574.0 1619.0 236.0	H	D	CRHR		3020	

TAGS INCLUDED: 1RH-V500SB-1 ----2RH-F512SB-1
 SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: RHD073-RESIDUAL HEAT REMOVAL

40

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M CATEG.	FUNCT. D	SAFETY FUNCTION	REG 1.27	CES #	REV #
2RH-F512SB-1	LIMIT SWITCH	M TAG NO 2TM 7 8SN	WESTINGH ^{SE}	BY FIELD	AB21	1574.0 1619.0 236.0	H (M)	D	CRHR		3021	
2RH-F513SA-1	MOTOR OPERATOR	RHR PUMP 1A-SA MIN FLOW RECIRC	WESTINGH ^{SE}	BY FIELD	AB21	1426.0 1623.0 236.0	H (M)	D	CRHR		3022	
2RH-F513SA-1	LIMIT SWITCH	M TAG NO 2TM 7 8SN	WESTINGH ^{SE}	BY FIELD	AB21	1426.0 1623.0 236.0	H (M)	D	CRHR		3023	
2RH-V506SB-1	GATE B	RHR HT EXC 1B- SH DISCHARGE TO CVCS CHG	WESTINGH ^{SE}	BY FIELD	AB21	1567.0 1579.0 236.0	H	A	CRHR		3716	
2RH-V506SB-1	MOTOR OPERATOR	M TAG NO RGM74 FE	WESTINGH ^{SE}	BY FIELD	AB21	1567.0 1579.0 236.0	H	A	CRHR		3024	
2RH-V506SB-1	LIMIT SWITCH	M TAG NO RGM74 FE	WESTINGH ^{SE}	BY FIELD	AB21	1567.0 1579.0 236.0	H	A	CRHR		3025	
2RH-V507SA-1	LIMIT SWITCH	M TAG NO RGM74 FE	WESTINGH ^{SE}	BY FIELD	AB21	1434.0 1579.0 236.0	H	A	CRHR		3027	
2RH-V507SA-1	MOTOR OPERATOR	RHR HT EXC 1A-SA DISCH TO CVCS CHG PMP	WESTINGH ^{SE}	BY FIELD	AB21	1434.0 1579.0 236.0	H	A	CRHR		3026	

TAGS INCLUDED: 2RH-F512SB-1 ----2RH-V507SA-1
SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84

SYSTEM # 3 NAME: RHD003-RESIDUAL HEAT REMOVAL


TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2RH-V507SA-1	GATE R	W TAG NO 8GN74 FE	WESTINGH'SE	BY FIELD	AB21	1434.0 1579.0 236.0	H	A	CRHR		3714	



SYSTEM # & NAME: S1003A-SAFETY INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
TE 1SI 0910A1 S A	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SI MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1485.0 1593.0 236.0	H	A	ERS		1341	
TE 1SI 0910A2 S W	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1485.0 1593.0 236.0	H	A	ERS		1342	
TE 1SI 0910A3 S A	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA MTR WINDI NG TEMP (TC)	WESTINGH'SE	WSO-20505 BY FIELD	AB21	1485.0 1593.0 236.0	H	A	ERS		1343	
TE 1SI 0910A4 S A	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1485.0 1593.0 236.0	H	A	ERS		1344	
TE 1SI 0910B1 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1351	
TE 1SI 0910B2 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1350	
TE 1SI 0910B3 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB MTR WINDI NG TEMP	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1349	
TE 1SI 0910B4 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB MTR WINDI NG TEMP	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1352	
TE 1SI 0910B5 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB MTR WINDI NG TEMP	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1353	
TE 1SI 0910B6 S B	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -2B MTR WINDI NG TEMP	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1354	
TE 1SI 0911A SA	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA UPPER BRG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1485.0 1593.0 236.0	H	A	ERS		1347	
TE 1SI 0911B SB	TEMPERATURE PRIMARY EL	CHRG SI PMP 1B -SB UPPER BRG TEMP (TC)	WESTINGH'SE	BY FIELD WSO-205	AB21	1532.0 1593.0 236.0	H	A	ERS		1355	

TAGS INCLUDED: TE 1SI 0910A1 S----TE 1SI 0911B SB
SHORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84



SYSTEM A PF:SI003A-SAFETY INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M/CATEG.	FUNCT. D	SAFETY FUNCTION	REG 1.97	REV #
2SI-V5U0SA-1	MOTOR OPERATOR	W TAG NO 3GM78 FM	WESTINGH'SE	BY FIELD	AB21	1452.0 1648.0 236.0	H (M)	D	ERS		3028
2SI-V5U0SA-1	LIMIT SWITCH	W TAG NO 3GM78 FM	WESTINGH'SE	BY FIELD	AB21	1452.0 1648.0 236.0	H (M)	D	ERS		3029
2SI-V5U0SA-1	GATE 3	HIGH HEAD INJ OUTLET HEADER TO RCS HL	WESTINGH'SE	BY FIELD	AB21	1452.0 1648.0 236.0	H (M)	D	ERS		3731
2SI-V501SB-1	GATE 3	W TAG NO 3GM78 FM	WESTINGH'SE	BY FIELD	AB11	1484.0 1630.0 230.0	H (M)	D	ERS		3727

TAGS INCLUDED: TE 1SI 0912A SA----2SI-V501SB-1
SORT TYPE:SYSDS,TAG GLOBAL REV#- 0 05/01/84

21



12



SYSTEM # & NAME: S1003A-SAFETY

INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M CATEG.	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V5015B-1	MOTOR OPERATOR	HIGH HEAD INJ OUTLET HEADER TO RCS HL	WESTINGH'S	BY FIELD	AB11	1484.0 1630.0 230.0	H (M)	D	ERS		3030	
2SI-V5015B-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1484.0 1630.0 230.0	H (M)	D	ERS		3031	
2SI-V5025A-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1568.0 1679.0 236.0	H (M)	D	ERS		3032	
2SI-V5025A-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB21	1568.0 1679.0 236.0	H (M)	D	ERS		3033	
2SI-V5035A-1	MOTOR OPERATOR	HIGH HEAD INJ TO BIT	WESTINGH'S	BY FIELD	AB11	1548.0 1604.0 217.0	H (M)	D	ERS		3034	
2SI-V5035A-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1548.0 1604.0 217.0	H (M)	D	ERS		3035	
2SI-V5035A-1	GATE 3	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1548.0 1604.0 217.0	H (M)	D	ERS		3726	
2SI-V5045B-1	GATE 3	INLET TO BIT UPSTREAM OF INLET SHUTOFF	WESTINGH'S	BY FIELD	AB11	1550.0 1604.0 217.0	H (M)	D	ERS		3728	
2SI-V5045B-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1550.0 1604.0 217.0	H (M)	D	ERS		3036	
2SI-V5045B-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1550.0 1604.0 217.0	H (M)	D	ERS		3037	
2SI-V5055B-1	MOTOR OPERATOR	BIT OUTLET DOWNSTREAM OF SHUTOFF VALVES	WESTINGH'S	BY FIELD	AB11	1540.0 1640.0 230.0	H (M)	D	ERS		3038	
2SI-V5055B-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'S	BY FIELD	AB11	1540.0 1640.0 230.0	H (M)	D	ERS		3039	

TAGS INCLUDED: 2SI-V5015B-1 ----2SI-V5035B-1
SORT TYPE: SYSDEF.TAG GLOBAL REV#- 0 05/01/84

SYSTEM # & NAME: S1703A-SAFETY

INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/P/ATEG.	FUNCT. ATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V5055H-1	GATE 3	W TAG NO 3GM78 FN	WESTINGH'SE	BY FIELD	AB11	1540.0 1640.0 230.0	H M		ERS		3730	
2SI-V506SA-1	GATE 3	BIT OUTLET TO RCS CL	WESTINGH'SE	BY FIELD	AB11	1539.0 1638.0 230.0	H (M)	D	ERS		3729	
2SI-V506SA-1	MOTOR OPERATOR	W TAG NO 3GM78 FN	WESTINGH'SE	BY FIELD	AB11	1539.0 1638.0 230.0	H (M)	D	ERS		3040	
2SI-V506SA-1	LIMIT SWITCH	W TAG NO 3GM78 FN	WESTINGH'SE	BY FIELD	AB11	1539.0 1638.0 230.0	H (M)	D	ERS		3041	
2SI-V515SA-1	SOLENOID VALVE	BIT RECIRC LINE TO VALVE 2SI-V515SA-1	WESTINGH'SE	BY FIELD	AB11	1545.0 1604.0 221.0	H (M)	D	ERS		3042	
2SI-V515SA-1	LIMIT SWITCH	W TAG NO 11A78 RE	WESTINGH'SE	BY FIELD	AB11	1545.0 1604.0 221.0	H (M)	D	ERS		3043	
2SI-V516SH-1	LIMIT SWITCH	W TAG NO 11A78 RE	WESTINGH'SE	BY FIELD	AB11	1543.0 1604.0 221.0	H (M)	D	ERS		3045	
2SI-V516SH-1	SOLENOID VALVE	W TAG NO 11A78 RF	WESTINGH'SE	BY FIELD	AB11	1543.0 1604.0 221.0	H (M)	D	ERS		3044	
2SI-V517SA-1	SOLENOID VALVE	W TAG NO 11A78 RF	WESTINGH'SE	BY FIELD	AB11	1541.0 1604.0 217.0	H (M)	D	ERS		3046	
2SI-V517SA-1	LIMIT SWITCH	BI RECIRC PUMPS DIS- CHARGE	WESTINGH'SE	BY FIELD	AB11	1541.0 1604.0 217.0	H (M)	D	ERS		3047	
2SI-V530-SB-1	SOLENOID VALVE	W TAG NO 11A68 RES	WESTINGH'SE	BY FIELD	AB21	1511.0 1626.0 255.0	H (M)	D	ERS		3048	
2SI-V530-SB-1	LIMIT SWITCH	W TAG NO 11A68 RES	WESTINGH'SE	BY FIELD	AB21	1511.0 1626.0 255.0	H (M)	D	ERS		3049	

TAGS INCLUDED: 2SI-V505SB-1 ----2SI-V530-1
SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84



200



SYSTEM # 4 NAME: S1003A-SAFETY

INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V535SA-1	MOTOR OPERATOR	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1537.0 1736.0 254.0	H	A	ERS		3050	
2SI-V535SA-1	LIMIT SWITCH	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1537.0 1736.0 254.0	H	A	ERS		3051	
2SI-V535SA-1	GATE 12	ACCUM TK 1C-SA INJ LINE TO RCS CL LOOP 3	WESTINGH'SE	BY FIELD	CB21	1537.0 1736.0 254.0	H	A	ERS		3734	
2SI-V536SB-1	GATE 12	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1518.0 1652.0 249.0	H	A	ERS		3733	
2SI-V536SB-1	LIMIT SWITCH H	ACCUM 1B-SB INJ LINE TO RCS CL LOOP 2	WESTINGH'SE	BY FIELD	CB21	1518.0 1652.0 249.0	H	A	ERS		3053	
2SI-V536SB-1	MOTOR OPERATOR	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1518.0 1652.0 249.0	H	A	ERS		3052	
2SI-V537SA-1	LIMIT SWITCH	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1448.0 1716.0 250.0	H	A	ERS		3055	
2SI-V537SA-1	MOTOR OPERATOR	W TAG NO 12GM8 8FNH	WESTINGH'SE	BY FIELD	CB21	1448.0 1716.0 250.0	H	A	ERS		3054	
2SI-V537SA-1	GATE 12	ACCUM 1A-SA INJ LINE TO RCS CL LOOP 1	WESTINGH'SE	BY FIELD	CB21	1448.0 1716.0 250.0	H	A	ERS		3732	
2SI-V55CS9-1	LIMIT SWITCH	W TAG NO 3/4IA 78RE	WESTINGH'SE	BY FIELD	AB21	1546.0 1645.0 236.0	H (M)	D	ERS	*	3057	
2SI-V55DSB-1	SOLENOID VALVE	W TAG NO 3/4IA 78RE	WESTINGH'SE	BY FIELD	AB21	1546.0 1645.0 236.0	H (M)	D	ERS	*	3056	
2SI-V554SB-1	SOLENOID VALVE	W TAG NO 11A78 RE	WESTINGH'SE	BY FIELD	AB21	1543.0 1644.0 249.0	H (M)	D	ERS	*	3058	


TAGS INCLUDED: 2SI-V535SA-1 ----2SI-V554SB-1
SORT TYPE: SYSDES, TAG GLOVAL REV#- 0 05/01/84

SYSTEM # NAME: S1003A-SAFETY

INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V554SB-1	LIMIT SWITCH	W TAG NO 11A78 RE	WESTINGH'SE	BY FIELD	AB21	1543.0 1644.0 249.0	H (M)	D	ERS	*	3059	
2SI-V555SA-1	SOLENOID VALVE	ACCUM TEST LINE AT PENETRATION	WESTINGH'SE	BY FIELD	CB21	1540.0 1651.0 255.0	H	A	ERS	*	3060	
2SI-V555SA-1	LIMIT SWITCH	W TAG NO 3/4IA 78RE	WESTINGH'SE	BY FIELD	CB21	1540.0 1651.0 255.0	H	A	ERS	*	3061	
2SI-V570SB-1	MOTOR OPERATOR	W TAG NO 14GM7 4FEH	WESTINGH'SE	BY FIELD	AB01	1545.0 1644.0 190.0	H (M)	D	ERS		3062	
2SI-V570SB-1	LIMIT SWITCH	W TAG NO 14GM7 4FEH	WESTINGH'SE	BY FIELD	AB01	1545.0 1644.0 190.0	H (M)	D	ERS		3063	
2SI-V570SB-1	GATE 14	SUCTION LINE TO RHR PUMP 1A -SB FROM CONT-	WESTINGH'SE	BY FIELD	AB01	1545.0 1644.0 190.0	H (M)	D	ERS		3737	
2SI-V571SA-1	GATE 14	W TAG NO 14GM7 4FEH	WESTINGH'SE	BY FIELD	AB01	1455.0 1644.0 190.0	H (M)	D	ERS		3735	
2SI-V571SA-1	MOTOR OPERATOR	W TAG NO 14GM7 4FEH	WESTINGH'SE	BY FIELD	AB01	1455.0 1644.0 190.0	H (M)	D	ERS		3064	
2SI-V571SA-1	LIMIT SWITCH	SUCTION LINE TO RHR PUMP 1A -SA FROM CONT-	WESTINGH'SE	BY FIELD	AB01	1455.0 1644.0 190.0	H (M)	D	ERS		3065	
2SI-V572SB-1	LIMIT SWITCH	W TAG NO 14GM7 4FE	WESTINGH'SE	BY FIELD	AB01	1548.0 1634.0 190.0	H (M)	D	ERS		3067	
2SI-V572SB-1	MOTOR OPERATOR	W TAG NO 14GM7 4FE	WESTINGH'SE	BY FIELD	AB01	1548.0 1634.0 190.0	H (M)	D	ERS		3066	
2SI-V572SB-1	GATE 14	SUCTION LINE TO RHR PUMP 1A -SB FROM CONT-	WESTINGH'SE	BY FIELD	AB01	1548.0 1634.0 190.0	H (M)	D	ERS		3738	

TAGS INCLUDED: 2SI-V554SB-1 ----2SI-V572SB-1
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84




SYSTEM # & NAME: SI003A-SAFETY

INJ.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V573SA-1	GATE 14	W TAG NO 14GM7 4FE	WESTINGH'SE	BY FIELD	AB01	1452.0 1634.0 190.0	H (P)	D	ERS		3736	
2SI-V573SA-1	LIMIT SWITCH	W TAG NO 14GM7 4FE	WESTINGH'SE	BY FIELD	AB01	1452.0 1634.0 190.0	H (M)	D	ERS		3069	
2SI-V573SA-1	MOTOR OPERATOR	SUCTION LINE TO RHR PUMP 1A -SA FROM CONT-	WESTINGH'SE	BY FIELD	AB01	1452.0 1634.0 190.0	H (M)	D	ERS		3068	
2SI-V574SB-1	LIMIT SWITCH	W TAG NO 14GM7 4FE W/LS	WESTINGH'SE	BY FIELD	AB01	1548.0 1626.0 190.0	H (M)	D	ERS		3071	
2SI-V574SB-1	MOTOR OPERATOR	W TAG NO 14GM7 4FE W/LS	WESTINGH'SE	BY FIELD	AB01	1548.0 1626.0 190.0	H (M)	D	ERS		3070	
2SI-V574SB-1	GATE 14	RWST OUTLET TO RHR PUMP 1B-SB SUCTION	WESTINGH'SE	BY FIELD	AB01	1548.0 1626.0 190.0	H (M)	D	ERS		3740	
2SI-V575SA-1	GATE 14	RWST OUTLET TO RHR PUMP 1A-SA SUCTION	WESTINGH'SE	BY FIELD	AB01	1452.0 1626.0 190.0	H (M)	D	ERS		3739	
2SI-V576SB-1	GATE 10	LOW HEAD INJ CROSS CONNECTION TO RCS HL	WESTINGH'SE	BY FIELD	AB21	1570.0 1632.0 236.0	H (M)	D	ERS		3741	
2SI-V576SB-1	LIMIT SWITCH	W TAG NO 10GM7 4FE	WESTINGH'SE	BY FIELD	AB21	1570.0 1632.0 236.0	H (M)	D	ERS		3073	
2SI-V576SB-1	MOTOR OPERATOR	W TAG NO 10GM7 4FE	WESTINGH'SE	BY FIELD	AB21	1570.0 1632.0 236.0	H (M)	D	ERS		3072	
2SI-V577SA-1	MOTOR OPERATOR	LOW HEAD INJ CROSS CONNECTION TO RCS HL	WESTINGH'SE	BY FIELD	AB21	1525.0 1626.0 236.0	H (M)	D	ERS		3074	
2SI-V577SA-1	LIMIT SWITCH	W TAG NO 10GM7 4FE	WESTINGH'SE	BY FIELD	AB21	1525.0 1626.0 236.0	H (M)	D	ERS		3075	

TAGS INCLUDED: 2SI-V573SA-1 ----2SI-V577SA-1
 SORT TYPE: SYSDES, TAG GLOBAL REV#- 0 05/01/84



SYSTEM # 5 NAME: S1073A-SAFETY

[MJ.]

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT [LOCATION]	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SI-V577SA-1	GATE 10	W TAG NO 10GM7 4FE	WESTINGH'SE	BY FIELD	AB21	1525.0 1626.0 236.0	H (M)	D	ERS		3742	
2SI-V578SB-1	GATE 10	LOW HEAD INJ TO RCS CL FROM RHR PUMP 1A-SA	WESTINGH'SE	BY FIELD	AB21	1564.0 1660.0 236.0	H (M)	D	ERS		3744	
2SI-V578SB-1	LIMIT SWITCH	W TAG NO 10GM7 8FN	WESTINGH'SE	BY FIELD	AB21	1564.0 1660.0 236.0	H (M)	D	ERS		3077	
2SI-V578SB-1	MOTOR OPERATOR	W TAG NO 10GM7 8FN	WESTINGH'SE	BY FIELD	AB21	1564.0 1660.0 236.0	H (M)	D	ERS		3076	
2SI-V579SA-1	MOTOR OPERATOR	LOW HEAD INJ TO RCS CL FROM RHR PUMP 1A-SA	WESTINGH'SE	BY FIELD	AB21	1516.0 1627.0 236.0	H (M)	D	ERS		3078	
2SI-V579SA-1	LIMIT SWITCH	W TAG NO 10GM7 8FN	WESTINGH'SE	BY FIELD	AB21	1516.0 1627.0 236.0	H (M)	D	ERS		3079	
2SI-V579SA-1	GATE 10	W TAG NO 10GM7 8FN	WESTINGH'SE	BY FIELD	AB21	1516.0 1627.0 236.0	H (M)	D	ERS		3745	
2SI-V587SA-1	GATE 10	SIS LOW HEAD INJ TO RCS HL	WESTINGH'SE	BY FIELD	AB21	1430.0 1674.0 245.0	H (M)	D	ERS		3743	
2SI-V587SA-1	LIMIT SWITCH	W TAG NO 10GM 78FN	WESTINGH'SE	BY FIELD	AB21	1430.0 1674.0 245.0	H (M)	D	ERS		3081	
2SI-V587SA-1	MOTOR OPERATOR	W TAG NO 10GM 78FN	WESTINGH'SE	BY FIELD	AB21	1430.0 1674.0 245.0	H (M)	D	ERS		3080	
TE 15 ^I 091045 A	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD	AB21	1485.0 1593.0 236.0	H	A	ERS		1345	
TE 15 ^I 091046 A	TEMPERATURE PRIMARY EL	CHRG SI PMP 1A -SA MTR WINDI NG TEMP (TC)	WESTINGH'SE	BY FIELD	AB21	1485.0 1593.0 236.0	H	A	ERS		1346	



[Faint, illegible text or markings in the center of the page]

SYSTEM # & NAME: WGD042-WASTE PROC. (GAS)

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2WG-D291SB-1	DIAPHRAGM 3/4	HYDROGEN SUPPLY TO RCDT	WESTINGH*SE	BY FIELD	AR21	1510.0 1630.0 236.0	H	(M)	D	*	4129	
2WG-D590SA-1	LIMIT SWITCH	W TAG NO 314 D A62R	WESTINGH*SE	BY FIELD	CB21	1507.C 1638.C 242.0	H	A		*	3197	
2WG-D590SA-1	SOLENOID VALVE	W TAG NO 314 D A62R	WESTINGH*SE	BY FIELD	CB21	1507.0 1638.C 242.0	H	A		*	3196	

SYSTEM # 3 NAME: WL0043-WASTE PROC. (LIQUID)

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2WL-D650SP-1	DIAPHRAGM 3	RCDT HX OUTLET HDR	WESTINGH'SE	BY FIELD	AB11	1493.0 1630.0 230.0	H (M)	D		*	1504	
2WL-D651SN-1	DIAPHRAGM 3	BY PASS A ROUND 2WL-L600 SN-1	WESTINGH'SE	BY FIELD	CB 11		H	A		*	4120	
2WL-L600SA-1	LIMIT SWITCH	W TAG LCV-1003	WESTINGH'SE	BY FIELD	CB11	1497.0 1638.0 230.0	H	A		*	3201	
2WL-L600SA-1	SOLENOID VALVE	W TAG LCV-1003	WESTINGH'SE	BY FIELD	CB11	1497.0 1638.0 230.0	H	A		*	3200	

EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER ACTUAL		DEH. QUALIF.	DOCUMENTATION ACTUAL		QUALIF. METHOD	H/M	OUTS ITEMS		
TAG NO: ICS-L500SN-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			/		ACCEL TIME:	
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA							ACCEL TEMP:	
COMPONENT: SOLENOID	TEMPERATURE	120° F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1			/	H	REPLACEMENT:	
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)			/	H	MAINTAIN.:	
MAJOR SUPPLIER: COPEL VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			/	H	SUBCOMPONENTS:	
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			/	H		
FUNCTIONS: LET DOWN LINE & SERVICE ISO. VALVE - SERVING VALVE ICS-L500SN-1	R GAMMA	4.7 E6		FSAR APP. 3.11.8-19 CONT. RAD. ZONE C5			/	H		
ACCUR. SPEC: N/A	A BETA	3.4 E7								
ACCUR. DEH.: N/A	D SHIELD									
SPECIFICATIONS: W. PROJ. SPEC. 678459 02 W. E. SPEC. 678444 02	T.I.D.									
P.O. #: 183622 CHD # 154.40251	AGE - INST LIFE	40 YEARS (PER 323-1974 DEF.)		110 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTION:	
PLANT LOC.: C.B. 21	SUBMERGED	228.3 YES	N/A	FSAR SECTION		N/A	/	NONE	AUTH. REFERENCE:	
COORDINATES X- 1461.0 Y- 1703.0 Z- 241.0										
INSTALLED (Y/N): INSTAL. REF: BY FLD. QUALIF EXEMPT: N/A	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165G-803							
QUALIF:	TEMPERATURE	T								
STATUS	PRESSURE	P								
*	REL. HUMIDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
PHYS DNG REF: CAR-2165G-138	AGING	A					REVISION # :			
PHYS DNG LOC: TOTAL EQUIP. LIST	SUBMERGENCE	S					DATE :			
HOUSING: N/A							SYSTEM: CHEM. & VOLU. CONT. SYS.			
EDUC. LUC: 3.2	FSAR ENV CAT: A						TAG: ICS-L500SN-1			
	1958 CATEG.:									
	APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	ITEMS	NOTES
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: ICS-L500SN-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT: VALVE TYPE	NORM/TEST	1 YEAR					ACCEL TEMP:
COMPONENT: LIMIT SW.	DBA	POST DBA					REPLACEMENT:
MANUFACTURER: NAMCO	TEMPERATURE	120°F NORM		FSAR TABLE 9.4.0-1		/	MAINTAIN:
MAJOR SUPPLIER: COPES VULCAN		FSAR FIG. 3.11.4-1		FSAR FIG. 3.11.4-1		H	SUBCOMPONENTS:
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1		/	
FUNCT. USE: LET DOWN LINE & SERVICE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3(DBA)		H	
ISOL. VALVE - SERVING VALVE ICS-L500SN-1	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
ACCUR. SPEC: N/A	R GAMMA	4.7 E6		FSAR APP. 3.11.8-19		/	
ACCUR. DEH.: N/A	A BETA D SHIELD	3.4 E7		CONT. RAD. ZONE C5		H	
SPECIFICATIONS: W. PROJ. SPEC. 678959.02 N.E. SPEC. 678844.02	AGE- INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
P.O # 183622 CMD # 15H#0251	(PER 323-1974 DEF.)						
PLANT LOC.: C.B. 21	SUBMERGED	228.3		FSAR SECTION		/	AUTH. REFERENCE:
COORDINATES X- 1461.0 Y- 1703.0 Z- 241.0	YES		N/A		N/A	NONE	
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. REF: BY FLD.	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-803				
QUALIF EXEMPTN: N/A	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
	SUBMERGENCE	S					
	FSAR ENV CAT:	A					
	10588 CATEG.:						
	APPENDIX E						REVISION #:
PHYS DMG REF: CAR-2165 G-138							DATE:
PHYS DMG LUC: TOTAL EQUIP. LIST							SYSTEM: CHEM. & VOLU. CONT. SYS.
MOUNTING: N/A							TAG: ICS-L500SN-1
EDUC. LUC: 9.2							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: ICS-LS01SN-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT TYPE: VALVE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA				ACCEL TEMP:
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		/	REPLACEMENT:
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. { FIG. 3.11.6-1 (DBA)		/	MAINTAIN.:
MAJOR SUPPLIER: COPE'S VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/	SUBCOMPONENTS:
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1		/	
FUNCTIONS & SERVICE: LET DOWN LINE 150. VALVE - SERVING VALVE ICS-LS01SN-1	R GAMMA A BETA D SHIELD	4.7 EG 3.4 E7 . T.I.D.	FSAR APP. 3.11.B-19 CONT. RAD. ZONE CS		/	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
ACCUR. DEM.: N/A	SUBMERGED	228.3 YES	FSAR SECTION		/	
SPECIFICATIONS: W. PROT. SPEC. 678959.02 W.E. SPEC. 678844.02	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
P.O. #: 183622 CHD # 15H.#0250	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-803			
PLANT LOC.: C.B. 21	TEMPERATURE	T				
COORDINATES X-1459.0 Y-1701.0 Z-241.0	PRESSURE	P				
INSTALLED (Y/N):	REL. HUMIDTY	H				
INSTAL. REF: BY FLD.	CHEM. SPRAY	C				
QUALIF EXEMPT: N/A	RADIATION	R	REVISION # :			
QUALIF:	AGING	A	DATE :			
STATUS:	SUBMERGENCE	S	SYSTEM: CHEM. & VOLL. CONT. SYS.			
PHYS DNG REF: CAR-2165 G-138	FSAR ENV CAT:	A	TAG: ICS-LS01SN-1			
PHYS DNG LOC: TOTAL EQUIP. LIST	19588 CATEG.:					
MOUNTING: N/A	APPENDIX E					
EQUIP. DUC. LUC: 3.2						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/H ITEMS	OUTS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL			
TAG NO: ICS-L501SN-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT TYPE: VALVE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP:
COMPONENTS: LIMIT SW.	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.:
MAJOR SUPPLIER: COPEL VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS:
FUNCTIONS & SERVICE: LET DOWN LINE ISO. VALVE - SERVING VALVE ICS-L501SN-1	CHEMICAL SPRAY	2000-2100 PRM BORON PH. 8.5-11.0		FSAR SECT. 3.11.5.1		H	
ACCUR. SPEC: N/A	R GAMMA A BETA D SHIELD	2.7 EG 3.4 E7 T.I.D.		FSAR APP. 3.11.8-19 CONT. RAD. ZONE C5		H	
ACCUR. DEH.: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
SPECIFICATIONS: W. PROJ. SPEC. 678959 02 W.E. SPEC. 678844 02	SUBMERGED	228.3 YES	N/A	FSAR SECTION		N/A	AUTH. REFERENCE:
P.O #: 183622 CHD # 15H#0250							
PLANT LOC.: C.B. 21							
COORDINATES X- 1459.0 Y- 1701.0 Z- 241.0							

INSTALLED (Y/N): INSTAL. REF: BY FLD. QUALIF EXEMPT: N/A ***** QUALIF: STATUS: ***** PHYS DWG REF: CAR 2165 G-138 PHYS DWG LOC: TOTAL EQUIP. LIST MOUNTING: N/A ED. DUC. LUC: 9.2	PARA-METER SUPPL. REVISION OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDITY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S FSAR ENV CAT: A 10588 CATEG.: APPENDIX E	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: FLOW DIAG. CAR-2165 G-803	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM: CHEM. & VOLU. CONT. SYS. TAG: ICS-L501SN-1
---	--	---	---

A/E: E SERVICES INC.
 UTIL: MOLINA POWER & LIGHT

FACILITY: SHEARON H NO.1
 COMPONENT EVALUATION

NSS: WESTINGHOUSE - PHH
 CAPACITY: 900 MW(E)

YN- 0
 SN-

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: ICS V509 SB-1	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	3		ACCEL TIME:
EQUIPMENT: VALVE TYPE: AIR OPERATED	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP:
COMPONENT: SOL. VALVE	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT:
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.:
MAJOR SUPPLIER: COPES VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS:
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			
FUNC. DES: & SERVICE	R GAMMA	1.15 E6		FSAR SECT 3.11.8-13 CONT. RAD. ZONE C1		H	
ACCUR. SPEC: N/A	A BETA	1.7 E7					
ACCUR. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	T. I. D.	1.1 E6					
P.O #: 183622 CND #: SH. 289	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: RCS EXCESS LETDOWN
PLANT LOC.: C, B.	(PER 323-1974 DEF.)						
COORDINATES X= 1523.0 Y= 1730.0 Z= 241.0	SUBMERGED	228.3		FSAR SECTION 3.6			AUTH. REFERENCE:
YES							
INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPTN: ***** QUALIF: STATUS ***** PHYS DNG REF: CAR-2165 G138 (F-17) PHYS DNG LUC: MOUNTING: EQ. DUC. LUC: W/ RO. 183622	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G803 VENDOR DWG. 1364-2936				REVISION #
	TEMPERATURE	T					DATE
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R	SYSTEM CHEMICAL & VOLUME CONTROL				
	AGING	A	TAG: ICS V509 SB-1				
	SUBMERGENCE	S					
	SAR ENV CAT:						
	10588 CATEG.:	C					
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIFICATION METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: ICS V509 SB-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT TYPE: VALVE AIR OPERATED	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENTS: LIMIT SW.	TEMPERATURE	120 F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.
MAJOR SUPPLIER: COPEL VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS
MODEL AND SERIAL #: EA170 11302	CHEMICAL SPRAY	2000-2100 PPM BORDON PH 8.5-11.0	FSAR SECT. 3.11.5.1		/	
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.15 EG 1.7 E7 100% BETA 1.1 EG	FSAR SECT 13.11.B-18 CONT. RAD. ZONE C1		H	
ACCUM. SPEC: N/A	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION: RCS EXCESS LETDOWN
ACCUM. DEM: N/A	SUBMERGED	228.3 YES	FSAR SECT. 3.6		/	AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 678959,RZ GEN. E-SPEC. 678844,RZ	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
P.O. # 183622 CND # 1 SH. 289	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G 803 VENDOR DWG. 1364-2936			
PLANT LOC.: C.T.	TEMPERATURE	T				
COORDINATES X= 1523.0 Y= 1730.0 Z= 241.0	PRESSURE	P				
INSTALLED (Y/N):	REL. HUMIDTY	H				
INSTAL. REF:	CHEM. SPRAY	C				
QUALIF EXEMPT:	RADIATION	R	REVISION # DATE			SYSTEM: CHEMICAL VOLUME CONTROL
QUALIF:	AGING	A				
STATUS:	SUBMERGENCE	S				
PHYS DWG REF: CAR-2165 G 138 (F-17)	FSAR ENV CAT:		TAG ICS V509 SB-1			
PHYS DWG LOC:	10500 CATEG.:	C				
MOUNTING:	APPENDIX E					
EW. DUC. LOC: P.O. 183622						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	UNITS	ITEMS	
	PARAMETER	ACTUAL	DEH.	QUALIF.					ACTUAL
TAG NO: ICS V510 SB-1	OPERABIL-ITY	40 YEARS			OPERABILITY REVIEW		/	ACCEL TIME	
EQUIPMENT TYPE: VALVE AIR OPERATED	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENTS: LIMIT SW.	TEMPERATURE	120° F NORM			FSAR TABLE 9.4.0-1		/	REPLACEMENT	
MANUFACTURER: NAMCO	URE	FSAR FIG. 3.11.4-1			FSAR FIG. 3.11.4-1		H	MAINTAIN.	
MAJOR SUPPLIER: COPEL VULCAN	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM.		/	SUBCOMPONENTS	
MODEL AND SERIAL: EA170 11302	SEE FSAR FIG 3.11.6-1 FOR DBA				FIG. 3.11.6-1 FOR DBA		H		
FUNCTIONS & SERVICE	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM		/		
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PHM BORON PH 8.5-11.0			FSAR SECT. 3.11.4.3 (DBA)		H		
ACCUM. DEH.: N/A	R GAMMA	11.5 EG			FSAR SECT. 3.11B-18		/		
SPECIFICATIONS: PROJ. E-SPEC. 6788959, RZ GEN. E-SPEC. 678844, RZ	A BETA	11.7 E7			CONT. RAD. ZONE C1		H		
P.O. # 183662 CMD # 1 SH. 288	D SHIELD	100% BETA							
PLANT LOC.: C.B.	T.I.D.	11.1 EG							
COORDINATES X=1525.0 Y=1730.0 Z=241.0	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION: RCS EXCESS LETDOWN	
INSTALLED (Y/N):	(PER 323-1974 DEF.)								
INSTALL. REF: QUALIF EXEMPT	SUBMERGED	228-3			FSAR SECT. 3.6		/	AUTH. REFERENCE	
QUALIFI STATUS	YES								
PHYS DNG REF: CAR-2165 G183(F-17)	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
PHYS DNG LUC: MOUNTING	OPERABILITY	O	REFERENCES: FLOW DIAGRAM 2165-G 803 VENDOR DWG. 1364-2936				REVISION # : DATE :		
EW. DUC. LUC: w/ P.O. 183662	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
	SUBMERGENCE	S							
	FSAR ENV CAT: A								
	10588 CATEG. C								
	APPENDIX E								
							SYSTEM: CHEMICAL CONTROL		
							TAG: ICS V510 SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: ICS VS10 SB-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT TYPE: VALVE AIR OPERATED	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOL. VALVE	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.
MAJOR SUPPLIER: COPES VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
FUNCTIONS & SERVICE	R GAMMA	1.15 EG	FSAR SECT. 3.11.B-18 CONT. RAD. ZONE C1		H	
ACCUR. SPEC: N/A	A BETA	1.7 E7				
ACCUR. DEH.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: PROJ. E-SPEC. 678959, RZ GEN. E-SPEC. 678844, RZ	• T.I.D.	1.1E6				
P.O #: 183622 CHD #: SH-288	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	110 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: RCS EXCESS LETDOWN
PLANT LOC.: C.B.	SUBMERGED	228.3	FSAR SECTION 3.6			AUTH. REFERENCE:
COORDINATES X= 1525.0 Y= 1730.0 Z= 241.0	YES					
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G 803 VENDOR DWG. 1364-2936			REVISION # : DATE :
QUALIF EXEMPT:	TEMPERATURE	T				
*****	PRESSURE	P				
QUALIF:	REL. HUMIDTY	H				
STATUS	CHEM. SPRAY	C				
*****	RADIATION	R				
PHYS DWG REF: CAR-2165 G138 (F-17)	AGING	A	SYSTEM: CHEMICAL CONTROL VOLUME CONTROL TAG: ICS VS10 SB-1			
PHYS DWG LUC:	SUBMERGENCE	S				
MOUNTING	FSAR ENV CAT:					
EQ. DOC. LUC: P.O. 183662	10588 CATEG.:	C				
	APPENDIX E					


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2CS-V511SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT TYPE: VALVE GLOBE	NORM/TEST DBA	1 YEAR					ACCEL TEMP
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1(DBA)		H	MAINTAIN.
MAJOR SUPPLIER: COPE'S VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)		H	SUBCOMPONENTS
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
FUNCTIONS: CHEM. & VOLUME CONT. & SERVICE SERVING VALVE 2CS-V511SA-1	R GAMMA A BETA D SHIELD	1.2 E6 3.3 E7		FSAR APP. 3.11.8-18 CONT. RAD. ZONE C3		H	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 325-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION
ACCUR. DEM.: N/A	SUBMERGED	228.3 YES	N/A	FSAR SECTION		N/A	AUTH. REFERENCE
SPECIFICATIONS: W. PROJ. SPEC. 678959 02 W.E. SPEC. 678944 02	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
P.O. #: 183622 CHD #: SK 0284	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G 803				
PLANT LOC.: C.B. 21	TEMPERATURE	T					
COORDINATES: X-1459.0 Y-1670.0 Z-248.0	PRESSURE	P					
INSTALLED (Y/N):	REL. HUMIDITY	H					
INSTALL. REF: BY FLD.	CHEM. SPRAY	C					
QUALITY EXEMPT: N/A	RADIATION	R		REVISION #			
PHYS. DMG. HFF: CAR-2165 G-138	AGING	A		DATE			
PHYS. DMG. LUCI: TOTAL EQUIP. LIST	SUBMERGENCE	S		SYSTEM: CHEM. & VOLUME CONT.			
HOISTING: N/A	FSAR ENV CAT:	A		TAG: 2CS-V511SA-1			
EV. DOC. LUCI: 3.2	OSOR CATEG.:						
	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEH.	QUALIF.				ACTUAL
TAG NO: 2CS-V511SA-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME:
EQUIPMENT: VALVE TYPE: GLOBE	NORM/TEST DBA	1 YEAR POST DBA				/		ACCEL TEMP:
COMPONENT: LIMIT SW.	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	/	H	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA			FSAR SECT. 3.11.6 NORM. { FIG. 3.11.6-1(DBA)	/	H	MAINTAIN.:
MAJOR SUPPLIER: COPE'S VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)	/	H	SUBCOMPONENTS:
MODEL AND SERIAL #: EA170-11302	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1	/	H	
FUNCTIONS: CHEM. & VOLUME CONT. & SERVICE SERVING VALVE 2CS-V511SA-1	R GAMMA	1.256			FSAR APP. 3.11.8-18	/	H	
ACCUR. SPEC: N/A	A BETA	3.367			CONT. RAD. ZONE C3	/	H	
ACCUR. DEH.: N/A	D SHIELD	.T.I.D.				/		
SPECIFICATIONS: N. PROJ. SPEC. 678959.02 W.E. SPEC. 678844.02	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS			110 CFR 50 PARAGRAPH 50.51	/		SAFETY FUNCTION:
P.O. #: 183622 CHD # 15M#0284	SUBMERGED	228.3 YES		N/A	FSAR SECTION	/	N/A	AUTH. REFERENCE:
PLANT LOC.: C.B. 21	PARAMETER	SUPPL. HEVIEH	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
COORDINATES X- 1459.0 Y- 1670.0 Z- 248.0	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-803				REVISION # : DATE : SYSTEM : CHEM. & VOLUME CONT. TAG : 2CS-V511SA-1	
INSTALLED (Y/N):	TEMPERATURE	T						
INSTAL. REF: BY FLD.	PRESSURE	P						
QUALIF EXEMPTN: N/A	REL. HUMIDTY	H						
*****	CHEM. SPRAY	C						
*****	RADIATION	R	APPENDIX E					
PHYS DNG REF: CAR-2165 G-138	AGING	A	FSAR ENV CAT: A					
PHYS DNG LOC: TOTAL EQUIP. LIST	SUBMERGENCE	S	10588 CATEG.:					
MOUNTING: N/A			10588 CATEG.:					
EQUIP. LOC: 9.2			APPENDIX E					




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	UNITS		
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.					
TAG NO: RCS-V512SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW		/		ACCEL TIME	
EQUIPMENT TYPE: VALVE GLOBE	NORM/TEST	1 YEAR						ACCEL TEMPI	
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM		FSAR TABLE 9.4.0-1		/		REPLACEMENT	
MANUFACTURER: ASCO	URL	FSAR FIG. 3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1		H		MAINTAIN.	
MAJOR SUPPLIER: COPE'S VULCAN	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H		SUBCOMPONENTS	
MODEL AND SERIAL #: FT 831654	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM		/			
FUNCTIONS: CHEM. & VOLUME CONT. & SERVICE SERVING VALVE RCS-V512SA-1				FSAR SECT. 3.11.4.3 (DBA)		H			
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		/			
ACCUR. DEH.: N/A	RADIATION	1.2E6		FSAR APP. 3.11.8-18		/			
SPECIFICATIONS: PROJ. SPEC. 678959 02 W.E. SPEC. 678844 02	A BETA SHIELD	3.3E7		CONT. RAD. ZONE C3		H			
P.O. #: 183622 CHD # 15H#0285	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION	
PLANT LOC.: C.B. 21									
COORDINATES: X-1458.0 Y-1669.0 Z-248.0	SUBMERGED	228.3		FSAR SECTION		/			
INSTALLED (Y/M):		YES	N/A			N/A	NONE	AUTH. REFERENCE	
INITIAL. REF: BY FLD.	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
QUALITY EXEMPTION: N/A	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-803						
QUALIFY:	TEMPERATURE	T							
STATUS:	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: CAR-2165 G-138	AGING	A					REVISION #		
PHYS DNG LOC: TOTAL EQUIP. LIST	SUBMERGENCE	S					DATE		
HOUSING: N/A							SYSTEM: CHEM. & VOLUME CONTROL		
EDUC. LVL: 3.2	FSAR ENV CAT:	A					TAG: RCS-V512SA-1		
	1958 CATEG.:								
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: 2CS-V5125A-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT TYPE: VALVE GLOBE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP:
COMPONENT: LIMIT SW.	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.:
MAJOR SUPPLIER: COPES VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS:
MODEL AND SERIAL #: EA170-11302	CHEMICAL SPRAY	2000-2100 PRM BORONI PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
FUNCTIONS & SERVICE: CHEM. & VOLUME CONT. SERVING VALVE 2CS-V5125A-1	R GAMMA A BETA D SHIELD T.I.D.	1.2 EG 3.3 EG		FSAR APP 3.11.8-18 CONT. RAD. ZONE C3		H	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 325-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
ACCUR. DEH.: N/A	SUBMERGED	228.3 YES	N/A	FSAR SECTION		N/A	AUTH. REFERENCE:
SPECIFICATIONS: W. PROV. SPEC. 678959 02 W.E. SPEC. 678844 02	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
P.O. #: 183622 CHD # 3540285	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165G-803				
PLANT LOC.: C.B. 21	TEMPERATURE	T					
COORDINATES X=1458.0 Y=1669.0 Z=248.0	PRESSURE	P					
INSTALLED (Y/N):	REL. HUMIDTY	H					
INSTAL. REF: BY FLD.	CHEM. SPRAY	C					
QUALIF EXEMPT: N/A	RADIATION	R	REVISION #		DATE		
QUALIF:	AGING	A	SYSTEM: CHEM. & VOLUME CONTROL		TAG: 2CS-V5125A-1		
STATUS:	SUBMERGENCE	S					
PHYS DMG REF: CAR-2165G-138	FSAR ENV CAT:	A					
PHYS DMG LUC: TOTAL EQUIP. LIST	10588 CATEG.:						
MOUNTING: N/A	APPENDIX E:						
EDUC. LUC: 9.2							

1000

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	UNITS	ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.				
TAG NO: 2CS-V513SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/		ACCEL TIME
EQUIPMENT TYPE: VALVE GLOBE	NORM/TEST	1 YEAR						ACCEL TEMP
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM		FSAR TABLE 9.4.0-1		/		REPLACEMENT
MANUFACTURER: ASCO	DBA	POST DBA		FSAR FIG. 3.11.4-1		H		MAINTENANCE
MAJOR SUPPLIER: COPES VULCAN	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1(DBA)		H		SUBCOMPONENTS
MODEL AND SERIAL #: FT 831654	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3(DBA)		H		
FUNCTION & SERVICE: CHEM. & VOLUME CONTROL SERVING VALVE 2CS-V513SA-1	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		H		
ACCUR. SPEC: N/A	R GAMMA	1.2E6		FSAR APP. 3.11.B-1B		/		
ACCUR. DEH.: N/A	BETA	3.3E7		CONT. RAD. ZONE C3		H		
SPECIFICATIONS: W. PROJ. SPEC. 678959.02 W.E. SPEC. 678844.02	T.I.D.							
P.O. # 183622	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION
PLANT LOC.: C.B. 21	(PER 323-1979 DEC.)							
COORDINATES X-1458.0 Y-1069.0 Z-248.0	SUBMERGED	228.3	N/A	FSAR SECTION		N/A	NONE	AUTH. REFERENCE
YES								
INSTALLED (Y/N):	PARA-SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
INSTAL. REF: BY FL2.	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-803					
QUALIF. EXEMPT: N/A	TEMPERATURE	T						
STATUS	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS. DWG. REF: CAR-2165-G138	AGING	A					REVISION #	
PHYS. DWG. LOC: TOTAL EQUIP. LIST	SUBMERGENCE	S					DATE	
HOUSING: N/A	FSAR ENV. CAT: A	A					SYSTEM: CHEM. & VOLUME CONTROL	
EV. DUC. LOC: 3.2	OS88 CATEG.:						TAG: 2CS-V513SA-1	
	APPENDIX E							



A/E: SERVICES INC.
 UTIL: CAROLINA POWER & LIGHT

FACILITY: SHEARON IS NO. 1
 COMPONENT EVALUATION SHEET

ISSN: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

REV: 0
 CES: -

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	UNITS
	PARAMETER	ACTUAL				
TAG NO: 2CS-V513SA-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT TYPE: VALVE GLOBE	NDRM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP:
COMPONENT: LIMIT SW.	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.:
MAJOR SUPPLIER: COPEL VULCAN	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS:
MODEL AND SERIAL #: EA170-11302	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1		H	
FUNCTIONS & SERVICE: CHEM. & VOLUME CONTROL SERVING VALVE 2CS-V513SA-1	R GAMMA A BETA D SHIELD T.I.D.	1.2E6 3.3E7	FSAR APP 3.11.8-18 CONT. RAD. ZONE C3		H	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
ACCUR. DEH.: N/A	SUBMERGED	228.3 YES	FSAR SECTION		N/A	AUTH. REFERENCE:
SPECIFICATIONS: W. PROJ. SPEC. 678959 02 W.E. SPEC. 678844 02	OTHER EQUIPMENT THIS CES APPLIES TO:		REFERENCES: FLOW DIAG. CAR-2165 G-803			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
P.O. #: 183622 CND # 15H#0286	PLANT LOC.: C.B. 21					REVISION #:
COORDINATES X-1458.0 Y-1669.0 Z-248.0	INSTALL. REF: BY FLD.					DATE:
QUALIF EXEMPTN: N/A	QUALIF STATUS:					SYSTEM: CHEM. & VOLL. CONTROL
PHYS DMG REF: CAR-2165 G-138	PHYS DMG LUCI TOTAL EQUIP. LIST					TAG: 2CS-V513SA-1
MOUNTING: N/A	EQ. DUC. LUC: 9.2					
	PARA-METER	SUPPL. REVIEW				
	OPERABILITY	O				
	TEMPERATURE	T				
	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
	AGING	A				
	SUBMERGENCE	S				
	FSAR ENV CAT:	A				
	1988 CATEG.:					
	APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: <i>2CS-V5165A-1</i>	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25	/	ACCEL TIME: 15092 HOURS
EQUIPMENT TYPE: <i>VALVE GLOBE</i>	NORM/TEST DBA	1 YEAR	1 YEAR				NONE
COMPONENT: <i>MOTOR</i>	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	SRS TABLE PAGE 1 C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	ACCEL TEMP: 180°C
MANUFACTURER: <i>LIMITORQUE</i>	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM & FIG.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 40 YEARS
MAJOR SUPPLIER: <i>WESTHS.</i>	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE PAGE 2B		MAINTAIN.:
MODEL AND SERIAL #: <i>SMB-00-10</i>	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	SUBCOMPONENTS: TORQUE & LIMIT SW.
FUNCTIONS: <i>CHEM. & VOLU. CONT. & SERVICE SERVING VALVE 2CS-V5165A-1</i>	PH	8.5-11.0	10.5-11.1		SRS TABLE PAGE 1D		
ACCUM. SPEC: <i>N/A</i>	H GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-20	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 19
ACCUM. DEM.: <i>N/A</i>	B BETA	3.3 E7	74 EG	CONT. RAD. ZONE C3	SRS TABLE FIG THRU 3G		
SPECIFICATIONS: <i>W. PROJ. SPEC. 952072 01 N.C. SPEC. 6678852 01</i>	SHIELD	100% BETA	100% BETA				
P.O. #: <i>18923</i> FCHD #: <i>15K#0266</i>	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1F
PLANT LOC.: <i>C.B. 21</i>	SURMERGED	228.3		FSAR SECTION 3.6	N/A		
COORDINATES X- <i>1561.0</i> Y- <i>1690.0</i> Z- <i>245.0</i>		YES	N/A		SRS TABLE PAGE 1A		
INSTALLED (Y/M): INSTAL. REF: <i>BY FLD.</i>	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
QUALIF EXEMPT: <i>N/A</i>	OPERABILITY	O HE-1	REFERENCES: <i>FLOW DIAG. CAR-2165 G-803</i> <i>LIMITORQUE TEST REPORT 600456</i>				REVISION #: 0 DATE: 14-21-84 SYSTEM: <i>CHEM. & VOLU. CONTRL</i> TAG: <i>2CS-V5165A-1</i>
QUALIF: <i>QUALIFIED, AWAITING STATUS CONFIRMATORY DATA</i>	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: <i>CAR-2165 G147</i>	AGING	A					
PHYS DNG LUC: <i>TOTAL EQUIP. LNT</i>	SURMERGENCE	S					
HOUSING	ISAR ENV CAT:						
EV. DOC. LUC: <i>W.P.O. 189234</i>	1958B CATEG.:	A					
	APPENDIX E						



1972



1973



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: ZCS-V517 SB-1	OPERABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4			REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS: LIMIT (TORQUE SW.)
MODEL AND SERIAL: SMB-00-10 193361	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE ZCS-V517 SB-1, SEE TAB B	R GAMMA A BETA D SHIELD T.I.D.	2.0 E4 7.2 E4 100% BETA 3.0 E4		FSAR FIG. 3.11B-23 ZONE RG			
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	BURNEGED	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
SPECIFICATIONS: P.O. # 189234 CND # 1 PLANT LOC. AB Z1							
COORDINATES X=1570.0 Y=1685.0 Z=236.0							

INSTALLED (Y/M):
 INSTAL. REFS BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG HFF: CAR 2165 G 140
 PHYS DNG LUC: D-17
 MOUNTING:
 ED. DUC. LUC: w/ P.O. 189234

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
IRRADIATION	R
AGING	A
EMERGENCY	S
ISAN ENV CAT:	
19500 CATEG.:	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIED TO:

REFERENCES:
 FLOW DIAG. CAR 2165 G803 (G-17)
 VENDOR DWG. E73-0545, 1364-46739

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: CHEMICAL & VOLUME
 CONTROL
 TAG: ZCS-V517 SB-1



1950



1951



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: ZCS-V518 SB-1	OPERABIL- ITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPER. VALVE TYPE	MOHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERAT- URE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
FUNCTION: SERVING VALVE & SERVICE ZCS-V518 SB-1. SEE TAB B	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD T.I.D.	2.0E4 7.2E4 100% BETA 3.0E4	FSAR FIG. 3.11B-23 ZONE RG			
ACCUM. DEM.: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
SPECIFICATIONS: PROJ. E-SPEC. 678959 RZ GEN. E-SPEC 678844 RZ	BURMEGED	191'0" YES	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
P.O. # 183622 CND # 1 SH.287						
PLANT LOC.: AB21						
COORDINATES X= 1445.0 Y= 1655.0 Z= 245.0						
INSTALLED (Y/II): INSTAL. MFT BY FIELD QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIFI	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 803 (A-17) VENDOR DWG. D-169448, 1364-2918			REVISION # DATE
STATUS	TEMPERATURE	T				
	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPIRAY	C				
PHYS DNG MFT: CAR 2165 G 140	RADIATION	R				SYSTEM: CHEMICAL VOLUME CONTROL TAG: ZCS V518 SB-1
PHYS DNG LUCI: F-4	AGING	A				
MOUNTING	BURMEGMENT	S				
EV.DUC.LUC: W/ P.O. 183622	ISAH ENY CAT:					
	19580 CATEG:					
	APPENDIX E					




11



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/MI UNITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: ZCS-VS18 SB-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: AIR OPER. VALVE TYPE	INDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4				REPLACEMENT	
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
FUNCTION: SERVING VALVE & SERVICE ZCS-VS18 SB-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
ACCUM. SPEC: N/A	R GAMMA	2.0E4		FSAR FIG. 3.11B-23					
ACCUM. DEM.: N/A	A BETA	7.2E4		ZONE RC					
SPECIFICATIONS: GEN. E-SPEC. 678959, R2	D SHIELD	100% BETA							
P.O. # 183622 CND # 1SH-287	T.I.D.	3.0E4							
PLANT LOC.: AB-21	ACC-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION	
COORDINATES X= 1445.0 Y= 1655.0 Z= 245.0	BURNEGED	1910" YES	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INITIAL. REPT: BY FIELD	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 6803 (A-17) VENDOR DWG. D-169448, 1364-2918				REVISION # : DATE : SYSTEM CONTROL (VOLUME CONTROL) TAG 12CS VS18 SB-1		
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIFI	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG HFF: CAR 2165 G140	AGING	A							
PHYS DNG LUC: F-4	BURNEGENCE	S							
MOUNTING	ISAN ENY CAT:								
EW.DUC.LUC: W.P.O. 183622	19588 CATEG.:								
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M UNITS	ITEMS	
	ACTUAL			ACTUAL	DEM. QUALIF.				
TAG NO: 2CS-V585 SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: VALVE	TEMPERATURE	NORMAL						ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	NORM/TEST DBA	1 YEAR POST DBA						REPLACEMENT	
MANUFACTURER: LIMITORQUE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				SUBCOMPONENTS	
MODEL AND SERIAL: SMB-00 339928	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM.					
FUNCTION: SERVING VALVE & SERVICE 2CS-V585 SA-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11.3 (DBA)					
ACCUM. SPEC: N/A	R GAMMA	18.1 E4		FSAR FIG. 3.11B-23					
ACCUM. DEM.: N/A	A BETA	NEGL.		ZONE RB					
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	D SHIELD	100% BETA							
P.O. # 173662 CND # 1	T.I.D.	19.1 E4							
PLANT LOC.: A.TS. 21	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
COORDINATES X=1017.0 Y=1586.0 Z=238.0	(PER 325-1974 DEF.)								
INSTALL (Y/M):	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
INSTALL. NEPS BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF. EXEMPT: N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378D38, 1364-4480 FLOW DIAG. CAR-2165G-805 (F-4)				REVISION # DATE SYSTEM: CHEMICAL & VOLUME CONTROL TAG: 2CS-V585A-1		
QUALIF. STATUS	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DWG REF: CAR-2165G-145	RADIATION	R							
PHYS DWG LUCI M-5	AGING	A							
MOUNTING	SURMERGED	S							
EDUC. LUCI W. P.O. 173662	FSAR ENH CAT: 19580 CATEG. 1								
	APPENDIX E								



1000



1000



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO: ZCS-V586 SB-1	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIMES
EQUIPMENT: VALVE TYPE	ITY	NORMAL		REVIEW				
	NORM/TEST	1 YEAR POST						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	DBA	DBA						
	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MANUFACTURER: WESTINGHOUSE LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
	MAJOR SUPPLIER							SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				
FUNCTION: SERVING VALVE & SERVICE ZCS-V586 SB-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
ACCUM. SPEC: N/A	R GAMMA	2.5 E4		FSAR FIG. 3.11B-				
ACCUM. DEM.: N/A	A BETA	NEGL.		RAD. ZONE R7				
	D SHIELD	100% BETA						
SPECIFICATIONS: GEN. E-SPEC. 678852, R2	T.I.D.	2.6 E4						
P.O. #189234 CND # 1	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
PLANT LOC.: AB.21	(PER 323-1974 DEF.)							
COORDINATES X=1547.0 Y=1595.0 Z=237.0	SUBMERGED	1910"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIFI:
 STATUS:
 PHYS DNG HFF: CAR-2165G-140
 PHYS DNG LUCI: D-13
 MOUNTING:
 EV. DUC. LUCI: w/ P.O. 189234

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
SAH ENV CAT:	
10500 CATEG.:	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DNG. E73-054-S, 136A-46739
 FLOW DIAG. CAR-2165 G-805 (J-16)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM CONTROL VOLUN CONTROL
 TAG: ZCS-V586 SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/MI	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: 2CS-V587 SA-1	OPERABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW					ACCEL TIMES
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS
MODEL AND SERIAL #: SMTB-00 266-125	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTIONS: SERVING VALVE & SERVICE 2CS-V587 SA-1	R GAMMA A BETA D SHIELD T.I.D.	8.9 E 4 NEGL. 100% BETA 1.89 E 5		FSAR FIG. 3.11B- RAD. ZONE RS					SAFETY FUNCTIONS
ACCUM. SPEC: N/A	AGE INST LIFE (PER 323- 1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					
ACCUM. DEM.: N/A	BURNEGED	191'0"	N/A	FSAR SECT. 3.6	N/A				AUTH. REFERENCE
SPECIFICATIONS: PROJ.-E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	INSTALL. DATE: 173662 CND # 1								
P.O. # 173662 CND # 1	PLANT LOC.: A.B-21								
COORDINATES X=1495.0 Y=1595.0 Z=247.0	OTHER EQUIPMENT THIS CES APPLIES TO:								
QUALIF. EXEMPT: N/A	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE								
QUALIFI	REVISION # 1								
STATUS	DATE								
PHYS DNG HFF: CAR-2165 G-140	SYSTEM (CHEMICAL VOLUME CONTROL)								
PHYS DNG LUC: K-8	TAG								
MOUNTING									
EW.DUC.LUC: W. P.O. 173662									
APPENDIX E									


REFERENCES:

VENDOR DWG. 8376D29, 1364-4485
 FLOW DIAG. CAR-2165 G-805 (I-11)

TAG: 2CS-V587 SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. H/MI UITS		ACCEL TIME	
	PARAMETER	ACTUAL		ACTUAL	QUALIF. METHOD	ITEMS			
TAG NO: 2CS-V588 SB-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW					
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMPI	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL # SMT3-00 262122	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 2CS-V588 SB-1	R GAMMA	8.9E4		FSAR FIG. 3.11B-					
ACCUM. SPEC: N/A	A BETA	NEGL.		RAD. ZONE RS					
ACCUM. DEM.: N/A	D SHIELD	100% BETA		10 CFR 50 PARAGRAPH 50.51					
SPECIFICATIONS: GEN. E-SPEC. 952065, R5 678852, R2	AGE - INST LIFE	40 YEARS (PER 325-1979 DEF.)						SAFETY FUNCTION	
P.O. # 173662 CND # 1	SURGE	191'0"	N/A	FSAR SECT. 3.6	N/A				
PLANT LOC. 1ATB 21								AUTH. REFERENCE	
COORDINATES X= 1502.0 Y= 1595.0 Z= 247.0									
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
QUALIF. EXEMPT: BY FIELD N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. 8376D29, 1364-4485 FLOW DIAG. CAR-21659-805 (J-11)				REVISION # DATE SYSTEM: CHEMICAL CONTROL TAG: 2CS-V588 SB-		
QUALIF. STATUS	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG HFF: CAR-21659-140	AGING	A							
PHYS DNG LIC: K-9	SURGE	S							
MOUNTING:	ISAR ENV CAT: 10500 CATEG. 1								
EDUC. LUC: P.O. 173662	APPENDIX E								



A/LE EDASCO SERVICES INC.
 UTILTY CAROLINA POWER & LIGHT

FACILITY: SHEARDII HARNES 110.1
 COMPONENT EVALUATION SHEET

19881 WESTINGHOUSE - PWH
 CAPACITY: 900 MW(E)

NEV-10
 CESD-

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/W/ UITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2CS-V589 SA-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENTS
MAINT. ALTERNATE LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL # SMTB-00 266923	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2CS-V589 SA-1	R GAMMA	8.9E4	FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	NEGL.	RAD. ZONE RS			
ACCUM. DEM.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: GEN. E-SPEC. 952065, RS 678852, R2	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. #173662 CND # 1	BURNEGED	1910"	FSAR SECT. 3.6	N/A		
PLANT LOC. 1A.B.21						
COORDINATES X=1518.0 Y=1576.0 Z=247.0						AUTH. REFERENCE:

INSTALLED (Y/II):
 INSTAL. KEYS BY FIELD
 QUALIF EXEMPT: N/A
 QUALIFI:
 STATUS:
 PHYS DWG REF: CAR-2165G-140
 PHYS DWG LUCI: K-10
 MOUNTING:
 EV.DUC.LUCI: W.P.O. 173662

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 BURNEGED S
 FSAR ENV CAT: 1988 CATEG. 1

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DWG. 8376D29, 1364-4485
 FLOW DIAG. CAR-2165G-805 (K-11)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM CHEMICAL VOLUME CONTROL

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2CS-V590SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	ITY	NORMAL					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	NORM/TEST	1 YEAR POST					REPLACEMENT
MANUFACTURER: LIMITORQUE	DBA	DBA					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			SUBCOMPONENTS
MODEL AND SERIAL: SMB-00 266926	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			
FUNCTION: SERVING VALVE & SERVICE 2CS-V590SB-1	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
ACCUM. DEM.: N/A	R GAMMA	8.9 E4		FSAR FIG.			
SPECIFICATIONS: PROJ. E-SPEC. 952065, RS GEN. E-SPEC. 678852, R2	A BETA	NEGL.		13.11B-			
P.O. #173662 CND #1	D SHIELD	100% BETA		RAD. ZONE			
PLANT LOC.: A.B. 21	T.I.D.	11.89E5		RS			SAFETY FUNCTION
COORDINATES X-1525.0 Y-1576.0 Z-247.0	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			
INSTALL (Y/N):	(PER 323-1979 DEF.)						
INSTAL. MFP: BY FIELD	SURMERGED	191±0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIFI	OPERABILITY	O	REFERENCES: VENDOR DWG. 8376D29, 136A-4485 FLOW DIAG. CAR-2165G-805 (K-11)				REVISION # DATE
STATUS	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
PHYS DWG MFP: CAR-2165G-140	RADIATION	R					
PHYS DWG LIC: K-11	AGING	A					
MOUNTING	SURMERGENCE	S					
EQ. DOC. LUC: W.P.O. 173662	ISAN ENV CAT:						
	1958B CATEG.						
	APPENDIX E						
							SYSTEM: CHEMICAL VOLUME CONTROL
							TAG: 2CS-V590SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M	UNITS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: 2CS-V600SB-1	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	4	5	6	7	ACCEL TIME
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS
MODEL AND SERIAL: SMTB-00-10 193362	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 2CS-V600SB-1	R GAMMA	18.9 E4		FSAR FIG. 3.11B-					
ACCUM. SPEC: N/A	A BETA	NEGL.		RAD. ZONE IRS					
ACCUM. DEN.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS: GEN. E-SPEC. 952065, RS 678852, R2	T.I.D.	11.89 E5							
P.O. #: 189234 CND # 1	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTION
PLANT LOC.: AB. 21	(PER 323-1979 DEF.)								
COORDINATES X= 1493.0 Y= 1592.0 Z= 247.0	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A				AUTH. REFERENCE
INSTALLED (Y/M):									
QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF. STATUS	OPERABILITY	O		REFERENCES: VENDOR DRAWING. E73-054S, 1364-46739 FLOW DIAG. CAR-2165G-805 (H-7)				REVISION # 1 DATE	
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG HFF: CAR-2165G-140	AGING	A							
PHYS DNG LUC: I-8	SURMERGENCE	S							
MOUNTING									
EDUC. LUC: w/ P.O. 189234	ISAN ENV CAT: 10500 CATEG. 1								
	APPENDIX E								
								SYSTEM CONTROL	
								TAG 12CS-V600SB-	




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M	UNIT	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO 12CS-V601SB-1	OPERABILITY	40 YEARS		OPERABILITY					ACCEL TIME	
	ITY	NORMAL		REVIEW						
EQUIPMENT: VALVE	NOHM/TEST	1 YEAR POST							ACCEL TEMP	
TYPE	DBA	DBA								
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM.		FSAR TABLE					REPLACEMENT	
		104°F DBA		9.4.0-1						
				FSAR FIG.						
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM.		FSAR SECT.					MAINTAIN.	
		DBA NORM.								
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM.		FSAR TABLE					SUBCOMPONENTS	
		100% DBA		9.4.0-1 NORM.						
MODEL AND SERIAL #				FSAR SECT.						
SMB-00-10				3.11.3 (DBA)						
193360	CHEMICAL SPRAY	N/A		FSAR SECT.						
FUNCT. USE: SERVING VALVE & SERVICE				3.11-						
2CS-V601SB-1										
ACCUM. SPEC: N/A	R GAMMA	18.9 E4		FSAR FIG.						
	A BETA	NEGL.		3.11B-						
	D SHIELD	100% BETA		RAD. ZONE						
	T.I.D.	1.89 ES		RS						
ACCUM. DEM.: N/A	ACC-INST LIFE	40 YEARS		10 CFR 50					SAFETY FUNCTIONS	
	(PER 323-1979 DEF.)			PARAGRAPH 50.51						
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	SURGEHEAD	191'0"	N/A	FSAR SECT. 3.6	N/A					
P.O. # 189234 CND # 1										
PLANT LOC. 1A.B.21										
COORDINATES X= 1516.0 Y= 1591.0 Z= 247.0									AUTH. REFERENCES	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTALL. NEPT BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DRAWING E73-0545 136A-46739 FLOW DIAG. CAR-2165G-805 (I-7)					REVISION # DATE SYSTEM CONTROL TAG 12CS-V601SB-1		
QUALIF EXEMPT: N/A	TEMPERATURE	T								
QUALIFI	PRESSURE	P								
STATUS	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
	RADIATION	R								
	AGING	A								
	SURMERGENCE	S								
PHYS DNG HFF: CAR-2165-G140	SAF ENV CAT									
PHYS DNG LUC: L-10	19588 CATEG.									
MOUNTING	APPENDIX E									
EV. DUC. LUC: w/ P.O. 189234										



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. N/A/MI UNITS		ACCEL TIMES	
	PARAMETER	ACTUAL	DEN.	QUALIF.	ACTUAL	DEN. QUALIF.		METHOD
TAG NO: RCS-VG03 SA-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMPS
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENTS
MAINT. ALTERNATE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS:
MODEL AND SERIAL: SP-00 269841	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE RCS-VG03 SA-1	R GAMMA	18.9 E4			FSAR FIG. 13.11.5-			
ACCUM. SPEC: N/A	A BETA	NEGL.			RAID. ZONE			
ACCUM. DEN.: N/A	D SHIELD	100% BETA			RS			
SPECIFICATIONS: GEN. E-SPEC. 952065, R5 678852, R2	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. #173662 CHD #1	SURMERGED	191'0"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES
PLANT LOC.: A.T.B. 21								
COORDINATES X=1495.0 Y=1575.0 Z=247.0								

INSTALLED (Y/N): INSTAL. MFP: BY FIELD QUALIF. EXEMPT: N/A QUALIFI: STATUS: PHYS DNG MFP: CAR-2165-G-140 PHYS DNG LUCI: M-8 MOUNTING: EN.DUC.LUCI: W.P.O. 173662	PARA-METER: OPERABILITY TEMPERATURE PRESSURE REL. HUMIDITY CHEM. SPRAY RADIATION AGING SURMERGENCE FSAR ENY CAT: 1958 CATEG.: APPENDIX E	SUPPL. REVIEW: O T H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: VENDOR DWG. 8376D92, 1364-4481 FLOW DIAG. CAR-2165G-805 (I-6)	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM CONTROL VOLUME: TAG: RCS-VG03 SA
--	---	---	--	--



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	M/M	UNIT	ITEMS
	PARAMETER	ACTUAL	DEN.	QUALIF.				
TAG NO: 2CS-V604-SB-1	OPERABIL- ITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1-NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL: SB-00 265404	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 2CS-V604-SB-1	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 NEGL. 100% BETA 11.89ES			FSAR FIG. 3.11B- RAD. ZONE RS			
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
ACCUM. DEN.: N/A PROJ. E-SPEC. 952065, R5 SPECIFICATIONS: GEN. E-SPEC. 678852, R2	BURMEGED	191'0"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES
P.O. #173662 CND # 1								
PLANT LOC.: A.T.B. 21								
COORDINATES X= 1502.0 Y= 1575.0 Z= 247.0								

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIFI:
 STATUS:
 PHYS DNG HFF: CAR-21659-140
 PHYS DNG LUC: M-9
 MOUNTING:
 EDUC. LUC: W.P.O. 173662

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 BURMEGENCE S
 FSAR ENY CAT: 19580 CATEG. 1
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DWG. 8376D92,
 1364-4481
 FLOW DIAG. CAR-21659-805 (3-6)

QUALIFICATION SIGNATURE
 FOUND IN DOCUMENTATION
 PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: CHEMICAL CONTROL
 TAG: 2CS-V604-SB



2
3

4

5

6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



101



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/A	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO: 2CS-VG05 SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW					ACCEL TIME	
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT	
MAINT ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS	
MODEL AND SERIAL: SB-00 265410	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-						
FUNCTION: SERVING VALVE & SERVICE 2CS-VG05 SA-1	R GAMMA	8.9 E4		FSAR FIG. 3.11B-						
ACCUM. SPEC: N/A	A BETA	NEGL.		RAD. ZONE RS						
ACCUM. DEM.: N/A	D SHIELD	100% BETA								
SPECIFICATIONS: PROJ. E-SPEC. 952065, RS GEN. E-SPEC. 678852, RZ	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTIONS	
P.O. #: 173662 CND # 1	BURNED	191'0"	N/A	FSAR SECT. 3.6	N/A					
PLANT LOC.: A.TS. 21									AUTH. REFERENCE	
COORDINATES X-1518.0 Y-1575.0 Z-247.0										
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
INSTAL. REF: BY FIELD	OPERABILITY	O								
QUALIF. EXEMPT: N/A	TEMPERATURE	T								
QUALIF:	PRESSURE	P								
STATUS:	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
	RADIATION	R								
	LACTIG	A								
	EMERGENCY	S								
PHYS DNG REF: CAR-2165 G-140	FSAR ENV CAT: 19580 CATEG. 1									
PHYS DNG LUCI: M-10	APPENDIX E									
MOUNTING:										
ED. DUC. LUCI: W.P.O. 173662										
			REFERENCES:				REVISION # 1			
			VENDOR DRAWING 8376D92, 1364-448.1				DATE			
			FLOW DIAG. CAR-2165 G-805 (J-6)				SYSTEM: CHEMICAL CONTROL			
							TAG: 2CS-VG05 SA-1			




103



104





EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M/OUTS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2CS-V609SB-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NOISE TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #: SMTB 000 279714	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2CS-V609SB-1	R GAMMA	2.0E4	FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	7.2E4	RAD. ZONE TR6			
ACCUM. DEM.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: GEN. E-SPEC. 952065, R5	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. # 173662 CND # 1	(PER 323-1979 DEF.)					
PLANT LOC.: A.B. 21	SUBMERGED	191'0"	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
COORDINATES X=1455.0 Y=1641.0 Z=236.0						

INSTALLED (Y/N):
 INSTAL. MPTS BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS DNG EFFICAR 2165G 14-0
 PHYS DNG LICIG-5
 MOUNTING:
 EW.DUC.LUC: N.P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
ISAR ENY CAT	
19500 CATEG.	
APPENDIX E	


OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:

VENDOR TAG. 8378D38, 1364-4480
 FLOW DIAG. CAR 2165 G803 (B-13)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

REVISION #:
 DATE:
 SYSTEM: CHEMICAL CONTROL
 TAG: 2CS-V609SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: RCS-VG10 SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		5		ACCEL TIME	
EQUIPMENT: VALVE TYPE	TEMPERATURE	NORMAL						ACCEL TEMP	
	DBA	1 YEAR POST DBA							
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL: SMB 000 279711	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE RCS-VG10SA-1	R GAMMA	2.0 E4		FSAR FIG. 3.11B-					
ACCUM. SPEC: N/A	A BETA	7.2 E4		RAD. ZONE RG					
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS: PROJ. E-SPEC. 952065.R5 GEN. E-SPEC. 678852.R2	T.I.D.	3.0 E4							
P.O. # 173662 END # 1	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION	
PLANT LOC.: ATB Z1	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
COORDINATES X=1457.0 Y=1642.0 Z=236.0									
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTAL. MFG: BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. B378D38, 1364-4480 FLOW DIAG. CAR 2165 G803 (B-17)						
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIFI	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG MFG: CAR 2165 G140	AGING	A	REVISION #				DATE		
PHYS DNG LIC: G-5	SURMERGENCE	S							
MOUNTING	ISAR ENV CAT						SYSTEM (CHEMICAL & VOLUME CONTROL		
EDUC. LUC: W P.O. 173662	19580 CATEG.						TAG RCS-VG10 SA-1		
	APPENDIX E								

81

62

11

12


13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: 2CS-VG11SB-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL #: SMD 00 19371	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 2CS-VG11SB-1	R GAMMA A BETA D SHIELD T.I.D.	2.5E4 NEGL. 100% BETA 2.6E4		FSAR FIG. 3.11B- RAD. ZONE R7				SAFETY FUNCTIONS	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					
ACCUM. DEN.: N/A	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES	
SPECIFICATIONS: P.O. # 173662 END # 1 PLANT LOC.: ATB C1 COORDINATES X=1530.0 Y=1576.0 Z=250.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTALLED (Y/M): INSTAL. MFP: BY FIELD QUALIF. EXEMPT: N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378D38, 1364-4480 FLOW DIAG. CAR2165 9805 (M-5)				REVISION # : DATE : SYSTEM CONTROL VOLUME CONTROL TAG 2CS-VG11SB-1		
QUALIF. STATUS	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
PHYS DNG MFP: CAR2165 9140 PHYS DNG LIC: M-1G MOUNTING : EQUIP. LOC: W.P.O. 173662	SURMERGENCE	S							
	FSAR ENY CAT: 19500 CATEG. 1								
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: 2CS-V636SA-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.		REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-		
FUNCTION: SERVING VALVE & SERVICE 2CS-V636SA-1	R GAMMA	7.7E3			FSAR FIG. 3.11B-		
ACCUM. SPEC: N/A	A BETA	NEGLIGIBLE			RAD. ZONE RIS		
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS: PROJ. E-SPEC. 678959.R2 GEN. E-SPEC. 678844.R2	T.I.D.	8.7E3					
P.O. #183642 CND #1	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTIONS
PLANT LOC.: A-B.31	EMERGENCY	191'0"	N/A		FSAR SECT. 3.6	N/A	
COORDINATES X=1603.0 Y=1621.0 Z=271.0		YES					AUTH. REFERENCES
INSTALLED (Y/M): INSTAL. NEP: BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. E-167329, 1364-2733 FLOW DIAG. CAR 21GS 4804 (G-15)			REVISION # DATE SYSTEM: CHEMICAL & VOLUME CONTROL TAG: 2CS-V636SA-1	
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS. DRG. EFFICAR 21GS 4157	RADIATION	R					
PHYS. DRG. LUCI MOUNTING	AGING	A					
EN. DUC. LUCI w/ P.O. 183642	EMERGENCY	S					
	1958 CATEG. I						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/W UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2CS-V636SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2CS-V636SA-1	R GAMMA	7.7E3		FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	NEGLIGIBLE		IRAD. ZONE			
ACCUM. DEM.: N/A	D SHIELD	100% BETA		IRIS			
SPECIFICATIONS: PROJ. E-SPEC. 678959,R2 GEN. E-SPEC. 678844,R2	AGE - INST LIFE (PER 325-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. # 183642 CND # 1	SURGE	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
PLANT LOC.: AB-31	YES						
COORDINATES X=1603.0 Y=1621.0 Z=271.0							
INSTALLED (Y/N): INSTAL. NEPS BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. E-167329 1364-2733 FLOW DIAG. CAR 21659804 (9-15)			REVISION #: DATE: SYSTEM: CHEMICAL VOLUME CONTROL TAG: 2CS-V636SA-1	
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	TAGGING	A					
	EMERGENCY	S					
PHYS. ENG. OFFICAR 21659157 PHYS. DNG. LUCI MOUNTING EQU. DUC. LUCI by P.O. 183642	1958 CATEG. 1 APPENDIX E						

2025

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M OUS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: 2CS-V637SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTIONS: SERVING VALVE & SERVICE 2CS-V637SB-1	R GAMMA	17.7E3		FSAR FIG. 3.11B-				
ACCUM. SPEC: N/A	A BETA	NEGLIGIBLE		RAD. ZONE				
ACCUM. DEN.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 678959,RZ GEN. E-SPEC. 678844,RZ	*T.I.D.	18.7 E3						
P.O #: 183642 CND # 1	AGE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
PLANT LOC.: A.TB.31	INST LIFE (PER 523-1974 DEF.)							
COORDINATES X= 1603.0 Y= 1621.0 Z= 271.0	BURMEGEU	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTALL. MFP: BY FIELD	OPERABILITY	O		REFERENCES: VENDOR DWG. E-167329, 1364-2733 FLOW DIAG. CAR2165 4804 (G-15)				REVISION #: DATE: SYSTEM: CHEMICAL CONTROL TAG: 2CS-V637SB-1
QUALIF. EXEMPT: N/A	TEMPERATURE	T						
STATUS:	PRESSURE	P						
	REL. HUMIDITY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG MFP: CAR2165 G157	AGING	A						
PHYS DNG LIC:	EMERGENCY	S						
MOUNTING:								
ED. DOC. LUC: w/ P.O. 183642	1950B CATEG.:							
	APPENDIX E							

A/LS BASE SERVICES INC.
 UTILTY LINE POWER & LIGHT

FACILITY: SHEARMAN & STAMM
 COMPONENT EVALUATION REPORT

11550 WESTINGHOUSE - PHN
 CAPACITY: 900 MW(E)

REV: 0
 CESD

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2CS-V637SB-1	OPERABILITY	140 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	INDM/TEST DBA	NORMAL					ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	1 YEAR POST DBA		FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	104°F NORM. 104°F DBA		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	ATMOS. NORM. DBA NORM.		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	20-90% NORM. 100% DBA		FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 2CS-V637SN-1	R GAMMA	N/A		FSAR FIG. 3.11B- RAD. ZONE TRIS			
ACCUM. SPEC: N/A	A BETA	7.7E3		10 CFR 50 PARAGRAPH 50.51			
ACCUM. DEM.: N/A	D SHIELD	NEGLIGIBLE					
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	Y.I.D.	100% BETA					
P.O. # 183642 CND # 1	ACC-	8.7E3					
PLANT LOC.: AB.31	INST LIFE (PER 325-1979 DEF.)	40 YEARS					
COORDINATES X=1603.0 Y=1621.0 Z=271.0	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A		
INSTALLED (Y/N):	PARAMETER	YES					
INSTALL. NEP: BY FIELD	OPERABILITY						
QUALIF. CRITERIA: N/A	TEMPERATURE						
QUALIFI:	PRESSURE						
STATUS:	REL. HUMIDTY						
	CHEM. SPRAY						
	RADIATION						
PHYS DNG HFF: CAR 2165 G157	TAGGING						
PHYS DNG LIC: MOUNTING	EMERGENCY						
ED. DUC. LUC: w/P.O. 183642	19500 CATEG. APPENDIX E						

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:

VENDOR DWG. E-167329, 1364-2733
 FLOW DIAG. CAR 2165 G 804 (G-15)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE

REVISION #:
 DATE:

SYSTEM: CHEMICAL CONTROL
 TAG: 2CS-V637SB-1

SAFETY FUNCTIONS:

AUTH. REFERENCE:

12/10


A/LI BASE SERVICES INC.
 UTILTY INHA POWER & LIGHT

FACILITY: SHEARON MI NO. 1
 COMPONENT EVALUATE SET


1950 WESTINGHOUSE - PWH
 CAPACITY: 900 MW(E)

REV-
 CE90-

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: 2CS-V759 SB-1	OPERABILITY	140 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	INDHM/TEST DBA	1 YEAR POST DBA						ACCEL TIME
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTION: SERVING VALVE & SERVICE 2CS-V759 SB-1	R GAMMA	2.5E4		FSAR FIG. 3.11B-23				
ACCUM. SPEC: N/A	A BETA	NEG.		27				
ACCUM. DEN.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS:	T.I.D.	2.6E4						
P.O #	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
PLANT LOC.: ABZ1	(PER 323-1974 DEF.)							
COORDINATES X- Y- Z-	SUBMERGED	19150'	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INDIAL. NEP: BY FIELD	OPERABILITY			REFERENCES: FLOW DIAG. CAR 2165 9804 (N-2)				
QUALIF EXEMPT: N/A	TEMPERATURE							
QUALIF	PRESSURE							
STATUS	REL. HUMIDITY							
	CHEMICAL SPRAY							
PHYS ONG VET.								REVISION #
PHYS ONG								DATE
MOUNTING								SYSTEM
EDUC. L...	FSAR ENV CAT: 1950 CATEG. 1							CHEMICAL & VOLUME CONTROL
	APPENDIX E							TAG 2CS-V759 SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.				
TAG NO: ZCS-V758 SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT	
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS	
FUNCTION: SERVING VALVE & SERVICE ZCS-V758 SA-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
ACCUM. SPEC: N/A	R GAMMA	2.5E4		FSAR FIG. 3.11B-23				
ACCUM. DEM.: N/A	A BETA	NEGL.		RAD. ZONE R7				
SPECIFICATIONS:	D SHIELD	100% BETA						
P.O. #: CND #:	T.I.D.	2.6E4						
PLANT LOC.: AB 21	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS	
CORORDINATES X- Y- Z-	BURNEGED	19150"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES	
INSTALLED (Y/M):								
INSTAL. NEPS BY FIELD								
QUALIF. EXEMPT: N/A								
QUALIFI:								
STATUS:								
PHYS DNG VTT:								
PHYS DNG TUC:								
MOUNTING:								
EDUC. LUC:								
	PARA- METER							
	SECURITY							
	RELATIVE HUMIDTY	N						
	CHEMICAL SPRAY							
	RADIATION	R						
	TAGING	A						
	BURNEGMENT	S						
	FSAR EHV CAT:							
	1958 CATEG.:							
	APPENDIX E							
OTHER EQUIPMENT THIS CES APPLIES TO:							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
REFERENCES: FLOW DIAG. CAR 2165 4804 (N-2)							REVISION #:	
							DATE:	
							SYSTEM: CHEMICAL (VOLUME CONTROL)	
							TAG: ZCS-V 758 SA-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2CS-V757 SA-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	INDM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MAINT ACTION: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCT. USE: SERVING VALVE & SERVICE 2CS-V757 SA-1	R GAMMA	2.5 EC	FSAR FIG. 3.11B-23			
ACCUM. SPEC: N/A	A BETA	NEGL.	RAD. ZONE R7			
ACCUM. DEN.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS:	• T.I.D.	2.6 EC				
P.O. NO: CND # 1	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A,B,21	(PER 525-1979 DEF.)					
COORDINATES X-Y-Z	EMERGENCY	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES

QUALIF. CRITERIA:
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDTY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 EMERGENCY S
 FSAR ENV CAT: 1958 CATEG. APPENDIX E

SUPPL. REVIEW:
 OTHER EQUIPMENT THIS CES APPLIED TO:
 REFERENCES: FLOW DIAG. CAR 2659804 (N-2)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION # 1
 DATE
 SYSTEM: CHEMICAL CONTINUAL
 TAG: 2CS-V757 SA




1942
11
*

11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: ZCS-V760 SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MAINT ALUMINIUM LIMITORQUE	PRESSURE	INT. NORM. INT. NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-10% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE ZCS-V760 SA-1	R GAMMA	2.5E4		FSAR FIG. 3.11B-23			
	A BETA	NEGL.		RAD. ZONE RT			
	D SHIELD	100% BETA					
	TYP D.	2.6E4					
SPECIFICATIONS:	EST. LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. #	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A		
PLANT LOC. #							AUTH. REFERENCE
COORDINATES X- Y- Z-							
INSTALLED (Y/M)	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTAL. NEPT BY FIELD	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G804(N-2)				
QUALIF EXEMPT: N/A	TEMPERATURE	T					
QUALIF	PRESSURE	P					
STATUS	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	FACING	A					REVISION #
PHYS DNG HFT	SURMERGENCE	S					DATE
PHYS DNG LUCI							SYSTEM (CHEMICAL & VOLUME CONTROL)
MOUNTING	FSAR ENV CAT						TAG
EW.DUC.LUCI	19580 CATEG. D						ZCS V760 SA-1
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.			
TAG NO: 2CS-L520 SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST	NORMAL 1 YEAR					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	DBA	POST DBA					REPLACEMENT
MANUFACTURER: LIMITORQUE	TEMPERATURE	104° F NORM 4 DBA		FSAR TABLE FSAR FIG.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM 4 DBA					SUBCOMPONENTS
MODEL AND SERIAL: SMB 000 265022	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					
ACCUM. SPEC: N/A	R GAMMA	2.7 EG		FSAR FIG. 3.11B-24			
ACCUM. DEM.: N/A	A BETA	NEGLIGIBLE		CONT. RAD. ZONE R 14			
SPECIFICATIONS: GEN. E-SPEC. 952065, R5 678852, RZ	D SHIELD	100% BETA					
P.O. # 173662 CND # 1	T.I.D.	2.8 EG					
PLANT LOC.: AB 24	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
COORDINATES X= 1543.0 Y= 1596.0 Z= 263.0	(PER 323-1974 DEF.)						
INSTALLED (Y/N):	SUBMERGED	191.0 YES					AUTH. REFERENCES
INSTALL. REF: QUALIF EXEMPT:	PARA-METER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF:	OPERABILITY	O	REFERENCES: VENDOR DWG. 1364-4531				
STATUS:	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DWG REF: CAR 2165 9140	RADIATION	R				REVISION #	
PHYS DWG LUCI B-9	AGING	A				DATE	
MOUNTING:	SUBMERGENCE	S				SYSTEM: CHEMICAL VOLUME CONT.	
EV. DOC. LUCI w/ P.O. 173662	ISAH ENV CAT:	A				TAG: 2CS L520 SA-1	
	19588 CATEG.:						
	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2CS L521 SB-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104° F NORM & DBA	FSAR TABLE FSAR FIG.			REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. & DBA				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL: SMB-00 265025	CHEMICAL SPRAY	N/A				
FUNCTIONS & SERVICE	R GAMMA	2.7 EG	FSAR FIG.			
ACCUM. SPEC: N/A	A BETA	NEGLIGIBLE	3.11B-24			
ACCUM. DEM: N/A	D SHIELD	100% BETA	CONT. RAD.			
SPECIFICATIONS: PROJ. E-SPEC. 952065, RS GEN. E-SPEC. 678852, RZ	T.I.D.	2.8 EG	ZONE R 14			
P.O #: 173662 CND # 1	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
PLANT LOC.: AB 24	(PER 323-1974 DEF.)					
COORDINATES X-1546-0 Y-1596-0 Z-263-0	SUBMERGED	191-0 YES				AUTH. REFERENCE
INSTALLED (Y/N): INSTAL. NEFT: QUALIF EXEMPT: QUALIF: STATUS: PHYS DRG REF: CAE-2165 G140 PHYS DRG LUC: B-9 MOUNTING: ED. DUC. LUC: w/ P.O. 173662	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
	OPERABILITY	O	REFERENCES: VENDOR DWG. 1364-4531			REVISION #: DATE:
	TEMPERATURE	T				SYSTEM: CHEMICAL (VOL. CONTROL)
	PRESSURE	P				TAG: 2CS L521 SB-1
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
	AGING	A				
	SUBMERGENCE	S				
	FSAR ENV CAT:	A				
	1958 CATEG.:					
	APPENDIX E					



100

100

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2CS-L522SB-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	INDHM/TEST	1 YEAR POST DBA						ACCEL TEMP
	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4	M		REPLACEMENT
COMPONENT: MOTOR OPERATOR	PRESSURE	ATMOS. NORM. DBA NORM.				M	NONE	MAINTEN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	M		SUBCOMPONENTS LIMIT TORQUE SW.
MODEL AND SERIAL: SM8-00 266918	CHEMICAL SPRAY	N/A.			FSAR SECT. 3.11-	M		
FUNCTIONS: SERVING VALVE & SERVICE 2CS-L522SB-1, SEE TAB B	R GAMMA	2.5 E 4			FSAR FIG. 3.11B-23			
ACCUM. SPEC: N/A	A BETA	NEGLECTIBLE			ZONE R7	H		
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 078852, R2	T.I.D.	2.6 E 4						
P.O. #173662 CND #1	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC: ABZ1	(PER 325-1979 DEF.)							
COORDINATES X=1521.0 Y=1574.0 Z=248.3	SURVEYED	1910"	N/A		FSAR SECT. 3.6		N/A	AUTH. REFERENCES
	YES							
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTAL. MFR: BY FIELD	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 805 (K-12) VENDOR TAG. 8376229, 1364-4485				REVISION # DATE	
QUALIF. EXEMPT: N/A	TEMPERATURE	T						
QUALIF. STATUS	PRESSURE	P						
	REL. HUMIDITY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG MFR: CAR 2165 G 140	RADIATION	A						
PHYS DNG LIC: N-10	EMERGENCY	S						
MOUNTING	ISAN ENH CAT						SYSTEM CONTROL VOLUME CONTROL	
EDUC. LUC: W P.O. 173662	19580 CATEG.						TAG 12CS L522SB-1	
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO 2CS-L523 SA-1	OPERABIL- ITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA			FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-4		M	REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.		M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		M	SUBCOMPONENTS: LIMIT & TORQUE SW.
MODEL AND SERIAL: SMTB-00 266921	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-		M	
FUNCTION: SERVING VALVE & SERVICE 2CSL523 SA-1, SEE TABS	R GAMMA A BETA D SHIELD T.I.D.	2.5 E4 INEGLIGIBLE 100% BETA 2.6 E4			FSAR FIG. 3.11B- RAD. ZONE 1R7		H	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	SURMERGED	191'-0" YES	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2								
P.O. # 173662 CND # 1								
PLANT LOC.: AE 21								
COORDINATES X= 1499.0 Y= 1573.0 Z= 248.3								

INSTALLED (Y/M):
 INSTAL. NEFI BY FIELD
 QUALIF EXEMPT: N/A
 QUALIFI
 STATUS
 PHYS DNG EFFICAR 2165 G140
 PHYS DNG LUCI N-9
 MOUNTING
 EV.DUC.LUCI P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENCE	S
ISAR ENV CAT: 19500 CATEG. 1	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 FLOW DIAG. CAR 2165 G805 (J-12)
 VENDOR DWG. 8376D29, 1364-4485

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:
 REVISION # :
 DATE :
 SYSTEM CONTROL
 TAG 2CS L522 SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UNIT	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.				
TAG NO: 2CC-VIG9SA-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	TEMPERATURE	NORMAL						ACCEL TEMP
	NORM/TEST DBA	1 YEAR POST DBA						REPLACEMENT
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			MAINTENANCE
	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			SUBCOMPONENTS
MAINTAINERS: LIMITORQUE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			
MAJOR SUPPLIER: WESTINGHOUSE	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
MODEL AND SERIAL #	R GAMMA	2.0E4			FSAR FIG. 3.11B-			
FUNCTION: SERVING VALVE & SERVICE 2CC-VIG9SA-1	A BETA	7.2E4			RAD. ZONE RG			
	D SHIELD	100% BETA						
ACCUM. SPEC: N/A	T.I.D.	3.0E4						
ACCUM. DEM.: N/A	AGE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	INST LIFE							
P.O. # 189267 CND # 1	EMERGED	191'0"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES
PLANT LOC. 1 A.7B 21								
COORDINATES X= 1558.0 Y= 1654.0 Z= 255.0								

INSTALLED (Y/N):
 INSTAL. MFP: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG MFP: CAR2165G123
 PHYS DNG LUCI: E-17
 MOUNTING:
 EV. DUC. LUCI: W.P.O. 189267

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
EMERGED	A
EMERGENCY	S
ISAN ENV CAT:	
1958 CATEG.:	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DWG. 678852, R2
 1364-3022
 FLOW DIAG. CAR 2165 G821 (E-1)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: COOLING
 TAG: 2CC-VIG9SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M UNITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: 2CC-V170 SB-1	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIME	
EQUIPMENT: VALVE TYPE	ITY	NORMAL		REVIEW					
	NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM.		FSAR TABLE				REPLACEMENT	
	URE	104°F DBA		9.4.0-1 FSAR FIG.					
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE		DBA NORM.						SUBCOMPONENTS	
	MODEL AND SERIAL #	SMTB-00-10							
FUNCT. USE: SERVING VALVE & SERVICE 2CC-V170 SB-1	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE					
				9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A		FSAR SECT.					
ACCUM. DEM.: N/A	R GAMMA	12.0E4		FSAR FIG.					
	D BETA	17.2E4		3.11B- RAD. ZONE					
SPECIFICATIONS:	D SHIELD	100% BETA		RG					
	T.I.D.	13.0E4							
P.O. # 189267 CND # 1	AGE - INST LIFE	40 YEARS		10 CFR 50				SAFETY FUNCTION	
PLANT LOC.: A.TB.21	(PER 323-1974 DEF.)			PARAGRAPH					
				50.51					
COORDINATES X=1559.0 Y=1661.0 Z=236.0	EMERGENCY	191'0"	N/A	FSAR SECT.	N/A			AUTH. REFERENCE	
				3.6					
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTAL. MFP: BY FIELD	OPERABILITY	O	REFERENCES:						
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIF. STATUS	PRESSURE	P	VENDOR DWG. 88724-2-S, 1364-3022 FLOW DIAG. CAR 2165G821(F-1)				REVISION # : DATE :		
	REL. HUMIDITY	H							
	CHEM. SPRAY	C					SYSTEM COMPONENT COOLING		
	RADIATION	R							
PHYS DNG MFP: CAR 2165G 123	AGING	A					TAG : 2CC-V170 SB-1		
PHYS DNG LUCI: E-1G	EMERGENCY	S							
PHYS DNG MOUNTING :	FSAR ENY CAT:								
EN.DUC.LUCI: W.P.O. 189267	1958 CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M UITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: 2CC-V172 SB-1	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIMES	
EQUIPMENT: VALVE TYPE	ITY	NORMAL		REVIEW				ACCEL TEMP	
	NOHM/TEST	1 YEAR POST						REPLACEMENT	
COMPONENT: MOTOR OPERATOR	DBA	DBA						MAINTAIN.	
	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				SUBCOMPONENTS	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					
	MAJOR SUPPLIER	WESTINGHOUSE							
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					
	FUNCTION: SERVING VALVE & SERVICE	2CC-V172 SB-1							
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
	ACCUM. DEN.: N/A								
SPECIFICATIONS:	R GAMMA	2.0E4		FSAR FIG. 3.11B-					
	A BETA	7.2E4		RAD. ZONE					
P.O. #189267 CND #1	D SHIELD	100% BETA		IRG				SAFETY FUNCTION	
	T.I.D.	3.0E4							
PLANT LOC.: A.P.-11	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51					
	(PER 323-1974 DEF.)								
COORDINATES X= 1534.0 Y= 1637.0 Z= 230.0	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
	INSTALL (Y/N):								
INSTALL. MFP: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. 88724-2-5, 1364-3022 FLOW DIAG. CAR 2165 G 821 (D-3)				REVISION # : DATE : SYSTEM COMPONENT : COOLING TAG : 2CC-V172 SB-1		
QUALIF:	TEMPERATURE	T							
STATUS:	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG MFP: CAR 2165 G 123	AGING	A							
PHYS DWG LUCI N-3	SUBMERGENCE	S							
MOUNTING:	ISAH ENV CAT:								
EN. DUC. LUCI: W.P.O. 189267	1958 CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	EQUIPMENT PARAMETER		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	UNITS	ITEMS
	ACTUAL			ACTUAL	DEN. QUALIF.				
TAG NO: 2CC-V182 SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW					ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST	1 YEAR POST							ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS
MODEL AND SERIAL #: SMB-00-10	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 2CC-V182 SB-1	R GAMMA	2.0 E4		FSAR FIG. 13.11B-					
ACCUM. SPEC: N/A	A BETA	7.2 E4		RAD. ZONE 1RG					
ACCUM. DEN.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	T.I.D.	3.0 E4							
P.O. #: 189267 END # 1	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTION
PLANT LOC.: A.B. 21	(PER 323-1979 DEF.)								
CORRDINATES X=1538.0 Y=1640.0 Z=245.0	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A				AUTH. REFERENCE
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTAL. NEPI BY FIELD	OPERABILITY	O		REFERENCES: VENDOR DWG. 88724-2-S, 1364-3022 FLOW DIAG. CAR 2165 G-821 (B-10)				REVISION # : DATE : SYSTEM COMPONENT COOLING TAG : 2CC-V182 SB-1	
QUALIF EXEMPT: N/A	TEMPERATURE	T							
QUALIF:	PRESSURE	P							
STATUS:	REL. HUMIDTY	H							
:	CHEM. SPRAY	C							
:	RADIATION	R							
PHYS DWG HFF: CAR 2165 G123	AGING	A							
PHYS DWG LUCI G-15	SURMERGENCE	S							
MOUNTING:	FSAR ENH CATI								
EV.DUC.LUCI: W.P.O.189267	19500 CATEG.								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M UITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: 2CC-V183 SB-1	OPERABIL- ITY	140 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG.				REPLACEMENT	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE 232	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL #: SMB-00-10	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 2CC-V183 SB-1	R GAMMA A BETA D SHIELD T.I.D.	2.0 E4 17.2 E4 100% BETA 13.0 E4		FSAR FIG. 13.11B- RAD. ZONE 1R6					
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
ACCUM. DEM.: N/A PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	BURMEGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
SPECIFICATIONS: P.O. # 189267 CND # 1 PLANT LOC. 1 AB 21 COORDINATES X= 1562.0 Y= 1666.0 Z= 245.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTALLED (Y/M): INSTAL. NEFI BY FIELD QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: VENDOR DRAWING 88724-2-5, 1364-3022 FLOW DIAG. CAR 2165 G 821 (E-12)				REVISION # 1 DATE		
QUALIF:	TEMPERATURE	T							
STATUS:	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DNG HFF: CAR 2165 G-123 PHYS DNG LUC: E-17 MOUNTING: EV. DUC. LUC: W.P.O. 189267	RADIATION TAGING BURMEGMENT ISAR ENV CAT: 1958 CATEG. I APPENDIX E	R A S					SYSTEM COMPONENT COOLING TAG: 2CC-V183 SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.
TAG NO: ZCC-V184SA-1	OPERABILITY	40 YEARS NORMAL	40 YEARS NORMAL	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 11.4.2	5	6	7	ACCEL TIME: 15092 HOURS
EQUIPMENT: VALVE GATE	NORM/TEST DBA	1 YEAR POST DBA	1 YEAR POST DBA						ACCEL TEMP: 180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST 4 SUPP. REVIEW	H	NONE	REPLACEMENT: 40 YEARS
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	REPORT 600450, PAGE 14	COMB. TYPE TEST 6 SUPP. REVIEW	H	NONE	MAINTAIN.
MAJOR SUPPLIER: WESTHS.		FSAR FIG. 3.11.8-1 FOR DBA	70 PSIG DBA	3.11.6-1 (DBA)	SRS TABLE PAGE 2B				SUBCOMPONENTS: LIMIT & TORQUE SW.
MODEL AND SERIAL: SMB-00-10 212765	RELATIVE HUMIDITY	40% NORM 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SECT. 4.4.3 PAGE 18	COMB. TYPE TEST 5 SUPP. REVIEW	H	SEE TAB 2 PAGE 1E	
FUNCTIONS: COMP. COOLING & SERVICE SERVING VALVE ZCC-V184SA-1	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	3000 PPM BORON PH 10.5-11.1	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	COMB. TYPE TEST 4 SUPP. REVIEW	H	NONE	
ACCUR. SPEC: N/A	R GAMMA A BETA	1.2 EG 3.3 EG	130 EG 74 EG	FSAR APP 3.11.8-20 CONT. RAD. ZONE C3	TEST REPORT SECT. 4.3 PAGE 12	COMB. TYPE TEST 4 SUPP. REVIEW	H	SEE TAB E PAGE 1G	
ACCUR. DEM.: N/A	D SHIELD	100% BETA	100% BETA		SRS TABLE PAGE 1G THRU 3G				
SPECIFICATIONS: W. PROJ. SPEC. 952065 05 & E. SPEC. 678852 02	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 301.1 PAGE 3	COMB. TYPE TEST 4 SUPP. REVIEW		SEE TAB E PAGE 1F	SAFETY FUNCTIONS: SEE TAB "B" OF HE-1
P.O. #: 189267 CHD # 15N. #095?	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A				
PLANT LOC.: C.B. 21		YES			SRS TABLE PAGE 1A	N/A		NONE	AUTH. REFERENCE: M. J. H.
COORDINATES X- 1555.0 Y- 1671.0 Z- 247.0									
INSTALLED (Y/M):									
INSTALL. REF: BY FLD.	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1	
QUALIF EXEMPT: N/A	OPERABILITY	O	HE-1	REFERENCES: FLOW DIAG. CAR-2165 G-821 LIMITORQUE TEST REPORT 600450				REVISION # : 0 DATE: 14-21-84 SYSTEM: COMP. COOLING WATER TAG: ZCC-V184SA-1	
QUALIF: QUALIFIED, AWAITING	TEMPERATURE	T							
STATUS: CONFIRMATORY DATA	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DMG REF: CAR-2165 G-120	DAGING	A							
PHYS DMG LUC: TOTAL EQUIP LIST	SURMERGENCE	S							
MOUNTING:									
EDUC. LUC: BY PO. 189267	FSAR ENV CAT:	A							
	10588 CATEG.:								
	APPENDIX E:								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M	OUTS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO: ZCC-V190 SB-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW					ACCEL TIME	
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP	
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT	
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS	
MODEL AND SERIAL: SDBM-00-15 5897	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-						
FUNCTION: SERVING VALVE & SERVICE ZCC-V190 SB-1	R GAMMA	2.0E4		FSAR FIG. 3.11B-						
ACCUM. SPEC: N/A	A BETA	7.2E4		RAD. ZONE						
ACCUM. DEM.: N/A	D SHIELD	100% BETA		RG						
SPECIFICATIONS: GENE-SPEC. 67885Z,R2 PROJ.-E-SPEC. 952065,R5	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTIONS	
P.O. #189267 CND # 1	PLANT LOC.: A.B. 21									
COORDINATES X=1549.0 Y=1648.0 Z=255.0	EMERGENCY	191'0"	N/A	FSAR SECT. 3.6	N/A				AUTH. REFERENCE	
INSTALLED (Y/M): INSTAL. NEP: BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG 88532-2-S, 1364-3023 FLOW DIAG. CAR2165 G821 (E-15)				REVISION #: DATE: SYSTEM COMPONENT COOLING TAG: ZCC-V190 SB-1			
	TEMPERATURE	T								
	PRESSURE	P								
	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
	RADIATION	R								
	AGING	A								
	EMERGENCY	S								
PHYS DWG HFF: CAR 2165 G123 PHYS DWG LIC: F-10 MOUNTING: EDUC. LUC: W/ P.O. 189267	FSAR ENV CATE 19500 CATEG. APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL					DEH. QUALIF.
TAG NO: <i>2CC-V191SA-1</i>	OPERABILITY	40 YEARS NORMAL	40 YEARS NORMAL	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25	TYPE TEST	NONE	ACCEL TIME: 15092 HOURS	
EQUIPMENT TYPE: <i>VALVE GATE</i>	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 1.4.0-1 FSAR FIG. 3.11.4-1	SRS TAB E PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TEMP: 180°C	
COMPONENT: <i>MOTOR</i>	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	NONE	REPLACEMENT: 40 YEARS	
MAINT. ACTION: <i>LIMITORQUE</i>	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 1.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 4.4.3 PAGE 18 SRS TAB E PAGE 1E	COMB. TYPE TEST & SUPP. REVIEW	NONE	MAINTAIN.	
MAJOR SUPPLIER: <i>WESTHS.</i>	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	3000 PPM BORON PH 10.5-11.1	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17 SRS TAB E PAGE 1D	COMB. TYPE TEST & SUPP. REVIEW	NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.	
MODEL AND SERIAL: <i>SMB-00-15</i>	R GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-20	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	NONE	SEE TAB E PAGE 1G	
FUNCTION: <i>COMP. COOLING & SERVICE SERVING VALVE 2CC-V191SA-1</i>	U SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TAB D P. 1G THRU 3G				
ACCUR. SPEC: <i>N/A</i>	AGE - INST LIFE (PER 325-1979 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3 SRS TAB E PAGE 1F THRU 3F	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE TAB "B" OF HE-1	
ACCUR. DEH.: <i>N/A</i>	SUBMERGED	228.3	N/A	FSAR SECTION 3.6	N/A				
SPECIFICATIONS: <i>W. PROJ. SPEC. 952065.05 KE. SPEC. 678852.02</i>		YES			SRS TAB E PAGE 1A			AUTH. REFERENCE: M.J.H.	
P.O. # <i>189267</i> CHD # <i>158#0959</i>									
PLANT LOC.: <i>C.B. 21</i>									
COORDINATES: <i>X-1542.0 Y-1655.0 Z-255.0</i>									
INSTALLED (Y/M):									
INSTAL. REF: <i>BY FLD.</i>									
QUALITY EXEMPT: <i>N/A</i>	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE (HE-1)		
QUALIF: <i>QUALIFIED, AWAITING CONFIRMATORY DATA</i>	OPERABILITY	O HE-1	REFERENCES: <i>FLOW DIAG. CAR-2165 G-821</i> <i>LIMITORQUE TEST REPORT 600456</i>				REVISION # : 0 DATE : 14-21-84 SYSTEM : <i>COMP COOLING WATER</i> TAG : <i>2CC-V191SA-1</i>		
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: <i>CAR-2165 G-120</i>	AGING	A							
PHYS DNG LUC: <i>TOTAL EQUIP. LIST</i>	SUBMERGENCE	S							
HOUSING: <i>W.P.O. 189267</i>	SAR ENV CAT:								
EV. DOC. LUC:	OSOR CATEG. 1A								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	UNITS	
	PARAMETER	ACTUAL					
TAG NO: 3CC-B5 SA-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 19.4.0-1 FSAR FIG.				REPLACEMENT
MAINT. ALTERNATE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL: SB-1 204528	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-				
FUNCT. USE: SERVING VALVE & SERVICE 3CC-B5 SA-1	R GAMMA A BETA D SHIELD T.I.D.	2.5 E4 NEGL. 100% BETA 2.6 E4	FSAR FIG. 3.11B- RAD. ZONE R7				
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
ACCUM. DEM.: N/A PROJ. E-SPEC. 952075, R1 GEN. E-SPEC. 678846, R1	BURNEGED	191'0"	FSAR SECT. 3.6	N/A			AUTH. REFERENCE
SPECIFICATIONS: P.O. #178282 CND #1 PLANT LOC.: A.B.21 COORDINATES X= 1422.0 Y= 1547.0 Z= 252.0							

QUALIF. EXEMPT	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
N/A	OPERABILITY	O		
	TEMPERATURE	T		
	PRESSURE	P		
	REL. HUMIDITY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
	AGING	A		
	BURNEGED	S		
	1958 CATEG. 1			
	APPENDIX E			

REFERENCES:
 VENDOR DWG. F-42247, 1364-298(A)
 FLOW DIAG. CAR2165 G819 (H-3)

REVISION #:
 DATE:
 SYSTEM: COOLING
 TAG: 3CC-B5 SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M UTILITY ITEMS	
	PARAMETER	ACTUAL		ACTUAL	QUALIF.			
TAG NO: 3CC-BG SB-1	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIME:
	ITY	NORMAL		REVIEW				
EQUIPMENT: VALVE	NOHM/TEST	1 YEAR POST						ACCEL TEMPO:
TYPE	DBA	DBA						
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM.		FSAR TABLE				REPLACEMENT:
	URE	104°F DBA		9.4.0-1				
				FSAR FIG.				MAINTAIN:
MAINT. ALTERNATE: LIMITORQUE	PRESSURE	ATMOS. NORM.		FSAR SECT.				SUBCOMPONENTS:
		DBA NORM.						
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM.		FSAR TABLE				
		100% DBA		9.4.0-1 NORM.				
MODEL AND SERIAL # 218446				FSAR SECT.				
FUNCTION: SERVING VALVE	CHEMICAL SPRAY	N/A		3.11.3 (DBA)				
& SERVICE 3CC-BG SB-1				FSAR SECT.				
				3.11-				
ACCUM. SPEC: N/A	R GAMMA	2.5 E4		FSAR FIG.				
	A BETA	NEGL.		3.11B-				
ACCUM. DEM.: N/A	D SHIELD	100% BETA		RAD. ZONE				
	T.I.D.	2.6 E3		R7				
SPECIFICATIONS: GEN. E-SPEC. 952075, R1	AGE	40 YEARS		10 CFR 50				SAFETY FUNCTIONS:
	INST LIFE			PARAGRAPH				
	(PER 323-1979 DEF.)			50.51				
P.O. # 178282 CND # 1	SURMERGED	191'0"	N/A	FSAR SECT.	N/A			
PLANT LOC.: A.TS. 21				3.0				AUTH. REFERENCE:
COORDINATES X=1556.0 Y=1547.0 Z=249.0								

INSTALLED (Y/II):
 INSTAL. MFP: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG MFP: CAR 2165 G 124
 PHYS DNG LIC: G-16
 MOUNTING:
 EQ. DUC. LUC: W.P.O. 178282

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENCE	S
1950B CATEG.	
API ENVI E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:

VENDOR DWG. F-42247, 136A-2786
 FLOW DIAG. CAR 2165 G 819 (I-3)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE

REVISION #:
 DATE:
 SYSTEM COMPONENT COOLING
 TAG: 3CC-BG SB

A/E: SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARWATER
 COMPONENT EVALUATION

NO. 1
 SHEET

ISSUE: WESTINGHOUSE - PWH
 CAPACITY: 900 MW(E)

REV: 0
 CES:

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M UIDS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO: 3CC-B19SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIMES
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL: SB-1 218447	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTION: SERVING VALVE & SERVICE 3CC-B19SA-1	R GAMMA	2.5E4		FSAR FIG. 3.11B-				
ACCUM. SPEC: N/A	A BETA	NEGL.		RAD. ZONE R7				
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: 678846, R1	T.I.D.	2.6E4						
P.O. #: 178282 CWD # 1	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
PLANT LOC.: AB. 21	BURNISHED	1910"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES
COORDINATES X-1479.0 Y-1551.0 Z-251.0								

INSTALLED (Y/N):
 INSTAL. MFR: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DWG MFR: CAR 2165 G124
 PHYS DWG LUC: G-9
 MOUNTING:
 ED. DUC. LUC: W.P.O. 178282

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
EMERGENCY	S
SAFETY CAT:	
1958 CATEG.:	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 VENDOR DWG. F-42247, 1364-2986
 FLOW DIAG. CAR 2165 G819 (F-16)

QUALIFICATION SIGN-OFF:
 FOUND IN DOCUMENTATION PACKAGE:

REVISION #:
 DATE:
 SYSTEM: COOLING
 TAG: 3CC-B19SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/M UTS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DOC. QUALIF.				
TAG NO: 3CC-B20 SB-1	OPENABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMPI	
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT	
MAINT ACTION: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL: SM2-00 218448	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTION: SERVING VALVE & SERVICE 3CC-B20 SB-1	R GAMMA A BETA D SHIELD T.I.D.	2.5E4 NEGL. 100% BETA 12.6E4		FSAR FIG. 3.11B- RAD. ZONE R7					
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION	
ACCUM. DEM.: N/A PROJ. E-SPEC. 952075, R1 GEN. E-SPEC. 678846 R1	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE	
SPECIFICATIONS: P.O. # 178282 END # 1 PLANT LOC.: A-B-21 COORDINATES X= 1498.0 Y= 1552.0 Z= 251.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTALLED (Y/N): INSTAL. NEP: BY FIELD QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. F-42247, 1364-2986 FLOW DIAG. CAR 2165 G 819 (9-16)				REVISION # DATE SYSTEM COMPONENT COOLING TAG 3CC-B20 SB-1		
STATUS	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DNG HFF: CAR-2165 G124 PHYS DNG LUCIG-4 MOUNTING EV.DUC.LUCI W.P.O. 178282	IRRADIATION RAGING SURMERGENCE	R A S							
	19588 CATEG.								
	API ENUX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: 3CC-LISA-1	OPERABIL- ITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED TYPE VALVE	NDHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERAT- URE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 3CC-LISA-1	R GAMMA A BETA D SHIELD T.I.D.	1.0E4 7.2E4 100%BETA 3.0E4	FSAR FIG. 3.11B- RAD. ZONE REG			
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1978 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	BURNEGED	1910" YES	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 952067,RZ GEN. E-SPEC. 678845,R1	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:		QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
P.O. # 191003 CND	OPERABILITY	O	REFERENCES: VENDOR DWG. C102861, 1364-3345 FLOW DIAG. CAR 2165 9822 (A-G)		REVISION # DATE SYSTEM COMPONENT COOLING TAG 3CC-LISA-1	
PLANT LOC.: A.B. 21	TEMPERATURE	T				
CORORDINATES X= 1519.0 Y= 1619.0 Z= 239.0	PRESSURE	P				
INSTALLED (Y/M):	REL. HUMIDTY	H				
INSTALL. MFP: BY FIELD	CHEM. SPRAY	C				
QUALIF EXEMPT: N/A	RADIATION	R				
QUALIF:	DAGING	A				
STATUS:	EMERGENCY	S				
19588 CATEG.: C	APPENDIX E					



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 3CC-L2SB-1	OPENABIL-ITY	140 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIMES
EQUIPMENT: AIR OPERATED VALVE	NDHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 3CC-L2SB-1	R GAMMA A BETA D SHIELD T.I.D.	2.0E4 7.2E4 100% BETA 3.0E4		FSAR FIG. 13.11B- RAD. ZONE 17C			
ACCUM. SPEC: N/A	ACC. INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	SUBMERGED	1910° YES	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
SPECIFICATIONS: PROJ. E-SPEC. 952067, R2 GEN. E-SPEC. 67884-5, R1							
P.O. # 191003 CND							
PLANT LOC. 1A.B.21							
COORDINATES X=1520.0 Y=1620.0 Z=239.0							

INSTALLED (Y/M):
 INSTAL. NEPS BY FIELD
 QUALIF. EXEMPT: N/A
 STATUS:
 PHYS DNG HFF: CAR 2165 G123
 PHYS DNG LIC: D-7
 MOUNTING:
 ED. DUC. LUC: w/ P.O. 191003

PARA-METER
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 SUBMERGENCE S
 1958 CATEG.: C
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR Dwg. SD-C-102861
 1364-3345
 FLOW DIAG. CAR 2165 G822 (B-G)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: COMPONENT COOLING
 TAG: 3CC-L2SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 3CC-L25B-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	MTY	NORMAL					
	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM.		FSAR TABLE 9.4.0-1			REPLACEMENT
	URE	104°F DBA		FSAR FIG.			
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM.		FSAR SECT.			MAINTAIN.
		DBA NORM.					SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM.		FSAR TABLE 9.4.0-1 NORM.			
MODEL AND SERIAL #		100% DBA		FSAR SECT. 3.11.3 (DBA)			
FUNCTIONS: SERVING VALVE & SERVICE 3CC-L25B-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
ACCUM. SPEC: N/A	R GAMMA	2.0E4		FSAR FIG. 3.11B-			
ACCUM. DEM.: N/A	A BETA	7.2E4		RAD. ZONE TRG			
	D SHIELD	100% BETA					
SPECIFICATIONS: PROJ. E-SPEC. 952067, R2 GEN. E-SPEC. 678845, R1	• T.I.D.	3.0E4					
	AGE- EST. LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. # 191003 CND # 1	SURMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A		
PLANT LOC.: A.B.21		YES					AUTH. REFERENCES
COORDINATES X= 1520.0 Y= 1620.0 Z= 239.0							
INSTALLED (Y/11):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. NEP: BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG SD-C-102861 1364-3345 FLOW DIAG. CAR-21654822 (B-C)				REVISION # : DATE :
QUALIF. EXEMPT: N/A	TEMPERATURE	T					
QUALIFI:	PRESSURE	P					
STATUS	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
PHYS DWG HFF: CAR2165 G123	SURMERGENCE	S					
PHYS DWG LIC: D-7							
MOUNTING:							
EV. DUC. LUC: w/ P.O. 191003	19588 CATEG.: C						
	APPENDIX E						
							SYSTEM COMPONENT COOLING
							TAG 3CC-L25B-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/MI OUTS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: 3CC-V165SA-1	OPENABIL-ITY	140 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG.				REPLACEMENT
MAINT ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL: SMB-00-10 5991	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTIONS: SERVING VALVE & SERVICE 3CC-V165SA-1	R GAMMA A BETA D SHIELD T.I.D.	2.5E4 NEGL. 100% BETA 2.6E4		FSAR FIG. 3.11B-				
ACCUM. SPEC: N/A	AGE - INST LIFE (PER 325-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
ACCUM. DEN.: N/A	SURVEGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 952065, RS GEN. E-SPEC. 678852, R2								
P.O. # 189267 CND # 1								
PLANT LOC.: A.B.21								
COORDINATES X= 1428.0 Y= 1567.0 Z= 238.0								

INSTALLED (Y/M):
 INSTAL. METH: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG MFF: CAR 2165 G 124
 PHYS DNG LUC: E-4
 MOUNTING:
 EN. DUC. LUC: W.F.O. 189267

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
IRRADIATION	R
AGING	A
EMERGENCY	S
1950 CATEG. 1 APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DRAWING 83816-S,
 1364-3059
 FLOW DIAG. CAR 2165 G 820 (A-7)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
 REVISION #:
 DATE:
 SYSTEM: COMPONENT COOLING.
 TAG: 3CC-V165SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 3CC-V167SB-1	OPENABILITY	40 YEARS			OPERABILITY			ACCEL TIMES
	ITY	NORMAL			REVIEW			
EQUIPMENT: VALVE	NORM/TEST	1 YEAR POST						ACCEL TEMP
TYPE	DBA	DBA						
COMPONENT: MOTOR	TEMPERATURE	104°F NORM.			FSAR TABLE			REPLACEMENT
OPERATOR		104°F DBA			9.4.0-1			
					FSAR FIG.			
MAINTAINERS: LIMITORQUE	PRESSURE	ATMOS. NORM.			FSAR SECT.			MAINTAIN.
		DBA NORM.						
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM.			FSAR TABLE			SUBCOMPONENTS
MODEL AND SERIAL #		100% DBA			9.4.0-1 NORM.			
SMT3-00-10 218929					FSAR SECT.			
FUNCTION: SERVING VALVE	CHEMICAL SPRAY	N/A			3.11.3 (DBA)			
& SERVICE: 3CC-V167SB-1					FSAR SECT.			
					3.11-			
ACCUM. SPEC: N/A	R GAMMA				FSAR FIG.			
	A BETA				3.11B-			
ACCUM. DEM.: N/A	D SHIELD				RAD. ZONE			
PROJ. E-SPEC. 952065, R5	. T.I.D.				R7			
GEN. E-SPEC. 678852, R2	AGE	40 YEARS			10 CFR 50			SAFETY FUNCTIONS
SPECIFICATIONS:	INST LIFE				PARAGRAPH			
P.O. # 189267 CND # 1	(PER 323-1979 DEF.)				50.51			
PLANT LOC.: A.B.21	BURMEGED	19150"	N/A		FSAR SECT.	N/A		
					3.6			AUTH. REFERENCES
COORDINATES X=1552.0 Y=1567.0 Z=238.0								

INSTALLED (Y/H):
 INSTAL. NEFI BY FIELD
 QUALIF. CRAMPING: N/A
 QUALIF:
 STATUS:
 PHYS DNG HFFI CAR 2165 G124
 PHYS DNG LIC1 E-16
 MOUNTING:
 EN. DUC. LUC: W.P.O. 189267


PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 IMAGING A
 EMERGENCY S
 10500 CATEG. 1
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 VENDOR DWG. 83816-S, 1364-3059
 FLOW DIAG CAR 2165 G 820 (B-7)

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

REVISION #:
 DATE:
 SYSTEM COMPONENT
 COOLING
 TAG: 3CC-V167SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H UNITS	ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: HYDROGEN RECOMBINER 1A-SA	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME:
EQUIPMENT TYPE	NDHM/TEST DBA	1 YEAR					ACCEL TEMP:
COMPONENT: HYDROGEN RECOMBINER	TEMPERATURE	120°F NORM 385°F FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT:
MANUFACTURER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)			MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE STURDAVANT DIVISION	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS: POWER SUPPLY & CONTROL PANEL
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.3 E7 3.7 E8 100% BETA 1.3 E7		FSAR APP. 3.11.8 CONT. RAD. ZONE CG			
ACCUR. SPEC: N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE TAB "B", SP-1
ACCUR. DEH.: N/A	SUBMERGED	228.3 YES		FSAR SECTION 3.6			AUTH. REFERENCE: M.J.H.
EQPT. SPEC. 679012721 SPECIFICATIONS: PROJ. SPEC. N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: SP-1	
P.O. # 217308 CND #	OPERABILITY	O SP-1	REFERENCES: EQUIP. QUAL. DATA PKG. EQDP-SP-1			REVISION # : DATE :	
PLANT LOC.: C.D.	TEMPERATURE	T					
COORDINATES X=	PRESSURE	P					
Y=	REL. HUMIDTY	H					
Z= 286.0	CHEM. SPRAY	C					
INSTALLED (Y/N):	RADIATION	R.					
INSTAL. REF: BY FIELD	AGING	A					
QUALIF EXEMPTN: NO	SUBMERGENCE	S					
*****	FSAR ENV CAT:	A					
*****	0588 CATEG.:						
*****	APPENDIX E						
PHYS DNG REF: CAR 2166 G 453							
PHYS DNG LUC:							
MOUNTING : FLOOR							
EQ. DUC. LUC: W/ P.O. 217308						SYSTEM : HYDROGEN CONT. (RECOMBINER) TAG : 1A-SA	

A/E: EPASCO SERVICES INC.
UTIL: IOLINA POWER & LIGHT

FACILITY: SHEARON HARTIS NO.1
COMPONENT EVALUATION: SET

HSSS: WESTINGHOUSE - PHW
CAPACITY: 900 MW(E)

REV: 0
TES:

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: HYDROGEN RECOMBINER 1B-SB	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME:
EQUIPMENT TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA				ACCEL TEMP:
COMPONENT: HYDROGEN RECOMBINER	TEMPERATURE	120° F NORM 1385° F FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT:
MANUFACTURER: WESTINGHOUSE STURDAVANT DIVISION	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.6-1 (DBA)			MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS: POWER SUPPLY CONTROL PANEL
MODEL AND SERIAL # A (EHRS) 59	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
FUNCTIONS: SEE SP-1, TAB "B" & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.3 E7 3.7 E8 100% BETA 1.3 E7	FSAR APP. 3.11.8 CONT. RAD. ZONE CG			
ACCUR. SPEC: N/A	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE TAB "B", SP-1
ACCUR. DEM.: N/A	SUBMERGED	228.3 YES	FSAR SECTION 3.61			AUTH. REFERENCE: M.J.H.
EQPT. SPEC. 679012R2 SPECIFICATIONS: PROJ. SPEC. N/A	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
P.O #: 217308 CND # :	OPERABILITY	O	REFERENCES: EQUIP. QUAL. DATA PKG. EQDP-SP-1			
PLANT LOC.: C.B.	TEMPERATURE	T				
COORDINATES X- Y- Z- 286.0	PRESSURE	P				
INSTALLED (Y/N): INSTAL. REF: BY FIELD QUALIF EXEMPTN: NO	REL. HUMIDTY	H				
PHYS DMG REF: CAR2166 453	CHEM. SPRAY	C				
PHYS DMG LUCI MOUNTING: FLOOR	RADIATION AGING	R A				
EQ. DUC. LUCI: Y RD. 217308	SUBMERGENCE	S	REVISION # : DATE :			
	FSAR ENV CAT: A 0588 CATEG.:	A	SYSTEM: HYDROGEN CONT. (RECOMBINER)			
	APPENDIX E		TAG: 1B-SB			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS	ITEMS
	PARAMETER	ACTUAL					
TAG NO: PT ICT 0950	OPERABILITY	40 YEARS	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT SENSOR TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: PRESS. XMTR.	TEMPERATURE	104° F NORM 104° F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5		M		REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. 4 DBA			M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS
MODEL AND SERIAL #: 752	CHEMICAL SPRAY	N/A			M		
FUNCTIONS: CONTAINMENT & SERVICE PRESSURE	R GAMMA	2.5 E4	FSAR FIG. 3.11B-24		H		
	A BETA	4.4 E5	CONT. RAD. ZONE RII				
	D SHIELD	100% BETA					
	T.I.D.	2.6 E4					
ACCUM. SPEC: N/A	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
ACCUM. DEM.: N/A	(PER 323-1974 DEF.)						
SPECIFICATIONS: E. SPEC 953333, R0 PROJECT SPEC. N/A	SUBMERGED	191-0 YES	FSAR SECT. 3.6				AUTH. REFERENCE
P.O. # 404835 CND # 1 SH. 185	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
PLANT LOC.: AB 31	OPERABILITY	O	REFERENCES:				
COORDINATES X- Y- Z- 265'6	TEMPERATURE	T					
INSTALLED (Y/II):	PRESSURE	P					
INITIAL. KEPI BY FIELD	REL. HUMIDTY	H					
QUALIF EXEMPT: N/A	CHEM. SPRAY	C					
QUALIF STATUS	RADIATION	R		REVISION #			
	AGING	A		DATE			
	SUBMERGENCE	S		SYSTEM: CONTAINMENT SPRAY			
PHYS DNG REFICAR2166G436 S05	FSAR ENV CAT: 10588 CATEG. D	D		TAG: PT ICT 0950			
PHYS DNG LUCI G-7	APPENDIX E						
MOUNTING:							
EN. DUC. LUCI R.O. 404835							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: PT ICT 0951	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR				ACCEL TEMP
COMPONENT: PRESS. XMTR.	TEMPERATURE	104°F NORM 104°F DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-5		M	REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. 4 DBA			M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL #: 752	CHEMICAL SPRAY	N/A			M	
FUNCTIONS: CONTAINMENT & SERVICE PRESSURE	R GAMMA	2.5 E4	FSAR FIG. 3.11B-24		H	
ACCUM. SPEC: N/A	A BETA	4.4 E5	CONT. RAD. ZONE RII			
ACCUM. DEM.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: E. SPEC 953333, R0 PROJECT SPEC. N/A	T.I.D.	2.6 E4				
P.O. # W404835CND # 1 SH. 185	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: AB 31	(PER 323-1978 DEF.)					
COORDINATES X- Y- Z- 265'6	SUBMERGED	191-0 YES	FSAR SECT. 3.6			AUTH. REFERENCE
INSTALLED (Y/M):	RARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTALL. NEP: BY FIELD	OPERABILITY	O	REFERENCES:			
QUALIF. EXEMPT: N/A	TEMPERATURE	T				
QUALIF. STATUS	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
PHYS DNG NEP: CAR 2166 G436 S05	ACTING	A				REVISION #
PHYS DNG LIC: G-8	SUBMERGENCE	S				DATE
MOUNTING						SYSTEM CONTAINMENT SPRAY
EDUC. LUC: W P.O. 404835	FSAR ENV CAT: 10500 CATEG. 1	D				TAG: PT ICT 0951
	APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: PT ICT 0952	OPERABILITY	40 YEARS			OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR					ACCEL TEMP
COMPONENT: PRESS. XMTR.	TEMPERATURE	104°F NORM 104°F DBA			FSAR TABLE 19.4.0-1 FSAR FIG. 13.11B-5	M	REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. 14 DBA				M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	M	SUBCOMPONENTS
MODEL AND SERIAL: 752	CHEMICAL SPRAY	N/A				M	
FUNCTIONS: CONTAINMENT & SERVICE PRESSURE	R GAMMA	2.5 E4			FSAR FIG. 13.11B-24		
	A BETA	4.4 ES			CONT. RAD. ZONE R11	H	
	D SHIELD	100% BETA					
	T.I.D.	2.6 E4					
ACCUM. SPEC: N/A	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTION
ACCUM. DEM.: N/A	(PER 323-1974 DEF.)						
E. SPEC 95333, R0	SUBMERGED	191-0			FSAR SECT. 13.6		
SPECIFICATIONS PROJECT SPEC. N/A	YES						AUTH. REFERENCE
P.O. # 404835CND # 1 SH. 185	PARAMETER		SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
PLANT LOC.: AB 31	OPERABILITY		O	REFERENCES:			
COORDINATES X=	TEMPERATURE		T				
Y=	PRESSURE		P				
Z= 265'6"	REL. HUMIDTY		H				
	CHEM. SPRAY		C				
	RADIATION		R				
INSTALLED (Y/N):	AGING		A		REVISION #		
INSTAL. KEPI BY FIELD	SUBMERGENCE		S		DATE		
QUALIF EXEMPT: N/A	ISAR ENV CAT:				SYSTEM CONTAINMENT SPRAY		
QUALIF:	10588 CATEG.:	D			TAG		
STATUS:	APPENDIX E				PT ICT 0952		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS	ITEMS
	PARAMETER	ACTUAL					
TAG NO: PT-ICT 0953	OPERABILITY	40 YEARS	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT SENSOR TYPE	INDM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: PRESS. XMTR.	TEMPERATURE	104°F NORM 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5		M		REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. 4 DBA			M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			M		
FUNCTIONS: CONTAINMENT & SERVICE PRESSURE	R GAMMA	2.5 E4	FSAR FIG. 3.11B-24				
ACCUM. SPEC: N/A	A BETA	4.4 E5	CONT. RAD. ZONE R11		H		
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
E. SPEC 95333, R0	T.I.D.	2.6 E4					
SPECIFICATIONS: PROJECT SPEC. N/A	AGE		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
P.O. # 404835CHD # 1 SH. 185	INST LIFE (PER 323-1979 DEF.)	40 YEARS					
PLANT LOC.: AB 31	SURMERGED	191-0 YES	FSAR SECT. 3.6				AUTH. REFERENCE
COORDINATES X- Y- Z- 265'6							
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
INITIAL. NEF: BY FIELD	OPERABILITY	O	REFERENCES:				
QUALIF. EXEMPT: N/A	TEMPERATURE	T					
QUALIF. STATUS	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A				REVISION #	
PHYS DNG NEF: CAR2166G436 SOS	SURMERGENCE	S				DATE	
PHYS DNG LUC: D-17						SYSTEM CONTAINMENT SPRAY	
MOUNTING:	ISAH ENV CAT:					TAG	
ED. DUC. LUC: P.O. 404835	10588 CATEG.					PT-ICT 0953	
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION	N/A	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL				DEM.
TAG NO: LT-1FW474	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT	COMB. TYPE		ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	ITY	NORMAL			REVIEW	TEST & SUPP.		NONE	
COMPONENT: LEVEL XMTR.	NORM/TEST DBA	1 YEAR	16.5 MO.		FSAR TABLE	REVIEW		ACCEL TEMP: 125 °C	
MANUFACTURER: BARTON	TEMPERATURE	120 °F NORM	104 °F NORM.		FSAR TABLE	TEST REPORT		REPLACEMENT: 5.99 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA		FSAR FIG. 3.11.4-1	TEST REPORT		MAINTAIN: O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM.	TEST REPORT		SUBCOMPONENTS: O-RINGS & CONNECTORS	
		FSAR FIG. 3.11.8-1 FOR DBA	80 PSIA DBA		FIG. 3.11.6-1 (DBA)	TEST REPORT			
	RELATIVE HUMIDITY	40% NORM.	100% DBA		FSAR TABLE	TEST REPORT			
		100% DBA	100% DBA		FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT			
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON		FSAR SECT. 3.11.5.1	TEST REPORT			
		PH 8.5-11.0	PH 10.7			TEST REPORT			
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	168.10 EG		FSAR FIG. 3.11.20	TEST REPORT			
ACCUM. DEM.: N/A	A BETA	3.3 EG	174.38 EG		CONT. RAD. ZONE C3	TEST REPORT			
	D SHIELD	100% BETA	100% BETA			TEST REPORT			
	T.I.D.	1.2 EG				TEST REPORT			
	AGE		5.99 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT		SAFETY FUNCTION: SEE ESE-3A, TAB D	
	INST LIFE (PER 323-1974 DEF.)	40 YEARS				TEST REPORT			
	SURMERGED	228.3				TEST REPORT			
		YES	N/A			TEST REPORT			
	COORDINATES X=1454.0 Y=1709.0 Z=236.0					TEST REPORT			
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-3A		
INITIAL. KEFI BY FIELD	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 9044				REVISION # 10 DATE 6-21-84 SYSTEM FEED WATER TAG LT-1FW474		
QUALIF EXEMPT: N/A	TEMPERATURE	T							
QUALIFI REQUIRES ANALYSIS	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG KEFI CAR 2165 G451	AGING	A							
PHYS DNG LUCI INSTRUMENT LIST MOUNTING	SURMERGENCE	S							
EQU. LOC: WRO. 407118	FSAR ENV CAT: A	A							
	10588 CATEG: A	A							
	APPENDIX E								

9



2

78



70

23



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF.	H/W/OUTS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL	DEM.	
TAG NO: LT-1FW475	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY	TEST REPORT	COMB. TYPE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	ITY	NORMAL		REVIEW	SECT. 7.0 PAGE 17 THRU 20	TEST & SUPP.	NONE
	NOHM/TEST DBA	1 YEAR	6.5 MO.		SRS TAB E PAGE 1B THRU 5B	REVIEW	ACCEL TEMP: 125 °C
COMPONENT: LVL. XMTR.	TEMPERATURE	120 °F NORM.	104 °F NORM.	FSAR TABLE	TEST REPORT	COMB. TYPE	NORM. SERV. TEMP. REPLACEMENT: 5.99 YEARS
		FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA	19.4.0-1 FSAR FIG. 3.11.4-1	SECT. 5.1 PAGE 9 (10)	TEST & SUPP. REVIEW	H
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT	COMB. TYPE	MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA	180 PSIA DBA	3.11.6-1 (DBA)	SECT. 5.4 Pg. 14	TEST & SUPP. REVIEW	H
					SRS TAB E Pg. 3D	REVIEW	NONE
MODEL AND SERIAL: 764 1155	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE	TEST REPORT	COMB. TYPE	SUBCOMPONENTS: O-RINGS & CONNECTORS
FUNCT. USE: FEED WATER LVL. & SERVICE		100% DBA	100% DBA	19.4.0-1 NORM.	SECT. 5.4 Pg. 14	TEST & SUPP. REVIEW	H
				FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E Pg. 3D	REVIEW	NONE
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM	12500 PPM	FSAR SECT. 3.11.5.1	TEST REPORT	COMB. TYPE	
		PRM BORON PH 8.5-11.0	BORON PH 10.7		SECT. 6.4 Pg. 16	TEST & SUPP. REVIEW	H
ACCUR. DEM.: N/A	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT	COMB. TYPE	
	A BETA	3.3 E7	174.38 EG	CONT. RAD. ZONE C3	SECT. 5.2 Pg. 10 & 11	TEST & SUPP. REVIEW	H
SPECIFICATIONS: PROJECT SPEC. 953328, R1 WE. SPEC. DWG. 8745D45, R3	D SHIELD	100% BETA	100% BETA		SRS TAB E Pg. 1C, 2C & 3C	REVIEW	
	T.I.D.	1.2 EG					
P.O. # 407118 CHD # 1993	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT	COMB. TYPE	SAFETY FUNCTIONS: SEE ESE-3A, TAB "B"
PLANT LOC.: CB 21					SECT. 7.5 Pg. 20	TEST & SUPP. REVIEW	NONE
					SRS TAB E Pg. 1B THRU 5B	REVIEW	
COORDINATES X= 1456.0 Y= 1717.0 Z= 236.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	N/A	NONE
		YES			SRS TAB E Pg. 1E	REVIEW	AUTH. REFERENCE: M.J.H.
INSTALLED (Y/11)	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
INSTALL. REFS: BY FIELD	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 6044				REVISION # 10
QUALIF EXEMPT: N/A	TEMPERATURE	T					DATE: 16-21-84
QUALIF. REQUIRES ANALYSIS	PRESSURE	P	SYSTEM: FEED WATER				
STATUS	REL. HUMIDTY	H	TAG: LT-1FW475				
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DWG REFS: CAR 2165 G451	AGING	A					
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	SURMERGENCE	S					
EQ. DOC. LUCI W/RO. 407118	FSAR ENV CAT: 10588 CATEG. A	A					
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				
TAG NO: LT-IFW 476	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT			ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	ITY	NORMAL			REVIEW			NONE
	NORM/TEST	1 YEAR	6.5 MO.		PAGE 17 THRU 20			
COMPONENT: LVL. XMTR.	IDBA	POST DBA	POST DBA		SRS TABLE			ACCEL TEMP: 125 °C
	TEMPERATURE	120° F NORM	104° F NORM.		PAGE 18 THRU 21			
MANUFACTURER: BARTON	FSAR FIG.	3.11.4-1	420° F DBA		FSAR TABLE			REPLACEMENT: 5.99 YEARS
	FSAR FIG.	3.11.4-1	420° F DBA		TEST REPORT			
MAJOR SUPPLIER: WESTINGHOUSE	FOR DBA	3.11.4-1	420° F DBA		SECT. 5.1			
	FSAR FIG.	3.11.8-1	180 PSIA DBA		PAGE 9 & 10			
MODEL AND SERIAL: 764 1156	FOR DBA	3.11.8-1	180 PSIA DBA		SRS TABLE			
	FSAR FIG.	3.11.8-1	180 PSIA DBA		P. 10 & 3B			
FUNCTION: FEEDWATER LVL. & SERVICE	RELATIVE HUMIDITY	40% NORM.	100% DBA		TEST REPORT			
	RELATIVE HUMIDITY	40% NORM.	100% DBA		SECT. 5.1			
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM	12500 PPM		PAGE 9 & 10			
	CHEMICAL SPRAY	PRM BORON	BORON		SRS TABLE			
ACCUM. DEM.: N/A	R GAMMA	1.2 EG	168.10 MG		P. 10 & 3B			
	A BETA	3.3 EG	174.38 EG		TEST REPORT			
SPECIFICATIONS: PROJECT SPEC. 9532871, W.E. SPEC. DWG 8765D45.R.3	D SHIELD	100% BETA	100% BETA		SECT. 5.4			
	T.I.D.	1.2 EG	100% BETA		Pg. 14			
P.O. # 407118 CND # 1944	AGE	40 YEARS	5.99 YEARS		SRS TABLE			
	INST LIFE (PER 323-1979 DEF.)	40 YEARS	5.99 YEARS		Pg. 3D			
PLANT LOC.: CB 21	BURNEGED	228.3	N/A		TEST REPORT			
	BURNEGED	228.3	N/A		SECT. 5.2			
COORDINATES X=1460.0, Y=1725.0, Z=236.0	PARAMETER	OPERABILITY	TEMPERATURE		Pg. 10 & 11			
	PARAMETER	TEMPERATURE	PRESSURE		SRS TABLE			
INSTALLED (Y/II): INSTAL. NEFI BY FIELD, QUALIF. EXEMPT: N/A	PARAMETER	PRESSURE	REL. HUMIDTY		P. 10, 2C & 3C			
	PARAMETER	REL. HUMIDTY	CHEM. SPRAY		TEST REPORT			
QUALIF. REQUIRES ANALYSIS	PARAMETER	CHEM. SPRAY	RADIATION		SECT. 7.5			
	PARAMETER	RADIATION	AGING		Pg. 20			
STATUS: PHYS DWG NEFI CAR 2165 G451, PHYS DWG LUCI INSTRUMENT LIST MOUNTING	PARAMETER	AGING	BURNEGENCE		SRS TABLE			
	PARAMETER	BURNEGENCE	FSAR ENV CAT		Pg. 18 THRU 21			
EQ. DOC. LUCI W/NO. 407118	PARAMETER	FSAR ENV CAT	1958 CATEG.					
	PARAMETER	1958 CATEG.	APPENDIX E					

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:

FLOW DIAG. CAR 2165 G044

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-3A


REVISION # : 0
 DATE : 6-21-84
 SYSTEM : FEED WATER
 TAG : LT-IFW 476

SAFETY FUNCTION: SEE ESE-3A, TAB D

AUTH. REFERENCE: M.J.H.

MAINTENANCE: O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS SUBCOMPONENTS: O-RINGS & CONNECTORS

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H/OUTS ITEMS		
	PARAMETER	ACTUAL	DEN.	QUALIF.				ACTUAL
TAG NO: LT-IFW 477	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.		SRS TABLE PAGE 1B THRU 5B			ACCEL TEMP: 125°C
COMPONENT: LVL. XMTR.	TEMPERATURE	120°F NORM	104°F NORM.		FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 (10) SUPP. REVIEW	H	REPLACEMENT: 5.99 YEARS
MANUFACTURER: BARTON		FSAR FIG. 13.11.4-1 FOR DBA	420°F DBA		FSAR FIG. 13.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 (10) SUPP. REVIEW	H	MANTAIN: O-RINGS REPLACED 01 YR. CONNECTORS 03 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14 SUPP. REVIEW	H	SUBCOMPONENTS: O-RINGS & CONNECTORS
MODEL AND SERIAL: 764 1163	RELATIVE HUMIDITY	40% NORM.	100% DBA		FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.4 Pg. 14 SUPP. REVIEW	H	
FUNCTION: FEED WATER LVL. & SERVICE		FSAR FIG. 13.11.8-1 FOR DBA	80 PSIA DBA		FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D		
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM	12500 PPM		FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16 SUPP. REVIEW	H	
ACCUM. DEN.: N/A	R GAMMA	1.2 EG	168.10 EG		FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11 SUPP. REVIEW	H	
SPECIFICATIONS: PROJECT SPEC. 95328, WE. SPEC. DWG 8765D45, R3	A BETA	3.3 E7	174.38 E6		CONT. RAD. ZONE C3	SRS TABLE Pg. 1C, 2C & 3C		
P.O. # 1407118 CWD # 1995	D SHIELD	100% BETA	100% BETA					
PLANT LOC.: CB 21	Y.I.D.	1.2 EG						
COORDINATES X=1454.0 Y=1709.0 Z=236.0	AGE		5.99 YEARS		110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 TEST & SUPP. REVIEW		SAFETY FUNCTION: SEE ESE-3A, TAB 'D'
INSTALLED (Y/II):	INST LIFE (PER 323-1974 DEF.)	40 YEARS						
INSTAL. REF: BY FIELD	SURMERGED	228.3			FSAR SECTION 3.6	N/A		
QUALIF EXEMPT: N/A	YES		N/A			SRS TABLE Pg. 1E		AUTH. REFERENCE: M.J.H.
QUALIF: REQUIRES ANALYSIS	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A	
STATUS	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G044				REVISION # : 0 DATE : 16-21-84 SYSTEM : FEED WATER TAG : LT-IFW 477	
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	ICHEM. SPRAY	C						
	RADIATION	R						
PHYS DWG REF: CAR 2165 G451	AGING	A						
PHYS DWG LOC: INSTRUMENT LIST	SURMERGENCE	S						
MOUNTING	FSAR ENV CAT:	A						
EQU. DUC. LOC: W70.407118	10588 CATEG.:	A						
	APPENDIX E							



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO: LT-IFW 484	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY	TEST REPORT			
	ITY	NORMAL		REVIEW	SECT. 7.0	COMB. TYPE	NONE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.		PAGE 17 THRU 20	TEST & SUPP.		
	DBA	POST DBA	POST DBA		SRS TABLE	REVIEW		ACCEL TEMP: 125 °C
					PAGE 18 THRU 5B			
COMPONENT: LVL. XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE	TEST REPORT	COMB. TYPE	NORM.	
					SECT. 5.1	TEST & SUPP.	H	REPLACEMENT: 5.99 YEARS
	URE	FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	PAGE 9 & 10	REVIEW		
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT	COMB. TYPE		MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS
				{ FIG. 3.11.6-1 (DBA)	SECT. 5.4	TEST & SUPP.	H	SUBCOMPONENTS: O-RINGS & CONNECTORS
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA	180 PSIA DBA		Pg. 14	REVIEW		
	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE	TEST REPORT	COMB. TYPE		
MODEL AND SERIAL #: 764 1157					SECT. 5.4	TEST & SUPP.	H	NONE
FUNCTIONS: FEED WATER LVL. & SERVICE				FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE	REVIEW		
					Pg. 3D			
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT	COMB. TYPE	H	NONE
ACCUR. SPEC: N/A		PH 8.5-11.0	PH 10.7		SECT. 6.4	TEST & SUPP.		
					Pg. 16	REVIEW		
	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT	COMB. TYPE		
ACCUR. DEM.: N/A	A BETA	3.3 EG	174.38 EG	CONT. RAD. ZONE C3	SECT. 5.2	TEST & SUPP.	H	NONE
	D SHIELD	100% BETA	100% BETA		Pg. 10 & 11	REVIEW		
	T.I.D.	1.2 EG			SRS TABLE			
					Pg. 1C, 2C & 3C			
	AGE-INBT LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT	COMB. TYPE		SAFETY FUNCTION: SEE ESE-3A, TAB 'D'
P.O. # 40718 CHD # 1993					SECT. 7.5	TEST & SUPP.	NONE	
PLANT LOC.: CB 21					Pg. 20	REVIEW		
					SRS TABLE			
COORDINATES X=1503.0 Y=1646.0 Z=236.0	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	N/A		AUTH. REFERENCE: M.J.H.
		YES			SRS TABLE			
					Pg. 1E			
INSTALLED (Y/N):	PARAMETER	SUPPL. METEN	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A				
INSTAL. REF: BY FIELD	OPERABILITY	O ESE 3A						
QUALIF EXEMPT: N/A	TEMPERATURE	T						
QUALIFI REQUIRES ANALYSIS	PRESSURE	P						
STATUS	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R	REFERENCES:					
PHYS DWG REF: CAR 2165 G451	AGING	A	FLOW DIAG. CAR 2165 G044					
PHYS DWG LUC: INSTRUMENT LIST MOUNTING	SUBMERGENCE	S						
EQ. DOC. LUC: W/NO. 40718	FSAR ENV CAT: 10500 CATEG. 1	A						
	APPENDIX E	A						
				REVISION # 1 0				
				DATE 6-21-84				
				SYSTEM FEED WATER				
				TAG LT-IFW 484				

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.
TAG NO: LT-IFW485	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT SECT. 7.0 PAGE 17 THRU 20			ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.		REVIEW				
COMPONENT: LVL. XMTR.	DBA	POST DBA	POST DBA		SRS TAB E PAGE 1B THRU 5B			ACCEL TEMP: 125 °C	
MANUFACTURER: BARTON	TEMPERATURE	120 °F NORM	104 °F NORM.		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT: 5.99 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA	420 °F DBA		TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E Pg. 1D, 3B				
SUBPLIER	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)			MAINTAIN: O-RINGS REPLACED 1 YR. CONNECTORS 20 YEARS SUBCOMPONENTS: O-RINGS & CONNECTORS	
MODEL AND SERIAL: 764 1158	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA		TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3D				
FUNCTION: FEED WATER LVL. & SERVICE	RELATIVE HUMIDITY	40% NORM.	100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)				
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON		TEST REPORT SECT. 6.4 Pg. 16 SRS TAB E Pg. 4D				
ACCUR. SPEC: N/A	R GAMMA	1.2 EG	168.10 EG		FSAR FIG. 3.11B-20				
ACCUR. DEM.: N/A	A BETA	3.3 ET	174.38 EG		TEST REPORT SECT. 5.2 Pg. 10 & 11				
SPECIFICATIONS: PROJECT SPEC. 95928 RI WE. SPEC. DWG 8765D45, R 3	D SHIELD	100% BETA	100% BETA		CONT. RAD. ZONE C3				
P.O. # 140718 CHD # 1993	T.I.D.	1.2 EG			TEST REPORT SECT. 7.5 Pg. 20 SRS TAB E Pg. 1B THRU 5B			SAFETY FUNCTION: SEE ESE-3A, TAB 'D'	
PLANT LOC.: CB 21	AGE - INST LIFE	40 YEARS	5.99 YEARS		110 CFR 50 PARAGRAPH 50.51				
COORDINATES X=1490.0 Y=1648.0 Z=236.0	(PER 323-1974 DEF.)				FSAR SECTION 13.6				
INSTALL (Y/N):	SUBMERGED	228.3	N/A		N/A			AUTH. REFERENCE: M.J.H.	
INSTAL. REF: BY FIELD	YES				SRS TAB E Pg. 1E				
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
QUALIF REQUIRES ANALYSIS	OPERABILITY	O ESE 3A	REFERENCES:						
STATUS	TEMPERATURE	T	FLOW DIAG. CAR 2165 G044						
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG REF: CAR 2165 G451	ACTING	A							REVISION # : 0
PHYS DWG LINC INSTRUMENT LIST MOUNTING	SUBMERGENCE	S							DATE : 6-21-84
EQ. DOC. LUG: W/NO. 40718	FSAR ENV CAT:	A							SYSTEM : FEED WATER
	FSAR CATEG.:	A							TAG : LT-IFW485
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A ITEMS	OUTS ITEMS													
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.	QUALIF.										
TAG NO: LT-IFW486	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 1673 HOURS												
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.5 MO.	POST DBA	FSAR TABLE PAGE 13 THRU 51	COMB. TYPE TEST & SUPP. REVIEW	H	ACCEL TEMP: 125 °C												
COMPONENT: LVL-XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TABLE PAGE 1D, 3B	COMB. TYPE TEST & SUPP. REVIEW	NORM. SERV. TEMP. 5.99 YEARS												
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR FIG. 3.11.8-1 FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	MAINTAIN. O-RINGS REPLACED 1 YR. CONNECTORS 5 YEARS											
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM.	100% DBA	100% DBA	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE											
MODEL AND SERIAL: 764 1159	CHEMICAL SPRAY	2000-2100 PPM BORON	2500 PPM BORON	PH 8.5-11.0	PH 10.7	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16 SRS TABLE Pg. 4D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE										
FUNCTION: FEEDWATER LVL. & SERVICE	R GAMMA	1.2 EG	168.10 EG	A BETA	3.3 EG	D SHIELD	100% BETA	100% BETA	T.I.D.	1.2 EG	FSAR FIG. 3.11B-20 CONT. RAD. ZONE C3	TEST REPORT SECT. 5.2 Pg. 10 & 11 SRS TABLE Pg. 1C, 2C & 3C	COMB. TYPE TEST & SUPP. REVIEW	H	NONE					
ACCUM. SPEC: N/A	AGE	INST LIFE	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20 SRS TABLE Pg. 1B THRU 51	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTIONS: SEE ESE-3A, TAB B											
ACCUM. DEM.: N/A	COORDINATES	X=1648.0 Y=1646.0 Z=236.0	SURMERGED	228.3	YES	FSAR SECTION 3.6	N/A	N/A	NONE	AUTH. REFERENCE: M.J.H.										
SPECIFICATIONS: PROJECT SPEC. 953328, R1 WE. SPEC. DWG. 8765D45, R3	INSTALL. DATE	BY FIELD	QUALIF. EXEMPT	N/A	REQUIRES ANALYSIS	STATUS	PHYS. DWG. NO. CAR 2165 G451	PHYS. DWG. LIST INSTRUMENT MOUNTING	EQU. DUC. LUCI NO. 407118	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A									
P.O. # 407118 CHD # 1994	PLANT LOC.: CB 21	COORDINATES	PARAMETER	SUPPL. REVIEW	OPERABILITY	TEMPERATURE	PRESSURE	REL. HUMIDTY	CHEM. SPRAY	RADIATION	AGING	SURMERGENCE	FSAR ENV. CAT.	19588 CATEG.	APPENDIX E	REFERENCES: FLOW DIAG. CAR 2165 G044	REVISION # 10	DATE: 16-21-84	SYSTEM: FEED WATER	TAG: LT-IFW486

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	
	PARAMETER ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO: LT-1FW487	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.	REVIEW	PAGE 17 THRU 20	TEST & SUPP. REVIEW	ACCEL TEMP: 125 °C
COMPONENT: LVL.XMTR.	DBA	POST DBA	POST DBA		SRS TAB E PAGE 1B THRU 5B		REPLACEMENT: 5.99 YEARS
MANUFACTURER: BARTON	TEMPERATURE	120° F NORM	104° F NORM.	FSAR TABLE	TEST REPORT SECT. 5.1	COMB. TYPE	MANTAIN: O-RINGS REPLACED 1 YR. CONNECTORS 50 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA	420' F DBA	19.4.0-1	PAGE 9 & 10	TEST & SUPP. REVIEW	SUBCOMPONENTS: O-RINGS & CONNECTORS
MODEL AND SERIAL: 764 1164	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.4	COMB. TYPE	
FUNCTIONS & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA	13.11.6-1 (DBA)	Pg. 14	TEST & SUPP. REVIEW	
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE	TEST REPORT SECT. 5.4	COMB. TYPE	
ACCUM. DEM.: N/A	PH	8.5-11.0	10.7	FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E Pg. 3D	TEST & SUPP. REVIEW	
SPECIFICATIONS: PROJECT SPEC. 95328, RI WE. SPEC. DWG 8765D45, R3	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4	COMB. TYPE	
P.O. # 407118 CHD # 1995	AGE	1.2 EG	168.10 EG	CONT. RAD. ZONE C3	Pg. 16	TEST & SUPP. REVIEW	
PLANT LOC.: CB 21	INST LIFE	40 YEARS	5.99 YEARS	110 CFR 50 PARAGRAPH 50.51	SRS TAB E Pg. 16, 24, 30	TEST & SUPP. REVIEW	SAFETY FUNCTION: SEE ESE-3A, TAB B
COORDINATES X=1496.0 Y=1646.0 Z=236.0	SURMERGED	228.3	N/A	FSAR SECTION 3.6	TEST REPORT SECT. 7.5	COMB. TYPE	
INSTALLED (Y/N):	YES				Pg. 20	TEST & SUPP. REVIEW	
INSTALL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES:				
QUALIF: REQUIRES ANALYSIS	TEMPERATURE	T	FLOW DIAG. CAR 2165 6044				
STATUS	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DWG REF: CAR 2165 6451	AGING	A					REVISION # 10
PHYS DWG LUC: INSTRUMENT LIST MOUNTING	SURMERGENCE	S					DATE 16-21-84
EQU. DOC. LUC: W/NO. 407118	FSAR ENV CAT: A						SYSTEM: FEED WATER
	19588 CATEG: A						TAG: LT-1FW487
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/WI UNITS	ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO: LT-1FW494	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	ITY	NORMAL		REVIEW	PAGE 17 THRU 20	TEST & SUPP.	NONE	
COMPONENT: LVL. XMTR.	NORM/TEST	1 YEAR	6.5 MO.		SRS TABLE PAGE 18 THRU 51	REVIEW	ACCEL TEMP: 125 °C	
MANUFACTURER: BARTON	DBA	POST DBA	POST DBA				REPLACEMENT: 5.99 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	NORM. SERV. TEMP. SEE TAB K	
	URE	FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	PAGE 9 & 10	TEST & SUPP. REVIEW		
	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. & FIG.	TEST REPORT SECT. 5.4	COMB. TYPE	MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
		FSAR FIG. 3.11.8-1 FOR DBA	80 PSIA DBA	3.11.6-1 (DBA)	Pg. 14	TEST & SUPP. REVIEW	SUBCOMPONENTS: O-RINGS & CONNECTORS	
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM. 100% DBA	100% DBA	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4	COMB. TYPE		
FUNCTIONS: FEED WATER LVL. & SERVICE				FSAR SECT. 3.11.4.3 (DBA)	Pg. 14	TEST & SUPP. REVIEW		
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4	COMB. TYPE		
ACCUM. SPEC: N/A		PH 8.5-11.0	PH 10.7		Pg. 16	TEST & SUPP. REVIEW		
	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2	COMB. TYPE		
ACCUM. DEM.: N/A	A BETA	3.3 E7	174.38 E6	CONT. RAD. ZONE C3	Pg. 10 & 11	TEST & SUPP. REVIEW		
SPECIFICATIONS: PROJECT SPEC. 953328, R1 W.E. SPEC. DWG. 8765D45, R3	D SHIELD	100% BETA	100% BETA		SRS TABLE Pg. 10, 22 & 30	REVIEW		
P.O. # 407118 CND # 1993	AGE - INST LIFE	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5	COMB. TYPE	SAFETY FUNCTIONS: SEE ESE-3A, TAB D	
PLANT LOC.: CB 21	(PER 323-1974 DEF.)				Pg. 20	TEST & SUPP. REVIEW		
COORDINATES X=1531.0 Y=1736.0 Z=236.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	SRS TABLE Pg. 18 THRU 51	REVIEW		
INSTALLED (Y/M):		YES						
INSTALL. MFT: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION	
QUALIF. EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES:				PACKAGE: ESE-3A	
QUALIF. REQUIRES ANALYSIS	TEMPERATURE	T	FLOW DIAG. CAR 2165 G044					
STATUS	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DWG MFT: CAR 2165 G451	AGING	A					REVISION # 10	
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	SURMERGENCE	S					DATE 16-21-84	
EQ. DOC. LUCI W/NO. 407118	FSAR ENV CAT: 19588 CATEG. A	A					SYSTEM: FEED WATER	
	APPENDIX E						TAG: LT-1FW494	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UITS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.	
TAG NO: LT-1FW495	OPERABIL-ITY	40 YEARS	16 YRS. NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	MONM/TEST DBA	1 YEAR	6.5 MO. POST DBA		SRS TAB E PAGE 18 THRU 15B	REVIEW		ACCEL TEMP: 125 °C	
COMPONENT: LVL.XMTR.	TEMPERAT-URE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST & SUPP.	H	REPLACEMENT: 5.99 YEARS	
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG. 3.11.4-1	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP.	H	MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP.	H	SUBCOMPONENTS: O-RINGS & CONNECTORS	
MODEL AND SERIAL #: 764 1161	CHEMICAL SPRAY	2000-2100 PPM BORON	2500 PPM PH 8.5-11.0	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP.	H		
FUNCTIONS: FEEDWATER LVL. & SERVICE	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP.	H		
ACCUR. SPEC: N/A	D SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TAB E Pg. 16, 2C & 3C	REVIEW			
ACCUR. DEM.: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP.		SAFETY FUNCTIONS: SEE ESE-3A, TAB 'D'	
SPECIFICATIONS: PROJECT SPEC. 95328, WE. SPEC. DWG 8765D45, R 3	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	SRS TABLE Pg. 1B THRU 5B	REVIEW			
P.O #1407118 CND # 1993	YES				N/A				
PLANT LOC.: CB 21									
COORDINATES X=1336.0 Y=1730.0 Z=236.0									
INSTALLED (Y/M):									
INSTALL. NEFI BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION		
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G 044				PACKAGE: ESE-3A		
QUALIF: REQUIRES ANALYSIS	TEMPERATURE	T							
STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG NEFI: CAR 2165 G 451	AGING	A					REVISION # 10		
PHYS DWG LUCI: INSTRUMENT LIST	SUBMERGENCE	S					DATE: 16-21-84		
MOUNTING							SYSTEM: FEED WATER		
EQUOC. LUCI: W/RO. 407118	FSAR ENV CAT: A						TAG: LT-1FW495		
	10588 CATEG.: A								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS					
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.	QUALIF.		
TAG NO: LT-1FW496	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 1673 HOURS				
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	6.5 MO.	POST DBA	SRS TABLE PAGE 1B THRU 5B	REVIEW		ACCEL TEMP: 125 °C				
COMPONENT: LVL. XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 (10)	COMB. TYPE TEST & SUPP.	H	REPLACEMENT: 5.99 YEARS				
MANUFACTURER: BARTON	FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA		FSAR FIG. 3.11.4-1	SRS TABLE Pg. 1D, 3E	REVIEW		MAINTAIN. O-RINGS REPLACED 1 YR. CONNECTORS 5 YEARS				
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP.	H	SUBCOMPONENTS: O-RINGS & CONNECTORS				
MODEL AND SERIAL: 764 1162	FSAR FIG. 3.11.8-1 FOR DBA	80 PSIA DBA		FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D	REVIEW						
FUNCTION: FEED WATER LVL. & SERVICE	RELATIVE HUMIDITY	40% NORM.	100% DBA	100% DBA	FSAR TABLE 19.4.0-1 NORM. FIG. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14	H					
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	PH 8.5-11.0	PH 10.7	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP.	H	NONE		
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	168.10 EG	A BETA	3.3 E7	174.38 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP.	H	NONE	
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA	T.I.D.	1.2 EG	ZONE C3	CONT. RAD.	SRS TABLE Pg. 1C, 2C & 3C	REVIEW			
SPECIFICATIONS: PROJECT SPEC. 953320, R1 WE. SPEC. DWG. 8765D45, R3	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS	110 CFR 50 PARAGRAPH 50.51			TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP.	REVIEW		NONE	SAFETY FUNCTION: SEE ESE-3A, TAB 'D'
P.O. # 407118 CND # 1994	SUBMERGED	228.3		13.6			SRS TABLE Pg. 1B THRU 5B					
PLANT LOC.: CB 21	YES		N/A				N/A					
COORDINATES X=1544.0 Y=1723.0 Z=236.0							SRS TABLE Pg. 1E					AUTH. REFERENCE: M.J.H.
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION		PACKAGE: ESE-3A			
INSTALL. REF: BY FIELD	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G 049						REVISION # 10 DATE 6-21-84 SYSTEM: FEED WATER TAG: LT-1FW496			
QUALIF. EXEMPT: N/A	TEMPERATURE	T										
QUALIF. REQUIRES ANALYSIS	PRESSURE	P										
STATUS	REL. HUMIDITY	H										
	CHEM. SPRAY	C										
	RADIATION	R										
PHYS. DWG. REF: CAR 2165 G 451	TAGING	A										
PHYS. DWG. LUCI INSTRUMENT LIST MOUNTING	SUBMERGENCE	S										
EQ. DOC. LUCI W/NO. 407118	FSAR ENV. CAT.	A										
	19588 CATEG.	A										
	APPENDIX E											

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: LT-1FW497	OPERABILITY	40 YEARS	16 YRS.	NORMAL	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR	NORM/TEST	1 YEAR	16.5 MO.		PAGE 17 THRU 20	TEST & SUPP. REVIEW	NONE
COMPONENT: LVL. XMTR.	DBA	POST DBA	POST DBA		SRS TAB E PAGE 18 THRU 58		ACCEL TEMP: 125°C
MANUFACTURER: BARTON	TEMPERATURE	120°F NORM	104°F NORM.	FSAR TABLE	TEST REPORT SECT. 5.1	COMB. TYPE	NORM. SERV. TEMP. SEE TAB K
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	19.4.0-1 FSAR FIG. 3.11.4-1	PAGE 9 & 10 SRS TAB E Pg. 10 & 3B	TEST & SUPP. REVIEW	REPLACEMENT: 5.99 YEARS
MODEL AND SERIAL: 764 1165	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE	O-RINGS REPLACED 1 YR. CONNECTORS 50 YEARS
FUNCTION: FEEDWATER LVL. & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA	13.11.6-1 (DBA)	SRS TAB E Pg. 3D	TEST & SUPP. REVIEW	SUBCOMPONENTS: O-RINGS & CONNECTORS
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE	NONE
ACCUM. DEM.: N/A				FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E Pg. 3D	TEST & SUPP. REVIEW	NONE
SPECIFICATIONS: PROJECT SPEC. 95328, WE. SPEC. DWG 8765D45, R3	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE	NONE
P.O. # 407118 CND # 1940	PH	8.5-11.0	10.7		SRS TAB E Pg. 4D	TEST & SUPP. REVIEW	NONE
PLANT LOC.: CB 21	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE	NONE
COORDINATES X=1544.0 Y=1723.0 Z=236.0	A BETA	13.3 EG	174.38 EG	CONT. RAD. ZONE C3	SRS TAB E Pg. 10, 2C, 3C	TEST & SUPP. REVIEW	NONE
INSTALLED (Y/M):	D SHIELD	100% BETA	100% BETA			TEST & SUPP. REVIEW	NONE
INSTALL. REF: BY FIELD	T.I.D.	1.2 EG				TEST & SUPP. REVIEW	NONE
QUALIF. EXEMPT: N/A	AGE		5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE	SAFETY FUNCTIONS: SEE ESE-3A, TAB B
QUALIF. REQUIRES ANALYSIS	INST LIFE	40 YEARS			SRS TAB E Pg. 18 THRU 58	TEST & SUPP. REVIEW	NONE
STATUS	(PER 323-1974 DEF.)					TEST & SUPP. REVIEW	NONE
PHYS DNG KEFI CAR 2165 G451	SURMERGED	228.3		FSAR SECTION 3.6	N/A	TEST & SUPP. REVIEW	NONE
PHYS DNG LUCI INSTRUMENT LIST MOUNTING	YES		N/A		SRS TAB E Pg. 1E	TEST & SUPP. REVIEW	NONE
EQU. DUC. LUCI W/RO. 407118						TEST & SUPP. REVIEW	NONE
OTHER EQUIPMENT THIS CES APPLIES TO:	PARA-METER	SUPPL. REVIEW					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
REFERENCES:	OPERABILITY	O ESE 3A					
FLOW DIAG. CAR 2165 G044	TEMPERATURE	T					REVISION # 10
	PRESSURE	P					DATE 16-21-84
	REL. HUMIDTY	H					SYSTEM: FEEDWATER
	CHEM. SPRAY	C					TAG: LT-1FW497
	RADIATION	R					
	AGING	A					
	SURMERGENCE	S					
	FSAR ENV CAT	A					
	10588 CATEG.	A					
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/N/OUTS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: FT-IMS474	OPERABILITY	40 YEARS	16 YRS.	NORMAL	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	ITY	NORMAL			PAGE 17 THRU 20	TEST & SUPP. REVIEW	NONE
COMPONENT: FLOW XMTR.	NORM/TEST	1 YEAR	6.5 MO.		SRS TABLE PAGE 18 THRU 21	REVIEW	ACCEL TEMP: 125 °C
MANUFACTURER: BARTON	DBA	POST DBA	POST DBA		FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	NORM. SERV. TEMP. SEE TAB K
MAJOR SUPPLIER: WESTINGHOUSE	TEMPERATURE	120° F NORM	104° F NORM.		PAGE 9 & 10	TEST & SUPP. REVIEW	REPLACEMENT: 5.99 YEARS
SUPPLIER	FSAR FIG.	3.11.4-1 FOR DBA	420° F DBA		FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.4	MAINTAIN: O-RINGS REPLACED 01 YR. CONNECTORS 10 YEARS
MODEL AND SERIAL: 764 1148	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.	TEST & SUPP. REVIEW	SUBCOMPONENTS: O-RINGS & CONNECTORS
FUNCTION: MAIN STEAM FLOW & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA		3.11.6-1 (DBA)	TEST REPORT SECT. 5.4	
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM.	100% DBA		FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4	
ACCUM. DEM.: N/A	PH	8.5-11.0	10.7		FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 6.4	
PROJECT SPEC: 95328, R1	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON		FSAR FIG. 3.11.20	TEST REPORT SECT. 5.2	
WE. SPEC. DWG 8765D45, R 3	PH	8.5-11.0	10.7		CONT. RAD. ZONE C3	TEST & SUPP. REVIEW	
P.O. # 407118	R GAMMA	1.2 EG	168.10 EG		FSAR FIG. 3.11.20	TEST REPORT SECT. 7.5	
PLANT LOC.: CB 21	A BETA	3.3 EG	174.38 EG		PARAGRAPH 50.51	TEST & SUPP. REVIEW	
COORDINATES X=1460.0	D SHIELD	100% BETA	100% BETA		FSAR SECTION 13.6	TEST REPORT SECT. 7.5	
Y=1725.0	T.I.D.	1.2 EG			N/A	TEST & SUPP. REVIEW	
Z=236.0	AGE		5.99 YEARS		N/A	TEST & SUPP. REVIEW	
INSTALLED (Y/II):	INST LIFE	40 YEARS	40 YEARS		N/A	TEST & SUPP. REVIEW	
INSTALL. REF: BY FIELD	(PER 323-1974 DEF.)				N/A	TEST & SUPP. REVIEW	
QUALIF EXEMPT: N/A	SUBMERGED	228.3	N/A		N/A	TEST & SUPP. REVIEW	
QUALIF REQUIRES ANALYSIS	YES				N/A	TEST & SUPP. REVIEW	
STATUS	OTHER EQUIPMENT THIS CES APPLIES TO:				N/A	TEST & SUPP. REVIEW	
PHYS DWG REF: CAR 2165 G451	REFERENCES:				N/A	TEST & SUPP. REVIEW	
PHYS DWG LUC: INSTRUMENT LIST MOUNTING	FLOW DIAG. CAR 2165 G044				N/A	TEST & SUPP. REVIEW	
EQU. DOC. LUC: W/NO. 407118	REVISION # : 0				N/A	TEST & SUPP. REVIEW	
	DATE : 6-21-84				N/A	TEST & SUPP. REVIEW	
	SYSTEM : MAIN STEAM				N/A	TEST & SUPP. REVIEW	
	TAG : FT-IMS474				N/A	TEST & SUPP. REVIEW	

SAFETY FUNCTION: SEE ESE-3A, TAB D

AUTH. REFERENCE: M.J.H.

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/ UITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: PT IMS 474	UPENABIL- ITY	40 YEARS NORMAL			OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19	COMBTYPE TEST 4 SUPP REVIEW	ACCEL TIME 1673 HRS.
EQUIPMENT: SENSOR TYPE	MONH/TEST DBA	1 YEAR POST DBA				SRS TABLE PAGE 15 THRU 15B		ACCEL TEMP 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 142°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10 FSAR TABLE Pg. 1B THRU 15B		M	NONE REPLACEMENT
MAINTALTYNER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-B	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3C		M	NONE MAINTALTYNER
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3C		H	NONE SUBCOMPONENTS: O-RINGS CONNECTORS
MODEL AND: 763 SERIAL #: N8500042	CHEMICAL SPRAY	N/A	12000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17 SRS TABLE Pg. 6C		M	NONE
FUNCTION: SG 1A STEAM PRESS. & SERVICE PR ST II	R GAMMA A BETA D SHIELD T.I.D.	5.8 E3 NEGL. 100% BETA 6.8 E3	15.0 E7 90 E7 68 E7	FSAR FIG. 3.11B-24 RAD. ZONE R12	TEST REPORT SECT. 5.2 Pg. 11 SRS TABLE Pg. 1A THRU 2A		H	NONE
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TABLE Pg. 3B			NONE SAFETY FUNCTION
ACCUM. DEM.: N/A	BURNEGED	191'0"	N/A	FSAR SECT. 3.0	N/A	N/A		NONE
SPECIFICATIONS: W. PROJ. SPEC. 95333, RO D.W.G. 876506623 GEN. E. SPEC. 95333, RO	COORDINATES X- Y- Z-261	YES			SRS TABLE			NONE AUTH. REFERENCES M.J.H.
P.O. #: 285110 CND # 15H-988	INSTALL. (Y/N): BY FIELD							
PLANT LOC.: A.B.31	QUALIF. EXEMPT: N/A							
COORDINATES X- Y- Z-261	OPERABILITY	O	SUPPL. REVIEW ESE-1	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-1A
TEMPERATURE	T			REFERENCES: FLOW DIAG. CAR 2165 9042 TEST REPORT EOIA				
PRESSURE	P							
REL. HUMIDTY	H							
CHEM. SPRAY	C							
PHYS DNG HFF: CAR 2165 9436 504	RADIATION	R						REVISION #: 0
PHYS DNG LICI: C-8	AGING	A						DATE: 10-11-84
MOUNTING	EMERGENCY	S						SYSTEM: MAIN STEAM
EQUIP. LUCI: W.T.O. 285110	19500 CATEG.:	D						TAG: IPTIMS 474
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: FT-IMS 475	OPERABILITY	40 YEARS NORMAL	16 YRS. NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.		SRS TABLE PAGE 18 THRU 58	REVIEW		ACCEL TEMP: 125 °C	
COMPONENT: FLOW XMTR.	DBA	POST DBA	POST DBA					REPLACEMENT: 5.99 YEARS	
MANUFACTURER: BARTON	TEMPERATURE	120 °F NORM	104 °F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST & SUPP.	H	NORM. SERV. TEMP. SECT AB 1K	
MAJOR SUPPLIER: WESTINGHOUSE	DBA	FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	SRS TABLE Pg. 1D, 3E	REVIEW		MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
MODEL AND SERIAL #: 764 1149	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP.	H	SUBCOMPONENTS: O-RINGS & CONNECTORS	
FUNCTIONS: MAIN STEAM FLOW & SERVICE	DBA	FSAR FIG. 3.11.8-1 FOR DBA	80 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D	REVIEW			
	RELATIVE HUMIDITY	40% NORM	100% DBA	FSAR TABLE 9.4.0-1 NORM	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP.	H	NONE	
				FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE Pg. 3D	REVIEW			
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP.	H	NONE	
ACCUM. SPEC: N/A		PH 8.5-11.0	PH 10.7		SRS TABLE Pg. 4D	REVIEW			
ACCUM. DEM.: N/A	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP.	H	NONE	
	A BETA	3.3 EG	174.38 EG	CONT. RAD. ZONE C3	SRS TABLE Pg. 1C, 2C & 3C	REVIEW			
SPECIFICATIONS: PROJECT SPEC. 953328 R1 WE. SPEC. DWG. 8745D45, R 3	D SHIELD	100% BETA	100% BETA						
P.O. # 407118 CND # 1991	T.I.D.	1.2 EG		110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP.		SAFETY FUNCTION: SEE ESE-3A, TAB D	
PLANT LOC.: CB 21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS		SRS TABLE Pg. 1D THRU 58	REVIEW			
COORDINATES X= 1468.0 Y= 1734.0 Z= 236.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	N/A		AUTH. REFERENCE: M.J.H.	
INSTALLED (Y/II):	YES								
INSTALL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A		
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G044						
QUALIF: REQUIRES ANALYSIS	TEMPERATURE	T							
STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DWG REF: CAR 2165 G451	RADIATION	R					REVISION # 10		
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	AGING	A					DATE: 6-21-84		
EQ. DUC. LUCI W/RO. 407118	SURMERGENCE	S					SYSTEM: MAIN STEAM		
	FSAR ENV CAT: A	A					TAG: FT-IMS 475		
	19588 CATEG: A	A							
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	UITS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.				
TAG NO: PT IMS 475	UPENABIL	140 YEARS			OPERABILITY TEST REPORT			ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	ITY	NORMAL			REVIEW SECT. 7.0 PAGE 18 & 19			ACCEL TEMP: 125°C
COMPONENT: PRESS. TRANSMITTER	INORM/TEST	1 YEAR POST			SRS TAB E PAGE 13 THRU 5B		NONE	REPLACEMENT:
MANUFACTURER: BARTON	TEMPERAT-	104°F NORM.	120°F NORM.	FSAR TABLE	TEST REPORT SECT. 5.1 PAGE 9 & 10		M	NONE
MAJOR SUPPLIER: WESTINGHOUSE	URE	104°F DBA	142°F DBA	FSAR FIG. 3.11B-5	SRS TAB E Pg. 13 THRU 5B			MAIN (AIN.)
MODEL AND SERIAL: 763 NB500048	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11-B	TEST REPORT SECT. 5.4 Pg. 14		M	NONE
FUNCTION: SG 1A STEAM PRESS. & SERVICE PR ST III	RELATIVE HUMIDITY	20-90% NORM.	100% NORM.	FSAR TABLE 19.4.0-1 NORM.	SRS TAB E Pg. 3C			SUBCOMPONENTS: O-RINGS CONNECTORS
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A	1200-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17		M	NONE
ACCUM. DEM.: N/A	R GAMMA	5.8 E3	15.0 E7	FSAR FIG. 3.11B-24	TEST REPORT SECT. 5.2 Pg. 11		H	NONE
SPECIFICATIONS: W PROJ. SPEC. 95333, RO 4 DWG 876506, R3 GEN. E SPEC 95333, RO	A BETA	NEGL.	90 E7	RAD. ZONE R12	SRS TAB E Pg. 1A THRU 2A			SAFETY FUNCTIONS
P.O. # 285110 CND # 15H-988	D SHIELD	100% BETA		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21			
PLANT LOC.: A.B. 31	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS			SRS TAB E Pg. 3B			
CORORDINATES X= Y= Z= 261	SURMERGED	191' 0"	N/A	FSAR SECT. 3.6	N/A			
INSTALLED (Y/II):		YES			SRS TAB E			AUTH. REFERENCES: M.J.H.

INITIAL. NEPI BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS DNG OFF: CAR 2165 6436 504
 PHYS DNG LIC: D-10
 MOUNTING:
 EN. DOC. LUC: W.T.O. 285110

PARAMETER	SUPPL. REVIEW
OPERABILITY	O ESE-1
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENCE	S
19588 CATEG.:	D
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES: FLOW DIAG. CAR 2165 6042
 TEST REPORT EOIA

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-1A
 REVISION # 10
 DATE 110-11-84
 SYSTEM: MAIN STREAM
 TAG: PTIMS 475

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/UNIT	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: PT IMS 476	UPHABIL	40 YEARS			OPERABILITY TEST REPORT		
	ITY	NORMAL			REVIEW SECT. 7.0		
	NORM/TEST	1 YEAR POST			PAGE 18, 19		
EQUIPMENT: SENSOR	DBA	DBA			SRS TAB E		
TYPE					PAGE 13 THRU 5B		
COMPONENT: PRESS. TRANSMITTER	TEMPERATURE	104°F NORM.	120°F NORM.	FSAR TABLE	TEST REPORT		
		104°F DBA	1420°F DBA	9.4.0-1	SECT. 5.1		
				FSAR FIG.	PAGE 9 & 10	M	NONE
MANUFACTURER: BARTON				3.11B-5	SRS TAB E		
					Pg. 13 THRU 5B		
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT.	TEST REPORT		
		DBA NORM.	175 PSIA DBA	3.11-B	SECT. 5.9	M	NONE
					Pg. 14		
					SRS TAB E		
					Pg. 3C		
MODEL AND SERIAL: 763 NB500047	RELATIVE HUMIDITY	20-90% NORM.	100% NORM.	FSAR TABLE	TEST REPORT		
		100% DBA	100% DBA	9.4.0-1 NORM.	SECT. 5.4	H	NONE
					Pg. 14		
					SRS TAB E		
					Pg. 3C		
FUNCTION: SG IA STEAM PRESS. & SERVICE PR ST IV	CHEMICAL SPRAY	N/A	12000-2100 PPM BORON	FSAR SECT.	TEST REPORT		
			PH 8.5-11.0	3.11-B	SECT. 6.4	M	NONE
					Pg. 17		
					SRS TAB E		
					Pg. 6C		
ACCUM. SPEC: N/A	R GAMMA	5.8 E3	15.0 E7	FSAR FIG.	TEST REPORT		
	A BETA	NEGL.	90 E7	3.11B-24	SECT. 5.2	H	NONE
	D SHIELD	100% BETA		RAD. ZONE	Pg. 11		
	T.I.D.	6.8 E3	68 E7	R12	SRS TAB E		
					Pg. 1A THRU 3A		
SPECIFICATIONS: W. PROJ. SPEC. 95333, R.O. 4, DWG 876506, R3 GEN. E. SPEC. 95333, R.O. 4	AGE - INST LIFE	40 YEARS		10 CFR 50	TEST REPORT		
P.O. # 285110 CND # 15H.988	(PER 323-1974 DEF.)			PARAGRAPH	SECT. 7.5		
				50.51	Pg. 21		
PLANT LOC.: A.B. 31					SRS TAB E		
					Pg. 3B		
COORDINATES X-Y-Z: 2-261	EMERGENCY	191'0"	N/A	FSAR SECT.	N/A	N/A	
		YES		3.0	SRS TAB E		

INSTALLED (Y/N) BY FIELD
 QUALIF. REPORTING: N/A
 QUALIF. STATUS:
 PHYS DNG WFCAR 2165 6436 504
 PHYS DNG LUCI D-12
 MOUNTING:
 EV.DUC.LUCI w/T.O. 285110


PARAMETER	SUPPL. REVIEW
OPERABILITY	O ESE-1
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
EMERGENCY	A
	S
19500 CATEG.	D
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 FLOW DIAG. CAR 2165 9042
 TEST REPORT EOIA

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A
 REVISION # 10
 DATE 110-11-84
 SYSTEM: MAIN STREAM
 TAG: PTIMS 476


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.
TAG NO: FT-IMS 484	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	6.5 MO. POST DBA		SRS TAB E PAGE 1B THRU 5B			ACCEL TEMP: 125 °C	
COMPONENT: FLOW XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	H	REPLACEMENT: 5.99 YEARS	
MANUFACTURER: BARTON	FSAR FIG. 3.11.4-1 FOR DBA		420 °F DBA	FSAR FIG. 3.11.4-1	SRS TAB E Pg. 1D, 8B			MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	SUBCOMPONENTS: O-RINGS & CONNECTORS	
MODEL AND SERIAL: 764 1150	FSAR FIG. 3.11.8-1 FOR DBA		80 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TAB E Pg. 3D				
FUNCTIONS: MAIN STEAM FLOW & SERVICE	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
	FSAR FIG. 3.11.4.3 (DBA)		100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E Pg. 3D				
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
ACCUR. SPEC: N/A	PH 8.5-11.0		PH 10.7		SRS TAB E Pg. 4D				
ACCUR. DEM: N/A	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
	A BETA	3.3 EG	174.38 EG	CONT. RAD. ZONE C3	SRS TAB E Pg. 1C, 2C & 3C				
	D SHIELD	100% BETA	100% BETA						
	T.I.D.	1.2 EG							
	AGE		5.99 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP. REVIEW		SAFETY FUNCTION: SEE ESE-3A, TAB "D"	
	INST LIFE (PER 323-1974 DEF.)	40 YEARS			SRS TAB E Pg. 1B THRU 5B				
	COORDINATES X=1490.0 Y=1643.0 Z=236.0	SURMERGENCE	228.3	FSAR SECTION 13.6	N/A			AUTH. REFERENCE: M.J.H.	
	YES		N/A		SRS TAB E Pg. 1E	N/A	NONE		
INSTALL. BY: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A		
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G044				REVISION # 10 DATE 6-21-84 SYSTEM: MAIN STEAM TAG: FT-IMS 484		
QUALIF REQUIRES ANALYSIS	TEMPERATURE	T							
STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
PHYS DNG REF: CAR 2165 G451	SURMERGENCE	S							
PHYS DNG LUC: INSTRUMENT LIST MOUNTING	FSAR ENV CAT: A	A							
EQU. DNG LUC: WTR. 407118	19588 CATEG. A	A							
	APPENDIX E								



EQUIP. DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS ITEMS	REMARKS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: PT IMS 484	UPENABIL	40 YEARS		OPERABILITY	TEST REPORT SECT. 7.0		ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	ITY	NORMAL		REVIEW	PAGE 18 & 19 SRS TAB E PAGE 18 THRU 19		
COMPONENT: PRESS. TRANSMITTER	NDHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP: 125°C
MANUFACTURER: BARTON	TEMPERATURE	104°F NORM.	120°F NORM.	FSAR TABLE 9.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E Pg. 18 THRU 19	M	REPLACEMENT:
MAJOR SUPPLIER: WESTINGHOUSE	URE	104°F DBA	120°F DBA	FSAR FIG. 3.11B-5			MAINTAIN:
MODEL AND SERIAL: 763 N8500050	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11-B	TEST REPORT SECT. 5.9 Pg. 14 SRS TAB E Pg. 3C	M	SUBCOMPONENTS: O-RINGS CONNECTORS
FUNCTION: 5G 1B STEAM PRESS. & SERVICE PR ST II	RELATIVE HUMIDITY	20-90% NORM.	100% NORM.	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C	H	
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A	2000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17 SRS TAB E Pg. 6C	M	
ACCUM. DEM.: N/A	R GAMMA	5.8 E3	15.0 E7	FSAR FIG. 13.11B-24	TEST REPORT SECT. 5.2 Pg. 11 SRS TAB E Pg. 1A THRU 2A	H	
SPECIFICATIONS: W. PROJ. SPEC. 95333, R.O.E. DWG. 8765066, R3 GEN. E SPEC. 95333 R.O.	A BETA	NEGL.	190 E7	IRAD. ZONE R12			
P.O. # 285110 CND # 15H.988	D SHIELD	100% BETA	68 E7	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TAB E Pg. 3B		SAFETY FUNCTION:
PLANT LOC.: A.B. 31	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS					
COORDINATES X= Y= Z=261	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A	N/A	AUTH. REFERENCES: M.J.H.

QUALIF. CRITERIA	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ISE-1A
OPERABILITY	TEMPERATURE	O ESE-1	REFERENCES: FLOW DIAG. CAR 2165 9042 TEST REPORT EOIA	REVISION # 10 DATE 110-11-84 SYSTEM MAIN STREAM TAG PTIMS 484
TEMPERATURE	PRESSURE	P		
PRESSURE	REL. HUMIDTY	H		
REL. HUMIDTY	CHEM. SPRAY	C		
CHEM. SPRAY	RADIATION	R		
PHYS DNG HFF: CAR 2165 4136 504	AGING	A		
PHYS DNG LIC: C-8	SUBMERGENCE	S		
INSTALLATION	19588 CATEG.:	D		
EM. DUC. LUC: W.T.O. 285110	APPENDIX E			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: FT-IMS 485	OPERABILITY	40 YEARS	16 YRS.	NORMAL	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE	NONE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	16.5 MO.		REVIEW	TEST & SUPP. REVIEW		ACCEL TEMP: 125°C
COMPONENT: FLOW XMTR.	DBA	POST DBA	POST DBA		SRS TABLE PAGE 18 THRU 25	REVIEW		REPLACEMENT: 5.99 YEARS
MANUFACTURER: BARTON	TEMPERATURE	120°F NORM	104°F NORM.		FSAR TABLE SECT. 5.1 PAGE 9 & 10	TEST & SUPP. REVIEW	H	MANTAIN. O-RINGS REPLACED 01 YR. CONNECTORS 05 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA		FSAR FIG. 3.11.4-1	TEST & SUPP. REVIEW	H	SUBCOMPONENTS: O-RINGS & CONNECTORS
MODEL AND SERIAL: 764 1151	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.4 Pg. 14	H	
FUNCTIONS: MAIN STEAM FLOW & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA		FSAR FIG. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D	H	
	RELATIVE HUMIDITY	40% NORM. 100% DBA	100% DBA		FSAR TABLE SECT. 9.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14	H	
	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON		FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	H	
ACCUM. SPEC: N/A	PH	8.5-11.0	10.7		FSAR FIG. 3.11.2-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	H	
ACCUM. DEM.: N/A	R GAMMA	1.2 EG	168.10 EG		CONT. RAD. ZONE C3	SRS TABLE Pg. 16, 26 & 30	H	
SPECIFICATIONS: W/PROJECT SPEC. 955328, R1 W.E. SPEC. DWG 8765D45, R 3	A BETA	3.3 E7	174.38 EG			TEST REPORT SECT. 7.5 Pg. 20		
P.O. # 407118 CMD # 1991	D SHIELD	100% BETA	100% BETA		110 CFR 50 PARAGRAPH 50.51	TEST & SUPP. REVIEW		SAFETY FUNCTION: SEE ESE-3A, TAB 'D'
PLANT LOC.: CB 21	T.I.D.	1.2 EG				SRS TABLE Pg. 18 THRU 21		
COORDINATES X= Y= Z= 236.0	AGE		5.99 YEARS					
INSTALLED (Y/II):	INST LIFE (PER 323-1974 DEF.)	40 YEARS						
INSTALL. NEFI BY FIELD	BURNEGED	228.3						
QUALIF EXEMPT: N/A	YES		N/A		FSAR SECTION 3.6	N/A	NONE	AUTH. REFERENCE: M.J.H.
QUALIF: REQUIRES ANALYSIS	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A	
STATUS	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 9094				REVISION # 10 DATE 16-21-84 SYSTEM: MAIN STEAM TAG: FT-IMS 485	
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DWG NEFI CAR 2165 9451	AGING	A						
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	BURNEGENCE	S						
EQU. DOC. LUCI W/NO. 407118	FSAR ENV CAT:	A						
	10588 CATEG.:	A						
	APPENDIX E							



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/A	UNIT	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: PT IMS 485	OPERABIL- ITY	140 YEARS NORMAL		OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19 SRS TAB E PAGE 13 THRU 5B	COMB TYPE TEST / SLFT / REVIEW	-	NONE	ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	INDM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP: 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 142°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E Pg. 1B THRU 5B		M	NONE	REPLACEMENT:
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-B	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C		M	NONE	MAINTENANCE: SUBCOMPONENTS: O-RINGS CONNECTORS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C		H	NONE	
MODEL AND: 763 SERIAL #: N8500049	CHEMICAL SPRAY	N/A	1200-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17 SRS TAB E Pg. 6C		M	NONE	
FUNCTION: SG 1B STEAM PRESS. & SERVICE PR ST III	R GAMMA A BETA D SHIELD T.I.D.	5.8E3 NEGL. 100% BETA 6.8E3	15.0 E7 90 E7 68 E7	FSAR FIG. 3.11B-24 RAD. BONE R12	TEST REPORT SECT. 5.2 Pg. 11 SRS TAB E Pg. 1A THRU 2A		H	NONE	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TAB E Pg. 3B		-	NONE	SAFETY FUNCTIONS:
ACCUM. DEM.: N/A	SURMERGENT	191'0" YES	N/A	FSAR SECT. 3.0	N/A SRS TAB E		-	NONE	AUTH. REFERENCES: M.J.H.
SPECIFICATIONS: W. PROJ. SPEC. 95333, RO1 DWG. 876506, R3 GEN. E SPEC. 95333, RO	INSTALLED (Y/N): INITIAL. KEPT BY FIELD QUALIF. EXEMPT: N/A								

PHYS DNG OFFICAR 2165 6436 504
 PHYS DNG LICID-10
 MOUNTING
 ED. DUC. LUCI w/ T.O. 285110

PARAMETER	SUPPL. REVIEW
OPERABILITY	O ESE-1
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENT	S
19500 CATEG.	D
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIED TO:

 REFERENCES:
 FLOW DIAG. CAR 2165 9042
 TEST REPORT EOIA

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE ESE-1A

 REVISION # 10
 DATE 110-11-84
 SYSTEM MAIN STREAM
 TAG PTIMS 485



10

11

12

13

14

15

16



17

18

19



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/A	OUTS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: PT IMS 486	UPENABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19	COMB. TYPE TEST SUFF. REVIEW			ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	NDHM/TEST DBA	1 YEAR POST DBA			SRS TAB E PAGE 15 THRU 52			NONE	ACCEL TEMP: 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 420°F DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10			M	REPLACEMENT:
MAINT ALIQUOT: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-D	TEST REPORT SECT. 5.4 Pg. 14			M	MAINTAIN:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14			H	SUBCOMPONENTS: O-RINGS CONNECTORS
MODEL AND: 763 SERIAL #: H850053	CHEMICAL SPRAY	N/A	12000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17			M	
FUNCTION: SG IB STEAM PRESS. & SERVICE PR ST IV	R GAMMA A BETA D SHIELD T.I.D.	5.8 E3 NEGL. 100% BETA 6.8 E3	15.0 E7 90 E7 68 E7	FSAR FIG. 3.11B-24 RAD. ZONE R12	TEST REPORT SECT. 5.2 Pg. 11			H	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21				SAFETY FUNCTION:
ACCUM. DEN.: N/A	BURNEGED	191'0"	N/A	FSAR SECT. 3.6	N/A	N/A			
SPECIFICATIONS: W. PROJ. SPEC. 95333, RO 4 DWG. 876506, R3 GEN. E. SPEC. 95333, RO	YES				SRS TAB E Pg. 3B				AUTH. REFERENCE: M.J.H.
P.O. #: 285110 CND # 15H.988	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-1A
PLANT LOC.: A.B.31	OPERABILITY	O ESE-1		REFERENCES: FLOW DIAG. CAR 2165 9042 TEST REPORT E01A					REVISION # 10
COORDINATES X- Y- Z- 261	TEMPERATURE	T							DATE 110-11-84
INSTALLED (Y/N):	PRESSURE	P			SYSTEM: MAIN STREAM				
INITIAL. REPT: BY FIELD	REL. HUMIDTY	H			TAG: PTIMS 486				
QUALIF. EXEMPT: N/A	CHEM. SPRAY	C							
QUALIFI	RADIATION	R							
STATUS	DAGING	A							
	EMERGENCY	S							
	19580 CATEG.:	D							
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: FT-1MS494	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY TEST REPORT		7	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	ITY	NORMAL			REVIEW		NONE		
COMPONENT: FLOW XMTR.	NORM/TEST	1 YEAR	6.5 MO.		TEST & SUPP. REVIEW			ACCEL TEMP: 125°C	
MANUFACTURER: BARTON	DBA	POST DBA	POST DBA		SRS TABLE PAGE 18 THRU 5B			REPLACEMENT: 5.99 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	TEMPERATURE	120°F NORM.	104°F NORM.	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE TEST & SUPP. REVIEW	H	NORM. SERV. TEMP. SECTAB K	
	FSAR FIG.	3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	H	REPLACEMENT: 5.99 YEARS	
	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	MAINTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	SUBCOMPONENTS: O-RINGS & CONNECTORS	
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
FUNCTION: MAIN STEAM FLOW & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
ACCUR. DEM: N/A	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11.20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
SPECIFICATIONS: PROJECT SPEC. 95328 RI, W.E. SPEC. DWG 8765D45, R 3	A BETA	3.3 EG	174.38 EG	CONT. RAD. ZONE C3	SRS TABLE Pg. 1C, 2C & 3C	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
P.O. # 407118 CND # 1990	D SHIELD	100% BETA	100% BETA	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP. REVIEW		SAFETY FUNCTION: SEE ESE-3A, TAB "D"	
PLANT LOC: CB 21	AGE - INST LIFE	40 YEARS	5.99 YEARS	FSAR SECTION 13.6	SRS TABLE Pg. 1B THRU 5B	COMB. TYPE TEST & SUPP. REVIEW		NONE	
COORDINATES X=154.0, Y=1723.0, Z=236.0	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	COMB. TYPE N/A		NONE	
INSTALLED (Y/N):	PARA-METER	SUPPL. METEN	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A		
INSTALL. REF: BY FIELD	OPERABILITY	O ESE 3A	REFERENCES: ... FLOW DIAG. CAR 2165 G044				REVISION # : 0 DATE : 6-21-84 SYSTEM : MAIN STEAM TAG : FT-1MS 494		
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIF. REQUIRES ANALYSIS	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG REF: CAR 2165 G451	AGING	A							
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	SUBMERGENCE	S							
EQU. DOC. LUCI W/NO. 407118	FSAR ENV CAT: 10588 CATEG. 1	A							
	APPENDIX E								


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.			
TAG NO: PT IMS 494	OPERABIL- ITY	140 YEARS NORMAL		OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19	COMB. TYPE TEST SUPP.	ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR POST DBA			SRS TAB E PAGE 13 THRU 15		ACCEL TEMP: 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 142°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E Pg. 13 THRU 15		REPLACEMENT:
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-D	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C	M	MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C	H	SUBCOMPONENTS: O-RINGS CONNECTORS
MODEL AND SERIAL: 763 NBS500051	CHEMICAL SPRAY	N/A	12000-2100 PPM BORON IPH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17 SRS TAB E Pg. 6C	M	
FUNCTION: SG IC STEAM PRESS. & SERVICE PR ST II	R GAMMA A BETA D SHIELD T.I.D.	5.8 E3 NEGL. 100% BETA 6.8 E3	15.0 E7 90 E7 68 E7	FSAR FIG. 13.11B-24 RAD. ZONE R12	TEST REPORT SECT. 5.2 Pg. 11 SRS TAB E Pg. 1A THRU 3A	H	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEP.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TAB E Pg. 3B		SAFETY FUNCTIONS
ACCUM. DEM.: N/A	BURMEGEN	191'0"	N/A	FSAR SECT. 13.6	N/A	N/A	
SPECIFICATIONS: W. PROJ. SPEC. 95333, RO DWG. 876506 GRS GEN. E SPEC. 95333, RO	YES	YES			SRS TAB E		AUTH. REFERENCE: M.J.H.
P.O. # 285110	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-1A	
PLANT LOC.: A.B. 31	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G042 TEST REPORT EOIA			REVISION # 10 DATE 110-11-84 SYSTEM: MAIN STEAM TAG: PTIMS 494	
COORDINATES X=	TEMPERATURE	T					
Y=	PRESSURE	P					
Z= 261	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
INSTALLED (Y/N):	RADIATION	R					
INITIAL. NEPI BY FIELD	DAGING	A					
QUALIF. EXEMPT: N/A	BURMEGEN	S					
QUALIF. STATUS	19500 CATEG. 1	D					
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS	ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.
TAG NO: FT-IMS 495	OPERABILITY	40 YEARS	16 YRS.	NORMAL	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE	NONE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.		REVIEW	SUPP.		ACCEL TEMP: 125°C	
COMPONENT: FLOW XMTR.	DBA	POST DBA	POST DBA		SRS TABLE PAGE 18 THRU 5B	REVIEW		REPLACEMENT: 5.99 YEARS	
MANUFACTURER: BARTON	TEMPERATURE	120°F NORM	104°F NORM.		FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 (10)	H	NORM. SERV. TEMP. SEE TAB K	
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA	420°F DBA		FSAR FIG. 3.11.4-1	SRS TABLE 3.1D.4.3B		MANTAIN. O-RINGS REPLACED @ 1 YR. CONNECTORS @ 5 YEARS	
MODEL AND SERIAL: 764 1153	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. (FIG.)	TEST REPORT SECT. 5.4 Pg. 14	H	SUBCOMPONENTS: O-RINGS & CONNECTORS	
FUNCTION: MAIN STEAM FLOW & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	80 PSIA DBA		FSAR FIG. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D			
	RELATIVE HUMIDITY	40% NORM.	100% DBA		FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14	H	NONE	
		100% DBA	100% DBA		FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE Pg. 3D			
	CHEMICAL SPRAY	2000-2100 PPM	12500 PPM		FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	H	NONE	
ACCUM. SPEC: N/A		PRM BORON	BORON			SRS TABLE Pg. 4D			
	R GAMMA	1.2 EG	168.10 EG.		FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	H	NONE	
ACCUM. DEM.: N/A	A BETA	3.3 E7	174.38 EG		CONT. RAD. ZONE C3	SRS TABLE Pg. 1C, 2C & 3C			
SPECIFICATIONS: PROJECT SPEC. 955328, W.E. SPEC. DWG. 8765D45, R3	D SHIELD	100% BETA	100% BETA		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20		SAFETY FUNCTION. SEE ESE-8A, TAB B	
P.O. # 407118 CWD # 1991	T.I.D.	1.2 EG				SRS TABLE Pg. 1B THRU 5B			
PLANT LOC.: CB 21	AGE - INST LIFE (PER 523-1978 DEF.)	40 YEARS	5.99 YEARS						
COORDINATES X=1544.0 Y=1713.0 Z=236.0	SUBMERGED	228.3			FSAR SECTION 13.6	N/A			
INSTALLED (Y/II):	YES		N/A			SRS TABLE Pg. 1E		AUTH. REFERENCE: M.J.H.	
INSTALL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-8A		
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 8A	REFERENCES: FLOW DIAG. CAR 2165 G 044				REVISION # 10 DATE 16-21-84 SYSTEM: MAIN STEAM TAG: FT-IMS 495		
QUALIF: REQUIRES ANALYSIS	TEMPERATURE	T							
STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG REF: CAR 2165 G 451	AGING	A							
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	SUBMERGENCE	S							
EQU. DOC. LUCI W/RO. 407118	FSAR ENV CAT:	A							
	10588 CATEG.:	A							
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M/ UITS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: PT IMS 495	UPENABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19	COMBTYPE TEST & SUFF REVIEW		ACCEL TIME 1673 HRS.
EQUIPMENT: SENSOR TYPE	INDHM/TEST IOBA	1 YEAR POST DBA			SRS TAB E PAGE 15 THRU 15B		NONE	ACCEL TEMP 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 142°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E Pg. 1B THRU 15B		M NONE	REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-B	TEST REPORT SECT. 5.9 Pg. 14 SRS TAB E Pg. 3C		M NONE	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C		H NONE	SUBCOMPONENTS: O-RINGS CONNECTORS
MODEL AND: 763 SERIAL #: NB500049	CHEMICAL SPRAY	N/A	2000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-15	TEST REPORT SECT. 6.4 Pg. 17 SRS TAB E Pg. 6C		M NONE	
FUNCTION: SG IC STEAM PRESS. & SERVICE PR ST III	R GAMMA A BETA D SHIELD T.I.D.	5.8E3 NEGL. 100% BETA 6.8E3	15.0 E7 90 E7 68 E7	FSAR FIG. 3.11B-24 RAD. BONE R12	TEST REPORT SECT. 5.2 Pg. 11 SRS TAB E Pg. 1A THRU 3A		H NONE	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 325- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TAB E Pg. 3B		NONE	SAFETY FUNCTION
ACCUM. DEN.: N/A W. PROJ. SPEC. 95333 RO 8 PNG. 876506 R3 GEN. E SPEC. 95333 RO	BURNEGED	191'0"	N/A	FSAR SECT. 3.6	N/A SRS TAB E	N/A	NONE	AUTH. REFERENCES M.J.H.
SPECIFICATIONS: P.O. #: 285110 CND # 15H.988	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-1A		
PLANT LOC.: A.B. 31	OPERABILITY	O ESE-1	REFERENCES: FLOW DIAG. CAR 2165 9042 TEST REPORT EOIA					
COORDINATES X= Y= Z=261	TEMPERATURE	T						
INSTALLED (Y/II):	PRESSURE	P						
INITIAL. NEPS BY FIELD	REL. HUMIDTY	H						
QUALIF. REPORTING: N/A	CHEM. SPRAY	C						
STATUS	RADIATION	R	REVISION #: 0			DATE: 110-11-84		
PHYS Dwg OFFICAR 2165 4136 504	AGING	A	SYSTEM: MAIN STREAM			TAG: PTIMS 495		
PHYS Dwg LIC: D-10	BURNEGED	S	19580 CATEG.: D					
MOUNTING	APPENDIX E							
EDUC. LUC: W.P.O. 285110								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	M/MI UNITS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: PT IMS 496	UPENABIL- ITY	140 YEARS NORMAL		OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18, 19	COMB. TYPE TEST & SUPP. REVIEW		ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR TYPE	NOHM/TEST DBA	1 YEAR POST DBA			SRS TAB E PAGE 18 THRU 19			ACCEL TEMP: 125°C
COMPONENT: PRESS. TRANSMITTER	TEMPERAT- URE	104°F NORM. 104°F DBA	120°F NORM. 420°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-5	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TAB E P. 1B THRU 5B		M	REPLACEMENT:
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS. NORM. 175 PSIA DBA	FSAR SECT. 3.11-D	TEST REPORT SECT. 5.9 Pg. 14 SRS TAB E Pg. 3C		M	MAINTENANCE: SUBCOMPONENTS: O-RINGS CONNECTORS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	100% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TAB E Pg. 3C		H	
MODEL AND SERIAL # 763 N8500054	CHEMICAL SPRAY	N/A	12000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11-B	TEST REPORT SECT. 6.4 Pg. 17 SRS TAB E Pg. 6C		M	
FUNCTION: SG 1A STEAM PRESS. & SERVICE FR ST IV	R GAMMA A BETA D SHIELD T.I.D.	5.8 E3 NEGL. 100% BETA 6.8 E3	5.0 E7 90 E7 68 E7	FSAR FIG. 3.11B-24 RAD. ZONE R12	TEST REPORT SECT. 5.2 Pg. 11 SRS TAB E P. 1A THRU 3A		H	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 21 SRS TAB E Pg. 3B			SAFETY FUNCTION:
ACCUM. DEN.: N/A	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A	N/A		AUTH. REFERENCE: M.J.H.
SPECIFICATIONS: W. PROJ. SPEC. 95333, ROL DWG 876506, R3 GEN. E SPEC. 95333, RO	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A		
P.O. # 285110 CND # 15H.988	OPERABILITY	O ESE-1	REFERENCES: FLOW DIAG. CAR 2165 6042 TEST REPORT EOIA			REVISION # 10 DATE 110-11-84 SYSTEM: MAIN STEAM TAG PTIMS 496		
PLANT LOC.: A.B.31	TEMPERATURE	T						
COORDINATES X- Y- Z- 261	PRESSURE	P						
INSTALLED (Y/II): INSTAL. MFP: BY FIELD	REL. HUMIDTY	H						
QUALITY EXEMPT: N/A	CHEM. SPRAY	C						
QUALIF:	RADIATION	R						
STATUS:	AGING	A						
PHYS DNG MFC: CAR 2165 6436 504	SUBMERGENCE	S						
PHYS DNG LUCI: D-12	1958 CATEG.:	D						
MOUNTING:	APPENDIX E							
REV. DUC. LUCI: W.P.O. 285110								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: 2MS VI SAB-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW	/	ACCEL TIME
EQUIPMENT: VALVE	NORM/TEST	1 YEAR					ACCEL TEMPI
COMPONENT: SOLENOID V.	TEMPERATURE	111° F NORM 340° F DBA			FSAR TABLE FSAR FIG.	/ H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM 48 PSIA DBA				/ H	MAINTAIN.
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H	SUBCOMPONENTS
MODEL AND SERIAL #: 832185E	CHEMICAL SPRAY	N/A				/	
FUNCTIONS & SERVICE	R GAMMA	2.5 E4			FSAR FIG. 3.11B-23	/	
ACCUM. SPEC: N/A	A BETA	7.2 E4			CONT. RAD. ZONE R17	M	
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS:	T.I.D.	2.6 E4					
P.O. # 15176	AGE- INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51	/	SAFETY FUNCTIONS: MAIN STEAM ISOLATION VALVE
PLANT LOC.: A.B.	(PER 323-1974 DEF.)						
COORDINATES X= 1492.0	SUBMERGED	191.0			FSAR SECT. 3.6	/	
Y= 1605.0		YES					AUTH. REFERENCE:
Z= 279.0							
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165-G042 VENDOR DWG. 1364-2092				
QUALIF EXEMPT:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: CAR 2165 G 067 (F.13)	AGING	A	REVISION #: DATE: SYSTEM: MAIN STEAM TAG: 2MS VI SAB-1				
PHYS DNG LUC:	SUBMERGENCE	S					
MOUNTING:	FSAR ENV CAT:	A					
EDUC. LUC:	10588 CATEG.:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: 2MS VI SAB-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW	/		ACCEL TIME	
EQUIPMENT: VALVE	NORM/TEST	1 YEAR						ACCEL TEMP	
COMPONENTS: LIMIT SW.	TEMPERATURE	111 °F NORM 340 °F DBA			FSAR TABLE FSAR FIG.	/		REPLACEMENT	
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. 48 PSIA DBA				/		MAINTAIN.	
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/		SUBCOMPONENTS	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A				/			
ACCUM. SPEC: N/A	R GAMMA	2.5 E4			FSAR SECT. 3.11B-24	/			
ACCUM. DEM.: N/A	A BETA	7.2 E4			CONT. RAD. ZONE R17				
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 15176 CND # SH.1001 1002	T.I.D.	2.6 E4							
PLANT LOC.: A.B.	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51	/		SAFETY FUNCTIONS: MAIN STEAM ISOLATION VALVE	
COORDINATES X-1492.0 Y-1605.0 Z-279.0	SUBMERGED	191.0 YES			FSAR SECT. 3.6	/		AUTH. REFERENCES	
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165-6042 VENDOR DWG. 1364-2092				REVISION # DATE SYSTEM: MAIN STEAM TAG: 2MS VI SAB-1		
QUALIF. EXEMPT:	TEMPERATURE	T							
QUALIF. STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG REF: CAR 2165 G 067 (F-13)	AGING	A							
PHYS DWG LUC:	SUBMERGENCE	S							
MOUNTING:	FSAR ENV CAT:	A							
EDUC. LUC:	OS88 CATEG.:								
	APPENDIX E								



30

4

47

48

444

49



50



51

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/H	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEH.	QUALIF.	ACTUAL	DEH.	QUALIF.		
TAG NO: 2MS VI SAB-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW		/	ACCEL TIME	
EQUIPMENT: VALVE	NORM/TEST	1 YEAR						ACCEL TEMP	
COMPONENT: LIMIT SW.	TEMPERATURE	111 °F NORM 340 °F DBA			FSAR TABLE FSAR FIG.		/	REPLACEMENT	
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. 48 PSIA DBA					/	MAINTAIN.	
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/	SUBCOMPONENTS	
MODEL AND SERIAL # EA740-20100	CHEMICAL SPRAY	N/A					/		
FUNCTIONS & SERVICE	R GAMMA	2.5 E4			FSAR SECT. 3.11B-24		/		
ACCUM. SPEC: N/A	A BETA	7.2 E4			CONT. RAD. ZONE R17				
ACCUM. DEB.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS:	T.I.D.	2.6 E4							
P.O. # 15176 CND # SH.1001 1002	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTIONS: MAIN STEAM ISOLATION VALVE	
PLANT LOC.: A.B.	(PER 323-1974 DEF.)								
COORDINATES X=1492.0 Y=1605.0 Z=279.0	BURMEGED	191.0 YES			FSAR SECT. 3.6		/	AUTH. REFERENCE	
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
QUALIF EXEMPT:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165-9042 VENDOR DWG. 1364-2092						
QUALIF STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DWG REF: CAR 2165 G 067 (F-13)	AGING	A					REVISION #		
PHYS DWG LUCI MOUNTING	SUBMERGENCE	S					DATE		
EDUC. LUCI	FSAR ENV CAT:	A					SYSTEM: MAIN STEAM		
	10588 CATEG.:						TAG: 2MS VI SAB-1		
	APPENDIX E								



11

12

13

14

15

16



17

18



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	I/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2MS V2 SAB 1	OPERABILITY	40 YEARS	OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOL. VALVE	TEMPERATURE	340° F DBA	FSAR TABLE FSAR FIG.		H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM 48 PSIA DBA			H	MAINTAIN.
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)		H	SUBCOMPONENTS
MODEL AND SERIAL #: 832185E	CHEMICAL SPRAY	N/A			/	
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	2.5E4 7.2E4 100% BETA 2.6E4	FSAR FIG. 3.11B-23 CONT. RAD. ZONE R17		M	
ACCUM. SPEC: N/A	AGE-INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION: MAIN STEAM ISOLATION VALVE
ACCUM. DEH.: N/A	(PER 323-1974 DEF.)					
SPECIFICATIONS:	SUBMERGED	191% YES	FSAR SECT. 3.6		/	AUTH. REFERENCE:
P.O. # 15176 CHD # SH # 1003E 1004	PLANT LOC.: A.B.					
COORDINATES X=1502.0 Y=1605.0 Z=279.0						
INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPTN: QUALIFI: STATUS: PHYS DNG REF: CAR 2165 G067(F-1) PHYS DNG LOC: HOUSING: EDUC. LOC:	PARAMETER: OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE FSAR ENV CAT: 10588 CATEG. APPENDIX E	SUPPL. REVIEW: O T P H C R A S A	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: FLOW DIAG. 2165 G042 VENDOR DWG. 1364-2092	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM: MAIN STEAM TAG: 2MS V2 SAB 1		



100

100

100

100

100

100



100

100



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.
TAG NO: 2MS V2 SAB 1	OPERABILITY	40 YEARS NORMAL	2	3	OPERABILITY REVIEW	5	6	7	ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	111° F NORM 340° F DBA			FSAR TABLE FSAR FIG.		H		REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM 48 PSIA DBA					H		MAINTAIN.
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					H		
FUNCTIONS & SERVICE	R GAMMA	2.5 E4			FSAR FIG. 3.11B-23				
ACCUM. SPEC: N/A	A BETA	7.2 E4			CONT. RAD. ZONE R17		M		
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS:	T.I.D.	2.6 E4							
P.O. # 15176 CND # 1003	AGE				110 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS: MAIN STEAM ISOLATION VALVE
PLANT LOC.: A.B.	INST LIFE (PER 323-1979 DEF.)	40 YEARS							
COORDINATES X=1502.0 Y=1605.0 Z=279.0	SURMERGED	191° YES			FSAR SECT. 3.6				AUTH. REFERENCE
INSTALLED (Y/II): INSTAL. NEP: QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G042 VENDOR DWG						
STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG NEP: CAR 2165 G067 (F-14)	ACTING	A					REVISION #:		
PHYS DNG LUCI:	SURMERGENCE	S					DATE:		
MOUNTING:	FSAR ENV CAT:	A					SYSTEM: MAIN STEAM		
EV.DUC.LUCI:	0588 CATEG.:						TAG: 2MS V2 SAB 1		
	APPENDIX E								

3
3
3

121

444

17

8

2

2



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2MS V2 SAB1	OPERABILITY	40 YEARS			OPERABILITY REVIEW	/	ACCEL TIME	
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMP	
COMPONENT: SOL. VALVE	TEMPERATURE	111° F NORM 340° F DBA			FSAR TABLE FSAR FIG.	/ H	REPLACEMENT	
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM 48 PSIA DBA				/ H	MAINTAIN.	
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H	SUBCOMPONENTS	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A				/		
ACCUM. SPEC: N/A	R GAMMA	2.5 E4			FSAR FIG. 3.11B-23	/		
ACCUM. DEM.: N/A	A BETA	7.2 E4			CONT. RAD. ZONE R17	M		
SPECIFICATIONS:	D SHIELD	100% BETA						
P.O. # 15176 CND # SH. # 1003	T.I.D.	2.6 E4						
PLANT LOC.: A.B.	AGE- INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51	/	SAFETY FUNCTIONS: MAIN STEAM ISOLATION VALVE	
COORDINATES X- 1502.0	(PER 323-1974 DEF.)							
Y- 1605.0	SUBMERGED	191° O			FSAR SECT. 3.6	/		
Z- 279.0		YES					AUTH. REFERENCE	
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
INSTALL. REFS:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G042 VENDOR DWG					
QUALIF EXEMPT:	TEMPERATURE	T						
QUALIF:	PRESSURE	P						
STATUS:	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION AGING	R A						
PHYS DNG REF: CAR 2165 G047 (F-14)	SUBMERGENCE	S					REVISION # :	
PHYS DNG LUC:	FSAR ENV CAT:	A					DATE :	
MOUNTING:	10588 CATEG.:						SYSTEM: MAIN STEAM	
EDUC. LUC:	APPENDIX E						TAG: 2MS V2 SAB1	

1000

1000


1000

1000


1000



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: 2MS V3 SAB-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW	/		ACCEL TIME	
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: LIMIT SW.	TEMPERATURE	111° F NORM 340° F DBA			FSAR TABLE FSAR FIG.	/ H		REPLACEMENT	
MANUFACTURER: NAMCO	PRESSURE	20-90% NORM 100% DBA				/ H		MAINTAIN.	
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	100% DBA			FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H		SUBCOMPONENTS	
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A				/			
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	2.5E4 7.2E4 100% BETA 2.6E4			FSAR FIG. 3.11B-23 CONT. RAD. ZONE R17	/ M			
ACCUM. SPEC: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51	/		SAFETY FUNCTIONS MAIN STEAM RELIEF VALVE	
ACCUM. DEM.: N/A	SUBMERGED	191-0 YES			FSAR SECT. 3.6	/		AUTH. REFERENCE	
SPECIFICATIONS:									
P.O. # 15176 CND # 15H # 1005 41006									
PLANT LOC.: A.B.									
COORDINATES X= 1512.0 Y= 1605.0 Z= 279.0									
INSTALLED (Y/M):									
INSTAL. REFI QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165-G042 VENDOR DWG 1364-2092				REVISION # : DATE : SYSTEM : MAIN STEAM TAG : 2MS V3 SAB-1		
STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REFI CAR 2165 G067(F-15)	AGING	A							
PHYS DNG LUCI MOUNTING	SUBMERGENCE	S							
EM.DUC.LUCI	FSAR ENV CAT:	A							
	19588 CATEG.								
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: 2MS V3 SAB-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW	/	ACCEL TIME
EQUIPMENT: VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENTS: SOLENOID V.	TEMPERATURE	111° F NORM 340° F DBA			FSAR TABLE FSAR FIG.	/ H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. 48 PSIA DBA				/ H	MAINTAIN.
MAJOR SUPPLIER: ROCKWELL	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H	SUBCOMPONENTS
MODEL AND SERIAL #: FT 832185E	CHEMICAL SPRAY	N/A				/	
FUNCTIONS & SERVICE	R GAMMA	2.5E4			FSAR FIG. 3.11B-23	/	
ACCUR. SPEC: N/A	A BETA	7.2E4			CONT. RAD. ZONE R17	M	
ACCUR. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS:	T.I.D.	12.6E4					
P.O. # 15176 CND # 15H # 1005	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51	/	SAFETY FUNCTIONS MAIN STEAM ISOLATION VALVE
PLANT LOC.: A.B	(PER 323-1978 DEF.)						
COR. COORDINATES X=1512.0 Y=1605.0 Z=279.0	SUBMERGED	191% YES			FSAR SECT. 13.6	/	AUTH. REFERENCE
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTAL. NEFT:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165-6042 VENDOR DWG. 1364-2092			REVISION # DATE SYSTEM: MAIN STEAM TAG: 2MS V3 SAB-1	
QUALIF. EXEMPTN:	TEMPERATURE	T					
QUALIF. STATUS:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
STATUS:	CHEM. SPRAY	C					
STATUS:	RADIATION	R					
PHYS DNG NEFT: CAR 2165 G 067 (F-15)	AGING	A					
PHYS DNG LUC:	SUBMERGENCE	S					
MOUNTING:	FSAR ENV CAT:	A					
EW.DUC.LUC:	10588 CATEG.:						
	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL	DEH. QUALIF.		ITEMS
TAG NO: FT-IRC-414	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT: SENSOR	NORM/TEST	NORMAL					ACCEL TEMP
TYPE	DBA	POST DBA					REPLACEMENT
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120° F NORM		FSAR TABLE 9.4.0-1		/	
		FSAR FIG. 3.11.4-1		FSAR FIG. 3.11.4-1			
MANUFACTURER: BARTON		FOR DBA					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM		FSAR SECT. 3.11.6 NORM		/	
		SEE FSAR FIG. 3.11.6-1		FIG. 3.11.6-1 (DBA)			SUBCOMPONENTS
		FOR DBA					
MODEL AND SERIAL: 752 4774	RELATIVE HUMIDITY	40% NORM		FSAR TABLE 9.4.0-1 NORM		/	
		100% DBA		FSAR SECT. 3.11.4.3 (DBA)			
FUNCT. DES: REACTOR COOLANT & SERVICE	CHEMICAL SPRAY	2000-2100		FSAR SECT. 3.11.5.1		/	
		PRM BORON PH 8.5-11.0					
ACCUR. SPEC: N/A	R Gamma	1.2 E6		FSAR APP. 3.11.8-10		/	
ACCUR. DEH.: N/A	A BETA	3.3 E7		CONT. RAD. ZONE C3			
	D SHIELD						
	T.I.D.						
SPECIFICATIONS: N. PROJ. SPEC. 953328, R3 955270, RO	AGE			10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION
P.O #: 414524 CHD # 15K#0195	INST LIFE	40 YEARS					
PLANT LOC.: C.B.	(PER 323-1974 DEF.)						
COORDINATES X=1454.0 Y=1709.0 Z=230.0	SUBMERGED	228.3		FSAR SECTION		/	
							AUTH. REFERENCE
INSTALLED (Y/M):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTALL. REFI:	OPERABILITY	O					
QUALIF EXEMPT:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
PHYS DNG REF: CAR-2166 G 451	SUBMERGENCE	S					
PHYS DNG LOC: TOTAL EQUIP. LIST							
MOUNTING:	FSAR ENV CAT:						REVISION # :
EQ. DUC. LUC:	10588 CATEG.:						DATE :
	APPENDIX E						SYSTEM : REACTOR COOLANT
							TAG : FT-IRC 0414

REFERENCES:
 FLOW DIAG. CAR-2165 G 800


A/E: E SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON H NO. 1
 COMPONENT EVALUATION SHEET

HSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH.	QUALIF.			
TAG NO: FT IRC 415	OPERABILITY	40 YEARS			OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT: SENSOR	NORM/TEST DBA	NORMAL					ACCEL TEMP
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120° F NORM			FSAR TABLE 9.4.0-1		REPLACEMENT
MANUFACTURER: BARTON		FSAR FIG. 3.11.4-1			FSAR FIG. 3.11.4-1		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1			FSAR SECT. 3.11.6 NORM. FIG.		SUBCOMPONENTS
MODEL AND SERIAL: 752 4775		FOR DBA			3.11.6-1 (DBA)		
FUNCTIONS: REACTOR COOLANT & SERVICE	RELATIVE HUMIDITY	40% NORM			FSAR TABLE 9.4.0-1 NORM		
		100% DBA			FSAR SECT. 3.11.4.3 (DBA)		
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		
ACCUR. DEH.: N/A	R GAMMA	1.2 EG			FSAR APP. 3.11.8-18		
SPECIFICATIONS: 953328, R3	A BETA	3.3 E7			CONT. RAD. ZONE C3		
P.O. #: 44524 CHD # 15H#0195	D SHIELD	T.I.D.					SAFETY FUNCTION
PLANT LOC.: C.B.	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		
COORDINATES X=1456.0	(PER 323-1974 DEF.)						
Y=1717.0	SURMERGED	228.3			FSAR SECTION		AUTH. REFERENCE
Z=236.0							
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
INSTAL. REF:	OPERABILITY	O	REFERENCES: FLOW. DIAG. CAR-2165 & 800			REVISION # DATE SYSTEM: REACTOR COOLANT TAG: FT IRC 0415	
QUALIF EXEMPTN:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: CAR-2166 G451	AGING	A					
PHYS DNG LOC: TOTAL EQUIP. LIST	SURMERGENCE	S					
MOUNTING							
EQ. DUC. LUC:	FSAR ENV CAT:						
	10588 CATEG.:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: FTIRC 0416	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME:
EQUIPMENT: SENSOR	NORM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMP:
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1		/	REPLACEMENT:
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		/	MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		/	SUBCOMPONENTS:
MODEL AND SERIAL: 752 4776	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		/	
FUNCT. DES: REACTOR COOLANT & SERVICE	R GAMMA A BETA D SHIELD	1.2 EG 3.3 E7 T.I.D.		FSAR APP. 3.11.8-18 CONT. RAD. ZONE C3		/	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		110 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION:
ACCUR. DEH.: N/A	SUBMERGED	228.3		FSAR SECTION		/	AUTH. REFERENCE:
SPECIFICATIONS: W. PROJ. SPEC. 953328, R3, 955270, R0	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
P.O #: 414524 CHD # 15M.0196	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G 800				
PLANT LOC.: C.B.	TEMPERATURE	T					
COORDINATES X= 1460.0 Y= 1725.0 Z= 236.0	PRESSURE	P					
INSTALLED (Y/II):	REL. HUMIDTY	H					
INSTAL. REF:	CHEM. SPRAY	C					
QUALIF. EXEMPTN:	RADIATION	R	REVISION #			DATE	
*****	AGING	A	SYSTEM: REACTOR COOLANT			TAG: FTIRC 0416	
QUALIF. STATUS	SUBMERGENCE	S	APPENDIX E				
*****	FSAR ENV CAT:						
PHYS DNG REF: CAR-2166 G 451	19588 CATEG.:						
PHYS DNG LUC: TOTAL EQUIP. LIST	APPENDIX E						
MOUNTING							
EQ. DUC. LUC:							



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.					
TAG NO: <i>FT-IRC-424</i>	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/		ACCEL TIME	
EQUIPMENT: <i>SENSOR</i>	NORM/TEST DBA	NORMAL 1 YEAR						ACCEL TEMP	
COMPONENT: <i>FLOW TRANSMITTER</i>	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		/		REPLACEMENT	
MANUFACTURER: <i>BARTON</i>	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		/		MAINTAIN.	
MAJOR SUPPLIER: <i>WESTINGHOUSE</i>	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/		SUBCOMPONENTS	
MODEL AND: <i>752</i> SERIAL #: <i>4777</i>	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		/			
FUNCTIONS: <i>REACTOR COOLANT & SERVICE</i>	R GAMMA	1.2 EG		FSAR APP. 3.11.B-18 CONT. RAD. ZONE C3		/			
ACCUR. SPEC: <i>N/A</i>	A BETA	3.3 E7							
ACCUR. DEH.: <i>N/A</i>	D SHIELD								
SPECIFICATIONS: <i>W. PROJ. SPEC. 953328, R3 955270, RO</i>	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION	
P.O #: <i>414524</i> CHD #: <i>SM#0195</i>	SUBMERGED	228.3		FSAR SECTION		/			
PLANT LOC.: <i>C.B.</i>									
COORDINATES X- <i>1503.0</i> Y- <i>1646.0</i> Z- <i>236.0</i>								AUTH. REFERENCE	
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTALL. REF:	OPERABILITY	O	REFERENCES: <i>FLOW DIAG. CAR-2165.9800</i>				REVISION #: DATE: SYSTEM: <i>REACTOR COOLANT</i> TAG: <i>FT-IRC-424</i>		
QUALIF. EXEMPTN:	TEMPERATURE	T							
*****	PRESSURE	P							
*QUALIF:	REL. HUMIDTY	H							
*STATUS	CHEM. SPRAY	C							
*	RADIATION	R							
PHYS DMG REF: <i>CAR-2166.9450</i>	AGING	A							
PHYS DMG LUC: <i>TOTAL EQUIP. LIST</i>	SUBMERGENCE	S							
MOUNTING:	FSAR ENV CAT:								
EQ. DOC. LUC:	1988 CATEG.:								
	APPENDIX E:								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: FT-IRC425	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: SENSOR	NORM/TEST	NORMAL				ACCEL TEMP
TYPE: DBA	DBA	1 YEAR POST DBA				REPLACEMENT
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			MAINTAIN.
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 3.11.6-1 (DBA)			SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			
MODEL AND SERIAL: 752 4778	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
FUNCTIONS: REACTOR COOLANT & SERVICE	R GAMMA	1.2 EG	FSAR APP 3.11.8-10 CONT. RAD. ZONE C 3			
ACCUR. SPEC: N/A	A BETA D SHIELD	3.3 E7				
ACCUR. DEM.: N/A	T.I.D.					
SPECIFICATIONS: 955270, R0	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O #: 44524 CMD #: SH.#195	(PER 523-1974 DEF.)					
PLANT LOC.: C.B.	SUBMERGED	228.3	FSAR SECTION			AUTH. REFERENCE
COORDINATES X=1496.0 Y=1646.0 Z=236.0						
INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
*****	OPERABILITY	O	REFERENCES: CAR-2165-9800 - FLOW DIAG.			
QUALIF:	TEMPERATURE	T				
STATUS	PRESSURE	P				
*	REL. HUMIDTY	H				
*	CHEM. SPRAY	C				
*****	RADIATION	R				REVISION #
PHYS DNG REF: CAR-2166-9450	AGING	A				DATE
PHYS DNG LOC: TOTAL EQUIP LIST	SUBMERGENCE	S				SYSTEM: REACTOR COOLANT
MOUNTING						TAG: FT-IRC425
EQ.DOC.LUC:	FSAR ENV CAT:					
	10588 CATEG.:					
	APPENDIX E					

A/E: E SERVICES INC.
 UTILITY CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL 0.1
 COMPONENT EVALUATION REPORT

HSS9: WESTINGHOUSE - PMH
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: FT-IRC426	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120° F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS
MODEL AND: 752 SERIAL #: 4779	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			
FUNCTIONS: REACTOR COOLANT & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.2 EG 3.3 ET		FSAR APP 3.11.8-18 CONT. RAD. ZONE C3			
ACCUR. SPEC: N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
ACCUR. DEH.: N/A N. PRODU. SPEC. 953328, R3 955270, R0	SUBMERGED	228.3		FSAR SECTION			AUTH. REFERENCE
SPECIFICATIONS: P.O. # 144524 CHD # 195 PLANT LOC.: C.B.	INSTALL. REF: QUALIF EXEMPTN: ***** QUALIF: STATUS ***** PHYS DNG REF: CAR-2166 G450 PHYS DNG LUC: TOTAL EQUIP. LIST MOUNTING EQ. DUC. LUC:	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: FLOW DIAG. CAR-2165 G800	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION # DATE SYSTEM: REACTOR COOLANT TAG: FT-IRC 426			

A/E: SERVICES INC.
UTILITIES DIVISION
MILWAUKEE POWER & LIGHT

FACILITY: SHEARON II NO. 1
COMPONENT EVALUATION REPORT

ISSUED: WESTINGHOUSE - PHW
CAPACITY: 900 MW(E)

VN-
55-

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: FT-IRC 434	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT: SENSOR	NORM/TEST	1 YEAR					ACCEL TEMP
TYPE	DBA	POST DBA					REPLACEMENT
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		/	MAINTAIN.
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 FOR DBA		/	SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/	
MODEL AND: 752 SERIAL #: 4780	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		/	
FUNCTIONS: REACTOR COOLANT & SERVICE	R GAMMA	1.2 EG		FSAR APP. 3.11 B-18 CONT. RAD. ZONE C3		/	
ACCUR. SPEC: N/A	A BETA	3.3 ET					
ACCUR. DEM.: N/A	D SHIELD						
SPECIFICATIONS: N. PROJ. SPEC. 953328, R3 955270, R0	T.I.D.						
P.O. # 144524 CND # 15H-0195	AGE- INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION
PLANT LOC.: C.B.	(PER 323-1974 DEF.)						
COORDINATES X-1531.0 Y-1736.0 Z-236.0	SUBMERGED	228.3		FSAR SECTION		/	AUTH. REFERENCE
INSTALLED (Y/H):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTALL. REF:	OPERABILITY	O	REFERENCES:				
QUALIF EXEMPTN:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R				REVISION # : DATE :	
	AGING	A					
	SUBMERGENCE	S					
PHYS DWG REF: CAP-2166 G 451	FSAR ENV CAT:					SYSTEM: REACTOR COOLANT	
PHYS DWG LOC: TOTAL EQUIP. LIST	1988 CATEG.:						
MOUNTING:	APPENDIX E						
EQ. DOC. LOC:						TAG: FT-IRC 434	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: FT-IRC 435	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT TYPE: SENSOR	NORM/TEST	1 YEAR					ACCEL TEMP
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120° F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		/	REPLACEMENT
MANUFACTURE: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		/	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/	SUBCOMPONENTS
MODEL AND SERIAL: 752 4781	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		/	
FUNCTIONS: REACTOR COOLANT & SERVICE	R GAMMA A BETA D SHIELD	1.2 E6 3.3 E7		FSAR APP. 3.11.8-18 CONT. RAD. ZONE C3		/	
ACCUR. SPEC: N/A	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTIONS
ACCUR. DEH.: N/A	(PER 323-1979 DEF.)						
SPECIFICATIONS: W. PROJ. SPEC. 953328, R3 955270, R0	SURMERGED	228.3		FSAR SECTION		/	AUTH. REFERENCE
P.O. # 414524 CHD # 15K # 0195							
PLANT LOC.: C.B.							
COORDINATES X-1536.0 Y-1730.0 Z-236.0							
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. GAR. 2165 G 800				REVISION # DATE SYSTEM: REACTOR COOLANT TAG: FT-IRC 435
QUALIF EXEMPT:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DMG EFF: CAR-2166 G 451	AGING	A					
PHYS DMG LUC: TOTAL EQUIP LIST	SURMERGENCE	S					
HOUSING	FSAR ENV CAT:						
EW. OUC. LUC:	1958 CATEG:						
	APPENDIX E						

1000

1000

1000

1000

1000



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	ACTUAL DEH. QUALIF.	QUALIF. METHOD	H/M	OUTS	ITEMS
	PARAMETER	ACTUAL						
TAG NO: FT-IRC 436	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME:
EQUIPMENT TYPE: SENSOR	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP:
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1				REPLACEMENT:
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 3.11.6-1(DBA)				MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)				SUBCOMPONENTS:
MODEL AND SERIAL #: 752 4782	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1				
FUNCTIONS & SERVICE: REACTOR COOLANT	R GAMMA	1.2E6		FSAR APP. 3.11.B-18				
ACCUR. SPEC: N/A	A BETA	3.3E7		CONT. RAD. ZONE C1				
ACCUR. DEH.: N/A	D SHIELD	T.I.D.						
SPECIFICATIONS: N. PROJ. SPEC. 95328, R3 955270, R0	AGE-INST LIFE	40 YEARS (PER 323-1974 DEF.)		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS:
P.O. #: 414524 CHD # 58#0196	SUBMERGED	228.3		FSAR SECTION				AUTH. REFERENCE:
PLANT LOC.: C.B.								
COORDINATES X=1544.0 Y=1723.0 Z=236.0								
INSTALLED (Y/M):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES	
INSTAL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 9800				REVISION # : DATE : SYSTEM : REACTOR COOLANT TAG : FT-IRC 436.	
QUALIF EXEMPTN:	TEMPERATURE	T						
QUALIF:	PRESSURE	P						
STATUS:	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG REF: CAR-2166 G451	AGING	A						
PHYS DNG LOC: TOTAL EQUIP. LIST	SUBMERGENCE	S						
HOUNTING								
EQ. DUC. LOC:	SAR ENV CAT:							
	10588 CATEG.:							
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL	DEM.	QUALIF.
TAG NO: LT-IRC 459	OPERABILITY	40 YEARS	16 YRS.	NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 1673 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.			SRS TABLE PAGE 18 THRU 58	REVIEW		ACCEL TEMP: 125°C	
COMPONENT: LVL. XMTR.	TEMPERATURE	120°F NORM	104°F NORM.		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 & 10 SRS TABLE 19.10.4.3B	COMB. TYPE TEST & SUPP. REVIEW	H	NORM. SERV. TEMP. SEE TAB K	
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA	100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SRS TABLE Pg. 3D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
MODEL AND SERIAL: 764 1145	CHEMICAL SPRAY	2000-2100 PPM BORON	12500 PPM BORON		FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16 SRS TABLE Pg. 4D	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
FUNCTIONS: PRESSURIZER LVL. & SERVICE	R GAMMA	1.2 EG	168.10 EG		FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11 SRS TABLE Pg. 1C, 2C & 3C	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
ACCUM. SPEC: N/A	A BETA	3.3 EG	174.38 EG		CONT. RAD. ZONE C3					
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA							
SPECIFICATIONS: PROJECT SPEC. 95328 RI W.E. SPEC. DWG 8745D45, R 3	Y.I.D.	1.2 EG								
P.O. #1407118 CWD # 1145	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	5.99 YEARS		10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20 SRS TABLE Pg. 18 THRU 58	COMB. TYPE TEST & SUPP. REVIEW		NONE	
PLANT LOC.: CB 21	SURMERGED	228.3			FSAR SECTION 13.6	N/A				
COORDINATES X= Y= Z= 236.0		YES	N/A			SRS TABLE 19.1E			NONE	
INSTALLED (Y/N): INSTAL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A			
QUALIF EXEMPT: N/A	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G801.				REVISION # : 0 DATE : 6-21-84 SYSTEM : REACTOR COOLANT TAG : LT-IRC 459			
QUALIF: REQUIRES ANALYSIS	TEMPERATURE	T								
STATUS	PRESSURE	P								
	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
PHYS DWG REF: CAR 2165 G451	RADIATION	R								
PHYS DWG LUC: INSTRUMENT LIST MOUNTING	LAGING	A								
EQU. DOC. LUC: W/NO. 407118	SURMERGENCE	S								
	FSAR ENV CAT: 10500 CATEG. 1	A								
	APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/N/OUTS ITEMS		
	PARAMETER ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO: LT-IRC 460	OPERABILITY	40 YEARS	16 YRS. NORMAL	OPERABILITY	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	6.5 MO. POST DBA		SRS TABLE PAGE 15 THRU 51			ACCEL TEMP: 125 °C
COMPONENT: LVL. XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	H	REPLACEMENT: 5.99 YEARS
MANUFACTURER: BARTON	FSAR FIG. 3.11.4-1 FOR DBA		420 °F DBA	FSAR FIG. 3.11.4-1	SRS TABLE Pg. 1D, 3B			
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	MAINTENANCE: O-RINGS REPLACED 01 YR. CONNECTORS 30 YEARS
	FSAR FIG. 3.11.8-1 FOR DBA		80 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE Pg. 3D			SUBCOMPONENTS: O-RINGS & CONNECTORS
MODEL AND SERIAL: 764 1146	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.4 Pg. 14	COMB. TYPE TEST & SUPP. REVIEW	H	
FUNCTION: PRESSURIZER LVL. & SERVICE			100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE Pg. 3D			
	CHEMICAL SPRAY	2000-2100 PPM	12500 PPM	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16	COMB. TYPE TEST & SUPP. REVIEW	H	
ACCUM. SPEC: N/A		PRM BORON BORON	PH 8.5-11.0		SRS TABLE Pg. 4D			
ACCUM. DEM.: N/A	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11.B-20	TEST REPORT SECT. 5.2 Pg. 10 & 11	COMB. TYPE TEST & SUPP. REVIEW	H	
SPECIFICATIONS: PROJECT SPEC. 955328, R1 W.E. SPEC. DWG 8765D45, R 3	A BETA	3.3 E7	174.38 EG	CONT. RAD. ZONE C 3	SRS TABLE Pg. 1C, 2C & 3C			
P.O. # 407118 CND # 145	D SHIELD	100% BETA	100% BETA					
PLANT LOC.: CB 21	T.I.D.	1.2 EG						
COORDINATES X=1490.0 Y=1046.0 Z=236.0	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE ESE-3A, TAB B
INSTALLED (Y/M):	SURMERGED	228.3		FSAR SECTION 13.6	SRS TABLE Pg. 1E			AUTH. REFERENCE: M.J.H.
INSTALL. REF: BY FIELD	YES		N/A					
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
QUALIF: REQUIRES ANALYSIS	OPERABILITY	O ESE 3A		REFERENCES: FLOW DIAG. CAR 2165 G 801				
STATUS	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
PHYS DWG REF: CAR 2165 G 451	RADIATION	R					REVISION # : 0	
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	AGING	A					DATE: 6-21-84	
EQU. DUC. LUCI W/NO. 407118	SURMERGENCE	S					SYSTEM: REACTOR COOLANT	
	FSAR ENV CAT: 19588 CATEG. 1	A					TAG: LT-IRC 460	
	APPENDIX E							




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	W/MI UTS	ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL			
TAG NO: LT-IRC 461	OPERABILITY	40 YEARS	16 YRS. NORMAL	TEST REPORT SECT. 7.0 PAGE 17 THRU 20	COMB. TYPE TEST & SUPP.		ACCEL TIME: 1673 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	6.5 MO.	SRS TAB E PAGE 18 THRU 15B	REVIEW		ACCEL TEMP: 125 °C
COMPONENT: LVL. XMTR.	TEMPERATURE	120 °F NORM	104 °F NORM.	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9 (10) SUPP. REVIEW	H	REPLACEMENT: 5.99 YEARS
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SUPP. REVIEW	H	MAINTAIN. 0-RINGS REPLACED 1 YR. CONNECTORS 5 YEARS SUBCOMPONENTS 0-RINGS & CONNECTORS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM.	100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.4 Pg. 14 SUPP. REVIEW	H	
MODEL AND SERIAL: 764 1147	CHEMICAL SPRAY	2000-2100 PPM PRM BORON BORON PH 8.5-11.0	12500 PPM PH 10.7	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 Pg. 16 SUPP. REVIEW	H	
FUNCTIONS: PRESSURIZER LVL. & SERVICE	R GAMMA	1.2 EG	168.10 EG	FSAR FIG. 3.11B-20	TEST REPORT SECT. 5.2 Pg. 10 (11) SUPP. REVIEW	H	
ACCUM. SPEC: N/A	A BETA	3.3 E7	174.38 EG	CONT. RAD. ZONE C3	SRS TAB E Pg. 1C, 2C, 3C		
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 Pg. 20 SUPP. REVIEW		SAFETY FUNCTIONS: SEE ESE-3A, TAB B
SPECIFICATIONS: PROJECT SPEC. 955328, RI W.E. SPEC. DWG 8765D45, R 3	INST LIFE (PER 323-1979 DEF.)	40 YEARS	5.99 YEARS		SRS TAB E Pg. 1B THRU 5B		
P.O #: 407118 CND #: 145	SURMERGED	228.3	N/A	FSAR SECTION 13.6	N/A		AUTH. REFERENCE: M.J.H.
PLANT LOC.: CB 21		YES			SRS TAB E Pg. 1E		
COORDINATES X= 1490.0 Y= 1647.0 Z= 236.0							
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-3A
INSTAL. HEFT: BY FIELD	OPERABILITY	O ESE 3A	REFERENCES: FLOW DIAG. CAR 2165 G 801				REVISION #: 0 DATE: 6-21-84 SYSTEM: REACTOR COOLANT TAG: LT-IRC 461
QUALIF EXEMPT: N/A	TEMPERATURE	T					
QUALIF: REQUIRES ANALYSIS	PRESSURE	P					
STATUS	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DWG HEFT: CAR 2165 G 451	AGING	A					
PHYS DWG LUCI INSTRUMENT LIST MOUNTING	SURMERGENCE	S					
EQ. DUC. LUCI: W/RO. 407118	FSAR ENV CAT: 10500 CATEG. 1	A					
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: LT-IRC 1310 SA	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT LEVEL TRANSMITTER TYPE	ITY	NORMAL				ACCEL TEMP
	NORM/TEST	1 YEAR				
COMPONENTS:	DBA	POST DBA				REPLACEMENT
	TEMPERATURE	104°F NORM 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M	
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM 14 DBA				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE					M	SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	
FUNCTIONS & SERVICE: (RVLIS) REACTOR VESSEL LEVEL	CHEMICAL SPRAY	N/A			M	
ACCUM. SPEC: N/A	R GAMMA	1.5 ES	FSAR FIG. 3.11B-23		H	
ACCUM. DEM.: N/A	A BETA	17.2 E4	ZONE RG			
SPECIFICATIONS:	D SHIELD	100% BETA				
P.O. # 459261 CND # 1SH-139	Y.I.D.	1.6 ES				SAFETY FUNCTION
PLANT LOC.: AB 21	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			
CORORDINATES X-Y-Z: 2-236.0	SUBMERGED	191.0 YES	FSAR SECT. 13.6			AUTH. REFERENCE
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPT:	OPERABILITY	O	REFERENCES: FLOW. DIAG. CAR 2165 G844			REVISION # DATE
QUALIF:	TEMPERATURE	T				
STATUS:	PRESSURE	P				
:	REL. HUMIDTY	H				
:	CHEM. SPRAY	C				
PHYS DNG REF: CAR 2166 G437503	RADIATION	R				SYSTEM (RVLIS) REACTOR COOLANT TAG: LT-IRC 1310 SA
PHYS DNG LUC: H-4	AGING	A				
MOUNTING	SUBMERGENCE	S				
EDUC. LUC: P.O. 459261	FSAR ENV CAT: 1958B CATEG. 1					
	APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UNITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: LIS-IRC 1310 SA	OPERABILITY	40 YEARS	2	3	OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT: DIFF. PRESS. IND. SW. TYPE	INDM/TEST	1 YEAR						ACCEL TEMP	
COMPONENT:	TEMPERATURE	104° F DBA			IFSAR TABLE 9.4.0-1			REPLACEMENT	
MANUFACTURER: BARTON		104° F DBA			IFSAR FIG. 3.11B-4	M		MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA				M		SUBCOMPONENTS	
MODEL AND SERIAL #: 581	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			IFSAR TABLE 9.4.0-1 NORM. IFSAR SECT. 3.11.4.3 (DBA)	M			
FUNCTIONS: (RVLIS) & SERVICE, REACTOR VESSEL LEVEL	CHEMICAL SPRAY	N/A				M			
ACCUM. SPEC: N/A	R GAMMA	2.0E4			IFSAR FIG. 3.11B-23				
ACCUM. DEM.: N/A	A BETA	7.2E4			ZONE RG	H			
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 459261 END # 139	T.I.D.	4.0E4							
PLANT LOC.: AB21	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE ESE-49 TAB B	
COORDINATES X- Y- Z-236.0	(PER 325-1974 DEF.)								
INSTALLED (Y/N):	SUBMERGED	191.0 YES			IFSAR SECT. 3.6			AUTH. REFERENCE: M.J.H.	
INSTALL. KEYS:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49		
QUALIF EXEMPTN:	OPERABILITY	OR ESE-49	REFERENCES: FLOW DIAG. CAR 2165 G 844				REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : LIS IRC 1310SA		
QUALIF:	TEMPERATURE	T							
STATUS:	PRESSURE	P							
:	REL. HUMIDITY	H							
:	CHEM. SPRAY	C							
:	RADIATION	R							
PHYS DNG REF: CAR 2166 G 437 503	RAGING	A							
PHYS DNG LUCI G-4	SUBMERGENCE	S							
MOUNTING:	IFSAR ENV CAT:								
EN.DUC.LUCI by P.O. 459261	1958 CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: LT-IRC1311SA	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: LEVEL TRANSMITTER TYPE	NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT:	TEMPERATURE	104° F NORM 104° F DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M	REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA					M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					M	
FUNCTIONS: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	R GAMMA	1.5E5			FSAR FIG. 3.11B-23		H	
ACCUM. SPEC: N/A	A BETA	17.2E4			ZONE RG			
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS:	T.I.D.	1.6E5						
P.O. # 459261 CND # 1SH.139	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
PLANT LOC.: AB21	(PER 325-1974 DEF.)							
COORDINATES X= Y= Z=236.0	SUBMERGED	191.0 YES			FSAR SECT. 3.6			AUTH. REFERENCE
INSTALLED (Y/N): INSTAL. NEP: QUALIF EXEMPTN: QUALIFI: STATUS: PHYS DNG NEP: CAR 2166 6437 503 PHYS DNG LUCI: MOUNTING: EN.DUC.LUCI: P.O. 459261	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 9844					
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R	REVISION #:					
	DAGING	A	DATE:					
	SUBMERGENCE	S	SYSTEM: (RVLIS) REACTOR COOLANT					
	FSAR ENV CAT:		TAG: LT-IRC1311SA					
	19588 CATEG.:							
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UNITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: LIS-IRC 1311SA	OPERABILITY	40 YEARS			OPERABILITY			ACCEL TIME	
EQUIPMENT: DIFF. PRESS. IND. SW. TYPE	WDMH/TEST	NORMAL			REVIEW			ACCEL TEMP	
COMPONENTS:	DBA	1 YEAR						REPLACEMENT	
MANUFACTURER: BARTON	TEMPERATURE	104° F NORM			FSAR TABLE 9.4.0-1			MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	DBA	POST DBA			FSAR FIG. 3.11B-4	M		SUBCOMPONENTS	
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM							
FUNCTIONS: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	DBA	4 DBA				M			
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	20-90% NORM.			FSAR TABLE 9.4.0-1 NORM				
ACCUM. DEM.: N/A	DBA	100% DBA			FSAR SECT. 3.11.4.3 (DBA)	M			
SPECIFICATIONS:	CHEMICAL SPRAY	N/A				M			
P.O. # 459261 CHD # 1 SH. # 139	R GAMMA	2.0 E4			FSAR FIG. 3.11B-23			SAFETY FUNCTIONS: SEE ESE-49 TAB 7B	
PLANT LOC.: AB21	A BETA	7.2 E4			ZONE RG	H			
COORDINATES X= Y= Z=236.0	D SHIELD	100% BETA							
INSTALL. REF: QUALIF EXEMPT:	T.I.D.	4.0 E4							
QUALIF:	AGE				110 CFR 50 PARAGRAPH 50.51				
STATUS:	INST LIFE	40 YEARS							
PHYS DNG REF: CAR-2166 G437 503	(PER 323-1974 DEF.)								
PHYS DNG LUC: G-4	SUBMERGED	191.0			FSAR SECT. 3.6			AUTH. REFERENCE: M.J.H.	
MOUNTING:	YES								
EDUC. LUC: P.O. 459261	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49		
	OPERABILITY	O ESE-49	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # : DATE :		
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
	RADIATION	R	SYSTEM: (RVLIS) REACTOR COOLANT						
	AGING	A	TAG LIS-IRC 1311SA						
	SUBMERGENCE	S							
	FSAR ENV CAT:								
	10500 CATEG.:								
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: LT-IRC 1312 SA	OPERABIL- ITY	40 YEARS NORMAL			OPERABILITY REVIEW				ACCEL TIME:
EQUIPMENT: LEVEL TRANSMITTER TYPE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP:
COMPONENT:	TEMPERAT- URE	104° F NORM 104° F DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 13.11B-4.		M		REPLACEMENT:
MAINT. ALTERN: BARTON	PRESSURE	ATMOS. NORM. DBA					M		MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS:
MODEL AND: 752 SERIAL #	CHEMICAL SPRAY	N/A					M		
FUNCTION: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	R Gamma A BETA D SHIELD T.I.D.	11.5E5 12.2E4 100% BETA 11.6E5			FSAR FIG. 13.11B-23 ZONE RG		H		
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS			110 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION:
ACCUM. DEM.: N/A	SUBMERGED	191.0 YES			FSAR SECT. 13.6				AUTH. REFERENCE:
SPECIFICATIONS:									
P.O. # 459261 CND # 15H.139									
PLANT LOC. 1 AB21									
COORDINATES X- Y- Z-236.0									
INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPT: QUALIF: STATUS	PARA- METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE FSAR ENY CAT: 1958 CATEG. APPENDIX E	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
PHYS DNG REF: CAR 2166 G437 503 PHYS DNG LUC: H-4 MOUNTING EQ. DUC. LUC: by P.O. 459261			REFERENCES: FLOW DIAG. CAR 2165 G 844			REVISION # DATE			
						SYSTEM: (RVLIS) REACTOR COOLANT			
						TAG: LT-IRC 1312 SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/ UTS	UTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					
TAG NO: LT-IRC 1320 SB	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	4	5	6	7	ACCEL TIME
EQUIPMENT: LEVEL TRANSMITTER TYPE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT:	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4			M		REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM DBA					M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M		SUBCOMPONENTS
MODEL AND SERIAL #: 752	CHEMICAL SPRAY	N/A					M		
FUNCTIONS: (RVLIS) & SERVICE, REACTOR VESSEL LEVEL	R GAMMA	1.5 ES		FSAR FIG. 3.11B-23				H	
ACCUM. SPEC: N/A	A BETA	7.2 E4		ZONE RG					
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS:	T.I.D.	1.6 ES							
P.O. # 459261 CND # 1 SH. 140	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTIONS
PLANT LOC.: AB21	SUBMERGED	191.0 YES		FSAR SECT. 3.6					AUTH. REFERENCE
COORDINATES X= Y= Z=236.0									
INSTALLED (Y/11): INSTAL. REF: QUALIF EXEMPTN: QUALIFI: STATUS: PHYS DNG REF: CAR2166 G436 50Z PHYS DNG LUC: C-17 MOUNTING: EN.DUC.LUC: by P.O. 459261	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 844				REVISION #: DATE: SYSTEM (RVLIS) REACTOR COOLANT TAG LT-IRC 1320 SB		
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPIRAY	C							
	RADIATION	R							
	AGING	A							
	SUBMERGENCE	S							
	FSAR ENV CAT:								
	1958 CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					DEM. QUALIF.
TAG NO: LT-IRC 1321 SB	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIME:	
EQUIPMENT: LEVEL TRANSMITTER	ITY	NORMAL		REVIEW				ACCEL TEMP:	
COMPONENT:	NDHM/TEST DBA	1 YEAR POST DBA						REPLACEMENT:	
MANUFACTURER: BARTON	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-4		M		MAINTAIN:	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM DBA				M		SUBCOMPONENTS:	
MODEL AND SERIAL #: 752	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M			
FUNCT. USE: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	CHEMICAL SPRAY	N/A				M			
ACCUM. SPEC: N/A	R GAMMA	1.5E5		FSAR FIG. 3.11B-23		H			
ACCUM. DEM.: N/A	A BETA	7.2E4		ZONE RG.					
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 459261 CND # 1 SH. 140	Y.I.D.	1.6E5						SAFETY FUNCTION:	
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					
COORDINATES X= Y= Z=236.0	SUBMERGED	191.0 YES		FSAR SECT. 3.6				AUTH. REFERENCE:	
INSTALLED (Y/II): INDIAL. NEF: QUALIF EXEMPTN: QUALIF: STATUS: PHYS DNG NEF: CAR 2166 G436 502 PHYS DNG LUC: C-17 MOUNTING: EN. DUC. LUC: P.O. 459261	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #: DATE: SYSTEM (RVLIS) REACTOR COOLANT TAG LT-IRC 1321 SB		
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
	SUBMERGENCE	S							
	FSAR ENV CAT:								
	FSAR CATEG.:								
	APPENDIX E								



207

4

6

15

1932



208

1933



209

21

22

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL	DEM.	QUALIF.		
TAG NO: LT-IRC 1322 SB	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT: LEVEL TRANSMITTER TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENTS:	TEMPERATURE	104° F NORM 104° F DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M	REPLACEMENT	
MAINTENANCE: BARTON	PRESSURE	ATMOS. NORM. DBA					M	MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS	
MODEL AND SERIAL #: 752	CHEMICAL SPRAY	N/A					M		
FUNCT. USES (RVLIS) & SERVICE REACTOR VESSEL LEVEL	R GAMMA	1.5E5			FSAR FIG. 3.11B-23		H		
ACCUM. SPEC: N/A	A BETA	7.2E4			ZONE RG				
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS:	T.I.D.	1.6E5							
P.O. # 459261 CND # 5H.140	AGE - INST LIFE (PER 323-1978 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS	
PLANT LOC.: AB21	SUBMERGED	191.0 YES			FSAR SECT. 3.6				
COORDINATES X= Y= Z=236.0	OTHER EQUIPMENT THIS CES APPLIES TO:							AUTH. REFERENCE	
QUALIF. EXEMPT:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF. STATUS:	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 844				REVISION # : DATE : SYSTEM (RVLIS) REACTOR COOLANT TAG : LT-IRC 1322 SB		
	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DNG REF: CAR 2166 G 436 SOZ	RADIATION	R							
PHYS DNG LOC: C-17	SUBMERGENCE	S							
MOUNTING	FSAR ENV CAT:								
EDUC. LOC: P.O. 459261	10500 CATEG.								
	APPENDIX E								



2

12

13

14

15




16

17



18

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UITS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.				
TAG NO: LIS-IRC 1312 SA	OPERABILITY	40 YEARS NORMAL	2	3	5	6	7	
EQUIPMENT: DIFF PRESS. IND. SW. TYPE	NORM/TEST	1 YEAR						
COMPONENT:	DBA	POST DBA						
MANUFACTURER: BARTON	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M		
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA				M		
MODEL AND SERIAL #: 581	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		
FUNCTIONS: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	CHEMICAL SPRAY	N/A				M		
ACCUM. SPEC: N/A	R GAMMA	2.0E4		FSAR FIG. 3.11B-23		H		
ACCUM. DEM.: N/A	A BETA	7.2E4		ZONE RG				
SPECIFICATIONS:	D SHIELD	100% BETA						
P.O. # 459261 CWD # 15H#139	T.I.D.	7.0E4						
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				
COORDINATES X=	SUBMERGED	191.0		FSAR SECT. 3.6				
Y=		YES						
Z=236.0								
INSTALLED (Y/11):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49	
INSTAL. REF:	METER	O ESE-49	REFERENCES: ... FLOW DIAG. CAR 2165 G844				REVISION #: DATE: SYSTEM: (RVLIS) REACTOR COOLANT TAG: LIS-IRC 1312 SA	
QUALIF EXEMPT:	OPERABILITY	T						
QUALIFI:	TEMPERATURE	P						
STATUS:	PRESSURE	H						
:	REL. HUMIDTY	C						
:	CHEM. SPRAY	R						
PHYS DNG REF: CAR-2166 G437503	RADIATION	A						
PHYS DNG LUC: G-4	AGING	S						
MOUNTING:	SUBMERGENCE							
EV.DUC.LUC: P.O. 459261	FSAR ENV CAT:							
	10500 CATEG.:							
	APPENDIX E							



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: LIS-IRC 1320 SB	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT TYPE: DIFF. PRESS. IND. SW.	TEMPERATURE	NORMAL						ACCEL TEMP	
COMPONENT: DBA	NORM/TEST	1 YEAR						REPLACEMENT	
MANUFACTURER: BARTON	TEMPERATURE	104° F NORM			FSAR TABLE 9.4.0-1		M	MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	TEMPERATURE	104° F DBA			FSAR FIG. 3.11B-4			SUBCOMPONENTS	
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM					M		
FUNCTIONS & SERVICE: REACTOR VESSEL LEVEL	PRESSURE	DBA							
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	20-90% NORM			FSAR TABLE 9.4.0-1 NORM		M		
ACCUM. DEM.: N/A	RELATIVE HUMIDITY	100% DBA			FSAR SECT. 3.11.4.3 (DBA)				
SPECIFICATIONS:	CHEMICAL SPRAY	N/A					M		
P.O. # 459261 CND # 1139	R GAMMA	2.0 E4			FSAR FIG. 3.11B-23		H		
PLANT LOC.: AB21	A BETA	7.2 E4			ZONE RG				
COORDINATES X=	D SHIELD	100% BETA							
Y=	• T.I.D.	7.0 E4							
Z=236.0	AGE				10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS: SEE ESE-49 TAB B	
INSTALLED (Y/N):	INST LIFE	40 YEARS							
INSTALL. NEFT:	(PER 325-1974 DEF.)								
QUALIF EXEMPT:	SUBMERGED	191.0			FSAR SECT. 3.6			AUTH. REFERENCE: M.J.H.	
QUALIF:	YES								
STATUS:	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49		
PHYS DNG NEFT: CAR-2166 G436 S02	OPERABILITY	O ESE-49	REFERENCES: FLOW DIAG. 2165 G 844				REVISION # DATE		
PHYS DNG LUC: 13-17	TEMPERATURE	T							
MOUNTING:	PRESSURE	P							
EVALUATION: P.O. 459261	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
	SUBMERGENCE	S							
	FSAR ENV CAT:								
	1958 CATEG.:								
	APPENDIX E								

REVISION #
 DATE
 SYSTEM: (RVLIS) REACTOR COOLANT
 TAG: LIS-IRC 1320 SB

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: LIS-IRC 13215B	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	5		ACCEL TIME
EQUIPMENT: DIFF. PRESS. IND. SW. TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT:	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M	REPLACEMENT
MAINTENANCE: BARTON	PRESSURE	ATMOS. NORM DBA				M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS:
MODEL AND SERIAL: 501	CHEMICAL SPRAY	N/A				M	
FUNCTION & SERVICE: (RVLIS) REACTOR VESSEL LEVEL	R GAMMA	2.0E4		FSAR FIG. 3.11B-23		H	
ACCUM. SPEC: N/A	A BETA	7.2E4		ZONE RG			
ACCUM. DEH.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS:	T.I.D.	4.0E4					
P.O. # 459261 CND # 140	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE TAB B OF ESE-49
PLANT LOC.: AB21	(PER 523-1974 DEF.)						
CORORDINATES X=	SUBMERGED	191.0		FSAR SECT. 3.6			AUTH. REFERENCE: M.J.N.
Y=		YES					
Z=236.0							
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49
INSTAL. NEP:	OPERABILITY	O ESE-49	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #: DATE: SYSTEM (RVLIS) REACTOR COOLANT TAG LIS-IRC 13215B
QUALIF EXEMPT:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG NEP: CAR 2165 G436502	AGING	A					
PHYS DNG LUC: B-17	SUBMERGENCE	S					
MOUNTING:	FSAR ENV CAT:						
EN.DUC.LUC: by P.O. 459261	1958 CATEG:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/ UTS	UTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: LIS-IRC 1322 SB	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIMES
EQUIPMENT: DIFF. PRESS. IND. SW. TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT:	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-4		M	REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM DBA					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE						M	SUBCOMPONENTS
MODEL AND SERIAL #: 581	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	
FUNCTIONS: (RVLIS) & SERVICE REACTOR VESSEL LEVEL	CHEMICAL SPRAY	N/A				M	
ACCUM. SPEC: N/A	R GAMMA	2.0E4		FSAR FIG. 3.11B-23		H	
ACCUM. DEM.: N/A	A BETA	7.2E4		ZONE RG			
SPECIFICATIONS:	D SHIELD	100% BETA					
P.O. # 459261 CND # 140	T.I.D.	14.0E4					
PLANT LOC.: AB21	AGE - INST LIFE (PER 323-1978 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS: SEE TAB B OF ESE-49
COORDINATES X= Y= Z=236.0	SUBMERGED	191.0 YES		FSAR SECT. 3.6			AUTH. REFERENCE: M.J.H.
INSTALLED (Y/N): INSTAL. NEP: QUALIF EXEMPT: QUALIF: STATUS: PHYS ENG REF: CAR 2166 G 436 S02 PHYS DNG LUG: B-17 MOUNTING: EV. DUC. LUG: by P.O. 459261	PARAMETER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-49	
	OPERABILITY	O ESE-49	REFERENCES: .. FLOW DIAG. CAR 2165 G 844				
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R	REVISION # : DATE :				
	AGING	A					
	SUBMERGENCE	S	SYSTEM (RVLIS) REACTOR COOLANT TAG LIS-IRC 1322 SB				
	FSAR ENV CAT:						
	19588 CATEG.:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M UNITS	REMARKS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL			
TAG NO: PT-IRC 402	OPERABILITY	40 YEARS	10 YEARS	OPERABILITY	TEST REPORT SECT. 7.0	1	ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR	NORM/TEST	1 YEAR	6.523 MO.	REVIEW	PAGE 18 (19)		ACCEL TEMP: 125 °C
COMPONENT: PRESS. TRANSMITTER	DBA	POST DBA	POST DBA	FSAR TABLE	TEST REPORT SECT. 5.1	H/	NONE
MANUFACTURER: BARTON	TEMPERATURE	120 °F NORM	120 °F NORM	FSAR FIG. 3.11.4-1 FOR DBA	TEST REPORT SECT. 5.1	H/	NONE
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR FIG. 3.11.6-1 FOR DBA	TEST REPORT SECT. 5.4	H/	NONE
MODEL AND SERIAL: 763 584	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR FIG. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.4	H/	NONE
FUNCTIONS: WIDE RANGE PRESS. REACTOR COOLANT & SERVICE LCCP C	CHEMICAL SPRAY	2000-2100 PPM BORON	2000-2100 PPM BORON	FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 6.4	H/	NONE
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	15.0 E7	FSAR APP. 3.11.8-20	TEST REPORT SECT. 5.2	H/	NONE
ACCUM. H.H.I: N/A	A BETA	3.3 E7	90 E7	CONT. RAD. ZONE C3	TEST REPORT PAGE 11	H/	NONE
SPECIFICATIONS: 8765246, R3	SHIELD	100% BETA	68 E7	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5	H/	NONE
P.O. # 407118 CHD # 15M/197	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	5.99 YEARS	FSAR SECTION 3.6	TEST REPORT PAGE 21	H/	NONE
PLANT LOC.: C.B. 21	SURVEILED	228.3	N/A	OTHER EQUIPMENT THIS CES APPLIES TO: N/A	TEST REPORT PAGE 32	H/	NONE
COORDINATES X-1531.0 Y-1736.0 Z-236.0	INSTALL. REF: LATER	QUALIF: NOT QUALIF. REQUIRES MAJOR ANALYSIS	SUPPL. REVIEW: ESE-1	REFERENCES: FLOW DIAG. CAR-2165 G-800 TEST REPORT, EOIA, R1 EQUIP. QUAL. DATA PKG. ESE-1A, R3	TEST REPORT PAGE 32	H/	NONE
QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A	PHYS DNG EFFICACY: CAR-2166 G 451	PHYS DNG LUC: TOTAL EQUIP. LIST	SAH ENV CAT: A	REVISION # 10	TEST REPORT	H/	NONE
EV. DUC. LUC: P.O. 407118	APPENDIX E CATEG. A		1950B CATEG. 1	DATE: 12-29-84	TEST REPORT	H/	NONE
				SYSTEM: REACTOR COOLANT (RVLIS)	TEST REPORT	H/	NONE
				TAG: PT-IRC 402	TEST REPORT	H/	NONE

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL		
TAG NO: PT-IRC403 SB	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	5	ACCEL TIME
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: PRESS. TRANSMITTER	TEMPERATURE	120°F NORM 380°F FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	H	REPLACEMENT
MANUFACTURER: VERITRAK	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	H	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4-3 (DBA)	H	SUBCOMPONENTS
MODEL AND SERIAL: 762PH2 N1250023	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1	H	
FUNCTIONS: RCS WIDE RANGE & SERVICE LOOP A PRESS.	R GAMMA A BETA D SHIELD T.I.D.	1.2 EG 3.3 E7 100% BETA 1.2 EG		FSAR APP. 3.11B-25 CONT. RAD. ZONE C3	H	
ACCUR. SPEC: N/A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTION
ACCUR. DEM.: N/A	SUBMERGED	228.3		FSAR SECTION 13.6		AUTH. REFERENCE
SPECIFICATIONS:						
P.O. # 435002CND #						
PLANT LOC.: CB						
COORDINATES X= Y= Z= 236.0						
INSTALLED (Y/II):						
INSTAL. REF:						
QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
*****	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 844			REVISION # DATE SYSTEM (RVLIS) REACTOR COOLANT TAG PT-IRC403 SB
*****	TEMPERATURE	T				
*****	PRESSURE	P				
*****	REL. HUMIDTY	H				
*****	CHEM. SPRAY	C				
*****	RADIATION	R				
*****	AGING	A				
*****	SUBMERGENCE	S				
*****	FSAR ENV CAT					
*****	10580 CATEG.					
*****	APPENDIX E					



1
*2



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.		
TAG NO: PT-IRC-455	OPERABILITY	40 YEARS	10 YEARS	OPERABILITY TEST REPORT	COMB.	ACCEL TIME: 1673 HRS.
EQUIPMENT: SENSOR	ITY	NORMAL	NORMAL	REVIEW SECT. 7.0	TYPE TEST	NONE
	NONH/TEST	1 YEAR	6.525 MO.	PAGE 18 & 19	SUPP.	
COMPONENT: PRESS. TRANSMITTER	DBA	POST DBA	POST DBA	SRS TAB E	REVIEW	ACCEL TEMP: 125°C
	TEMPERATURE	120°F NORM.	120°F NORM.	FSAR TABLE	COMB.	INORM.
MANUFACTURER: BARTON	FSAR FIG.	3.11.4-1 FOR DBA	420°F DBA	9.4.0-1 FSAR FIG.	TYPE TEST	REPLACEMENT: 5.99 YRS.
	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	3.11.4-1 FSAR SECT.	SUPP.	SEE TAB K
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.8-1 FOR DBA	75 PSIA DBA	3.11.6 NORM. FIG.	TYPE TEST	MAINTAIN. O-RINGS REPLACED AT 1YR.
	RELATIVE HUMIDITY	40% NORM	100% NORM	3.11.6-1 (DBA) FSAR SECT.	SUPP.	CONNECTORS AT 5 YRS.
MODEL AND SERIAL: 763 581	FSAR FIG.	3.11.4.3 (DBA)	100% DBA	FSAR TABLE	REVIEW	SUBCOMPONENTS: O-RINGS CONNECTORS
	FUNCTIONS & SERVICE	PRESSURIZER & SERVICE PRESS.		TEST REPORT SECT. 5.4	TYPE TEST	
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	2000-2100 PPM BORON	3.11.5.1 FSAR SECT.	TYPE TEST	NONE
	PH 8.5-11.0	PH 8.5-11.0		TEST REPORT SECT. 6.4	SUPP.	
ACCUR. DEM. N/A	R GAMMA	1.2 EG	5.0 E7	FSAR APP. 3.11.8-20	TYPE TEST	NONE
	A BETA	3.3 E7	90 E7	CONT. RAD. ZONE C3	SUPP.	
SPECIFICATIONS: 87GSDA6, R3	D SHIELD	100% BETA	68 E7	SRS PAGE 1A THRU 3A	REVIEW	
	T.I.D.	1.2 EG				
P.O. # 407118 CND # SH. 148	AGE-INST LIFE	40 YEARS	5.99 YEARS	10 CFR 50 PARAGRAPH 50.51	TYPE TEST	NONE
	PLANT LOC.: C.B. 21			SRS PAGE 3.7, TAB K	SUPP.	
COORDINATES X= 1456.0 Y= 1653.0 Z= 236.0	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A	NONE
	INSTALLED (Y/M): LATER			SRS PAGE 1E TAB E		
QUALIF EXEMPT: NO	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A		
QUALIF NOT QUALIF. REQUIRES MAJOR ANALYSIS	OPERABILITY	O ESE-1	N/A	REVISION # 10 DATE 12-29-84 SYSTEM: REACTOR COOLANT TAG: PT-IRC-455		
PHYS DNG REF: CAR-2166 G-450	TEMPERATURE	T	REFERENCES:			
PHYS DNG LUCI: TOTAL EQUIP LIST	PRESSURE	P	FLOW DIAG. CAR-2165 G801			
HOUSING	REL. HUMIDTY	H	TEST REPORT EQIA, RI			
EV. DUC. LUCI: W/ P.O. 407118	CHEM. SPRAY	C	EQUIP QUAL. DATA PKG. ESE-1A, R3			
	RADIATION	R				
	AGING	A				
	SURMERGENCE	S				
	FSAR ENV CAT: A	A				
	1958R CATEG. 1					
	APPENDIX E CATEG A					

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO: PT-IRC 456	OPERABILITY	40 YEARS	10 YEARS	OPERABILITY	TEST REPORT			
	ITY	NORMAL	NORMAL	REVIEW	SECT. 7.0	COMB. TYPE TEST	ACCEL TIME: 1673 HRS.	
EQUIPMENT TYPE: SENSOR	NORM/TEST	1 YEAR	6.523 MO.		PAGE 18, 19	SUPP.	NONE	
COMPONENT: PRESS. TRANSMITTER	DBA	POST DBA	POST DBA		SRS TABLE	REVIEW	ACCEL TEMP: 125°C	
	TEMPERATURE	120°F NORM	120°F NORM	FSAR TABLE	TEST REPORT	COMB. TYPE TEST	NORM. REPLACEMENT: 5.99 YRS.	
		FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	9.4.0-1 FSAR FIG. 3.11.4-1	SECT. 5.1	SUPP.	H/	
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	SECT. 5.4	TYPE TEST	H/	
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA	75PSIA DBA	3.11.6-1 (DBA)	PAGE 14	SUPP.	NONE	
	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE	TEST REPORT	COMB. TYPE TEST	MAINTENANCE: O-RINGS REPLACED AT 1 YR. CONNECTORS AT 5 YRS. SUBCOMPONENTS: O-RINGS CONNECTORS	
MODEL AND SERIAL: 763 582		100% DBA	100% DBA	9.4.0-1 NORM	SECT. 5.4	SUPP.	H/	
FUNCTION & SERVICE: PRESSURIZER PRESSURE	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	2000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1	SECT. 6.4	TYPE TEST	H/	
ACCUR. SPEC: N/A					PAGE 17	SUPP.	NONE	
ACCUR. DEM: N/A	AGE-INST LIFE	40 YEARS	5.99 YEARS	110 CFR 50 PARAGRAPH 50.51	SECT. 7.5	TYPE TEST	NONE	
42 YRS 50% M.P.O. SPEC. 953328, R1 N.C. SPEC. DWG SPECIFICATIONS: 8765246, P3	(PER 325-1979 DEF.)				PAGE 21	SUPP.		
P.O. # 407118 CND # 1 SH 148	SURMERGED	228.3	N/A	FSAR SECTION 3.6	SRS TABLE	REVIEW	SAFETY FUNCTIONS: SEE TAB B ESE-1A	
PLANT LOC: C.B.					PAGE 32			
COORDINATES X=1490.0 Y=1648.0 Z=236.0								
INSTALLED (Y/M): LATER	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A	
INSTALL. HEFT: LATER	OPERABILITY	O ESE-1	N/A					
QUALIF EXEMPT: NO	TEMPERATURE	T						
QUALIF NOT QUALIF. REQUIRES MAJOR ANALYSIS	PRESSURE	P						
STATUS	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG HEFT: CAP-21666 450	AGING	A						
PHYS DNG LUCI: TOTAL EQUIP. LIST	SURMERGENCE	S						
HOUSING								
EDUC. LUC: M.P.O. 407118	FSAR ENV CAT: A							
	OSOR CATEG. I							
	APPENDIX E, CAT. A							
			REFERENCES: FLOW DIAG. CAP-2165 9801 TEST REPORT E01A, R1 EQUIP. QUAL. DATA PKG. ESE-1A, P3				REVISION # 10 DATE 12-29-84 SYSTEM REACTOR COOLANT	
							TAG: PT-IRC 456	

A/E: EBASC CES INC.
UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARR
COMPONENT EVALUATION SHEET

ISSUE: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

4

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO: PT-IRC 457	OPERABILITY	40 YEARS	10 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 18 & 19	COMB. TYPE TEST SUPP.	ACCEL TIME: 1673 HRS.	
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	6.525 MO.		SRS TAB E PAGE 18 THRU 5B	REVIEW	ACCEL TEMP: 125 °C	
COMPONENT: PRESS. TRANSMITTER	TEMPERATURE	120 °F NORM	120 °F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 9 & 10	COMB. TYPE TEST SUPP. REVIEW	REPLACEMENT: 5.99 YRS.	
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.4 PAGE 14	COMB. TYPE TEST SUPP. REVIEW	MAINTEN. O-RINGS REPLACED AT 1 YR.	
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	SRS TAB E PAGE 18 THRU 5B	H/	CONNECTORS AT 5 YRS.	
MODEL AND SERIAL: 763 583	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR SECT. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.4 PAGE 3C	COMB. TYPE TEST SUPP. REVIEW	SUBCOMPONENTS: O-RINGS CONNECTORS	
FUNCT. USE: PRESSURIZER & SERVICE PRESSURE	CHEMICAL SPRAY	2000-2100 PPM BORON	2000-2100 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.4 PAGE 17	COMB. TYPE TEST SUPP. REVIEW		
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	5.0 E7	FSAR APP 3.11.8-20	TEST REPORT SECT. 5.2 PAGE 11	COMB. TYPE TEST SUPP. REVIEW		
ACCUM. DEM: N/A	A BETA	3.3 E7	9.0 E7	CONT. RAD. ZONE C3	SRS TAB E PAGE 1A THRU 3A	H/		
W. PROJ. SPEC. 953328, 21	D SHIELD	100% BETA						
W. E. SPEC. DWG.	T.I.D.	1.2 EG	68 E7					
SPECIFICATIONS: 8765D46, R3	AGE-INST LIFE	40 YEARS	5.99 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.5 PAGE 21	COMB. TYPE TEST SUPP. REVIEW	SAFETY FUNCTIONS: SEE TAB B, ESE-1A	
P.O.: 407118 CHD # USA # 148	(PER 325-1979 DEF.)				SRS TAB E PAGE 3B			
PLANT LOC.: C.B. 21	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A	N/A		
COORDINATES X=1490.0		YES			SRS TAB E PAGE 1E		AUTH. REFERENCE: M.J.H.	
Y=1647.0								
Z=236.0								
INSTALLED (Y/M): LATER	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-1A	
INSTALL. REF: LATER	OPERABILITY	O ESE-1	N/A					
QUALIF EXEMPT: NO	TEMPERATURE	T						
QUALIF: NOT QUALIF. REQUIRES	PRESSURE	P						
STATUS MAJOR ANALYSIS	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
PHYS DWG REF: CAR-2166 G450	EMERGENCY	S						
PHYS DWG LOC: TOTAL EQUIP. LIST	ISAR ENV CAT: A						REVISION #: 0	
MOUNTING: WALL MOUNT	1958R CATEG.:						DATE: 12-29-84	
EV. DUC. LUC: W. P.O. 407118	APPENDIX F. CATEG. A						SYSTEM: REACTOR COOLANT	
							TAG: PT-IRC 457	

REFERENCES:
FLOW DIAG. CAR-2165 G801
TEST REPORT, EOIA, R1
EQUIP. QUAL. DATA PKG. ESE 1A, R3

12
14
16

22


24

26



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	DUIS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.				
TAG NO: IRC-V526SN-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 4.6 PAGE 11 & 25	/	ACCEL TIME: 15092 HOURS	
EQUIPMENT TYPE: VALVE GATE	NDM/TEST UDA	1 YEAR POST DBA	1 YEAR POST DBA				NONE	
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	NONE	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.6-1 (DBA)	REPORT 600456, PAGE 10 & 14 SRS TABLE PAGE 2B	COMB. TYPE TEST & SUPP. REVIEW	NONE	
MAJOR SUPPLIER: WESTHS.	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SEC. 4.4.3 PAGE 18 SRS TABLE PAGE 1E	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1E	
MODEL AND SERIAL: SB-00 222:61	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SEC. 4.4.2 PAGE 17 SRS TABLE PAGE 1D	COMB. TYPE TEST & SUPP. REVIEW	NONE	
FUNCTION: REACTOR COOLANT SERVING VALVE IRC-V526SN-1	R GAMMA	1.3 E7	130 EG	FSAR APP. 3.11.8-21	TEST REPORT SEC. 4.3 PAGE 12 SRS TABLE FIG THRU 3G	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1G	
ACCUR. SPEC: N/A	A BETA	3.7 E8	74 EG	CONT. RAD. ZONE CG				
ACCUR. DEM: N/A	D SHIELD	100% BETA	100% BETA					
SPECIFICATIONS: W.P.O.J. SPEC. 952065 05 W.E. SPEC. 678852 02	T.I.D.	1.3 E7	204 EG					
P.O. # 473662 CHD # 15H.#0160	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YE	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3 SRS TABLE PAGE 1F THRU 3F	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1F	
PLANT LOC.: C.B. 41	SUBMERGED	228.3		FSAR SECTION 3.6	N/A			
COORDINATES: X-1484.0 Y-1666.0 Z-309.0		YES	N/A		SRS TABLE PAGE 1A	N/A	NONE	
INSTALLED (Y/N): BY FLD.	OTHER EQUIPMENT THIS CES APPLIES TO:	PARA-METER	SUPPL. REVIEW					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
QUALITY EXEMPT: N/A	OPERABILITY	O	HE-1	REFERENCES: FLOW DIAG. CAR-2165G-801 LIMITORQUE TEST REPORT 600456				REVISION # : 0
QUALIF: QUALIFIED, AWAITING CONFIRMATORY DATA	TEMPERATURE	T						DATE: 4-21-84
STATUS: CONFIRMATORY DATA	PRESSURE	P						SYSTEM: REACTOR COOLANT
	REL. HUMIDTY	H						TAG: IRC-V526SN-1
	CHEM. SPRAY	C						
PHYS DNG EFFIC: CAR-2165 G 148	RADIATION	R						
PHYS DNG LUCI: TOTAL EQUIP LIST	AGING	A						
HOUSING: ...	SUBMERGENCE	S						
INDUC. LUCI: W. P.O. 173662	FSAR LIV CAT: 1950B CATEG.:	A						
	APPENDIX F.							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DES. QUALIF.	ACTUAL	DES. QUALIF.			
TAG NO: <i>IRC-V5275N-1</i>	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 14.6 PAGE 11 & 29		ACCEL TIME: 15092 HOURS	
EQUIPMENT TYPE: <i>VALVE GATE</i>	NORM/TEST DBA	1 YEAR	1 YEAR				ACCEL TEMP: 180°C	
COMPONENT: <i>MOTOR</i>	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 19.4.0-1	SRS TABLE 19.4.0-1 PAGE 1C THRU 1C	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 40 YEARS	
MANUFACTURER: <i>LIMITORQUE</i>	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. & FIG.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	MAINTAIN.	
MAJOR SUPPLIER: <i>WESTHS.</i>		FSAR FIG. 3.11.4-1 FOR DBA	1385°F DBA	3.11.6-1 (DBA)	SRS TABLE PAGE 2, 2		SUBCOMPONENTS: TORQUE & LIMIT SW.	
MODEL AND SERIAL: <i>SB-00 31111</i>	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 4.4.3 PAGE 18	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1E	
FUNCTIONS: <i>REACTOR COOLANT & SERVICE SERVING VALVE IRC-V5275N-1</i>	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW		
ACCUM. SPEC: <i>N/A</i>	R GAMMA	1.3 E7	130 EG	FSAR APP. 3.11.B-21	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1G	
ACCUM. DEM.: <i>N/A</i>	A BETA	3.7 E8	74 EG	CONT. RAD. ZONE C6	SRS TABLE PAGE 1G THRU 1G			
SPECIFICATIONS: <i>W. PROJ. SPEC. 952065 05 H.E. SPEC. 678862 02</i>	D SHIELD	100% BETA	100% BETA					
P.O. # <i>173662</i> CND # <i>13H#0161</i>	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1F	
PLANT LOC.: <i>C.B. 41</i>	SURMERGED	228.3		FSAR SECTION 3.6	N/A			
COORDINATES: <i>X=1484.0 Y=1669.0 Z=309.0</i>		YES	N/A		SRS TABLE PAGE 1A			
INSTALLED (Y/N): <i>BY FED.</i>	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
QUALIF EXEMPT: <i>N/A</i>	OPERABILITY	O HE-1		REFERENCES: <i>FLOW DIAG. CAP. 2165 G-801 LIMITORQUE TEST REPORT 600456</i>				REVISION # <i>10</i>
QUALIF: <i>QUALIFIED AWAITING</i>	TEMPERATURE	T						DATE: <i>14-21-84</i>
STATUS: <i>CONFIRMATORY DATA</i>	PRESSURE	P						SYSTEM: <i>REACTOR COOLANT</i>
	REL. HUMIDTY	H						TAG: <i>IRC-V5275N-1</i>
	CHEM. SPRAY	C						
PHYS DNG RFF: <i>CAR-2165 G 148</i>	RADIATION	R						
PHYS DNG LUCI: <i>TOTAL EQUIP. LIST</i>	AGING	A						
HOUSING: <i>N/A</i>	SURMERGENCE	S						
EDUC. LUCI: <i>W. P.O. 173662</i>	FSAR ENV CAT: <i>19588 CATEG. 1</i>	A						
	APPENDIX F							



AZEL EDASC FACLES INC.
UTILITY: () IA POWER & LIGHT

FACILITY: SHEARON HARBOR U.1
COMPONENT EVALUATION

ISSUE: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

EVN- 0

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	I/M ITEMS	UNITS		
	PARAMETER	ACTUAL	DES. QUALIF.	ACTUAL				DES. QUALIF.	
TAG NO: <i>IRC-V528SN-1</i>	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 22	TYPE TEST	NONE	ACCEL TIME: 15092 HRS.	
EQUIPMENT TYPE: <i>VALVE GATE</i>	REPAIR/TEST	1 YEAR	1 YEAR					ACCEL TEMPI: 180°C	
COMPONENT: <i>MOTOR</i>	TEMPERATURE	120°F NORM	144°F NORM.	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1 FOR DBA	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	NONE	REPLACEMENT: 40 YEARS	
MAINTENANCE: <i>LIMITORQUE</i>	PRESSURE	ATMOS NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.6-1 (DBA)	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	NONE	MATERIAL:	
MAJOR SUPPLIER: <i>WESTHS.</i>	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 4.4.3 PAGE 18 SRS TABLE PAGE 1E	COMB. TYPE TEST & SUPP. REVIEW	NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.	
MODEL AND SERIAL: <i>SB00</i>	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	3000 PPM BORON PH 10.5-11.1	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17 SRS TABLE PAGE 1D	COMB. TYPE TEST & SUPP. REVIEW	NONE		
FUNCTION: <i>REACTOR COOLANT & SERVICE SERVING VALVE IRC-V528SN-1</i>	R GAMMA	1.3E7	130 EG	FSAR APP. 3.11.8-21	TEST REPORT SEC. 4.3 PAGE 12, SRS TABLE PAGE 1G THRU 3G	COMB. TYPE TEST & SUPP. REVIEW	NONE		
ACCUR. SPEC: <i>N/A</i>	B BETA	3.7E8	74 EG	CONT. RAD. ZONE CG					
ACCUR. DES: <i>N/A</i>	D SHIELD	100% BETA	100% BETA						
SPECIFICATIONS: <i>W.P.D.I. SPEC. 952065 05 W.E. SPEC. 678852 02</i>	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3 SRS TABLE PAGE 1F THRU 3F	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE TAB "B" OF HE-1	
P.O. # <i>173662</i> CHD # <i>ISH#0250</i>	SUBMERGED	228.3		FSAR SECTION 3.6					
PLANT LOC.: <i>C.B. 21</i>		YES	N/A						
COORDINATES X- <i>1459.0</i> Y- <i>1701.0</i> Z- <i>241.0</i>								AUTH. REFERENCE: M.J.H.	
INSTALLED (Y/M): INSTAL. REFI: <i>BY FLD.</i>	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1		
QUALITY EXEMPT: <i>N/A</i>	OPERABILITY	O HE-1	REFERENCES: <i>FLOW DIAG. CAR-2165 G-801 LIMITORQUE TEST REPORT 600456</i>				REVISION # 10 DATE 14-21-84 SYSTEM <i>REACTOR COOLANT</i> TAG <i>IRC-V528SN-1</i>		
QUALIF: QUALIFIED, AWAITING	TEMPERATURE	T							
STATUS CONFIRMATORY DATA	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
PHYS DNG REFI: <i>CAR-2165 G-148</i>	RADIATION	R							
PHYS DNG LUCI: <i>TOTAL EQUIP. LIST</i>	AGING	A							
HOUSING	SUBMERGENCE	S							
ED. DOC. LUCI: <i>W.P.O. 173662</i>	FSAR LIV CAT: 1950A CATEG. 1	A							
	APPENDIX F								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/WI UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2RC-DS25 SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	ENVIRONMENT	NORMAL					ACCEL TEMP
	NOHM/TEST DBA	1 YEAR POST DBA					REPLACEMENT
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			MAINTAIN.
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			
FUNCTION: SERVING VALVE & SERVICE 2RC-DS25 SB-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
ACCUM. SPEC: N/A	R GAMMA	2.5E4		FSAR FIG. 3.11B-			
ACCUM. DEM.: N/A	A BETA	4.4 E5		RAD. ZONE R11			
SPECIFICATIONS: GEN. E-SPEC. 678853, R2 PROJ. E-SPEC. 952073, R4	D SHIELD	100% BETA					SAFETY FUNCTIONS
	T.I.D.	2.6E4					
P.O. #162148	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			
PLANT LOC.: A.B. 21	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
COORDINATES X=1556.0 Y=1657.0 Z=245.0		YES					
INSTALLED (Y/II): INST. MFR: BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIFI STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378DI9, 1364-4469 FLOW DIAG. CAR 2165 6801 (C-17)				REVISION # DATE SYSTEM: REACTOR COOLANT TAG: 2RC-DS25 SB-1
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
	EMERGENCY	S					
	19500 CATEG. I						
	APPENDIX E						


EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/US	USIS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: ZRC-D525 SB-1	OPENABIL-ITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIMES	
EQUIPMENT: AIR OPERATED VALVE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT	
MAINTALIENCE: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS	
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
FUNCTIONS: SERVING VALVE & SERVICE ZRC-D525 SB-1	R GAMMA	2.5E4		FSAR FIG. 3.11B-					
ACCUM. SPEC: N/A	A BETA	4.4.E5		RAP. ZONE R11					
ACCUM. DEN.: N/A	D SHIELD	100% BETA		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
SPECIFICATIONS: GEN. E-SPEC. 678853, R2 PROJ. E-SPEC. 952073, R4	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS		FSAR SECT. 3.6	N/A			AUTH. REFERENCES	
P.O. # 162148 CND # 1	BURMEGED	1910° YES	N/A						
PLANT LOC.: A-TS. 21									
COORDINATES X= 1556.0 Y= 1657.0 Z= 245.0									
INSTALLED (Y/M):	PARAMETER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES		
INSTAL. NEPS BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378D19, 13CA-4469 FLOWING. CAR21GS 9801 (C-17)				REVISION # DATE SYSTEM: REACTOR COOLANT TAG: ZRC-D525 SB-1		
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIFI	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
PHYS DRG NFFI CAR 21GS 9108	EMERGENCY	S							
PHYS DRG LUCI F-9									
MOUNTING									
EDUC. LUCI w/ P.O. 162148									
	19588 CATEG. 1								
	APPENDIX E								

1
2
3
4
5



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	DUIS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: ZRC-D528SA-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW	/	ACCEL TIME
EQUIPMENT TYPE: VALVE DIAPH.	HURH/TEST DBA	1 YEAR POST DBA				/	ACCEL TEMP
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	/ H	REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA			FSAR SECT. 3.11.6 NORM. { FIG. 3.11.6-1 (DBA)	/ H	MAINTAIN.
MAJOR SUPPLIER: GRINNELL	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H	SUBCOMPONENTS
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1	/ H	
FUNCTION: REACTOR COOLANT & SERVICE SERVING VALVE ZRC-D528SA-1	R GAMMA	1.2 EG			FSAR APP 3.11.8-18 CONT. RAD. ZONE C3	/ H	
ACCUR. SPEC: N/A	A BETA	3.3 E7					
ACCUR. DEM.: N/A	D SHIELD	T.I.D.					
SPECIFICATIONS: W. PROJ. SPEC. 952067 02 W.E. SPEC. 078845 01 P.O. # 191003 CHO # 15K#0170	AGE-INST LIFE	40 YEARS (PER 323-1979 DEF.)			10 CFR 50 PARAGRAPH 50.51	/	SAFETY FUNCTIONS
PLANT LOC.: C.B. 21	SUBMERGED	228.3 YES		N/A	FSAR SECTION	N/A /	AUTH. REFERENCES
COORDINATES: X-1508.0 Y-1639.0 Z-255.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTALLED (Y/N): BY FLD.	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-21659-801				
QUALIF. EXEMPT: N/A	TEMPERATURE	T					
STATUS	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG EFF: CAR-21659-147	AGING	A					
PHYS DNG LUC: TOTAL EQUIP. LIST	SUBMERGENCE	S					
HOURLING: N/A	FSAR ENV CAT:	A					
EDUC. LUC: 3.2	1988 CATEG.:						
	APPENDIX E						REVISION #: DATE: SYSTEM: REACTOR COOLANT TAG: ZRC-D528SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2RC-D5285A-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT TYPE: VALVE DIAPH.	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA	FSAR SECT. 3.11.6 NORM. { FIG. 3.11.6-1 (DBA)			MAINTAIN.
MAJOR SUPPLIER: GRINNELL	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #: EA170-14302	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
FUNCTIONS: REACTOR COOLANT & SERVICE SERVING VALVE 2RC-D5285A-1	R GAMMA	1.266	FSAR APP 3.11.8-18 CONT. RAD. ZONE C3			
ACCUR. SPEC: N/A	A BETA	3.367				
ACCUR. DEH.: N/A	D SHIELD					
SPECIFICATIONS: W. PROJ. SPEC. 952067 02 N.E. SPEC. 6784501	T.I.D.					
P.O. #: 191003 CND #: 3400170	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
PLANT LOC.: C.B.21	SUBMERGED	228.3 YES	FSAR SECTION			AUTH. REFERENCE
COORDINATES X- 1509.0 Y- 1639.0 Z- 255.0						
INSTALLED (Y/N): BY FLD.	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-801			
QUALIF:	TEMPERATURE	T				
STATUS:	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
PHYS DNG REF: CAR-2165 G-147	AGING	A				REVISION # :
PHYS DNG LUC: TOTAL EQUIP. LIST	SUBMERGENCE	S				DATE :
MOUNTING: N/A						SYSTEM: REACTOR COOLANT
EDUC. LUC: 9.2	FSAR ENV CAT: A					TAG: 2RC-D5285A-1
	19588 CATEG.:					
	APPENDIX E					



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	M/M	UNIT	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: ZRC-DS29SB-1	OPENABILITY	40 YEARS NORMAL			OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
FUNCTION: SERVING VALVE & SERVICE ZRC-DS29SB-1	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-				
ACCUM. SPEC: N/A	R GAMMA	2.0E4			FSAR FIG. 3.11B-				
ACCUM. DEM.: N/A	A BETA	7.2E4			IRAD. ZONE TRG				
SPECIFICATIONS: GEN. E-SPEC. 952067,R2 678845,R1	D SHIELD	100% BETA							
P.O. # 191003 CND # 1	T.I.D.	19.2E4							
PLANT LOC. 1A.B.21	ACC. INST LIFE (PER 323-1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
COORDINATES X=1510.0 Y=1610.0 Z=236.0	BURNISHED	1910° YES	N/A		FSAR SECT. 3.6	N/A			AUTH. REFERENCES

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF CRAMPING: N/A
 QUALIF STATUS:
 PHYS DWG HFF: CAR-2165 G182
 PHYS DWG LIC: K-10
 MOUNTING:
 ED. DUC. LUC: w/ P.O. 191003

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 EMERGENCY S
 1958 CATEG. 3
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIED TO:

REFERENCES:
 VENDOR DWG SD-C-102864
 1364-2947
 FLOW DIAG. CAR-2165 G801 (C-17)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM REACTOR COOLANT TAG: ZRC-DS29SB-

1

2

3


4

5

6

7

EQUIPMENT DESCRIPTION	ENVIRONMENTAL		DOCUMENTATION		QUALIF. METHOD	N/M/ U/S	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2RC-D529SB-1	UPENABIL-ITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2RC-D529SB-1	R GAMMA	2.0E4			FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	17.2E4			RAD. ZONE RC			
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 952067,RZ GEN. E-SPEC. 678845,R1	T.I.D.	19.2E4						
P.O. # 191003 END # 1	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A.B.21	(PER 323-1979 DEF.)							
COORDINATES X= 1510.0 Y= 1610.0 Z= 236.0	BURMEGED	1910" YES	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES
INSTALLED (Y/M): INDIAL. NEPI BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. SD-C-102864 1364-2947 FLOW DIAG. CAR-21654801 (C-17)					
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
PHYS DNG OFFICAR-21654182	RADIATION	R						
PHYS DNG LUCI K-10	AGING	A					REVISION #	
MOUNTING	EMERGENCY	S					DATE	
EN. DUC. LUCI w/ P.O. 191003	19500 CATEG. APPENDIX E						SYSTEM REACTOR COOLANT	
							TAG 2RC-D529SB-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO: TE-IRC 0410	OPERABILITY	40 YEARS	20 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 116	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR POST DBA	6.52 MO. POST DBA		SRS TAB E PAGE 15 THRU 15			ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM.	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 9	COMB. TYPE TEST & SUPP. REVIEW	H NONE	REPLACEMENT: 20 YEARS
MANUFACTURER: R&F	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.6 PAGE 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE	MAINTAIN:
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA	8 PPSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TAB E PAGE 13 & 28			SUBCOMPONENTS:
MODEL AND SERIAL: 21205 213	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SECT. 5.6 PAGE 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
FUNCTIONS: REACTOR COOLANT & SERVICE LOOP 1 COLD LEG TEMP.				FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E P. 66 OF 110			
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	12750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.6 PAGE 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
ACCUM. DEM.: N/A W.E. SPEC. 953332, DWG. #3258, N/G	R GAMMA A BETA D SHIELD T.I.D.	1.1 EG 17 E7 100% BETA 1.15 EG	24.7 E7 GAMMA 91.3 E7 BETA 100% BETA 24.7 E7	FSAR APP. 3.11.8-20 CONT. RAD. ZONE C1	TEST REPORT SECT. 5.3 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
P.O. # 265762 CHD # 15N.#184	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	20 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 16	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE TABS OF ESE-5
PLANT LOC.: C.B.21	SUBMERGED	228.3	N/A	FSAR SECTION 3.6	N/A	N/A	NONE	AUTH. REFERENCES: M.J.H.
COORDINATES X=1470.0 Y=1703.0 Z=255.0		YES			SRS TAB E PAGE 1A			

INSTALLED (Y/N):
 INSTAL. REF: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF: QUALIFIED -
 STATUS: WITHOUT EXCEPTION
 PHYS DWG REF: CAR-2165 G163
 PHYS DWG LUC: C-16
 MOUNTING:
 EQ. DOC. LUC: W.P.O. 265762

PARAMETER	SUPPL. REVIEW
OPERABILITY	O ESE-5
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION AGING	R A
SUBMERGENCE	S
FSAR ENV CAT: 10588 CATEG. A	
APPENDIX E	


OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 FLOW DIAG. CAR. 2165 G800

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES ESE-5

REVISION # : 0
 DATE : 16-13-84
 SYSTEM : REACTOR COOLANT
 TAG : TE-IRC 0410

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/HI OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAB NO: TE-IRC 0411B	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA	NORMAL 6.25 MO. POST DBA	REVIEW	SRS TABLE P. 17 THRU 4F			ACCEL TEMP: 400 °F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120 °F NORM	122 °F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE TEST & SUPP. REVIEW	H NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: Rdf	FSAR FIG.	3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	SRS TABLE P. 7G OF 9G			MAINTAIN:
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H NONE	SUBCOMPONENTS:
	FSAR FIG.	3.11.8-1 FOR DBA	81PSIA DBA	3.11.6-1 (DBA)	SRS TABLE P. 7G OF 9G			
MODEL AND SERIAL: 21204 216	RELATIVE HUMIDITY	40% NORM 100% DBA	100% NORM 100% DBA	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
FUNCTIONS & SERVICE: REACTOR COOLANT, DIFF. TEMP. TEMP. AVG. CONTROL HOT LEG	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	12750 PPM BORON PH 10.7 @ 25 °C	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
ACCUM. SPEC: N/A	R GAMMA	1.1 EG	124.7 E7 GAMMA	FSAR APP. 3.11.8-20	TEST REPORT SECT. 5.3 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	H NONE	
ACCUM. DEM. N/A N.E. SPEC. 95337 RO DWG. 43252 X7	A BETA	1.7 E7	191.7 E3 BETA	CONT. RAD. ZONE C1	SRS TABLE P. 17 THRU 4F			
SPECIFICATIONS:	D SHIELD	100% BETA	100% BETA					
P.O. # 265762 CND # 15H.#187	T.I.D.	1.15 EG	124.7 E7					
PLANT LOC.: C.B. 21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE TAB B OF ESE-6
COORDINATES X=1478.0 Y=1708.0 Z=236.0	SUBMERGED	228.3 YES	NA	FSAR SECTION 3.6	SRS TABLE PAGE 1A			AUTH. REFERENCE: H. J. H.
INSTALLED (Y/H):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6		
INSTAL. KEYS BY FIELD	OPERABILITY	O ESE-6	REFERENCES: FLOW DIAG. CAR-2165 6802			REVISION # : 0 DATE 16-12-84 SYSTEM : REACTOR COOLANT TAG : TE-IRC 0411B		
QUALIF EXEMPT: N/A	TEMPERATURE	T						
QUALIF QUALIFIED	PRESSURE	P						
STATUS WITHOUT EXCEPTION	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG KEYS: CAR-2165 G163	ACTION	A						
PHYS DNG LUCI: TOTAL EQUIP. LIST	SUBMERGENCE	S						
MOUNTING	FSAR ENV CAT: 19580 CATEG. 1	A						
EQ. DOC. LUCI: W. RO. 265762	APPENDIX E							



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	UNIT	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEH. QUALIF.					
TAG NO: TE-IRC 0411C	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW			ACCEL TIME: 264 HOURS	
EQUIPMENT: SENSOR TYPE	NDRH/TEST DBA	1 YEAR	6.52 MO. POST DBA		SRS TABLE P. 1F THRU 4F			NONE	ACCEL TEMP: 400°F	
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM.	FSAR TABLE 9.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	REPLACEMENT: 23 YEARS	
MANUFACTURER: K&F	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	SRS TABLE P. 7G OF 9G				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: 21204 217	FSAR FIG. 3.11.8-1 FOR DBA		81 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE P. 7G OF 9G					
FUNCTIONS: REACTOR COOLANT, DIFF. TEMP. - TEMP. AVG. CONTROL - COLD LEG	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE		
	FSAR SECT. 3.11.4.3 (DBA)		100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE P. 7G OF 9G					
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE		
	PH 8.5-11.0		PH 10.7		SRS TABLE P. 8G OF 9G					
ACCUR. DEM.: N/A	R GAMMA	1.1 EG	24.7 ETG	FSAR APP 3.11.8-20	TEST REPORT SECT. 5.3 PAGE 9 (10)	COMB. TYPE TEST & SUPP. REVIEW	H	NONE		
	A BETA	1.7 E7	91.3 E7 BETA	CONT. RAD. ZONE C1	SRS TABLE P. 1E THRU 4E					
SPECIFICATIONS: N.E. SPEC. 45337, RD 4257, R7	T.I.D.	1.15 EG	24.7 E7							
P.O. #: 265762 CHD #:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW		NONE	SAFETY FUNCTION: SEE TAB B OF ESE-G	
PLANT LOC.: C.B..21	SURMERGED	228.3		FSAR SECTION 3.6	N/A	N/A		NONE	AUTH. REFERENCE: M.J.H.	
COORDINATES X= 1472.0 Y= 1702.0 Z= 236.0		YES	N/A							
INSTALLED (Y/H): BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G			
QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G 802							
QUALIF: QUALIFIED	TEMPERATURE	T								
STATUS: WITHOUT EXCEPTION	PRESSURE	P								
	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
	RADIATION	R								
PHYS DNG REF: CAR-2165 G163	AGING	A	REVISION # 10				DATE 16-18-84			
PHYS DNG LUC: TOTAL EQUIP LIST	SURMERGENCE	S	SYSTEM: REACTOR COOLANT				TAG: TE-IRC 0411C			
EDUC. LUC: w/p.o. 265762	FSAR ENV CAT: 10588 CATEG. A	A								
	APPENDIX E									




1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.			
TAG NO: TE-IRC 0412A	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	ACCEL TIME: 264 HOURS
EQUIPMENT TYPE: SENSOR	NORM/TEST DBA	1 YEAR	6.52 MO. POST DBA		SRS TABLE P. 15 THRU 4F		ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 23 YEARS
MANUFACTURER: RDF		FSAR FIG. 13.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 13.11.4-1	SRS TABLE P. 7G OF 9G	H NONE	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	SUBCOMPONENTS:
MODEL AND SERIAL: 2120 & 218		FSAR FIG. 13.11.8-1 FOR DBA	81 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE P. 7G OF 9G	H NONE	
FUNCTION & SERVICE: REACTOR COOLANT DIFF. TEMP. TEMP. AVG. PROTECTION	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE P. 7G OF 9G	H NONE	
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON PH 10.7 @ 25°C	FSAR SECT. 13.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	
ACCUR. SPEC: N/A					SRS TABLE P. 8G OF 9G	H NONE	
ACCUR. DEM.: N/A	R GAMMA	1.1 EG	24.7 E7 GAMMA	FSAR APP. 3.11.8-2.0	TEST REPORT SECT. 5.3 PAGE 9 & 10	COMB. TYPE TEST & SUPP. REVIEW	
	A BETA	1.7 E7	91.3 E7 BETA	CONT. RAD. ZONE C1	SRS TABLE P. 1E THRU 1F	H NONE	
	D SHIELD	100% BETH	100% BETH				
	T.I.D.	1.15 EG	24.7 E7				
SPECIFICATIONS: ME. SPEC. 95337 & DNG. #3257, P. 1	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	23 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	SAFETY FUNCTIONS: SEE TAB B OF ESE-G
P.O. # 265762 CHD # 15H.0191					SRS TABLE P. 1E THRU 1F	NONE	
PLANT LOC.: C.3. 21	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	N/A	AUTH. REFERENCE: M. J. H.
COORDINATES X= 1477.0 Y= 1708.0 Z= 236.0		YES			SRS TABLE PAGE 1A	NONE	
INSTALLED (Y/II):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G
INSTAL. REF: BY FIELD	OPERABILITY	O ESE-G	REFERENCES: FLON DNG. CAR-2165 G 802				REVISION # 10 DATE 16-18-89 SYSTEM: REACTOR COOLANT TAG: TE-IRC 0412A
QUALIF EXEMPT: N/A	TEMPERATURE	T					
QUALIFI: QUALIFIED	PRESSURE	P					
STATUS: WITHOUT EXCEPTION	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: CAR-2165 G163	AGING	A					
PHYS DNG LUC: TOTAL EQUIP. LIST	SUMMERGENCE	S					
MOUNTING:	FSAR ENV CAT: 10588 CATEG. 1	A					
EQ. DUC. LUC: BY P.O. 265762	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: TE-IRC 0412B	OPERABILITY	40 YEARS	123 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR	NORM/TEST DBA	1 YEAR	16.52 MO.		SRS TABLE P. 1F THRU 4F		NONE
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM.	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 10 SRS TABLE P. 7G OF 9G	COMB. TYPE TEST & SUPP. REVIEW	ACCEL TEMP: 400°F
MANUFACTURER: RdF	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. (FIG. 13.11.6-1 (DBA))	TEST REPORT SECT. 5.7 PAGE 14 SRS TABLE P. 7G OF 9G	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 23 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.7 PAGE 14 SRS TABLE P. 7G OF 9G	COMB. TYPE TEST & SUPP. REVIEW	MAINTAIN.
MODEL AND SERIAL: 21209 219	CHEMICAL SPRAY	2000-2100 PPM	12750 PPM	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14 SRS TABLE P. 8G OF 9G	COMB. TYPE TEST & SUPP. REVIEW	SUBCOMPONENTS:
FUNCTIONS & SERVICE: REACTOR COOLANT DIFF. TEMP. TEMP. AVG. PROTECTION	R GAMMA	1.1 EG	124.7 E7 GAMMA	FSAR APP 3.11.8-20	TEST REPORT SECT. 5.3 PAGE 9 (10) SRS TABLE P. 1E THRU 4E	COMB. TYPE TEST & SUPP. REVIEW	
ACCUM. SPEC: N/A	A BETA	1.7 E7	91.3 E7 BETA	CONT. RAD. ZONE C1			
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA				
SPECIFICATIONS: M.C. SEC. 95537 RO DWG. 43257, R7	T.I.D.	1.15 EG	24.7 E7				
P.O. # 1265762 CND # 15K#191	INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17 SRS TABLE P. 1E THRU 6E	COMB. TYPE TEST & SUPP. REVIEW	SAFETY FUNCTIONS: SEE TABLE OF ESE-6
PLANT LOC.: C-7-21	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A	N/A	
COORDINATES X- 1476.0 Y- 1708.0 Z- 236.0		YES					AUTH. REFERENCES: M. J. H.
INSTALLED (Y/N): BY FIELD	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-6		REFERENCES: FLOW DIAG. CAR-21659802			
QUALIF: QUALIFIED	TEMPERATURE	T					
STATUS: WITHOUT EXCEPTION	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DWG REF: CAR-21659163	AGING	A					REVISION # 10
PHYS DWG LOC: TOTAL EQUIP LIST	SURMERGENCE	S					DATE 16-18-84
MOUNTING							SYSTEM: REACTOR COOLANT
EQ. DOC. LOC: PO. 265762	FSAR ENV CAT: 19588 CATEG. 1	A					TAG: TE-IRC 0412B
	APPENDIX E						



10

11

12

13



14

15

16

17

18

19



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/WI OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: TE-IRC 0412C	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO.		SRS TAB E P. 17 THRU 46	REVIEW		ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE TEST & SUPP.	H NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: RUF		FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	SRS TAB E P. 76 OF 96	REVIEW		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE	SUBCOMPONENTS:
		FSAR FIG. 3.11.8-1 FOR DBA	81PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	FIG. 14 SRS TAB E P. 76 OF 96	REVIEW		
MODEL AND SERIAL #	RELATIVE HUMIDITY	70% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE	
FUNCTION: REACTOR COOLANT, & SERVICE DIFF. TEMP. CONTROL - COLD LEG		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 14 SRS TAB E P. 76 OF 96	REVIEW		
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP.	H NONE	
		PH 8.5-11.0	PH 10.7		SRS TAB E P. 86 OF 96	REVIEW		
ACCUM. DEM.: N/A	R GAMMA	1.2 EG	12.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE TEST & SUPP.	H NONE	
	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	PAGE 9 & 10 SRS TAB E P. 16 THRU 46	REVIEW		
SPECIFICATIONS: SEE SPEC. 95337	D SHIELD	100% BETA	100% BETA					
P.O. # 265762	T.I.D.	14.7 EG	124.7 E7					
PLANT LOC. 1CB. 31	AGE - INST LIFE	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP.	NONE	SAFETY FUNCTIONS: SEE TAB B OF ESE-G
COORDINATES X=1470.0 Y=1704.0 Z=257.0	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	SRS TAB E PAGE 1A	N/A	NONE	AUTH. REFERENCE: M. J. H.
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G	
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-G	REFERENCES: FLOW DIAG. 2165. G802				REVISION # 10 DATE 16-18-84 SYSTEM: REACTOR COOLANT TAG: TE-IRC 0412C	
QUALIF: QUALIFIED	TEMPERATURE	T						
STATUS WITHOUT EXCEPTION	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
PHYS DNG REF: CAR 2165 G163	RADIATION	R						
PHYS DNG LUCI: TOTAL EQPT. LIST	AGING	A						
MOUNTING	SUBMERGENCE	S						
EQ. DUC. LUCI: P.O. 265762	FSAR ENV CAT: 10588 CATEG. 1	A						
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/WI UITS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: TE-IRC 0412D	OPERABIL-ITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO.	POST DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	SUPP. REVIEW	NONE
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE SUPP. REVIEW	ACCEL TEMP: 400°F
MANUFACTURER: R/J	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE SUPP. REVIEW	REPLACEMENT: 23 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM	100% NORM	100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.7 PAGE 14	MAINTAIN. SUBCOMPONENTS
MODEL AND SERIAL #: 21204 221	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	PH 8.5-11.0	PH 10.7	1025°C	
FUNCTIONS: REACTOR COOLANT & SERVICE DIFF. TEMP. AG. PROTECTION	R GAMMA	1.2 EG	12.7 E7 GAMMA	A BETA	3.4 E7	D SHIELD	100% BETA
ACCUM. SPEC: N/A	T.I.D.	14.7 EG	124.7 E7				
ACCUM. DEM.: N/A	AGE-INST LIFE	40 YEARS	23 YEARS	(PER 323-1974 DEF.)			
SPECIFICATIONS: W.E. SPEC. 95337	SURMERGED	228.3	YES				
P.O. # 265762	COORDINATES	X=1469.0 Y=1704.0 Z=257.0					
PLANT LOC.: CB. 31	OTHER EQUIPMENT THIS CES APPLIES TO:						
COORDINATES	REFERENCES:						
INSTALLED (Y/II):	FLOW DIAG. 2165 G 802						
INSTALL. REF: BY FIELD							
QUALIF EXEMPT: N/A							
QUALIF: QUALIFIED							
STATUS WITHOUT EXCEPTION							
PHYS DNG REF: CAR 2165 G 163							
PHYS DNG LOC: TOTAL EQPT. LIST							
MOUNTING							
EQ. DOC. LOC: W. P.O. 265762							

SAFETY FUNCTION: SEE TAB B OF ESE-G

AUTH. REFERENCE: M. J. H.


QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G

REVISION # : 0

DATE : 16-18-84

SYSTEM : REACTOR COOLANT

TAG : TE-IRC 0412D



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: TE-IRC 0413	OPERABILITY	40 YEARS	20 YEARS	OPERABILITY TEST REPORT	COMB. TYPE		ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR	ITY	NORMAL	NORMAL	REVIEW	TEST & SUPP. REVIEW	NONE	
COMPONENT: TEMP. ELEMENT	NORM/TEST DBA	1 YEAR	6.52 MO.	PAGE 16			ACCEL TEMP: 400°F
MANUFACTURER: Rdf	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE	COMB. TYPE		REPLACEMENT: 20 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	9.4.0-1 FSAR FIG. 3.11.4-1	TEST & SUPP. REVIEW	H	
MODEL AND SERIAL: 21205 214	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT	H	MAINTAIN.
FUNCTION: REACTOR COOLANT & SERVICE LOOP / HOT LEG TEMP.	FSAR FIG. 3.11.8-1 FOR DBA	81 PSI DBA	81 PSI DBA	3.11.6-1 (DBA)	TEST REPORT	H	SUBCOMPONENTS:
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE	COMB. TYPE		
ACCUM. DEM.: N/A	PH	8.5-11.0	10.7	9.4.0-1 NORM	TEST & SUPP. REVIEW	H	
SPECIFICATIONS: W.G. SPEC. 95337R	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT	H	
P.O. #1265762 CHD # 15H. #183	PH	8.5-11.0	10.7	3.11.5.1	TEST REPORT	H	
PLANT LOC.: C.B. 31	R GAMMA	1.2 EG	24.7 GAMMA	FSAR APP	COMB. TYPE		
COORDINATES X=1475.0 Y=1709.0 Z=257.0	A BETA	3.4 E7	91.3 E7 BETA	3.11.8-21	TEST & SUPP. REVIEW	H	
INSTALLED (Y/M):	D SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE CS	TEST REPORT		
INSTALL. REF: BY FIELD	T.I.D.	4.7 EG	24.7 E7	20 CFR 50 PARAGRAPH 50.51	TEST & SUPP. REVIEW		SAFETY FUNCTIONS: SEE TAB B OF ESE-5
QUALIF EXEMPT: N/A	AGE	40 YEARS	20 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT	NONE	
QUALIF: QUALIFIED	INST LIFE (PER 323-1974 DEF.)	40 YEARS	20 YEARS	50.51	TEST & SUPP. REVIEW		
WITHOUT EXCEPTION	SURMERGED	228.3	N/A	FSAR SECTION 3.6	TEST & SUPP. REVIEW	NONE	AUTH. REFERENCE: M.J.H.
PHYS DNG REF: CAR. 2165 G163	OTHER EQUIPMENT THIS CES APPLIES TO:						
PHYS DNG LUC: TOTAL EQUIP. LIST	REFERENCES:			FLOW DIAG. CAR. 2165 G800			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-5
EQU. DUC. LUC: P.O. 265762	FSAR ENV CAT: 10588 CATEG. 1						REVISION #: 0
	APPENDIX E						DATE: 16-18-84
							SYSTEM: REACTOR COOLANT
							TAG: TE-IRC 0413

11 2 3

4

5

6

7

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/ UITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: YE-IRC 0420	OPERABILITY	40 YEARS	20 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 16 SR5 TAB E	COMB. TYPE	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT TYPE: SENSOR	NORM/TEST	1 YEAR	6.52 MO.		SR5 TAB E	TEST & SUPP.		ACCEL TEMP: 400 °F
COMPONENT: TEMP. ELEMENT	DBA	POST DBA	POST DBA		19.18 THRU 7B	REVIEW		REPLACEMENT: 20 YEARS
MANUFACTURER: RDF	TEMPERATURE	120 °F NORM	122 °F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	H NONE	MAINTAIN:
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA	420 °F DBA	FSAR FIG. 3.11.4-1	Page 9 SR5 TAB E	TEST & SUPP.		SUBCOMPONENTS:
MODEL AND SERIAL: R1205 215	DBA				Page 18 & 28	REVIEW		
FUNCTION: REACTOR COOLANT & SERVICE LOOP 2 COLD LEG	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT PAGE 12 & 13 SR5 TAB E	COMB. TYPE	H NONE	
	FSAR FIG.	3.11.8-1 FOR DBA	815 PSIA DBA	3.11.6-1 (DBA)	Page 6 & 7 of 11	TEST & SUPP.		
	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.6	COMB. TYPE	H NONE	
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 12 & 13 SR5 TAB E	TEST & SUPP.		
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.6	COMB. TYPE	H NONE	
ACCUR. SPEC: N/A	PH	8.5-11.0	10.7		PAGE 12 & 13 SR5 TAB E	TEST & SUPP.		
	R GAMMA	1.2 E6	24. E7 GAMMA	FSAR APP. 3.11.8-21	TEST REPORT SECT. 5.3	COMB. TYPE	H NONE	
ACCUR. DEM.: N/A	A BETA	3.4 E7	91.3 E7 BETA	CONT. RAD. ZONE C5	Page 9 & 10 SR5 TAB E	TEST & SUPP.		
	D SHIELD	100% BETA	100% BETA		Page 28 THRU 5B	REVIEW		
	T.I.D.	4.7 E6	24.7 E7		SR5 TAB E	REVIEW		
SPECIFICATIONS: IME.SAC. 9533770 219.43258, RG	AGE-INST LIFE (PER 523-1974 DEF.)	40 YEARS	20 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE	NONE	SAFETY FUNCTION: SEE TAB B OF ESE-5
P.O. #: 265762 CHD #: 158. # 184					Page 16 SR5 TAB E	TEST & SUPP.		
PLANT LOC.: C.B. 31					Page 18 THRU 7B	REVIEW		
COORDINATES: X-1511.0 Y-1678.0 Z-257.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	COMB. TYPE	NONE	AUTH. REFERENCE: H.J.H
INSTALLED (Y/M): BY FIELD								
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-5	
QUALIF STATUS: QUALIFIED WITHOUT EXCEPTION	OPERABILITY	O ESE-5	REFERENCES: FLOW DIAG. CAR-2165 9800				REVISION # 10 DATE 16-13-84 SYSTEM: REACTOR COOLANT TAG: YE-IRC 0420	
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
	EMERGENCY	S						
	FSAR ENV CAT: 19588 CATEG. 1	A						
	APPENDIX E							



11
12
13
14

15
16

17
18


19

20

21

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFYING METHOD	H/WI UITS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.			
TAG NO: TE-IRC 0421B	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	16.52 MO.		SRS TAB E	SUPP.	NONE
COMPONENT: TEMP. ELEMENT	DBA	POST DBA	POST DBA		IF THRU 4F	REVIEW	ACCEL TEMP: 400°F
MANUFACTURER: Rdf	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	REPLACEMENT: 23 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10	SUPP.	H NONE
MODEL AND SERIAL: 21204 222	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM	SRS TAB E	REVIEW	MAINTAIN.
FUNCT. USE: REACTOR COOLANT & SERVICE	FSAR FIG.	3.11.8-1 FOR DBA	81PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	PAGE 14	SUPP.	H NONE
	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	SRS TAB E	REVIEW	SUBCOMPONENTS
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 14	SUPP.	H NONE
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	SRS TAB E	REVIEW	
ACCUR. SPEC: N/A		PH 8.5-11.0	PH 10.7		P. 76 OF 96	REVIEW	
ACCUR. DEM.: N/A	R GAMMA	1.2 EG	124.7E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE	H NONE
	A BETA	3.4 E7	11.7E7 BETA	CONT. RAD. ZONE CS	PAGE 9 & 10	SUPP.	H NONE
	D SHIELD	100% BETA	100% BETA		SRS TAB E	REVIEW	
SPECIFICATIONS: WE SPEC 95337	T.I.D.	4.7 EG	124.7 E7		P. 15 THRU 4E	REVIEW	
P.O. # 265762	AGE - INST LIFE (PER 323-1978 DEF.)	40 YEARS	23 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE	NONE
PLANT LOC: 1CB. 31					PAGE 17	SUPP.	SAFETY FUNCTION: SEE TAB B OF ESE-6
COORDINATES X=1511.0 Y=1676.0 Z=257.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	SRS TAB E	N/A	NONE
INSTALLED (Y/III):	YES				PAGE 1A		AUTH. REFERENCE: M. J. H.
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6
QUALIFY QUALIFIED	OPERABILITY	O ESE-6	REFERENCES: FLOW DIAG. 2165 G802				REVISION # : 0 DATE : 10-18-84 SYSTEM : REACTOR COOLANT
STATUS WITHOUT EXCEPTION	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DWG REF: CAR 2165 G163	RADIATION	R					
PHYS DWG LIC: TOTAL EQPT. LIST	AGING	A					
MOUNTING	SURMERGENCE	S					
EQ. DUC. LUC: W P.O. 265762	FSAR ENV CAT: 10588 CATEG.	A					
	APPENDIX E						TAG : TE-IRC 0421B

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M ITEMS	OUTS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: TE-IRC 0421C	OPERABIL-ITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO	POST DBA	SRS TAB E P. 17 THRU 46	SUPP. REVIEW	NONE	ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE	H NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: R&F	URE	FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	SRS TAB E P. 76 OF 96	SUPP. REVIEW	NONE	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. (FIG. 3.11.6-1 (DBA))	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE	H NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: 21204 223	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE	H NONE	
FUNCTIONS & SERVICE: REACTOR COOLANT DIFF. TEMP. CONT. HOT LEG	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	2750 PPM BORON PH 10-7 1025°C	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE	H NONE	
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	124.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3 PAGE 9 & 10	COMB. TYPE	H NONE	
ACCUM. DEM.: N/A	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	SRS TAB E P. 15 THRU 46	SUPP. REVIEW	NONE	
SPECIFICATIONS: W&E SPEC. 95337	D SHIELD	100% BETA	100% BETA	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE	NONE	SAFETY FUNCTION: SRS TAB B OF ESE-6
P.O. #1265762	T.I.D.	4.7 EG	124.7 E7		SRS TAB E P. 15 THRU 46	SUPP. REVIEW	NONE	
PLANT LOC. 1CB. 31	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS					
COORDINATES X=1509.0 Y=1681.0 Z=257.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	SRS TAB E	NONE	AUTH. REFERENCE: M. J. H.
INSTALLED (Y/II):								
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION	
QUALIF: QUALIFIED	OPERABILITY	O					PACKAGE: ESE-6	
STATUS WITHOUT EXCEPTION	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R	REFERENCES: FLOW DIAG. 2165 G802					
PHYS DNG REFICAR 2165 G163	RAGNO	A					REVISION # 10	
PHYS DNG LUCI TOTAL EQPT. LIST MOUNTING	SURMERGENCE	S					DATE 16-18-84	
EQ. DUC. LUCI W P.O. 265762	FSAR ENV CAT: 10588 CATEG. 1	A					SYSTEM: REACTOR COOLANT	
	APPENDIX E						TAG: TE-IRC 0421C	



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: TE-IRC 0422A	OPERABIL-ITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 264 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO.		SRS TAB E	SUPP.	NONE	
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	ACCEL TEMP: 400°F	
MANUFACTURER: RLF	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10	SUPP.	REPLACEMENT: 23 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.7	COMB. TYPE	MAINTAIN.	
MODEL AND SERIAL #: 21204 224	FSAR FIG. 3.11.8-1 FOR DBA		81 PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	PAGE 14	SUPP.	SUBCOMPONENTS:	
FUNCTIONS: REACTOR COOLANT & SERVICE DIFF. TEMP. TEMP. AVG. PROTECTION	RELATIVE HUMIDITY	40% NORM.	100% NORM.	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.7	COMB. TYPE		
ACCUM. SPEC: N/A		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 14	SUPP.	H NONE	
ACCUM. DEN.: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	12750 PPM BORON	FSAR SECT. 3.11.5.1	PAGE 14	SUPP.	H NONE	
SPECIFICATIONS: W.E. SPEC. 953397	R GAMMA	1.2 EG	124.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE		
P.O. #1265762	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	PAGE 10	SUPP.	H NONE	
PLANT LOC.: CB. 31	D SHIELD	100% BETA	100% BETA		SRS TAB E	REVIEW		
COORDINATES X=1512.0 Y=1671.0 Z=257.0	T.I.D.	4.7 EG	124.7 E7		P. 15 THRU 4E			
INSTALLED (Y/II):	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE	SAFETY FUNCTIONS: SECT. B OF ESE-G	
INSTALL. KEF: BY FIELD	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	PAGE 17	SUPP.	NONE	
QUALIF EXEMPT: N/A	YES				SRS TAB E	N/A	NONE	
QUALIF: QUALIFIED					PAGE 1A		AUTH. REFERENCE: M.J.H.	
STATUS: WITHOUT EXCEPTION	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G	
	OPERABILITY	O ESE-G	REFERENCES: FLOW DIAG. 2165 G 802				REVISION # 10 DATE 16-18-84 SYSTEM: REACTOR COOLANT TAG: TE-IRC 0422A	
	TEMPERATURE	T						
	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
	SUBMERGENCE	S						
	SAR ENV CAT: 10588 CATEG. 1	A						
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	H/W ITEMS	NOTES
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: TE-IRC 0422B	OPERABILITY	40 YEARS	23 YEARS	TEST REPORT SECT. 7.0	COMB TYPE		ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	ITY	NORMAL	NORMAL	REVIEW	TEST & SUPP.	NONE	ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	NOHM/TEST DBA	1 YEAR	16.52 MO.	SRS TAB E	REVIEW		REPLACEMENT: 23 YEARS
MANUFACTURER: TRDF	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE TEST & SUPP.	H NONE
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10 SRS TAB E	REVIEW	
MODEL AND SERIAL: 21204 225	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE
FUNCTION & SERVICE: REACTOR COOLANT LOOP B DIFF. TEMP. TEMP. AVG.	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 6.7	COMB. TYPE TEST & SUPP.	H NONE
ACCUR. DEM.: N/A	R GAMMA	1.2 EG	124.7E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE TEST & SUPP.	H NONE
SPECIFICATIONS: WE SPEC. 95337 REV. 0 DWS. 43257.R7	A BETA	3.4 E7	11.7E7 BETA	CONT. RAD. ZONE CS	PAGE 9 & 10 SRS TAB E	REVIEW	
P.O. #1265762	D SHIELD	100% BETA	100% BETA		PAGE 14 SRS TAB E	REVIEW	
PLANT LOC.: CB. 31	T.I.D.	14.7 EG	124.7 E7		PAGE 14 SRS TAB E	REVIEW	
COORDINATES X=1512.0 Y=1672.0 Z=257.0	AGE			110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE TEST & SUPP.	NONE
INSTALLED (Y/II):	INST LIFE	40 YEARS	23 YEARS		PAGE 17 SRS TAB E	REVIEW	SAFETY FUNCTIONS: SEE TAB B OF ESE-6
INSTALL. NEP: BY FIELD	SURMERGENCE	228.3	N/A	FSAR SECTION 13.6	PAGE 1A	N/A	AUTH. REFERENCES: M.J.H.
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW					
QUALIF: QUALIFIED	OPERABILITY	O	ESE-6	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6
STATUS: WITHOUT EXCEPTION	TEMPERATURE	T		REFERENCES: FLOW DIAG. 2165.G802			REVISION: 0
	PRESSURE	P					DATE: 10-18-84
	REL. HUMIDTY	H					SYSTEM: REACTOR COOLANT
	CHEM. SPRAY	C					TAG: TE-IRC 0422B
	RADIATION	R					
PHYS DNG NEP: CAR 2165 G163	AGING	A					
PHYS DNG LUC: TOTAL EQPT. LIST	SURMERGENCE	S					
MOUNTING	FSAR ENV CAT:						
EQ. DUC. LUC: P.O. 265762	10588 CATEG.:	A					
	APPENDIX E						



245



246



247

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/W	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL	DEM.	QUALIF.		
TAG NO: TE-IRC 0422C	OPERAVIL-ITY	40 YEARS	23 YEARS	NORMAL	OPERABILITY REVIEW	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 264 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO.	NORMAL	POST DBA	PAGE 17 SRS TAB E	SUPP. REVIEW	NONE	
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	NORMAL	POST DBA	IF THRU 4F	REVIEW	ACCEL TEMP: 400°F	
MANUFACTURER: R/J	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA		FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	H NONE	
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG. 3.11.8-1 FOR DBA		81PSIA DBA		FSAR FIG. 3.11.4-1	PAGE 10 SRS TAB E	SUPP. REVIEW	REPLACEMENT: 23 YEARS	
MODEL AND SERIAL: 21204 226	RELATIVE HUMIDITY	40% NORM	100% NORM	100% DBA	FSAR SECT. 13.11.6 NORM. FIG.	TEST REPORT SECT. 5.7	COMB. TYPE	H NONE	
FUNCTION: REACTOR COOLANT, & SERVICE LOOP C PROTECTION	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	PH 8.5-11.0	PH 10.7	1025°C	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7	
ACCUR. SPEC: N/A	R GAMMA	1.2 EG	124.7 E7 GAMMA				TEST REPORT SECT. 5.3	COMB. TYPE	
ACCUR. DEM.: N/A	A BETA	3.4 E7	11.7 E7 BETA				PAGE 14 SRS TAB E	SUPP. REVIEW	
SPECIFICATIONS: W.E. SPEC. 95337	D SHIELD	100% BETA	100% BETA				PAGE 14 SRS TAB E	REVIEW	
P.O. #1265762	T.I.D.	14.7 EG	124.7 E7				110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	
PLANT LOC.: 1CB. 31	INST LIFE (PER 323-1979 DEF.)	40 YEARS	23 YEARS				PAGE 17 SRS TAB E	REVIEW	
COORDINATES X=1511.0 Y=1679.0 Z=257.0	SURMERGED	228.3		N/A			PAGE 1A	REVIEW	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION		
INSTAL. REF: BY FIELD	OPERABILITY	O ESE-G	REFERENCES: FLOW DIAG. 2165 G802				REVISION # 10 DATE 16-18-84 SYSTEM REACTOR COOLANT TAG TE-IRC 0422C		
QUALIF EXEMPT: N/A	TEMPERATURE	T							
QUALIF: QUALIFIED	PRESSURE	P							
STATUS WITHOUT EXCEPTION	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
PHYS DNG REF: CAR 2165 G163	RADIATION	R							
PHYS DNG LUCI TOTAL EQPT. LIST	AGING	A							
MOUNTING	SURMERGENCE	S							
EQ. DUC. LUCI W P.O. 265762	FSAR ENV CAT: 10588 CATEG.	A							
	APPENDIX E								

SAFETY FUNCTIONS: SEE TAB B OF ESE-G
AUTH. REFERENCE: M.J.H.



12 448

478

12 448

478

12 448

478

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M/OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: TE-IRC 0422D	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	DBA	POST DBA	POST DBA		SRS TAB E P. 1F THRU 4F	REVIEW		ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1 PAGE 10	COMB. TYPE TEST & SUPP.	H NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: RDF	DBA	3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	SRS TAB E P. 76 OF 96	REVIEW		MAINTAIN:
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP.	H NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: 21204 227	DBA	3.11.8-1 FOR DBA	81PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	SRS TAB E P. 76 OF 96	REVIEW		
FUNCTIONS: REACTOR COOLANT & SERVICE DIFF. TEMP.-TEMP. AVG PROTECTION	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP.	H NONE	
	DBA	100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TAB E P. 76 OF 96	REVIEW		
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7 PAGE 14	COMB. TYPE TEST & SUPP.	H NONE	
ACCUM. SPEC: N/A	PH	8.5-11.0	10.7		SRS TAB E P. 86 OF 96	REVIEW		
ACCUM. DEN.: N/A	R GAMMA	1.2 EG	124.7 E7 GAMMA	FSAR APP 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE TEST & SUPP.	H NONE	
	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	PAGE 9 & 10	REVIEW		
	D SHIELD	100% BETA	100% BETA		SRS TAB E P. 1F THRU 4F	REVIEW		
	T.I.D.	14.7 EG	124.7 E7					
SPECIFICATIONS: SEE SPEC. 153377 REV. 0 Dwg. 43257 RT	AGC			110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 17	COMB. TYPE TEST & SUPP.	NONE	SAFETY FUNCTIONS: SEE TAB B OF ESE-6
P.O. #1265762 CND # 1191	INST LIFE (PER 325-1974 DEF.)	40 YEARS	23 YEARS		SRS TAB E P. 1F THRU 6 E	REVIEW		
PLANT LOC.: CB. 31	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	N/A	N/A	NONE	AUTH. REFERENCE: M.J.H.
COORDINATES X=1510.0 Y=1680.0 Z=257.0	YES				SRS TAB E PAGE 1A			
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6
INSTALL. REF: BY FIELD	OPERABILITY	O ESE-6		REFERENCES: FLOW DIAG. 2165 G802				REVISION # : 0 DATE : 16-18-84 SYSTEM : REACTOR COOLANT TAG : TE-IRC 0422D
QUALIF EXEMPT: N/A	TEMPERATURE	T						
QUALIF: QUALIFIED	PRESSURE	P						
STATUS WITHOUT EXCEPTION	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS Dwg REF: CAR 2165 G163	AGING	A						
PHYS Dwg LIC: TOTAL EQPT. LIST	SUBMERGENCE	S						
MOUNTING								
EQ. DUC. LUC: P.O. 265762	FSAR ENV CAT: 10588 CATEG. 1	A						
	APPENDIX E							

25

26

27

28

29

30

31

32

33

34

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL		
TAG NO: TE-IRC 0423	OPERABILITY	40 YEARS	120 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0	COMBTYPE NONE
EQUIPMENT: SENSOR	NORM/TEST DBA	1 YEAR	16.52 MO.	POST DBA	PAGE 16 SRSTAB E P. 18THRU 7B	REVIEW
COMPONENT: TEMP ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMBTYPE TEST & SUPP. H NONE
MANUFACTURER: RDF	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	PAGE 18 & 28	REVIEW
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM	TEST REPORT SECT. 5.6	COMBTYPE TEST & SUPP. H NONE
MODEL AND SERIAL: 21205 216	FSAR FIG. 3.11.8-1 FOR DBA		161 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	PAGE 12 & 13 SRSTAB E P. 6C & 11C	REVIEW
FUNCTIONS: REACTOR COOLANT & SERVICE LOOP 2 HOT LEG	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.6	COMBTYPE TEST & SUPP. H NONE
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 7C & 11C	REVIEW
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM	12750 PPM	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.6	COMBTYPE TEST & SUPP. H NONE
		PRM BORON	BORON @ 25°C		PAGE 12 & 13 SRSTAB E	REVIEW
ACCUM. DEM.: N/A	R GAMMA	1.2 E6	247 E6	FSAR APP 3.11.8-21	TEST REPORT SECT. 5.3	COMBTYPE TEST & SUPP. H NONE
	A BETA	3.4 E7	91.367 BETA	CONT. RAD. ZONE C5	PAGE 9 & 10 SRSTAB E	REVIEW
SPECIFICATIONS: WE SPEC. 153357 RO DWG. 43258, R/G	D SHIELD	100% BETA	100% BETA		PAGE 28THRU 5B	REVIEW
P.O. # 265762 CHD # 15H. # 183	• T.I.D.	4.7 E6	1247 E7			
PLANT LOC.: C.B. 31	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	20 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMBTYPE TEST & SUPP. NONE
COORDINATES X- 1513.0 Y- 1673.0 Z- 257.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	PAGE 18THRU 7A	REVIEW
INSTALLED (Y/N): BY FIELD		YES			N/A SRSTAB E PAGE 1A	N/A NONE

QUALIF EXEMPT: **N/A**

QUALIF: **QUALIFIED WITHOUT EXCEPTION**

PHYS DWG REF: **CR-2165 G163**

PHYS DWG LOC: **TOTAL EQUIP. LIST**

EQ. DUC. LOC: **W P.O. 265762**

PARAMETER	SUPPL. REVIEW
OPERABILITY	O ESE-5
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENCE	S
FSAR ENV CAT: 19588 CATEG. 1	A
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
FLOW DIAG. CAR-2165 G 800

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: **ESE-5**

REVISION # **10**

DATE: **16-18-84**

SYSTEM: **REACTOR COOLANT**

TAG: **TE-IRC 0423**


SAFETY FUNCTION: **SEE TAB B OF ESE-5**

AUTH. REFERENCE: **M.J.H**

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A/OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.		
TAG NO: TE-IRC 0430	OPERABILITY	40 YEARS	20 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0 Pg. 16	COMB. TYPE TEST & SUPP.	NONE	ACCEL TIME: 264 HOURS		
EQUIPMENT: SENSOR TYPE	NDRH/TEST DDA	1 YEAR POST DBA	16.52 MO POST DBA		SRS TAB E Pg. 18 THRU 7B	REVIEW		ACCEL TEMP: 400 °F		
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120 °F NORM	122 °F NORM	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1 FOR DBA	TEST REPORT SECT. 5.1 Page 9	COMB. TYPE TEST & SUPP. REVIEW	H NONE	REPLACEMENT: 20 YEARS		
MANUFACTURER: RJF	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.6 Page 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE	MAINTAIN.		
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA	81 PSIA DBA	3.11.6-1 (DBA)	SRS TAB E Pg. 6C & 11C			SUBCOMPONENTS:		
MODEL AND SERIAL: 21205 217	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.6 Page 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE			
FUNCTION: REACTOR COOLANT & SERVICE LOOP 3 COLD LEG	CHEMICAL SPRAY	2000-2100 PPM PRM BORON PH 8.5-11.0	12750 PPM BORON PH 10.7 @ 25 °C	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.6 PAGE 12 & 13	COMB. TYPE TEST & SUPP. REVIEW	H NONE			
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD T.I.D.	1.2 E6 3.4 E7 100% BETA 4.7 E6	24. E7 GAMMA 91.3 E7 BETA 100% BETA 124.7 E7	FSAR APP 3.11.8-21 CONT. RAD. ZONE C5	TEST REPORT SECT. 5.3 PAGE 7 & 10	COMB. TYPE TEST & SUPP. REVIEW	H NONE			
SPECIFICATIONS: TIME SPEC. 953337, DWG. #3258, RG	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	20 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0 PAGE 16	COMB. TYPE TEST & SUPP. REVIEW	NONE	SAFETY FUNCTION: SEE TAB B OF ESE-5		
P.O. # 1265762 CND # 151-184	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A SRS TAB E PAGE 1A			AUTH. REFERENCE: M. J. H.		
PLANT LOC.: C.B. 21	COORDINATES X=1513.0 Y=1724.0 Z=257.0	YES								
INSTALLED (Y/N): BY FIELD	QUALIF EXEMPT: N/A	STATUS: QUALIFIED WITHOUT EXCEPTION	PHYS DWG REF: CAR-2165 G163	PHYS DWG LUC: TOTAL EQUIP LIST	MOUNTING: W P.O. 265762	EDUC. LUC: W P.O. 265762	PARA-METER: OPERABILITY	SUPPL. REVIEW: 0 ESE-5	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-5
									REFERENCES: FLOW DIAG. CAR-2165 G 800	REVISION # 10
										DATE: 16-18-84
										SYSTEM: REACTOR COOLANT
										TAG: TE-IRC 0430


EQU. DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: TE-IRC 0431B	OPERABIL-ITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 264 HOURS	
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO.	REVIEW	PAGE 17	TEST & SUPP.	NONE	
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE	TEST REPORT SECT. 5.1	COMB. TYPE	ACCEL TEMP: 400°F	
MANUFACTURER: RDF	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10	TEST & SUPP.	REPLACEMENT: 23 YEARS	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. (FIG.)	TEST REPORT SECT. 5.7	COMB. TYPE	MAINTAIN.	
MODEL AND SERIAL: 21204 228	RELATIVE HUMIDITY	40% NORM.	100% NORM.	FSAR TABLE 9.4.0-1 NORM.	TEST REPORT SECT. 5.7	COMB. TYPE	SUBCOMPONENTS:	
FUNCTIONS: REACTOR COOLANT, DIFF. TEMP. TEMP. AVG. CONTROL HOT LEG	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7	COMB. TYPE		
ACCUM. SPEC: N/A	R GAMMA	1.1 EG	124.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE		
ACCUM. DEM.: N/A	A BETA	17 E7	11.7 E7 BETA	CONT. RAD. ZONE C1	TEST REPORT PAGE 9 & 10	COMB. TYPE		
SPECIFICATIONS: W.E. SPEC. 95337	T.I.D.	11.15 EG	124.7 E7		TEST REPORT SRS TAB E	COMB. TYPE		
P.O. #1265762	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE	SAFETY FUNCTION: SEE TAB B OF ESE-6	
PLANT LOC. 1CB. 21	SUBMERGED	228.3	N/A	FSAR SECTION 13.6	TEST REPORT PAGE 17	COMB. TYPE		
COORDINATES X=1515.0 Y=1716.0 Z=236.0		YES			SRS TAB E	COMB. TYPE		
INSTALLED (Y/II):					PAGE 1A	COMB. TYPE	AUTH. REFERENCE: M.J.H.	
INSTAL. NEFI BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION	
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-6	REFERENCES:				PAGE: ESE-6	
QUALIF: QUALIFIED	TEMPERATURE	T	FLOW DIAG. 2165 G802					
STATUS: WITHOUT EXCEPTION	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG NEFI: CAR 2165 G163	AGING	A						REVISION #: 0
PHYS DNG LUCI: TOTAL EQPT. LIST	SUBMERGENCE	S						DATE: 16-18-84
MOUNTING								SYSTEM: REACTOR COOLANT
EQ. DUC. LUCI: W. P.O. 265762	FSAR ENV CAT: 10588 CATEG. A	A						TAG: TE-IRC 0431B
	APPENDIX E							

EQUIP. DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: TE-IRC 0431C	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	16.52 MO.	REVIEW	PAGE 17	NONE	ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	DBA	POST DBA	POST DBA	IF SAR TABLE	TEST REPORT SECT. 5.1	H NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: RUF	TEMPERATURE	120°F NORM	122°F NORM	IF SAR FIG. 3.11.4-1 FOR DBA	PAGE 10		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	IF SAR FIG. 3.11.6-1 FOR DBA	SRS TAB E P. 76 OF 96	H NONE	SUBCOMPONENTS:
MODEL AND SERIAL: 21204 229	RELATIVE HUMIDITY	40% NORM	100% NORM	IF SAR FIG. 3.11.8-1 FOR DBA	PAGE 14	H NONE	
FUNCTION: REACTOR COOLANT & SERVICE DIFF. TEMP. - TEMP. AVG. CONTROL	CHEMICAL SPRAY	2000-2100 PPM BORON	12750 PPM BORON	IF SAR SECT. 3.11.4.3 (DBA)	SRS TAB E P. 76 OF 96	H NONE	
ACCUM. SPEC: N/A	R GAMMA	1.1 EG	124.7 E7 GAMMA	IF SAR SECT. 3.11.5.1	PAGE 14	H NONE	
ACCUM. DEM.: N/A	A BETA	17 E7	11.7 E7 BETA	IF SAR APP. 3.11B-21	SRS TAB E P. 86 OF 96	H NONE	
SPECIFICATIONS: W.E. SPEC. 953397	D SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C1	PAGE 9 & 10	H NONE	
P.O. #1265762	T.I.D.	EG	124.7 E7	110 CFR 50 PARAGRAPH 50.51	SRS TAB E P. 15 THRU 4E	NONE	SAFETY FUNCTION: SEE TABS B OF ESE-G
PLANT LOC.: CB. 21	AGE-INST LIFE	40 YEARS	23 YEARS	IF SAR SECTION 13.6	PAGE 1A	NONE	AUTH. REFERENCE: M.J.H.
COORDINATES X=1513.0 Y=1724.0 Z=236.0	BURMEGED	228.3	N/A	IF SAR SECTION 13.6	N/A	NONE	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G
INSTAL. NEFI BY FIELD	OPERABILITY	O ESE-G	REFERENCES: FLOW DIAG. 2165 G 802				REVISION: 10 DATE: 16-18-84 SYSTEM: REACTOR COOLANT TAG: TE-IRC 0431C
QUALIF EXEMPTN: N/A	TEMPERATURE	T					
QUALIF: QUALIFIED	PRESSURE	P					
STATUS WITHOUT EXCEPTION	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DNG NEFICAR 2165 G 163	RADIATION	R					
PHYS DNG LUCI TOTAL EQPT. LIST MOUNTING	AGING	A					
EQ. DOC. LUCI W P.O. 265762	SURMERGENCE	S					
	SAR ENV CAT: 10588 CATEG. 1	A					
	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI OUTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: TE-IRC 0432A	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT	COMB. TYPE	
	ITY	NORMAL	NORMAL	REVIEW	SECT. 7.0	TEST &	ACCEL TIME: 264 HOURS
	NORM/TEST	1 YEAR	6.52 MO.		PAGE 17	SUPP.	NONE
EQUIPMENT: SENSOR	DBA	POST DBA	POST DBA		SRS TAB E	REVIEW	ACCEL TEMP: 400°F
	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE	TEST REPORT	COMB. TYPE	
COMPONENT: TEMP. ELEMENT		FSAR FIG. 3.11.4-1 FOR 1 DBA	420°F DBA	FSAR FIG. 3.11.4-1	SECT. 5.1	TEST &	REPLACEMENT: 23 YEARS
	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	PAGE 10	SUPP.	
MANUFACTURER: R&F		FSAR FIG. 3.11.8-1 FOR 1 DBA	81PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TAB E	REVIEW	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM.	100% NORM.	FSAR TABLE	TEST REPORT	COMB. TYPE	
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SECT. 5.7	TEST &	SUBCOMPONENTS:
MODEL AND SERIAL: 21204 230	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT	COMB. TYPE	
		PH 8.5-11.0	PH 10.7		SECT. 5.7	TEST &	
			1025°C		PAGE 14	SUPP.	
FUNCTION & SERVICE: REACTOR COOLANT, LOOP C PROTECTION, DIFF. TEMP. - TEMP. AVG.	R GAMMA	1.2 EG	124.7 EG	FSAR APP. 3.11B-21	SRS TAB E	REVIEW	
	A BETA	3.4 E7	11.7 E7	CONT. RAD. ZONE CS	PAGE 14	SUPP.	
	D SHIELD	100% BETA	100% BETA		SRS TAB E	REVIEW	
	T.I.D.	14.7 EG	124.7 E7		PAGE 10	SUPP.	
ACCUR. SPEC: N/A	AGE			10 CFR 50 PARAGRAPH 50.51	TEST REPORT	COMB. TYPE	
	INST LIFE	40 YEARS	23 YEARS		SECT. 7.0	TEST &	SAFETY FUNCTION: SEE TAB B OF ESE-6
	(PER 523-1974 DEF.)				PAGE 17	SUPP.	
SPECIFICATIONS: W.E. SPEC. 95337	BURMEGED	228.3	N/A	FSAR SECTION 3.6	SRS TAB E	REVIEW	
P.O. #1265762	YES				PAGE 1A	N/A	
PLANT LOC. 1CB. 31							AUTH. REFERENCE: M.J.H.
COORDINATES X=1516.0 Y=1718.0 Z=257.0							
INSTALL (Y/II):	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-6
INSTALL. REFS: BY FIELD	OPERABILITY	O ESE-6		REFERENCES: FLOW DIAG. 2165 G802			REVISION # : 0
QUALIF EXEMPT: N/A	TEMPERATURE	T					DATE: 10-18-84
AQUALIF: QUALIFIED	PRESSURE	P					SYSTEM: REACTOR COOLANT
STATUS WITHOUT EXCEPTION	REL. HUMIDTY	H					TAG: TE-IRC 0432A
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: CAR 2165 G163	AGING	A					
PHYS DNG LIC: TOTAL EQPT. LIST	SUBMERGENCE	S					
MOUNTING	FSAR ENV CAT: 10500 CATEG. 1	A					
EQ. DUC. LUC: W. P.O. 265762	APPENDIX E						


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHOD	H/W/OUTS ITEMS	ACCEL TIME	ACCEL TEMP	REPLACEMENT	MAINTENANCE	SUBCOMPONENTS	SAFETY FUNCTION	AUTH. REFERENCE
	PARAMETER	ACTUAL	DESIGN	QUALIFIED									
TAG NO: TE-IRC 0432B	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0	COMB. TYPE	NONE	264 HOURS					
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	16.52 MO		PAGE 17	TEST & SUPP.							
COMPONENT: TEMP. ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	H	NONE	400°F				
MANUFACTURER: R/J	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10	SUPP. REVIEW			23 YEARS				
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.7	COMB. TYPE	H	NONE					
MODEL AND SERIAL: 21204-231	FSAR FIG. 3.11.8-1 FOR DBA		81 PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	PAGE 14	SUPP. REVIEW							
FUNCTION: REACTOR COOLANT LOOP C. DIFF. TEMP. & SERVICE TEMP. AVG. PROTECTION	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.7	COMB. TYPE	H	NONE					
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 14	SUPP. REVIEW							
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7	COMB. TYPE	H	NONE					
ACCUM. SPEC: N/A		PH 8.5-11.0	PH 10.7		PAGE 14	SUPP. REVIEW							
	R GAMMA	1.2 EG	124.7 EG	FSAR APP. 3.11.B-21	TEST REPORT SECT. 5.3	COMB. TYPE	H	NONE					
ACCUM. DEN.: N/A	A BETA	3.4 E7	11.7 E7	CONT. RAD. ZONE CS	PAGE 10	SUPP. REVIEW							
	D SHIELD	100% BETA	100% BETA		SRS TAB E								
SPECIFICATIONS: W. E. SPEC. 95337	T.I.D.	4.7 EG	124.7 EG		PAGE 15 THRU 4E								
P.O. #1265762	AGE-INST LIFE	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE		NONE				SAFETY FUNCTION: SEE TABS B OF ESE-G	
PLANT LOC: 1CB.31	(PER 323-1979 DEF.)				PAGE 17	SUPP. REVIEW							
COORDINATES X=1517.0 Y=1719.0 Z=257.0	SURMERGED	228.3	N/A	FSAR SECTION 13.6	PAGE 1E THRU 6E								
INSTALLED (Y/N):	YES				N/A	SRS TAB E		NONE					AUTH. REFERENCE: M.J.H.
INSTALL. KEYS: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G						
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-G											
QUALIF: QUALIFIED	TEMPERATURE	T											
STATUS WITHOUT EXCEPTION	PRESSURE	P											
	REL. HUMIDTY	H											
	CHEM. SPRAY	C											
	RADIATION	R											
	AGING	A											
PHYS DNG REF: CAR 2165 G163	SURMERGENCE	S											
PHYS DNG LUCI: TOTAL EQPT. LIST MOUNTING	FSAR ENV CAT: 10500 CATEG.:	A											
EQ. DUC. LUCI: W. P.O. 265762	APPENDIX E												
			REFERENCES: FLOW DIAG. 2165 G802				REVISION # : 0						
							DATE: 16-18-84						
							SYSTEM: REACTOR COOLANT						
							TAG: TE-IRC 0432B						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/WI UUTS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: TE-IRC 0432C	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY	TEST REPORT	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	ITY	NORMAL	NORMAL	REVIEW	SECT. 7.0	TEST & SUPP.	NONE
	NORM/TEST	1 YEAR	16.52 MO.		PAGE 17		
COMPONENT: TEMP. ELEMENT	DBA	POST DBA	POST DBA		SRS TAB E	REVIEW	ACCEL TEMP: 400°F
	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE	TEST REPORT	COMB. TYPE	
MANUFACTURER: RDF	URE	FSAR FIG.		19.4.0-1	SECT. 5.1	TEST & SUPP.	H NONE
		3.11.4-1 FOR DBA	420°F DBA	FSAR FIG.	PAGE 10	REVIEW	REPLACEMENT: 23 YEARS
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT	COMB. TYPE	MAINTAIN.
		FSAR FIG.		13.11.6-1 (DBA)	SECT. 5.7	TEST & SUPP.	H NONE
MODEL AND SERIAL: 21204 232	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE	TEST REPORT	COMB. TYPE	
		100% DBA	100% DBA	19.4.0-1 NORM	SECT. 5.7	TEST & SUPP.	H NONE
FUNCT. USE: REACTOR COOLANT & SERVICE LOOP C. DIFF. TEMP. TEMP. AVG. PROTECTION	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT	COMB. TYPE	
		PH 8.5-11.0	PH 10.7		SECT. 5.7	TEST & SUPP.	H NONE
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	124.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT	COMB. TYPE	
ACCUM. DEM.: N/A	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	SECT. 5.3	TEST & SUPP.	H NONE
	D SHIELD	100% BETA	100% BETA		PAGE 9 & 10	REVIEW	
SPECIFICATIONS: W.E. SPEC. 953397	T.I.D.	4.7 EG	124.7 E7		SRS TAB E	REVIEW	
	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	23 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT	COMB. TYPE	
P.O. #1265762	SUBMERGED	228.3	N/A	SECTION 13.6	SECT. 7.0	TEST & SUPP.	NONE
COORDINATES X=1513.0 Y=1726.0 Z=257.0		YES			PAGE 17	REVIEW	
					SRS TAB E	REVIEW	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G
QUALIF. EXEMPT: N/A	OPERABILITY	O ESE-G	REFERENCES: FLOW DIAG. 2165 G802				REVISION # 10 DATE 1-6-84 SYSTEM: REACTOR COOLANT TAG: TE-IRC 0432C
QUALIF: QUALIFIED	TEMPERATURE	T					
STATUS WITHOUT EXCEPTION	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DNG REF: CAR 2165 G163	RADIATION	R					
PHYS DNG LUC: TOTAL EQPT. LIST	AGING	A					
MOUNTING	SUBMERGENCE	S					
EQ. DUC. LUC: W. P.O. 265762	FSAR ENV CAT:	A					
	10588 CATEG.:	A					
	APPENDIX E						

SAFETY FUNCTION: SEE TAB B OF ESE-G

AUTH. REFERENCE: M.J.H.



EQUIP DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHODS		N/A ITEMS	OTHER
	PARAMETER	ACTUAL	DESIGN	QUALIFIED	ACTUAL	DESIGN		
TAG NO: TE-TRC 0432D	OPERABILITY	40 YEARS	23 YEARS	OPERABILITY TEST REPORT	SECT. 7.0	COMB. TYPE	NONE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST	1 YEAR	16.52 MO.	REVIEW	PAGE 17	TEST & SUPP.	NONE	ACCEL TEMP: 400°F
COMPONENT: TEMP. ELEMENT	DBA	POST DBA	POST DBA	FSAR TABLE	P. 15 THRU 4E	REVIEW	NONE	REPLACEMENT: 23 YEARS
MANUFACTURER: TRF	TEMPERATURE	120°F NORM	122°F NORM	FSAR FIG. 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE TEST & SUPP.	H NONE	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	DBA	3.11.4-1 FOR DBA	420°F DBA	FSAR FIG. 3.11.4-1	PAGE 10	TEST & SUPP. REVIEW	H NONE	SUBCOMPONENTS:
MODEL AND SERIAL: 21204 233	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE	
FUNCTION: REACTOR COOLANT & SERVICE DIFF. TEMP. AVG. PROTECTION	DBA	3.11.8-1 F	81PSIA DBA	FSAR FIG. 3.11.6-1 (DBA)	PAGE 14	TEST & SUPP. REVIEW	H NONE	
	RELATIVE HUMIDITY	40% NORM.	100% NORM.	FSAR TABLE 19.4.0-1 NORM.	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE	
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 14	TEST & SUPP. REVIEW	H NONE	
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON	12750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.7	COMB. TYPE TEST & SUPP.	H NONE	
ACCUR. DES: N/A		PH 8.5-11.0	PH 10.7 @ 25°C		PAGE 14	TEST & SUPP. REVIEW	H NONE	
SPECIFICATIONS: IWE SPEC. 953337	R GAMMA	1.2 EG	14.7 E7 GAMMA	FSAR APP. 3.11B-21	TEST REPORT SECT. 5.3	COMB. TYPE TEST & SUPP.	H NONE	
P.O. # 265762	A BETA	3.4 E7	11.7 E7 BETA	CONT. RAD. ZONE CS	PAGE 9 & 10	TEST & SUPP. REVIEW	H NONE	
PLANT LOC: 1CB. 31	D SHIELD	100% BETA	100% BETA		SRS TAB E	REVIEW	NONE	SAFETY FUNCTIONS: SEE TABS B OF ESE-G
COORDINATES X=1513.0 Y=1726.0 Z=257.0	T.I.D.	4.7 EG	14.7 E7		P. 15 THRU 4E	REVIEW	NONE	
INSTALLED (Y/11):	AGE			10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE TEST & SUPP.	NONE	
QUALIF EXEMPT: N/A	INST LIFE	40 YEARS	23 YEARS		PAGE 17	TEST & SUPP. REVIEW	NONE	
QUALIF: QUALIFIED	(PER 323-1974 DEF.)				SRS TAB E	REVIEW	NONE	
STATUS: WITHOUT EXCEPTION	SURMERGED	228.3	N/A	FSAR SECTION 13.6	P. 1E THRU 6E	REVIEW	NONE	AUTH. REFERENCES: M. J. H.
PHYS DNG REF: CAR 2165 G 163	YES				N/A	N/A	NONE	
PHYS DNG LIC: TOTAL EQPT. LIST MOUNTING					SRS TAB E	N/A	NONE	
EQ. DUC. LUC: W P.O. 265762					PAGE 1A		NONE	
	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-G
	OPERABILITY	O ESE-G		REFERENCES: FLOW DIAG. 2165 G 802				REVISION # : 0
	TEMPERATURE	T						DATE: 10-18-84
	PRESSURE	P						SYSTEM: REACTOR COOLANT
	REL. HUMIDTY	H						TAG: TE-TRC 0432D
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
	SURMERGENCE	S						
	FSAR ENV CAT: 10588 CATEG. 1	A						
	APPENDIX E							




A/E: EBAS ICES INC.
 UTILITY: MA POWER & LIGHT

FACILITY: SHEARON HARBOR
 COMPONENT EVALUATION

ISSUE: WESTINGHOUSE - PNH
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UNITS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL			
TAG NO: TE-IRC 0433	OPERABILITY	40 YEARS	20 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 7.0	COMB. TYPE	ACCEL TIME: 264 HOURS
EQUIPMENT: SENSOR TYPE	NORM/TEST DBA	1 YEAR	6.52 MO.		PAGE 16 SRS TAB E	TEST & SUPP. REVIEW	ACCEL TEMP: 400°F
COMPONENT: TEMP ELEMENT	TEMPERATURE	120°F NORM	122°F NORM	FSAR TABLE 19.4.0-1	TEST REPORT SECT. 5.1	COMB. TYPE	REPLACEMENT: 20 YEARS
MANUFACTURER: R/J	FSAR FIG. 3.11.4-1 FOR DBA		420°F DBA	FSAR FIG. 3.11.4-1	PAGE 4 SRS TAB E	TEST & SUPP. REVIEW	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG.	TEST REPORT SECT. 5.6	COMB. TYPE	SUBCOMPONENTS:
MODEL AND SERIAL: 21205 218	FSAR FIG. 3.11.8-1 FOR DBA		81 PSIA DBA	FSAR SECT. 3.11.6-1 (DBA)	PAGE 12 & 13 SRS TAB E	TEST & SUPP. REVIEW	
FUNCTION: REACTOR COOLANT & SERVICE LOOP 3 HOT LEG	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 5.1	COMB. TYPE	
		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	PAGE 12 & 13 SRS TAB E	TEST & SUPP. REVIEW	
	CHEMICAL SPRAY	2000-2100 PPM BORON	2750 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 5.6	COMB. TYPE	
ACCUM. SPEC: N/A		PH 8.5-11.0	PH 10.7		PAGE 12 & 13 SRS TAB E	TEST & SUPP. REVIEW	
ACCUM. DEH.: N/A	R GAMMA	1.2 E6	24.7 GAMMA	FSAR APP. 3.11.8-21	TEST REPORT SECT. 5.3	COMB. TYPE	
	A BETA	3.4 E7	19.3 E7 BETA	CONT. RAD. ZONE C5	PAGE 9 & 10 SRS TAB E	TEST & SUPP. REVIEW	
SPECIFICATIONS: IWE SPEC. 953337A DNG. #325826	D SHIELD	100% BETA	100% BETA		P. 28 THRU 78	TEST & SUPP. REVIEW	
P.O. # 265762 CHD # 15K 183	T.I.D.	4.7 E6	24.7 E7			TEST & SUPP. REVIEW	
PLANT LOC.: C.B. 31	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS	20 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 7.0	COMB. TYPE	SAFETY FUNCTIONS: SEE TAB B OF ESE-5
COORDINATES X= 1517.0 Y= 1719.0 Z= 255.0	SURMERGED	228.3	N/A		PAGE 16 SRS TAB E	TEST & SUPP. REVIEW	
INSTALLED (Y/N):		YES			P. 18 THRU 78	TEST & SUPP. REVIEW	
INSTALL. KEYS BY FIELD QUALIF EXEMPTN: N/A	PARAMETER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-5
QUALIF:	OPERABILITY	O ESE-5	REFERENCES: FLOW DIAG. CAR-2165 G 800				REVISION # 10
STATUS QUALIFIED	TEMPERATURE	T					DATE 16-18-84
WITHOUT EXEMPTION	PRESSURE	P					SYSTEM: REACTOR COOLANT
	REL. HUMIDTY	H					TAG: TE-IRC 0433
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG KEYS: CAR-2165 G 163	AGING	A					
PHYS DNG LUCI: TOTAL EQUIP LIST	SURMERGENCE	S					
MOUNTING	FSAR ENV CAT: 19588 CATEG. A	A					
EQ. DOC. LUCI: W P.O. 265762	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS	
	PARAMETER	ACTUAL	DEN.	QUALIF.				ACTUAL
TAG NO: TE-IRC 1313 SA	OPERABILITY	40 YEARS			OPERABILITY			ACCEL TIME
EQUIPMENT TYPE: TEMP. ELEMENT	NORM/TEST	1 YEAR			REVIEW			ACCEL. TEMP
COMPONENT: DBA	POST DBA							
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM			FSAR TABLE 19.4.0-1			REPLACEMENT
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.4-1			FSAR FIG. 3.11.4-1		H	MAINTENANCE
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM.			SUBCOMPONENTS
FUNCTION & SERVICE: REACTOR HEAD & SERVICE CAPILLARY INBOARD TEMP.		FSAR FIG. 3.11.8-1			FIG. 3.11.6-1 (DBA)		H	
	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM.			
ACCUM. SPEC: N/A					FSAR SECT. 3.11.4.3 (DBA)		H	
ACCUM. DEN.: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1			
SPECIFICATIONS:	H GAMMA	1.2 EG			FSAR FIG. 3.11.8-21			
P.O. # 435917 CND # 1 SH # 341	A BETA	3.4 E7			CONT. RAD. ZONE CS		H	
PLANT LOC.: C.B.	D SHIELD	100% BETA						
COORDINATES X= Y= Z= 278'9"	T.I.D.	4.7 EG						
INSTALLED (Y/II):	AGE-				10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE ESE-42 TAB 'B'
INSTALL. REF: BY FIELD	INST LIFE	40 YEARS						
QUALIF. EXEMPTN: N/A	(PER 323-1974 DEF.)							
QUALIF. STATUS	SUBMERGED	228.3			FSAR SECTION 13.6			AUTH. REFERENCE: M.J.H.
PHYS DWG REF: CAR-2166 G453	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-42	
PHYS DWG LIC: F-6	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # DATE SYSTEM (RVLIS) REACTOR COOLANT TAG TE-IRC 1313 SA	
MOUNTING	TEMPERATURE	T						
EDUC. LUCI W RO. 435917	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
	SUBMERGENCE	S						
	FSAR ENV CAT:							
	1958 CATEG.							
	APPENDIX E							




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION			QUALIF. METHOD	N/M/OUTS	UTS ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL				DEM.
TAG NO: TE-IRC 1314 SA	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR						ACCEL TEMP	
	DBA	POST DBA							
COMPONENT:	TEMPERATURE	120°F NORM			FSAR TABLE 19.4.0-1			REPLACEMENT	
		FSAR FIG. 3.11.4-1 FOR DBA			FSAR FIG. 3.11.4-1		H		
MANUFACTURER: MINCO	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM.			MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.8-1 FOR DBA			{ FIG. 3.11.6-1 (DBA)		H	SUBCOMPONENTS	
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM.				
					FSAR SECT. 3.11.4.3 (DBA)		H		
FUNCT. USE: RVLIS REACTOR HEAD & SERVICE CAPILLARY OUTBOARD TEMP.	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1				
							H		
ACCUM. SPEC: N/A	H GAMMA	1.1 EG			FSAR FIG. 3.11.B.21				
ACCUM. DEM.: N/A	A BETA	3.1 E7			CONT. RAD. ZONE C4				
	D SHIELD	100% BETA					H		
SPECIFICATIONS:	T.I.D.	1.15 EG							
	AGE - INST LIFE (PER 323-1978 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS: SEE ESE-42 TAB 'D'	
P.O # 435917 CND # 1 SH # 341	SURMERGED	228.3			FSAR ISECTION 13.6				
PLANT LOC.: C.B.									
COORDINATES X= Y= Z= 266-1								AUTH. REFERENCE: M.J.H.	
INSTALLED (Y/II):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42		
INSTAL. REF: BY FIELD	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : TE-IRC 1314 SA		
QUALIF EXEMPTN: N/A	TEMPERATURE	T							
QUALIF STATUS	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: CAR-2166 G452	AGING	A							
PHYS DNG LIC: B-10	SURMERGENCE	S							
MOUNTING	FSAR ENV CAT:								
EQ. DUC. LUC: P.O. 435917	10500 CATEG.								
	APPENDIX E								


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION METHODS		H/MI OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		
TAG NO: TE-IRC 1315 SA	OPERABILITY	40 YEARS	2	OPERABILITY REVIEW	3	4	5	ACCEL TIME
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR						ACCEL TEMP
COMPONENT:	DBA	POST DBA						REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM		FSAR TABLE 19.4.0-1				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1			H	SUBCOMPONENTS
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM		FSAR SECT. 3.11.6 NORM. FIG.			H	
FUNCTION: REACTOR HOT LEG & SERVICE CAPILLARY INBOARD TEMP	FSAR FIG.	3.11.8-1 FOR DBA		FSAR SECT. 3.11.6-1 (DBA)				
	RELATIVE HUMIDITY	40% NORM, 100% DBA		FSAR TABLE 19.4.0-1 NORM			H	
	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			H	
ACCUM. SPEC: N/A	R GAMMA	1.1 EG		FSAR FIG. 3.11.8-20			H	
ACCUM. DEM.: N/A	A BETA	1.7 E7		CONT. RAD. ZONE C1				
SPECIFICATIONS:	D SHIELD	100% BETA						
P.O. # 435917 CND # SH# 34	T.I.D.	1.15 EG						
PLANT LOC.: C.B.	AGE			10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION: SEE ESE-42 TAB B
COORDINATES X=	INST LIFE	40 YEARS						
Y=	(PER 323-1974 DEF.)							
Z= 249.3	SUBMERGED	228.3		FSAR SECTION 13.6				AUTH. REFERENCE: M.J.H.
INSTALLED (Y/N):								
INSTALL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42	
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42	REFERENCES: ... FLOW DIAG. CAR 2165 G044				REVISION # DATE SYSTEM: (RVLIS) REACTOR COOLANT TAG: TE-IRC 1315 SA	
QUALIF:	TEMPERATURE	T						
STATUS:	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
PHYS DNG REF: CAR 2166 G451	RADIATION	R						
PHYS DNG LUCI: H-15	DAGING	A						
MOUNTING:	SUBMERGENCE	S						
EQU. DUC. LUCI: W.P.O. 435917	FSAR ENV CAT:							
	10588 CATEG.							
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL	DEM.	QUALIF.		
TAG NO: TE-IRC 1316 SA (SPARE)	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIMES	
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR						ACCEL TEMP	
COMPONENT:	DBA	POST DBA						REPLACEMENT	
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM			FSAR TABLE 19.4.0-1			MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA			FSAR FIG. 3.11.4-1		H	SUBCOMPONENTS	
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM. FIG.		H		
FUNCTIONS: RVLIS REACTOR HOT & SERVICE LEG CAPILLARY OUTBOARD TEMP.		FSAR FIG. 3.11.8-1 FOR DBA			FSAR SECT. 3.11.6-1 (DBA)				
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		H		
ACCUM. DEM.: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		H		
SPECIFICATIONS:	R GAMMA A BETA D SHIELD T.I.D.				FSAR FIG. 3.11B CONT. RAD. ZONE		H		
P.O. # 435917 CND # 15H#34	AGC INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS: SEE ESE-42 TAB B	
PLANT LOC.: C.B.	SURMERGENCE	228.3			FSAR SECTION 13.6				
COORDINATES X- Y- Z-								AUTH. REFERENCE: M.J.H.	
INSTALLED (Y/II): INSTAL. REF: BY FIELD QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE ESE-42		
QUALIF:	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #: DATE: SYSTEM: (RVLIS) REACTOR COOLANT TAG: TE-IRC 1316 SA		
STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF:	TAGGING	A							
PHYS DNG LUCI:	SURMERGENCE	S							
MOUNTING:									
EU.DUC.LUCI W.P.O.435917	FSAR ENV CAT: 10500 CATEG. 1 APPENDIX E								


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION		H/WI UITS	ITEMS	
	PARAMETER	ACTUAL	DEN.	QUALIF.	ACTUAL	DEN.			QUALIF.
TAG NO: TE-IRC1317SA <i>BOTTOM OF REACTOR</i>	OPERABILITY	40 YEARS			OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: TEMP. ELEMENT TYPE	INDHM/TEST	1 YEAR							ACCEL TEMP
COMPONENT:	DBA	POST DBA							REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM			FSAR TABLE 19.4.0-1				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA			FSAR FIG. 3.11.4-1		H		SUBCOMPONENTS
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM. FIG.		H		
FUNCTIONS: CAPILLARY TO SEAL & SERVICE TABLE INBOARD TEMP.	FSAR FIG.	3.11.8-1 FOR DBA			FSAR SECT. 13.11.6-1 (DBA)				
ACCUM. SPEC: N/A	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM		H		
ACCUM. DEN.: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		H		
SPECIFICATIONS:	R GAMMA A BETA D SHIELD T.I.D.				FSAR FIG. 3.11B-20 CONT. RAD. ZONE C1		H		
P.O. # 435917 CND # 15H#341	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS: SEE ESE-42 TAB B
PLANT LOC.: C.B.	SUBMERGED	228.3			FSAR SECTION 13.6				AUTH. REFERENCE: M.J.H.
COORDINATES X- Y- Z- 225-9	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42		
INSTALLED (Y/N): BY FIELD	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #: DATE:		
QUALIF EXEMPT: N/A	TEMPERATURE	T							
STATUS	PRESSURE	P	SYSTEM: (RVLIS) REACTOR COOLANT TAG: TE-IRC1317SA						
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION AGING	R							
PHYS DNG REF: CAR 2166 G452	SUBMERGENCE	S							
PHYS DNG LUCI MOUNTING	FSAR ENV CAT: 10588 CATEG. APPENDIX E								
EW.DUC.LUCI W.P.O. 435917									



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION		N/M/OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD	
TAG NO: TE-IRC 1318 SA BOTTOM OF REACTOR	OPERABILITY	40 YEARS		OPERABILITY			ACCEL TIME
EQUIPMENT: TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR		REVIEW			ACCEL TEMP
COMPONENT:	DBA	POST DBA					REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM		FSAR TABLE			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA		9.4.0-1 FSAR FIG. 3.11.4-1		H	SUBCOMPONENTS
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	
FUNCTIONS: CAPILLARY TO SEAL & SERVICE TABLE INBOARD TEMP.	RELATIVE HUMIDITY	40% NORM, 100% DBA		FSAR TABLE 9.4.0-1 NORM, FSAR SECT. 3.11.4.3 (DBA)		H	
ACCUM. SPECI. N/A	CHEMICAL SPRAY	2000-2100 PRM BOROM PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
ACCUM. DEM.: N/A	R GAMMA A BETA D SHIELD	T.I.D.		FSAR FIG. 3.11B-20 CONT. RAD. ZONE C1		H	
SPECIFICATIONS:	AGE - INST LIFE	40 YEARS (PER 323-1974 DEF.)		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE ESE-42 TAB 7B
P.O. # 435917 CHD # SH# 341	SURMERGENCE	228.3		FSAR SECTION 13.6			AUTH. REFERENCE: M.J.H.
PLANT LOC.: C.B.	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
COORDINATES X- Y- Z- 235-7	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #
INSTALLED (Y/N):	TEMPERATURE	T					DATE
INSTALL. REF: BY FIELD	PRESSURE	P	SYSTEM: (RVLIS) REACTOR COOLANT				
QUALIF EXEMPT: N/A	REL. HUMIDTY	H	TAG: TE-IRC 1318 SA				
QUALIF STATUS	CHEM. SPRAY	C					
PHYS DNG REF: CAR 2166 G452	RADIATION AGING	R A					
PHYS DNG LUCI MOUNTING	SURMERGENCE	S					
EDUC. LUCI: W.P.O. 435917	FSAR ENV CAT: 10580 CATEG. 1 APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION		N/M/OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD			
TAG NO: TE-IRC 1319 SA (SPARE)	OPERABILITY	40 YEARS	NORMAL	OPERABILITY	REVIEW			ACCEL TIME	
EQUIPMENT: TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR						ACCEL TEMP	
COMPONENT:	DBA	POST DBA						REPLACEMENT	
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM		FSAR TABLE	19.4.0-1			MAINTAIN.	
	URE	FSAR FIG. 3.11.4-1		FSAR FIG.	3.11.4-1		H	SUBCOMPONENTS	
	FOR DBA								
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.		FSAR SECT.	3.11.6 NORM.				
		FSAR FIG 3.11.8-1		FIG.	3.11.6-1(DBA)		H		
	FOR DBA								
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE	19.4.0-1 NORM				
FUNCTIONS: RVLIS CAPILLARY FROM & SERVICE SEAL TABLE TEMP.				FSAR SECT.	3.11.4.3(DBA)		H		
	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT.	3.11.5.1				
ACCUM. SPEC: N/A									
ACCUM. DEM.: N/A	R GAMMA A BETA D SHIELD T.I.D.			FSAR FIG. 3.11B CONT. RAD. ZONE			H		
SPECIFICATIONS:	AGE- INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS: SEE ESE-42 TAB D	
P.O. # 435917 CND # 1 SH # 34	(PER 323- 1974 DEF.)								
PLANT LOC.: C.B.	SUBMERGENCE	228.3		FSAR SECTION 13.6				AUTH. REFERENCE: M.J.H.	
COORDINATES X- Y- Z-									
INSTALLED (Y/N): INSTAL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42		
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42							
QUALIF:	TEMPERATURE	T							
STATUS:	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
	AGING	A							
PHYS DNG REF:	SUBMERGENCE	S							
PHYS DNG LUCI									
MOUNTING:									
EQUIP. LUCI: W P.O. 435917	FSAR ENV CAT:		REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION #: DATE:		
	10588 CATEG.:						SYSTEM: (RVLIS) REACTOR COOLANT		
	APPENDIX E						TAG: TE-IRC 1319 SA		



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: TE-IRC 1323 SB	OPERABILITY	40 YEARS	2	OPERABILITY REVIEW	5		ACCEL TIME
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR					ACCEL TEMP
COMPONENT:	DBA	POST DBA					REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120° F NORM		FSAR TABLE 19.4.0-1			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1		H	SUBCOMPONENTS
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.		H	
FUNC. USE: REACTOR HEAD & SERVICE CAPILLARY INBOARD TEMP.	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		H	
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON IPH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
ACCUM. DEM.: N/A	R GAMMA	1.2 EG		FSAR FIG. 3.11B-21			
SPECIFICATIONS:	A BETA	3.4 E7		CONT. RAD. ZONE C5		H	
P.O. # 435917 CND # 1 SH # 342	T. I. D.	4.7 EG					
PLANT LOC.: C.B.	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS: SEE ESE-42 TAB 7B
COORDINATES X= Y= Z= 278-9	(PER 325-1979 DEF.)						
INSTALLED (Y/II):	SURMERGED	228.3		FSAR SECTION 3.6			AUTH. REFERENCE: M.J.H.
INSTALL. NEFT: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # DATE SYSTEM: (RVLIS) REACTOR COOLANT TAG: TE-IRC 1323 SB
QUALIF:	TEMPERATURE	T					
STATUS:	PRESSURE	P					
:	REL. HUMIDTY	H					
:	CHEM. SPRAY	C					
PHYS DNG NEFT: CAR-2166 G453	RADIATION	R					
PHYS DNG LUCI: F-G	AGING	A					
MOUNTING:	SURMERGENCE	S					
EN. DUC. LUCI: W.P.O. 435917	FSAR ENV CAT:						
	10508 CATEG.:						
	APPENDIX E						

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL		
TAG NO: TE-IRC 1324SB	OPERABILITY	40 YEARS	2	OPERABILITY REVIEW	5	7
EQUIPMENT TYPE: TEMP. ELEMENT	NORM/TEST	1 YEAR				
COMPONENT: DBA	POST DBA					ACCEL TIME
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM		FSAR TABLE 9.4.0-1		ACCEL TEMP
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1	H	REPLACEMENT
	PRESSURE	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.		MAINTAIN.
	FSAR FIG.	3.11.8-1 FOR DBA		3.11.6-1 (DBA)	H	SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	H	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1	H	
ACCUM. SPEC: N/A	K GAMMA	1.1 EG		FSAR FIG. 3.11B-21		
ACCUM. DEM.: N/A	A BETA	3.1 E7		CONT. RAD. ZONE C4	H	
SPECIFICATIONS:	T.I.D.	1.15 EG				
P.O. # 435917 CHD # 1 SH # 342	AGE - INST LIFE (PER 523-1978 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTIONS: SEE ESE-42 TAB B
PLANT LOC.: C.B.	SUBMERGED	228.3		FSAR SECTION 13.6		
COORDINATES X= Y= Z= 268-7						AUTH. REFERENCE: M.J.H.
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
INSTAL. REFS: BY FIELD	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844			REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : TE-IRC 1324SB
QUALIF EXEMPT: N/A	TEMPERATURE	T				
QUALIFI STATUS	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
PHYS DNG REF: CAR 2166 G452	AGING	A				
PHYS DNG LUC: H-14	SUBMERGENCE	S				
MOUNTING	FSAR ENV CAT:					
EDUC. LUC: W P.O. 435917	19588 CATEG.:					
	APPENDIX E					


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI OUTF. ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL		
TAG NO: TE-IRC 1325 SB	OPERABILITY	40 YEARS		OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR				ACCEL TEMP
COMPONENT:	DBA	POST DBA				
MANUFACTURER: MINCO	TEMPERATURE	120° F NORM		FSAR TABLE 19.4.0-1		REPLACEMENT
MAJOR SUPPLIER: WESTINGHOUSE		FSAR FIG. 3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1	H	MAINTAIN.
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM		FSAR SECT. 3.11.6 NORM. FIG.	H	SUBCOMPONENTS
FUNCTION: REACTOR HOT LEG & SERVICE CAPILLARY INBOARD TEMP.		FSAR FIG. 3.11.8-1 FOR DBA		3.11.6-1 (DBA)		
	RELATIVE HUMIDITY	40% NORM, 100% DBA		FSAR TABLE 19.4.0-1 NORM	H	
				FSAR SECT. 3.11.4.3 (DBA)		
	CHEMICAL SPRAY	2000-2100 PRM BOROM IPH 8.5-11.0		FSAR SECT. 3.11.5.1	H	
ACCUM. SPEC: N/A	R GAMMA	1.1 EG		FSAR FIG. 3.11B-20		
ACCUM. DEM.: N/A	A BETA	1.7 E7		CONT. RAD. ZONE C-1	H	
SPECIFICATIONS:	D SHIELD	100% BETA				
P.O. # 435917 CHD # SH# 342	T.I.D.	1.15 EG				SAFETY FUNCTIONS: SEE ESE-42 TAB B
PLANT LOC.: C.B.	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		
COORDINATES X=	(PER 323-1974 DEF.)					
Y=	SUBMERGED	228.3		FSAR SECTION 13.6		
Z= 249-3						AUTH. REFERENCE: M.J.H.

INSTALL. REFS: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42		
QUALIF:	TEMPERATURE	T		
STATUS:	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
PHYS DNG REF: CAR-2K66G 450	AGING	A		
PHYS DNG LUC: C-5	SUBMERGENCE	S		
MOUNTING:				
EQU. DUC. LUC: P.O. 435917	FSAR ENV CAT: 10500 CATEG. 1 APPENDIX E		REFERENCES: FLOW DIAG. CAR 2165 G844	REVISION # : DATE :
				SYSTEM: (RVLIS) REACTOR COOLANT TAG: TE-IRC 1325 SB

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS
	PARAMETER	ACTUAL	DEH.	QUALIF.			
TAG NO: TE-IRC 1326 SB	OPERABILITY	40 YEARS			OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT TEMP. ELEMENT TYPE	INORM/TEST	1 YEAR					ACCEL TEMP
COMPONENT:	TEMPERATURE	120° F NORM			FSAR TABLE 19.4.0-1		REPLACEMENT
MANUFACTURER: MINCO	DBA	POST DBA			FSAR FIG. 3.11.4-1 FOR DBA	H	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM. FIG.	H	SUBCOMPONENTS
MODEL AND SERIAL #	FSAR FIG.	3.11.8-1 FOR DBA			FSAR FIG. 3.11.6-1 (DBA)		
FUNCTION: RVLIS REACTOR HOT LEG CAPILLARY OUTBOARD TEMP.	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	H	
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1	H	
ACCUM. DEM.: N/A	H GAMMA	1.2 EG			FSAR FIG. 3.11B-20	H	
SPECIFICATIONS:	A BETA	3.3E7			CONT. RAD. ZONE C3		
P.O. # 435917 CHD # 1 SH# 342	D SHIELD	100% BETA					SAFETY FUNCTION: SEE ESE-42 TAB B
PLANT LOC.: C.B.	T.I.D.	1.25 EG					
COORDINATES X=	AGE-				110 CFR 50 PARAGRAPH 50.51		
Y=	INST LIFE	40 YEARS					
Z= 248-6	(PER 323-1974 DEF.)						
INSTALLED (Y/II):	SUBMERGED	228.3			FSAR SECTION 13.6		AUTH. REFERENCES: M.J.H.
INSTALL. REFS: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : TE-IRC 1326 SB
QUALIF:	TEMPERATURE	T					
STATUS:	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DNG REFS: CAR 2166 G450	RADIATION AGING	R. A					
PHYS DNG LUCI: C-16	SUBMERGENCE	S					
MOUNTING:	FSAR ENV CAT:						
EDUC. LUCI: W.T.O. 435917	10500 CATEG.:						
	APPENDIX E:						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL		
TAG NO: TE-IRC 1327 SB <i>BOTTOM OF REACTOR</i>	OPERABILITY	40 YEARS		OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR				ACCEL TEMP
COMPONENT:	DBA	POST-DBA				REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120° F NORM		FSAR TABLE 19.4.0-1		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1		FOR DBA	H	SUBCOMPONENTS:
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM.		
FUNCTIONS: CAPILLARY TO SEAL & SERVICE TABLE INBOARD TEMP.	FSAR FIG.	3.11.8-1		FOR DBA	H	
	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM		
	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.4.3 (DBA)	H	
ACCUR. SPEC: N/A				FSAR SECT. 3.11.5.1	H	
ACCUR. DEM.: N/A	R GAMMA A BETA D SHIELD			FSAR FIG. 3.11B-20 CONT. RAD. ZONE C1	H	
SPECIFICATIONS:						
P.O. # 435917 CND # 15H# 342	AGE- INST LIFE	40 YEARS		110 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTION: SEE ESE-42 TAB B
PLANT LOC.: C.B.	(PER 323-1979 DEF.)					
COORDINATES X= Y= Z= 225-9	SUBMERGED	228.3		FSAR SECTION 13.6		AUTH. REFERENCE: M.J.H.
INSTALLED (Y/II):						
INSTALL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844			REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : TE-IRC 1327 SB
QUALIF: CAR 2165 G452	TEMPERATURE	T				
STATUS	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
PHYS DNG REF:	TAGGING	A				
PHYS DNG LUC:	SUBMERGENCE	S				
MOUNTING						
EQU. DNG LUC: W P.O. 435917	FSAR ENV CAT:					
	19588 CATEG.					
	APPENDIX E					




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.	ACTUAL	DEM.	QUALIF.		
TAG NO: TE-IRC 1328 SB BOTTOM OF REACTOR	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT: TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR						ACCEL TEMP	
COMPONENT:	DBA	POST DBA						REPLACEMENT	
MANUFACTURER: MINCO	TEMPERATURE	120° F NORM			FSAR TABLE 19.4.0-1			MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	FSAR FIG.	3.11.4-1			FOR DBA		H	SUBCOMPONENTS	
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.			FSAR SECT. 3.11.6 NORM. & FIG.		H		
FUNCTIONS: RYLIIS CAPILLARY TO & SERVICE SEAL TABLE OUTBOARD TEMP.	FSAR FIG.	3.11.8-1			FOR DBA				
ACCUR. SPEC: N/A	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		H		
ACCUR. DEM.: N/A	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		H		
SPECIFICATIONS:	R GAMMA A BETA D SHIELD	T.I.D.			FSAR FIG. 3.11B-20 CONT. RAD. ZONE C1		H		
P.O. # 435917 CND # 1 SH # 342	AGE - INST LIFE	40 YEARS (PER 325-1974 DEF.)			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: SEE ESE-42 TAB B	
PLANT LOC.: C.B.	SUBMERGED	228.3			FSAR SECTION 13.6			AUTH. REFERENCE: M.J.H.	
COORDINATES X= Y= Z= 235-7	OTHER EQUIPMENT THIS CES APPLIES TO:							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:						REVISION #
INSTAL. REF: BY FIELD	OPERABILITY	O ESE-42	REFERENCES:						DATE
QUALIF EXEMPT: N/A	TEMPERATURE	T	FLOW DIAG. CAR 2165 G844						SYSTEM: (RYLIIS) REACTOR COOLANT
QUALIF:	PRESSURE	P							TAG: TE-IRC 1328 SB
STATUS:	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: CAR 2166 G452	AGING	A							
PHYS DNG LUC:	SUBMERGENCE	S							
MOUNTING:	FSAR ENV CAT:								
EQU. DUC. LUC: W P.O. 435917	10500 CATEG.								
	APPENDIX E								


1
2
3
4




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIFICATION		H/MI OUTS ITEMS			
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.	METHOD					
TAG NO: TE-IRC 1329 SB	OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW	3	4	5	6	7	ACCEL TIME
EQUIPMENT: TEMP. ELEMENT TYPE	NORM/TEST	1 YEAR								ACCEL TEMP
COMPONENT:	DBA	POST DBA								REPLACEMENT
MANUFACTURER: MINCO	TEMPERATURE	120°F NORM		FSAR TABLE 19.4.0-1						MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	URE	FSAR FIG. 3.11.4-1 FOR DBA		FSAR FIG. 3.11.4-1			H			SUBCOMPONENTS
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.			H			
FUNCTIONS: RVLIS CAPILLARY & SERVICE FROM SEAL TABLE TEMP.	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)			H			
ACCUM. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			H			
ACCUM. DEM.: N/A	R GAMMA	1.2 EG		FSAR FIG. 3.11.B.20			H			
SPECIFICATIONS:	A BETA	3.3 E7		CONT. RAD. ZONE C3						
P.O. # 435917 CND # 15H#342	D SHIELD	100% BETA								SAFETY FUNCTIONS: SEE ESE-42 TAB B
PLANT LOC.: C.B.	T.I.D.	1.25 EG								
COORDINATES X=	AGC-			110 CFR 50 PARAGRAPH 50.51						
Y=	INST LIFE	40 YEARS								
Z= 248-G	(PER 323-1974 DEF.)									
INSTALLED (Y/II):	SUBMERGED	228.3		FSAR SECTION 13.6						AUTH. REFERENCE: M.J.H.
INSTALL. REF: BY FIELD	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ESE-42			
QUALIF EXEMPT: N/A	OPERABILITY	O ESE-42	REFERENCES: FLOW DIAG. CAR 2165 G844				REVISION # : DATE : SYSTEM : (RVLIS) REACTOR COOLANT TAG : TE-IRC 1329 SB			
QUALIF STATUS	TEMPERATURE	T								
	PRESSURE	P								
	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
PHYS DNG REF: CAR 2166 G451	RADIATION	R								
PHYS DNG LUCI H-15	AGING	A								
MOUNTING	SUBMERGENCE	S								
EDUC. LUCI: W P.O. 435917	FSAR ENV CAT:									
	10588 CATEG.:									
	APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UITS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.		
TAG NO: 25 IRC R 528	OPERABILITY	40 YEARS		OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT: RELIEF VALVE	NOHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: POSITION SW.	TEMPERATURE	120°F NORM 380°F FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		REPLACEMENT
MANUFACTURER: CROSBY	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		
FUNCTIONS: PRESSURIZER SAFETY & SERVICE RELIEF VALVE	R GAMMA A BETA D SHIELD T.I.D.	1.3E7 3.7E8 100% BETA 1.3E7		FSAR APP. 3.11B-21 CONT. RAD. ZONE CG		
ACCUR. SPEC: N/A	AGE INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTION
ACCUR. DEM.: N/A	SUBMERGED	228.3 YES		FSAR SECTION 3.6		AUTH. REFERENCE
SPECIFICATIONS:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
P.O # : CHD # :	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G801			
PLANT LOC.: CB 41	TEMPERATURE	T				
COORDINATES X- Y- Z- 308.0	PRESSURE	P				
INSTALLED (Y/II):	REL. HUMIDTY	H				
INSTAL. REF:	CHEM. SPRAY	C				
QUALIF. EXEMPT:	RADIATION AGING	R A				REVISION # :
STATUS:	SUBMERGENCE	S				DATE :
PHYS DWG REF: CAR 2165 G148	FSAR ENV CAT: 10588 CATEG. 4					SYSTEM: REACTOR COOLANT
PHYS DWG LUC:	APPENDIX E					TAG : 25 IRC R 528
MOUNTING :						
EQ. DUC. LUC:						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	QUALIF. METHOD	H/M	OUTS	ITEMS
	PARAMETER	ACTUAL					
TAG NO: ES IRC R 529	OPERABILITY	40 YEARS	2	3	4	5	7
EQUIPMENT: RELIEF VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA		OPERABILITY REVIEW			ACCEL TIME
COMPONENT: POSITION SW.	TEMPERATURE	120°F NORM 380°F FOR DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1			ACCEL TEMP
MANUFACTURER: CROSBY	PRESSURE	ATMOS. NORM.		FSAR SECT. 3.11.6 NORM. FIG.			REPLACEMENT
MAJOR SUPPLIER: WESTINGHOUSE		52 PSIA FOR DBA		3.11.6-1 (DBA)			MAINTAIN.
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS
FUNCTIONS: PRESSURIZER & SERVICE SAFETY RELIEF VALVE	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1			
ACCUR. SPEC: N/A	R GAMMA	1.3 E7		FSAR APP. 3.11.B-21			
ACCUR. DEM.: N/A	A BETA	3.7 E8		CONT. RAD. ZONE CG			
SPECIFICATIONS:	D SHIELD	100% BETA					
P.O #:	T.I.D.	1.3 E7					
PLANT LOC.: CB 41	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
COORDINATES X-Y-Z	SUBMERGED	228.3		FSAR SECTION 3.6			AUTH. REFERENCE
INSTALLED (Y/H):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G801				
QUALIF EXEMPTN:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG REF: CAR 2165 G148	AGING	A					REVISION #:
PHYS DNG LOC:	SUBMERGENCE	S					DATE:
MOUNTING:	FSAR ENV CAT:						SYSTEM: REACTOR COOLANT
EQ. DUC. LUC:	1958 CATEG.:						TAG: ES IRC R 529
	APPENDIX E:						



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: ZS IRC R530	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: RELIEF VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: POSITION SW.	TEMPERATURE	120°F NORM 380°F FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT
MANUFACTURER: CROSBY	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1(DBA)			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)			SUBCOMPONENTS
FUNCTION: PRESSURIZER SAFETY & SERVICE RELIEF VALVE	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD	1.3 E7 13.7 E8 100% BETA T.I.D. 1.3 E7	FSAR APP 3.11B-21 CONT. RAD. ZONE CG			
ACCUM. DEH.: N/A	AGE- INST LIFE	40 YEARS (PER 323-1974 DEF.)	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
SPECIFICATIONS:	SUBMERGED	228.3	FSAR SECTION 3.6			AUTH. REFERENCE
P.O #: CHD # :	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
PLANT LOC.: CB41	OPERABILITY	O	REFERENCES:			
COORDINATES X- Y- Z- 308.0	TEMPERATURE	T				
INSTALLED (Y/N):	PRESSURE	P				
INSTAL. REF:	REL. HUMIDTY	H				
QUALIF EXEMPT:	CHEM. SPRAY	C				
QUALIF STATUS:	RADIATION	R				
PHYS DMG REF: CAR 2165 G148	AGING	A				REVISION # :
PHYS DMG LUC:	SUBMERGENCE	S				DATE :
MOUNTING:	FSAR ENV CAT:					SYSTEM : REACTOR COOLANT
EQ. DOC. LUC:	10588 CATEG.:					TAG : ZS IRC R 530
	APPENDIX E					




EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER ACTUAL		DEH. QUALITY	DOCUMENTATION ACTUAL		DEH. QUALITY	QUALIF. METHOD	H/M	OUTS ITEMS	
TAG NO : NE-41 (POWER RANGE)	OPERABILITY	40 YEARS		OPERABILITY REVIEW						ACCEL TIME
EQUIPMENT TYPE : EXCORE NUCLEAR INSTRUMENTATION	NORM/TEST DBA	1 YEAR POST DBA								ACCEL TEMP
COMPONENT : NEUTRON DETECTOR	TEMPERATURE	120°F NORM 380°F FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1						REPLACEMENT
MANUFACTURER : WESTINGHOUSE	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)						MAINTAIN.
MAJOR SUPPLIER : WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)						SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1						
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.3E7 3.7E8		FSAR APP. 3.11B-18 CONT. RAD. ZONE CO						
ACCUR. SPEC : N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51						SAFETY FUNCTION
ACCUR. DEH. : N/A	SUBMERGED	228.3		FSAR SECTION 13.6						AUTH. REFERENCE
SPECIFICATIONS :	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO :				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE :			
P.O # 177181 CHD # 1 SH.# 63	OPERABILITY	O	REFERENCES :							
PLANT LOC. : C.B.	TEMPERATURE	T								
COORDINATES X- Y- Z-	PRESSURE	P								
INSTALLED (Y/N) :	REL. HUMIDTY	H								
INSTAL. REF :	CHEM. SPRAY	C								
QUALIF EXEMPTN :	RADIATION	R					REVISION # :			
QUALIF :	AGING	A					DATE :			
STATUS :	SUBMERGENCE	S					SYSTEM :			
PHYS DMG REF :	FSAR ENV CAT :						REACTOR PROTECTION			
PHYS DMG LUC :	1958 CATEG. :						SYS.			
MOUNTING :	APPENDIX E :						TAG : NE-41			
EQ. DUC. LUC :										

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO : NE-42 (POWER RANGE)	OPERABILITY	40 YEARS			OPERABILITY REVIEW		
EQUIPMENT TYPE : EXCORE NUCLEAR INSTRUMENTATION	NORM/TEST DBA	1 YEAR POST DBA					
COMPONENT : NEUTRON DETECTOR	TEMPERATURE	120°F NORM 380°F FOR DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		
MANUFACTURER : WESTINGHOUSE	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA			FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1(DBA)		
MAJOR SUPPLIER : WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)		
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD	1.3E7 3.7E8 T.I.D.			FSAR APP. 3.11B-18 CONT. RAD. ZONE CO		
ACCUR. SPEC : N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51		
ACCUR. DEM. : N/A	SUBMERGED	228.3			FSAR SECTION 3.6		
SPECIFICATIONS :							
P.O # : 177181 CND # : SH# 66							
PLANT LOC. :							
COORDINATES X- Y- Z-							

INSTALLED (Y/N) : INSTAL. REF : QUALIF EXEMPTN : QUALIF : STATUS : PHYS DNG REF : PHYS DNG LOC : MOUNTING : EQ. DUC. LOC :	PARA-METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE SAR ENV CAT : 10500 CATEG. : APPENDIX E	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO : REFERENCES :	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE : REVISION # : DATE : SYSTEM : REACTOR PROTECTION SYS. TAG : NE-42
--	--	---	---	--



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: NE-43 (POWER RANGE)	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME:
EQUIPMENT TYPE: EXCORE NUCLEAR INSTRUMENTATION	NORM/TEST DBA	1 YEAR				ACCEL TEMP:
COMPONENT: NEUTRON DETECTOR	TEMPERATURE	120°F NORM 380°F FOR DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT:
MANUFACTURER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)			MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	40% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)			SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	1.3E7 3.7E8	FSAR APP. 3.11B-18 CONT. RAD. ZONE 20			
ACCUR. SPEC: N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	110 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS:
ACCUR. DEM.: N/A	SUBMERGED	228.3	FSAR SECTION 3.6			AUTH. REFERENCES:
SPECIFICATIONS:	INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPT:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:		QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
P.O # 177181 CHD # SH # 67	OPERABILITY		O	REFERENCES:		
PLANT LOC.:	TEMPERATURE		T			
COORDINATES X- Y- Z-	PRESSURE		P			
	REL. HUMIDTY		H			
	CHEM. SPRAY		C			
	RADIATION		R	REVISION # : DATE : SYSTEM : REACTOR PROTECTION SYS. TAG : NE-43		
	AGING		A			
	SUBMERGENCE		S			
	FSAR ENV CAT:					
	10588 CATEG.:					
	APPENDIX E					



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/MI OUTS
	PARAMETER	ACTUAL			
TAG NO : NE-44 (POWER RANGE)	OPERABILITY	40 YEARS	OPERABILITY		
EQUIPMENT : EXCORE NUCLEAR INSTRUMENTATION	ITY	NORMAL	REVIEW		
COMPONENT : NEUTRON DETECTOR	NORM/TEST	1 YEAR			
MANUFACTURER : WESTINGHOUSE	DBA	POST DBA			
MAJOR SUPPLIER : WESTINGHOUSE	TEMPERATURE	120°F NORM 380°F FOR DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		
MODEL AND SERIAL #	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		
FUNCTIONS & SERVICE	RELATIVE HUMIDITY	40% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		
ACCUR. SPECI : N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1		
ACCUR. DEM. : N/A	R GAMMA	1.3E7	FSAR APP. 3.11B-18		
SPECIFICATIONS :	A BETA	3.7E8	CONT. RAD. ZONE 20		
P.O # : 177181 CHD # : SH.#69	D SHIELD	T.I.D.			
PLANT LOC. :	AGE-INST LIFE	40 YEARS	110 CFR 50 PARAGRAPH 50.51		
COORDINATES X- Y- Z-	(PER 323-1974 DEF.)				
INSTALLED (Y/N) :	SUBMERGED	228.3	FSAR SECTION 13.6		

INSTALL. REF:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPTN:	OPERABILITY	O	REFERENCES:	
STATUS:	TEMPERATURE	T		
	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
PHYS DMG REF:	RADIATION	R		
PHYS DMG LOC:	AGING	A		
MOUNTING :	SUBMERGENCE	S		
EQ. DUC. LOC:	FSAR ENV CAT:			
	10500 CATEG.:			
	APPENDIX E			

REVISION # :
DATE :
SYSTEM : REACTOR PROTECTION SYS.
TAG : NE-44

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	UNITS	ITEMS			
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL	DEM.	QUALIF.
TAG NO: 1RH-V5005B-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25	TYPE TEST	/	NONE	ACCEL TIME: 15092 HOURS		
EQUIPMENT TYPE: VALVE GATE	NORM/TEST DBA	1 YEAR	1 YEAR	POST DBA	POST DBA				ACCEL TEMP: 180°C		
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1	SRS TABLE 3.11.4-1	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	REPLACEMENT: 40 YEARS		
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR FIG. 3.11.4-1 FOR DBA	385°F DBA	FSAR SECT. 3.11.6 NORM. FIG.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	NONE	MAINTAIN.:	
MAJOR SUPPLIER: WESTHS.	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 9.4.0-1 NORM	70 PSIG DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE PAGE 2B	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.
MODEL AND SERIAL: SMB-1	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	PH 8.5-11.0	PH 10.5-11.1	FSAR SECT. 3.11.5.1	TEST REPORT SEC. 4.4.2 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
FUNCTIONS & SERVICE: RESIDUAL HEAT REMOVAL - SERVING VALVE 1RH-V5005B-1	R Gamma	1.2 EG	130 EG	FSAR APP. 3.11.B-21	CONT. RAD. ZONE C5	TEST REPORT SEC. 4.3	PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E PAGE 19	
ACCUM. SPEC: N/A	A BETA	3.4 EG	74 EG	FSAR APP. 3.11.B-21	CONT. RAD. ZONE C5	TEST REPORT SEC. 4.3	PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E PAGE 19	
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA	FSAR APP. 3.11.B-21	CONT. RAD. ZONE C5	TEST REPORT SEC. 4.3	PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E PAGE 19	
SPECIFICATIONS: W.E. SPEC. 952065 05	T.I.D.	9.7 EG	204 EG	FSAR APP. 3.11.B-21	CONT. RAD. ZONE C5	TEST REPORT SEC. 4.3	PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E PAGE 19	
P.O. # 173662	AGE - INST LIFE	40 YEARS	456 YEARS	110 CFR 50 PARAGRAPH 50.51		TEST REPORT SEC. 3.1.1	PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	/	SEE TAB E PAGE 19	SAFETY FUNCTION: SEE TAB "B" OF HE-1
PLANT LOC.: C.B. 21	SURMERGED	228.3		FSAR SECTION 3.6		SRS TABLE PAGE 1A	N/A	COMB. TYPE TEST & SUPP. REVIEW	/	NONE	AUTH. REFERENCE: M.J.H.
COORDINATES X-1520.0		YES	N/A								
Y-1702.0											
Z-251.0											
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1			
INSTALL. REF: BY FLD.	OPERABILITY	O HE-1		REFERENCES: FLOW DIAG. CAR-2165 G-824 RNR & SAFETY INJ. PIPING CAR-2165 G-155 LIMITORQUE TEST REPORT 600456				REVISION # : 0 DATE : 4-21-84 SYSTEM : RESIDUAL HEAT REMOVAL TAG : 1RH-V5005B-1			
QUALIF EXEMPT: N/A	TEMPERATURE	T									
QUALIF: QUALIFIED, AWAITING	PRESSURE	P									
STATUS CONFIRMATORY DATA	REL. HUMIDTY	H									
	CHEM. SPRAY	C									
	RADIATION	R									
PHYS DMG REF: CAR-2165 G-155	AGING	A									
PHYS DMG LUCI TOTAL EQUIP. LIST	SURMERGENCE	S									
HOUSING											
EDUC. LUCI	FSAR ENV CAT: 19586 CATEG. A										
BY P.O. 173662	APPENDIX E										

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO: <i>IRH-V5015A-1</i>	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25	5	NONE	ACCEL TIME: 15092 HOURS
EQUIPMENT TYPE: <i>VALVE GATE</i>	NORM/TEST DBA	1 YEAR	1 YEAR					ACCEL TEMPI: 180°C
COMPONENT: <i>MOTOR</i>	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	SRS TABLE 1 PAGE 1C THRU 6C		NONE	REPLACEMENT: 40 YEARS
MANUFACTURER: <i>LIMITORQUE</i>	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.4-1	REPORT 600456 PAGE 10 & 14		NONE	MAINTAIN.
MAJOR SUPPLIER: <i>WESTHS.</i>		FSAR FIG. 3.11.84 FOR DBA	170 PSIG DBA	FSAR SECT. 3.11.6-1 (DBA)	SRS TABLE 1 PAGE 2B		NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.
MODEL AND SERIAL #: <i>SMB-1</i>	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 9.4.0-1 NORM	TEST REPORT SECT. 4.4.3 PAGE 18		NONE	SEE TAB E, PAGE 1E
FUNCTIONS & SERVICE: <i>RESIDUAL HEAT REMOVAL - SERVING VALVE IRH-V5015A-1</i>	CHEMICAL SPRAY	2000-2100 PPM BORON	1300 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17		NONE	
ACCUR. SPEC: <i>N/A</i>		PH 8.5-11.0	PH 10.5-11.1		SRS TABLE 1 PAGE 1D		NONE	
ACCUR. DEM.: <i>N/A</i>	H GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-21	TEST REPORT SEC. 4.3 PAGE 12		NONE	SEE TAB E PAGE 1G
SPECIFICATIONS: <i>W. PROJ. SPEC. 952065 05 M.E. SPEC. 67885Z 02</i>	D SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TABLE 1 FIG THRU 3G		NONE	
P.U. # <i>173662</i> CHD # <i>ISM#0330</i>	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	45G YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3		NONE	SEE TAB E PAGE 1F
PLANT LOC.: <i>C.B.11</i>					SRS TABLE 1 PAGE 1F THRU 1F		NONE	SAFETY FUNCTION: SEE TAB "B" OF HE-1
COORDINATES: <i>X-1548.0 Y-1682.0 Z- 230.0</i>	SURCHENGED	228.3		FSAR SECTION 3.6	N/A		NONE	AUTH. REFERENCE: M. J. H.
INSTALLED (Y/H): <i>BY FLD.</i>	PARA-METER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
QUALIF EXEMPTING: <i>N/A</i>	OPERABILITY	O	HE-1	REFERENCES: <i>FLOW DIAG. CAR-2165 G-824 RHR & SAFETY INJECTION SYS. CAR-2165 G-155 LIMITORQUE TEST REPORT 600456</i>				REVISION # : 0
QUALIF: <i>QUALIFIED, AWAITING STATUS CONFIRMATORY DATA</i>	TEMPERATURE	T						DATE: <i>14-21-84</i>
	PRESSURE	P						SYSTEM: <i>RESIDUAL HEAT REMOVAL</i>
	REL. HUMIDTY	H						TAG: <i>IRH-V5015A-1</i>
	CHEM. SPRAY	C						
PHYS DNG REF: <i>CAR-2165 G-155</i>	RADIATION	R						
PHYS DNG LUCI: <i>TOTAL EQUIP. LIST</i>	AGING	A						
INSTALLING	SURVIVGENCE	S						
EV. DUC. LUCI: <i>W.P.O. 173662</i>	FSAR ENV CAT: 10588 CATEG. 1A							
	APPENDIX F							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	ACCEL TIME:
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: <i>IRH-V502SB-1</i>	OPERABILITY	40 YEARS	140 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25	NONE	15092 HOURS
EQUIPMENT: VALVE GATE	NORM/TEST DBA	1 YEAR	1 YEAR				ACCEL TEMP: 180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 19.4.0-1	SRS TABLE PAGE 1C THRU 16C	NONE	REPLACEMENT: 40 YEARS
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR FIG. 3.11.4-1	FSAR FIG. 3.11.4-1	NONE	MAINTAIN.
MAJOR SUPPLIER: WESTHS.		70 PSIG DBA	1385°F DBA	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.6-1 (DBA)	REPORT 600456 PAGE 10 & 14	NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.
MODEL AND SERIAL: <i>SMB-1 2224</i>	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 4.4.3 PAGE 18	NONE	SEE TAB 1E, PAGE 11E
FUNCTION & SERVICE: <i>RESIDUAL HEAT REMOVAL - SERVING VALVE IRH-V502SB-1</i>	CHEMICAL SPRAY	2000-2100 PPM	3000 PPM	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	NONE	
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-2	TEST REPORT SECT. 4.3 PAGE 12	SEE TAB E	
ACCUM. DEM.: N/A	A BETA	3.4 E7	74 EG	CONT. RAD. ZONE CS	SRS TAB D FIG THRU 3G	SEE TAB E PAGE 1G	
SPECIFICATIONS: <i>W.E. SPEC. 952065 02 N.E. SPEC. 678852 02</i>	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3	SEE TAB E PAGE 1F	SAFETY FUNCTION: SEE TAB "B" OF HE-1
P.U. #: 173662 CHD #: <i>ISAR #0329</i>	SURVEILED	228.3	N/A	FSAR SECTION 3.6	SRS TABLE PAGE 1F THRU 3E	NONE	AUTH. REFERENCE: M.J.H.
PLANT LOC.: C.B. 21	OPERABILITY	YES	N/A				
COORDINATES X-1480.0 Y-1702.0 Z-251.0	TEMPERATURE						
INSTALLED (Y/M):	PRESSURE						
INSTALL. REF: <i>BY FLD.</i>	REL. HUMIDTY						
QUALIF EXEMPT: <i>N/A</i>	CHEM. SPRAY						
QUALIF: QUALIFIED, AWAITING CONFIRMATORY DATA	RADIATION AGING						
PHYS DNG REF: <i>CAR-2165 G-155</i>	SURVEILLANCE						
PHYS DNG LIST: <i>TOTAL EQUIP LIST</i>	ISAR ENV CAT: 10500 CATEG. 1A						
MOUNTING:	APPENDIX E						
EDUC. LOC: <i>W.P.O. 173662</i>							

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES: FLOW DIAG. CAR-2165 G-824
 RHR/SAFETY INJ. SYS. CAR-2165 G-155
 LIMITORQUE TEST REPORT 600456

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1

REVISION #: 0
 DATE: 14.21-84

SYSTEM: RESIDUAL HEAT REMOVAL
 TAG: IRH-V502SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M ITEMS	OTHER
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 1RH-V5035A-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25		ACCEL TIME: 15092 HOURS
EQUIPMENT TYPE: VALVE GATE	NORM/TEST DBA	1 YEAR POST DBA	1 YEAR POST DBA			NONE	ACCEL TEMP: 180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 19.4.0-1	SRS TAB E PAGE 1C THRU 16C	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 40 YEARS
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. & FIG.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	MAINTAIN.
MAJOR SUPPLIER: WESTHS.		FSAR FIG. 3.11.4-1 FOR DBA	1385°F DBA	3.11.6-1 (DBA)	SRS TAB E PAGE 2B	NONE	SUBCOMPONENTS: TORQUE & LIMIT SW.
MODEL AND SERIAL #: SMB-1	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 19.4.0-1 NORM	TEST REPORT SECT. 4.4.3 PAGE 18	COMB. TYPE TEST & SUPP. REVIEW	SEE TAB E, PAGE 1E
FUNCTIONS & SERVICE: RESIDUAL HEAT REMOVAL - SERVING VALVE 1RH-V5035A-1	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 14	COMB. TYPE TEST & SUPP. REVIEW	NONE
ACCUM. SPEC: N/A	R GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-20	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	SEE ITAB E PAGE 1G
ACCUM. DEM.: N/A	D SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TAB D FIG THRU 3G		
SPECIFICATIONS: W.E. SPEC. 678852 02	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	SEE ITAB E PAGE 1F
P.O. # 173662 CHD # ISM # 0329	SURHEMGED	228.3		FSAR SECTION 3.6	N/A		
PLANT LOC.: C.B. 11		YES	N/A		SRS TAB E PAGE 1A	N/A	
COORDINATES: X-1457.0, Y-1676.0, Z-230.0							
INSTALLED (Y/M):							
INSTALL. REF: BY FID.	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
QUALIF EXEMPT: N/A	OPERABILITY	O HE-1	REFERENCES: FLOW DIAGRAM CAR-2165-82A RNP & SAFETY INJECTION SYS. CAR-2165-155 LIMITORQUE TEST REPORT 600456				REVISION #: 0 DATE: 4-21-84 SYSTEM: RESIDUAL HEAT REMOVAL TAG: 1RH-V5035A-1
QUALIF STATUS: QUALIFIED, AWAITING CONFIRMATORY DATA	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
	SURHEMGENCE	S					
PHYS DNG REF: CAR-2165-155	FSAR ENV CAT: 19588 CATEG. 1A						
PHYS DNG LUC: TOTAL EQUIP. LIST	APPENDIX F						
MOUNTING:							
EV. DUC. LUC: W.P.O. 173662							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	UNITS	
	PARAMETER	ACTUAL					
TAG NO: 2RHV 506 SB-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104° F NORM DBA	FSAR TABLE FSAR FIG.				REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)				SUBCOMPONENTS
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					
ACCUM. SPEC: N/A	R GAMMA	1.9 EG	FSAR FIG.				
ACCUM. DEH.: N/A	A BETA	NEGLIGIBLE	3.11B-23				
SPECIFICATIONS: PROJ. E. SPEC. 952065, RS GEN. E. SPEC. 678852, RZ	D SHIELD	100% BETA	CONT. RAD ZONE R4				
P.O. #: 173662 CND	AGE - INST LIFE	40 YEARS (PER 323-1974 DEF.)	10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
PLANT LOC.: AB 21	SUBMERGED	191'0 YES					AUTH. REFERENCE
COORDINATES X= 1567.0 Y= 1579.0 Z= 236.0							
INSTALLED (Y/M): INSTAL. REF: QUALIF EXEMPT:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
QUALIFI:	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G824 VENDOR DWG. 1364-4528				
STATUS:	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R				REVISION #	
PHYS DWG REF: CAR 2165 G152	AGING	A				DATE	
PHYS DWG LUC: K-17	SUBMERGENCE	S				SYSTEM: RESIDUAL HEAT REMOVAL	
MOUNTING:	ISAR ENV CAT:	A				TAG: 2RHV 506 SB	
ED. DOC. LUC: w/ P.O. 173662	10588 CATEG.:						
	APPENDIX E						

DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS	CESP
	PARAMETER ACTUAL	DEM. F.					
TAG NO: 2RHV507 SA-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM 4 DBA	FSAR TABLE FSAR FIG.				REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. 4 DBA					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					
FUNCTIONS & SERVICE	R GAMMA	1.9 EG	FSAR FIG. 3.11B-23				
ACCUM. SPEC: N/A	A BETA	NEGLIGIBLE	CONT. RAD. ZONE R4				
ACCUM. DEM.: N/A	D. SHIELD	100% BETA					
SPECIFICATIONS: PROJE. SPEC. 952065, RS GEN E. SPEC. 67885L, RL	T. I. D.	2.0 EG					
P.O. # 173662 CND # 1	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
PLANT LOC.: AB 21	SURMERGED	191-0 YES					AUTH. REFERENCE
COORDINATES X= 1434.0 Y= 1579.0 Z= 236.0							

QUALIF. EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
.....	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 824 VENDOR DWG. 1364-4486	REVISION # : DATE : SYSTEM RESIDUAL HEAT REMOVAL TAG : 2RHV 507 SA-1
.....	TEMPERATURE	T		
.....	PRESSURE	P		
.....	REL. HUMIDTY	H		
.....	CHEM. SPRAY	C		
.....	RADIATION	R		
.....	AGING	A		
.....	SURMERGENCE	S		
.....	FSAR ENV CAT:	A		
.....	FSAR CATEG.:	APPENDIX E		

INSTALLED (Y/N):
 INSTAL. KEYS:
 PHYS DWG KEYS: CAR 2165 G 152
 PHYS DWG LUC: K-G
 MOUNTING:
 EN. DUC. LUC: w/ P.O. 173662



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	W/MT OUTS ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2RH-F512SB-1	OPENABIL-ITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT-URE	104°F NORM. DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MAINT ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2RH-F512SB-1	R GAMMA	2.0E4			FSAR FIG.			
ACCUM. SPEC: N/A	A BETA	7.2E4			3.11B- RAD. ZONE IRG			
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	T.I.D.	3.0E4						
P.O. #189234 CND #1	AGE-IMBT LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A.D. 21	(PER 323-1979 DEF.)							
COORDINATES X=1574.0 Y=1419.0 Z=236.0	BURNEGED	191'0"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCE

INSTALLED (Y/II):
 INSTAL. MFT: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DWG MFT: CAR 2165 G152
 PHYS DWG LIC: G-4
 MOUNTING:
 EV. DUC. LUCI: W.P.O. 189234

- PARA-METER
- TEMPERABILITY
- TEMPERATURE
- PRESSURE
- REL. HUMIDITY
- CHEM. SPRAY
- RADIATION
- AGING
- FREQUENCY
- 1958 CATEG.
- APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:


 REFERENCES:
 VENDOR DWG. E73-020
 FLOW DIAG. CAR 2165 G024 (G-4)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

 REVISION #:
 DATE:
 SYSTEM: RESIDUAL HEAT REMOVAL
 TAG: 2RH-F512SB-1


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	UNIT ITEMS		
	PARAMETER	ACTUAL	DEM.	QUALIF.					ACTUAL
TAG NO: 2RH-F513SA-1	OPENABILITY	40 YEARS			OPERABILITY				ACCEL TIME
EQUIPMENT VALVE TYPE	ITY	NORMAL			REVIEW				ACCEL TEMP
	INDHM/TEST DBA	1 YEAR POST DBA							REPLACEMENT
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.				MAINTENANCE
	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.				SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-				
FUNCTION: SERVING VALVE & SERVICE 2RH-F513SA-1	R GAMMA	2.0E4			FSAR FIG. 3.11B-				
ACCUM. SPEC: N/A	A BETA	7.2E4			RAD. ZONE IRG				
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS: GEN. E-SPEC. 952065, R5	T.I.D.	1.2 E							
P.O. # 189234 CND # 1	AGE	40 YEARS			10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
PLANT LOC.: A, 75-21	INST LIFE (PER 323-1979 DEF.)								
COORDINATES X=1426.0 Y=1623.0 Z=236.0	BURNISHED	19150"	N/A		FSAR SECT. 3.6	N/A			AUTH. REFERENCE
INSTALL (Y/H): INSTAL. NEP: BY FIELD QUALIF. CRMP: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CED APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF:	OPERABILITY	O	REFERENCES: VENDOR DWG. E73-020 FLOW DIAG. CAR 2165 G 824						
STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
PHYS DWG HFF: CAR 2165 G 152	RADIATION	R							
PHYS DWG LUC: G-18	TAGGING	A							
MOUNTING:	EMERGENCY	S							
EDUC. LUC: W.P.O. 189234	1958 CATEG.								
	APPENDIX E								
							REVISION # DATE SYSTEM RESIDUAL HEAT REMOVAL TAG: 2RH-F513SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL				
TAG NO: FIS IRH 0602A SA	UPHABIL- ITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: FLOW SWITCH TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT:	TEMPERAT- URE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #: 288A	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-B-			
FUNCTIONS: RESID. HEAT REMOVAL & SERVICE PMP. 1A FLOW	R GAMMA A BETA D SHIELD T.I.D.	3.3E4 7.2E4 100% BETA 3.4E4	FSAR FIG. 3.11B-B-22 RAD. ZONE R3			SAFETY FUNCTIONS
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51			
ACCUM. DEM.: N/A	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A	AUTH. REFERENCE
SPECIFICATIONS: P.O. #1404484 CND # 1323 PLANT LOC.: AB 11 COORDINATES X- Y- Z- 216.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUANTIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTALLED (Y/N): INSTAL. NEP: BY FIELD QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G 824			
QUALIF:	TEMPERATURE	T				
STATUS:	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R	REVISION # : DATE : SYSTEM : RESIDUAL HEAT REMOVAL TAG : FIS IRH 0602A SA			
PHYS DNG HFF: CAR 2165 G 436 S01	AGING	A				
PHYS DNG LIC: L-1	SUBMERGEC.	S				
MOUNTING: EDUC. LUC: w/ P.O. 404484	ISAR ENY CAT: 1958 CATEG.: APPENDIX E					




EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/WI UITS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO: FIS IRH 602B SB	OPENABIL-ITY	140 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: FLOW SW. TYPE	NDRM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT:	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MANUFACTURER: BARTON	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL #: 288A	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTION: RESID. HEAT REMOVAL & SERVICE PMP. 1B FLOW	R GAMMA	3.3E4		FSAR FIG. 3.11B-22				
ACCUM. SPEC: N/A	A BETA	7.2E4		RAD. ZONE R3				
ACCUM. DEM.: N/A	D SHIELD	100% BETA		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
SPECIFICATIONS:	T.I.D.	3.4E4						
P.O. #: 404484 CND # 1324	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS						
PLANT LOC.: AD 11	BURNED	1910"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES
COORDINATES X= Y= Z= 216.0								
OTHER EQUIPMENT THIS CES APPLIES TO:	PARAMETER	SUPPL. REVIEW						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIF EXEMPT: N/A	OPERABILITY	O						
QUALIF:	TEMPERATURE	T						
STATUS:	PRESSURE	P						
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG HFF (CAR 2165 G436 50)	EMERGENCY	A						
PHYS DNG LUCI L-17	FSAR ENY CAT: 19580 CATEG. 1	S						REVISION # DATE
MOUNTING	APPENDIX E							SYSTEM RESIDUAL HEAT REMOVAL
EV. OUC. LUCI w/ P.O. 404484								TAG: FIS IRH 602B SB

REFERENCES: FLOW DIAG CAR 2165 G 824



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUANT.	DOCUMENTATION		QUALIF. METHOD	H/M	UNITS	CESP-
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: 1A SA (ITEM APCH)	OPERABILITY	40 YEARS	3.8 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 5.2	TYPE TEST SUPP.			ACCEL TIME: 168 HOURS
EQUIPMENT: PUMP TYPE	NORM/TEST	1 YEAR	DBA		SRS TABLE PAGE 1 THRU 3P	REVIEW		NONE	ACCEL TEMP: 210°C
COMPONENT: MOTOR	TEMPERATURE	104°F NORM 104°F DBA	104°F FOR NORM. & DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2	TEST REPORT SECT. 5.7	TYPE TEST SUPP.	M	NONE	REPLACEMENT: 3.8 YEARS
MANUFACTURER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS.	FSAR SECT.	DATA PACKAGE SECT. 1.7 & 2.6	TYPE TEST SUPP.		NONE	MAINTENANCE: SEE MANUAL & SUBCOMPONENTS: LUBRICANTS, BEARING:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20%-90% NORM 100% DBA	100%	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.6	TYPE TEST SUPP.	M	NONE	
MODEL AND SERIAL: HSDP 75FG952319-74	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11-	DATA PACKAGE SECT. 1.7 & 2.6	N/A	N/A	NONE	
FUNCTIONS: CENTRIFUGAL & SERVICE CHARGING PUMP (SEE TAB B)	R GAMMA	8.9 E 4	50 E 7	FSAR FIG. 3.11B-23	TEST REPORT SECT. 5.1	TYPE TEST SUPP.		SEE SRS PAGE 1E	
ACCUM. SPEC: N/A	A BETA	100% BETA		ZONE RS	SRS TABLE PAGE 1, 2 & 3E	REVIEW	H		
ACCUM. DEM.: N/A	T.I.D.	1.89 E 5	50 E 7						
SPECIFICATIONS: W. PROJ. SPEC. 952269, RI WE. SPEC. 677474	AGE-INSTR LIFE	40 YEARS	3.8 YEARS NORM. & DBA	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 5.2	TYPE TEST SUPP.		NONE	SAFETY FUNCTION: SEE TAB B OF AE-2
P.O. # 189501 CND # 1221	(PER 323-1974 DEF.)				SRS TABLE PAGE 1 THRU 3P	REVIEW			
PLANT LOC.: R. AUX. BLDG. 21	SURMERGED	191-0 YES	N/A	FSAR SECT. 3.6A	N/A SRS TABLE	N/A		NONE	AUTH. REFERENCE: M.J.H.
COORDINATES X=1487 Y=1583-8 Z=238-11	PARAMETER	SUPPL. REVIEW		OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: AE-2	
INSTALLED (Y/M): 4-11-84 100%	OPERABILITY	O AE-2		REFERENCES: FLOW DIAG. CAR-2165 G W. TEST REPORT AOZA W. DATA PACKAGE AE-2				REVISION # 0	
INSTALL. REF: BY FIELD	TEMPERATURE	T						DATE: 5-1-84	
QUALIF EXEMPT: N/A	PRESSURE	P		SYSTEM: SAFETY INJECTION					
QUALIF: QUALIFIED	REL. HUMIDITY	H						TAG: 1A SA	
STATUS	CHEM. SPRAY	C							
	RADIATION AGING	R A							
	SURMERGENCE	S							
PHYS DNG REF: CAR 2165 G140	ISAR ENV CAT: B								
PHYS DNG LUC: CAR 2166 SKE-133	1958 CATEG.:								
MOUNTING: SEE PUMP DETAIL DWG.	APPENDIX E CAT.								
EDUC. LUC: W. P.O. 189501									

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL					DEH. N
TAG NO: 1BSB (ITEM APCH)	OPERAVIL-ITY	40 YEARS	3.8 YEARS	OPERABILITY REVIEW	TEST REPORT SECT. 5.2	TYPE TEST SUPP. NONE	ACCEL TIME: 168 HOURS
EQUIPMENT: PUMP TYPE	NORM/TEST DBA	1 YEAR	POST DBA		SRS TABLE PAGE 1 THRU 3B		ACCEL TEMP: 210°C
COMPONENT: MOTOR	TEMPERATURE	104°F NORM	104°F FOR NORM. DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11 B-2	TEST REPORT SECT. 5.7	TYPE TEST SUPP. REVIEW M	REPLACEMENT: 3.8 YEARS
MANUFACTURER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA	ATMOS.	FSAR SEC.	DATA PACKAGE SECT. 1.7 (2.6)	TYPE TEST SUPP. REVIEW M	MAINTENANCE: SEE INSTRUCTION MANUAL
MAJOR SUPPLIER: WESTINGHOUSE					SRS TABLE PAGE 1C		SUBCOMPONENTS: LUBRICANT, BEARINGS
MODEL AND SERIAL #: HSDP 73F695232S-74	RELATIVE HUMIDITY	20%-90% NORM. 100% DBA	100%	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)	TEST REPORT SECT. 5.6	TYPE TEST SUPP. REVIEW M	NONE
FUNCTIONS & SERVICE: CENTRIFUGAL CHARGING PUMP (SEE TAB B)	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11	DATA PACKAGE SECT. 1.7 (2.6) SEE SRS TABLE PAGE 1C	N/A	N/A
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD	8.9 E4	50 E7	FSAR FIG. 3.11 B-23	TEST REPORT SECT. 5.1	TYPE TEST SUPP. REVIEW H	SEE SRS PAGE 1E
SPECIFICATIONS: W. PROJECT SPEC. 152269, R1 W.E. SPEC. 677474	T.I.D. AGE	1.89 E5	50 E7	CONT. RAD. ZONE RS	SRS TABLE PAGE 1, 2, 3E		
P.O. # 189501 CND # 1222	INST LIFE (PER 323-1974 DEF.)	40 YEARS	3.8 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 5.2	TYPE TEST SUPP. REVIEW	SAFETY FUNCTION: SEE TAB B OF AE-2
PLANT LOC.: R. AUX. BLDG. 21					SRS TABLE PAGE 1 THRU 3B		
COORDINATES X= 1510-3 Y= 1583-8 Z= 238-11	SUBMERGED	191-0	N/A	FSAR SECT. 3.6A	N/A	SRS TABLE N/A	NONE
INSTALLED (Y/M): 4-11-84 100%							AUTH. REFERENCE: M.J.H.
INSTAL. REF: BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: AE-2
QUALIF EXEMPT: N/A	OPERABILITY	O AE-2	REFERENCES: FLOW DIAG. CAR-2165 G W. TEST REPORT A02A W. DATA PACKAGE AE-2				REVISION #: 0 DATE: 15-1-84 SYSTEM: SAFETY INJECTION TAG: 1BSB
QUALIF: QUALIFIED	TEMPERATURE	T					
STATUS	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
PHYS DNG REF: CAR 2165 G140	RADIATION	R					
PHYS DNG LUC: CAR 2166 SKE-133	AGING	A					
MOUNTING: SEE PUMP DETAIL DNG.	SUBMERGENCE	S					
EQUIP. LUC: W. P.O. 189501	ISAR ENV CAT: 10500 CATEG. 1	B					
	APPENDIX E	CAT.					



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	OTHER
	PARAMETER	ACTUAL	DES. VAL.	ACTUAL	DES. QUALIF.				
TAG NO: IC-SAB (ITEM APCH)	OPERABILITY	40 YEARS	3.8 YEARS	OPERABILITY TEST REPORT REVIEW	SECT. 5.2	TYPE TEST SUPP. REVIEW		NONE	ACCEL TIME: 168 HOURS
EQUIPMENT TYPE: PUMP	NORM/TEST DBA	1 YEAR POST DBA	NORM. 4 DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2	TEST REPORT SECT. 5.7	TYPE TEST SUPP. REVIEW	M	NONE	ACCEL TEMP: 210°C
COMPONENT: MOTOR	TEMPERATURE	104°F NORM 104°F DBA	104°F NORM. 4 DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2	TEST REPORT SECT. 5.7	TYPE TEST SUPP. REVIEW	M	NONE	REPLACEMENT: 3.8 YEARS
MANUFACTURER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.	ATMOS.	FSAR SECT.	DATA PACKAGE SECT. 1.7(2.6)	TYPE TEST SUPP. REVIEW	M	NONE	MAINTAIN. SEE INSTRUCTION MANUAL
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20%-90% NORM. 100% DBA	100%	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3(DBA)	TEST REPORT SECT. 5.6	TYPE TEST SUPP. REVIEW	M	NONE	SUBCOMPONENTS: LUBRICANT, BEARINGS
MODEL AND SERIAL: HSDP 73F6952333-74	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11	DATA PACKAGE SECT. 1.7(2.6)	N/A	N/A	NONE	
FUNCTION: CENTRIFUGAL & SERVICE CHARGING PUMP	R GAMMA A BETA D SHIELD	8.9E4 100% BETA	50E7	FSAR FIG 3.11B-23 ZONE R5	TEST REPORT SECT. 5.1	TYPE TEST SUPP. REVIEW	H	ISEE ISRS PAGE 1E1	
ACCUR. SPEC: N/A	T.I.D.	1.89E5	50E7		SRS TABLE PAGE 1,2,3E				
ACCUR. DES.: N/A	AGE - INST LIFE (PER 323-1979 DEF.)	3.8 YEARS NORM. 4 DBA	3.8 YEARS NORM. 4 DBA	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 5.2	TYPE TEST SUPP. REVIEW		NONE	SAFETY FUNCTIONS: SEE TAB B OF AE-2
SPECIFICATIONS: W. PROJ. SPEC. 752269, R1 WE. SPEC. 677474	SURMERGED	191°O YES	N/A	FSAR SECT. 3.6A	N/A	N/A		NONE	AUTH. REFERENCE: M.J.H.

INSTALLED (Y/M): 4-11-84 100% INSTAL. REF: BYFIELD QUALIF EXEMPT: N/A QUALIF: QUALIFIED STATUS: PHYS DWG REF: CAR-2165 G140 PHYS DWG LUC: CAR-2166 SKE-133 MOUNTING: SEE PUMP DETAIL DWG EV. DUC. LUC: W. RD 189501	PARA-METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SURMERGENCE ISAR ENV CAT: B 10588 CATEG. APPENDIX E CAT.	SUPPL. REVIEW O AE-2 T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: FLOW DIAG. CAR-2165 G W. TEST REPORT A02A W. DATA PACKAGE AE-2	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: AE-2 REVISION #: 0 DATE: 15-1-84 SYSTEM: SAFETY INJECTION TAG: IC-SAB
---	--	--	--	--

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS	CES#
	PARAMETER	ACTUAL					
TAG NO: TE ISI 0910 A1 SA	OPERABILITY	40 YEARS	OPERABILITY		/		ACCEL TIME
EQUIPMENT: MOTOR	NDHM/TEST	NORMAL	REVIEW				ACCEL TEMP
TYPE	DBA	1 YEAR					
COMPONENT: TEMP. ELEMENT	TEMPERATURE	104°F NORM	FSAR TABLE		/		REPLACEMENT
(FOR C. CHARGING PMP)		104°F DBA	9.4.0-1		M		
MANUFACTURER:			FSAR FIG.				MAINTAIN.
			3.11B-2				
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM			/		SUBCOMPONENTS
		DBA NORM.			M		
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM	FSAR TABLE		/		
		100% DBA	9.4.0-1 NORM				
FUNCTIONS & SERVICE			FSAR SECT.		M		
			3.11.4.3 (DBA)				
ACCUM. SPEC: N/A	CHEMICAL SPRAY	N/A			/		
ACCUM. DEM.: N/A	R GAMMA	13.9E4	FSAR		/		
	A BETA		FIG. 3.11B-20				
	D SHIELD	100% BETA	ZONE 5		H		
	T.I.D.	1.89E5					
SPECIFICATIONS:	AGE-INST LIFE	40 YEARS	10 CFR 50		/		SAFETY FUNCTIONS
P.O. # 189501 CHD. # 1 SH. # 220	(PER 323-1979 DEF.)		PARAGRAPH 50.51				
PLANT LOC.: AB 21	SUBMERGED	191.0	FSAR SECT.		/		
COORDINATES X=1485.0		YES	3.6				AUTH. REFERENCE
Y=1593.0							
Z=236.0							
INSTALLED (Y/N):							

INSTALL. REF:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPT:	OPERABILITY	O		
QUALIF:	TEMPERATURE	T		
STATUS:	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
	AGING	A		
	SUBMERGENCE	S		
PHYS DNG REF:	FSAR ENV CAT:			REVISION #
PHYS DNG LUC:	10588 CATEG.			DATE
MOUNTING:	APPENDIX E			SYSTEM SAFETY INJECTION
EV. DUC. LUC: W. P.O. 189501			REFERENCES:	TAG SITE ISI 0910 A1 SA

EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUANT.	DOCUMENTATION ACTUAL	QUALIFICATION METHOD	H/M/UTS	ITEMS	RESP.	
TAG NO: TE ISI 0910A2 SW-	OPERABILITY	40 YEARS	2	OPERABILITY REVIEW		/	7	ACCEL TIME:	
EQUIPMENT TYPE: MOTOR	NORM/TEST DBA	NORMAL 1 YEAR POST DBA						ACCEL TEMP:	
COMPONENT: TEMP ELEMENT (FOR C. CHARGING PMP)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT:	
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM				/		MAINTAIN.:	
MAJOR SUPPLIER: WESTINGHOUSE						M		SUBCOMPONENTS:	
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M			
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A				/			
ACCUM. SPEC: N/A									
ACCUM. DEM.: N/A	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 100% BETA 1.89 E5		FSAR FIG. 3.11B-20 ZONE 5		H			
SPECIFICATIONS:	AGE- INST LIFE (PER 323-1978 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION:	
P.O. # 189501 CMD # SH 220 PLANT LOC.: AB 21	SUBMERGED	191.0 YES		FSAR SECT. 3.6		/		AUTH. REFERENCE:	
COORDINATES X= 1485.0 Y= 1593.0 Z= 236.0									
INSTALLED (Y/N): INSTAL. NEP: QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF:	OPERABILITY	O	REFERENCES:						
STATUS:	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R					REVISION #: DATE:		
PHYS DNG NEP:	AGING	A							
PHYS DNG LUC:	SUBMERGENCE	S							
MOUNTING:							SYSTEM SAFETY INJECTION		
EDUC. LUC: W/PO, 189501	FSAR ENV CAT: 10500 CATEG. APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS	CESP
	PARAMETER	ACTUAL					
TAG NO: TEISI 0910A3 SA	OPERABILITY	40 YEARS	OPERABILITY REVIEW		/		ACCEL TIME
EQUIPMENT: MOTOR	NORM/TEST	1 YEAR					ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR C. CHARGING PMP.)	TEMPERATURE	104° F NORM 104° F DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.			/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE					M		SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% Norm. 100% DBA	FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A			/		
ACCUM. SPEC: N/A	R GAMMA	1.89 E4	FSAR FIG. 3.11B-20		/		
ACCUM. DEM.: N/A	A BETA	100% BETA	ZONE 5		H		
SPECIFICATIONS:	T.I.D.	1.89 E5					
P.O. # 189501 CMD # SH.# 220	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTIONS
PLANT LOC.: AB 21							
COORDINATES X=1485.0 Y=1593.0 Z=236.0	SUBMERGED	191.0 YES	FSAR SECT. 3.6		/		AUTH. REFERENCES

INSTALLED (Y/II): INSTAL. REF: QUALIF EXEMPTN: QUALIFI: STATUS: PHYS DNG REF: PHYS DNG LOC: MOUNTING: EQ. DNG. LOC: W.P.O. 189501	PARA-METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION LAGING SUBMERGENCE ISAN ENV CAT: 10588 CATEG. APPENDIX E	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM SAFETY INJECTION TAG: TEISI 0910A3 SA
---	--	---	---	---

ELEMENT DESCRIPTION	ENVIRONMENT		DEM. QUAL.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: TE1SI0910BI5B	OPERABILITY	40 YEARS		OPERABILITY REVIEW			/		ACCEL TIME
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA							ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP.)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM DBA NORM					/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					/		
FUNCTIONS & SERVICE	R GAMMA	18.9 E4		FSAR FIG. 3.11B-20			/		
ACCUM. SPEC: N/A	A BETA			ZONE RS			H		
ACCUM. DEM.: N/A	D SHIELD	100% BETA							
SPECIFICATIONS:	T.I.D.	1.89 E5							
P.O. # 189501 CND # 1SH # 220	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTION
PLANT LOC.: ABZ1	SUBMERGED	191.0		FSAR SECT. 3.6			/		
COORDINATES X=1532.0 Y=1593.0 Z=236.0		YES							AUTH. REFERENCE

INSTALL. REF: QUALIF. EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES:
.....	OPERABILITY	O	REFERENCES:	
.....	TEMPERATURE	T		
.....	PRESSURE	P		
.....	REL. HUMIDTY	H		
.....	CHEM. SPRAY	C		
.....	RADIATION	R		
PHYS DNG REF:	AGING	A		REVISION # :
PHYS DNG LUG:	SUBMERGENCE	S		DATE :
.....			
.....	FSAR ENV CAT:			SYSTEM : SAFETY INJECTION
.....	10588 CATEG.:			TAG : TE1SI0910BI5B
.....	APPENDIX E			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. NU	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	CESP
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: TE ISI 0910 A4 SA	OPERABILITY	40 YEARS		OPERABILITY REVIEW		5	/	7	ACCEL TIMES
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA							ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR C. CHARGING PMP.)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.					/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					/		
FUNCTIONS & SERVICE	R GAMMA	8.9E4		FSAR FIG. 3.11B-20			/		
ACCUM. SPEC: N/A	A BETA SHIELD	100% BETA		ZONE 5			H		
ACCUM. DEM.: N/A	T.I.D.	1.89E5							
SPECIFICATIONS:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTIONS
P.O. # 189501 CMD # 15H# 220	SUBMERGED	191.0 YES		FSAR SECT. 3.6			/		
PLANT LOC.: AB 21									
COORDINATES X=1532.0 Y=1593.0 Z=236.0									AUTH. REFERENCE

INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPTN: QUALIF: STATUS: PHYS DNG REF: PHYS DNG LUC: MOUNTING: EQ. DUC. LUC: w/ P.O. 189501	PARA-METER SUPPL. REVIEW OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S FSAR ENV CAT: 10500 CATEG.: APPENDIX E	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION # : DATE : SYSTEM : SAFETY INJECTION TAG : TE ISI 0910 A4 SA
--	---	---	--

EQUIPMENT DESCRIPTION		ENVIRONMENTAL PARAMETER ACTUAL		DEM. QUAL.	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	H/M	UTS ITEMS	CESD	
TAG NO: TE ISW0910A5 SA		OPERABILITY	40 YEARS	2	OPERABILITY REVIEW	4	5	/	7	ACCEL TIME	
EQUIPMENT: MOTOR TYPE		NORM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP	
COMPONENT: TEMP. ELEMENT (FOR C. CHARGING PMP.)		TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2			/ M		REPLACEMENT	
MANUFACTURER:		PRESSURE	ATMOS. NORM. DBA NORM.					/		MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE		RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			/ M		SUBCOMPONENTS	
MODEL AND SERIAL #		CHEMICAL SPRAY	N/A					/			
FUNCTIONS & SERVICE		R GAMMA	18.9E4		FSAR FIG. 3.11B-20			/			
ACCUM. SPEC: N/A		A BETA	100% BETA		ZONE 5			H			
ACCUM. DEM.: N/A		D SHIELD	T.I.D. 11.89E5								
SPECIFICATIONS:		AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTION	
P.O. # 189501 CND # ISH# 220		(PER 323-1974 DEF.)									
PLANT LOC.: AB 21		SUBMERGED	191.0 YES		FSAR SECT. 3.6			/		AUTH. REFERENCE	
COORDINATES X= 1485.0 Y= 1593.0 Z= 236.0											
INSTALLED (Y/N):		PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INITIAL. REFI		OPERABILITY	O	REFERENCES:							
QUALIF EXEMPTN:		TEMPERATURE	T								
QUALIF:		PRESSURE	P								
STATUS:		REL. HUMIDTY	H								
:		CHEM. SPRAY	C								
:		RADIATION	R								
PHYS DNG REFI		AGING	A						REVISION # :		
PHYS DNG LUC:		SUBMERGENCE	S						DATE :		
MOUNTING :									SYSTEM : SAFETY INJECTION		
EQ. DUC. LUC: w/ P.O. 189501		FSAR ENV CAT:							TAG : TE ISW0910A5SA		
		19588 CATEG.:									
		APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUA	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	H/M	UTS ITEMS	CESD-	
TAG NO: TE ISW0910A6 SA	OPERABILITY	40 YEARS	2	OPERABILITY REVIEW	4	5	/	7	ACCEL TIME	
EQUIPMENT: MOTOR TYPE	NORM/TEST	1 YEAR							ACCEL TEMP	
COMPONENT: TEMP. ELEMENT (FOR C. CHARGING PMP.)	TEMPERATURE	104°F NORM 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT	
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.					/		MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M		SUBCOMPONENTS	
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					/			
FUNCTIONS & SERVICE	R GAMMA	8.9E4		FSAR FIG. 3.11B-20 ZONE 5			/			
ACCUM. SPEC: N/A	A BETA	100% BETA					H			
ACCUM. DEM.: N/A	D SHIELD	1.89E5					/			
SPECIFICATIONS:	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTIONS	
P.O. # 189501 CND # ISH# 220	(PER 323-1974 DEF.)						/			
PLANT LOC.: AB 21	SUBMERGED	191.0 YES		FSAR SECT. 3.6			/		AUTH. REFERENCES	
COORDINATES X 1485.0 Y 1593.0 Z 236.0	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE			
INSTALLED (Y/N):	OPERABILITY	O	REFERENCES:							
INSTAL. REF:	TEMPERATURE	T								
QUALIF EXEMPT:	PRESSURE	P								
QUALIFI:	REL. HUMIDTY	H								
STATUS:	CHEM. SPRAY	C								
•	RADIATION	R								
•	AGING	A								
•	SUBMERGENCE	S								
PHYS DNG REF:	ISAR ENV CAT:						REVISION # :			
PHYS DNG LUC:	10500 CATEG.:						DATE :			
MOUNTING :	APPENDIX E						SYSTEM : SAFETY INJECTION			
EQ. DUC. LUC: w/ P.O. 189501							TAG : TE ISW0910A6 SA			



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QU.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: TE ISI 0910 B2 SB-	OPERABILITY	40 YEARS		OPERABILITY REVIEW			/		ACCEL TIME
EQUIPMENT: MOTOR TYPE	NORM/TEST	1 YEAR							ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP)	DBA	POST DBA							
MANUFACTURER:	TEMPERATURE	104°F NORM 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.					/		MAINTAIN.
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)			M		SUBCOMPONENTS
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					/		
ACCUM. SPEC: N/A	R GAMMA	8.9E4		FSAR FIG. 3.11B-20			/		
ACCUM. DEM.: N/A	A BETA	100% BETA		ZONE RS			H		
SPECIFICATIONS:	D SHIELD	1.89 E5							
P.O. #: 189501 CMD # SH.220	T.I.D.								
PLANT LOC.: AB 21	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTIONS
COORDINATES X= 1532.0 Y= 1593.0 Z= 236.0	(PER 323-1979 DEF.)								
INSTALLED (Y/N):	SUBMERGED	191.0		FSAR SECT. 3.6			/		
INSTALL. REF:	YES								AUTH. REFERENCE

QUALIF EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
OPERABILITY	TEMPERATURE	O		
TEMPERATURE	PRESSURE	P		
PRESSURE	REL. HUMIDTY	H		
REL. HUMIDTY	CHEM. SPRAY	C		
CHEM. SPRAY	RADIATION	R		
RADIATION	AGING	A		
AGING	SUBMERGENCE	S		
SUBMERGENCE	ISAR ENV CAT:			
ISAR ENV CAT:	10588 CATEG.:			
10588 CATEG.:	APPENDIX E			
APPENDIX E			REFERENCES:	
				REVISION #
				DATE
				SYSTEM SAFETY INJECTION
				TAG : TE ISI 0910 B2 SB



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS	CESB
	PARAMETER	ACTUAL					
TAG NO: TE 1510910B3 SB	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW		/		ACCEL TIME:
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP:
COMPONENTS: TEMP. ELEMENT (FOR CHARGING PMP. MTR.)	TEMPERATURE	104° F NORM 104° F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT:
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.			/		MAINTAIN.:
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			/		
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 100% BETA 1.89 E5	FSAR FIG. 3.11B-20 ZONE RS		/	H	
ACCUR. SPEC: N/A	AGE INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION:
ACCUR. DEM.: N/A	SUBMERGED	191.0 YES	FSAR SECT. 3.6		/		AUTH. REFERENCE:
SPECIFICATIONS:							
P.O. # 189501 CND # 1220							
PLANT LOC.: AB 21							
COORDINATES X=1532.0 Y=1593.0 Z=236.0							

INSTALLED (Y/N): INSTAL. REF: QUALIF. EXEMPTING: QUALIF. STATUS: PHYS. DNG. REF: PHYS. DNG. LOC. MOUNTING: ED. DUC. LUC: w/ 189501	PARA-METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDITY CHEM. SPRAY RADIATION AGING SUBMERGENCE FSAR ENV. CAT: 19588 CATEG. I APPENDIX E	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM: SAFETY INJECTION TAG: TE 1510910B3 SB
--	---	---	---	--



3

2
4




EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QU.	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	H/M	OUTS ITEMS	
TAG NO: TE ISI 0910B4 SB	OPERABILITY	40 YEARS		OPERABILITY REVIEW			/		ACCEL TIME
EQUIPMENT: MOTOR TYPE	NDHM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP
COMPONENT: TEMP ELEMENT (FOR CHARGING PMP. MTR.)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT
MANUFACTURER	PRESSURE	ATMOS. NORM. DBA NORM.					/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE							M		SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M		
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					/		
ACCUM. SPEC: N/A	R GAMMA	8.9 E4		FSAR FIG. 3.11B-20			/		
ACCUM. DEM.: N/A	A BETA			ZONE RS			H		
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 189501 CMD # SH. 220	T.I.D.	1.89 E5							
PLANT LOC.: AB 21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			/		SAFETY FUNCTIONS
COORDINATES X= 1532.0 Y= 1593.0 Z= 236.0	SUBMERGED	191.0 YES		FSAR SECT. 3.6			/		AUTH. REFERENCES

INSTALL. REF:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPT:	OPERABILITY	O		
QUALIF STATUS:	TEMPERATURE	T		
	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
PHYS DNG REF:	AGING	A		
PHYS DNG LUC:	SUBMERGENCE	S		
HOUSING:				
EDUC. LUC: W. P.O. 189501	FSAR ENV CAT: 10588 CATEG. 1 APPENDIX E		REFERENCES:	REVISION # : DATE : SYSTEM : SAFETY INJECTION TAG : TE ISI 0910B4 SB

EQUIPMENT DESCRIPTION		ENVIRONMENTAL PARAMETER ACTUAL		DEM. NUM.	DOCUMENTATION ACTUAL	QUALIF. METHOD	H/M	UNITS	CESS.
TAG NO : TE ISI 0910 BS SB		OPERABILITY	40 YEARS NORMAL	2	OPERABILITY REVIEW		/	7	ACCEL TIME
EQUIPMENT: MOTOR TYPE		NOHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENTS: TEMP. ELEMENT (FOR CHARGING PMP.) MTR.		TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT
MANUFACTURER:		PRESSURE	ATMOS. NORM. DBA NORM.				/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE		RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS:
FUNCTIONS & SERVICE		CHEMICAL SPRAY	N/A				/		
ACCUM. SPEC: N/A		R GAMMA	1.89 E4		FSAR FIG. 3.11B-20		/		
ACCUM. DEN.: N/A		A BETA	100% BETA		ZONE RS		H		
SPECIFICATIONS:		D SHIELD	1.89 E5				/		
P.O. # 189501 CND # 1SH#220		AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTIONS:
PLANT LOC.: AB 21		(PER 323-1974 DEF.)					/		
COORDINATES X=1532.0 Y=1593.0 Z=236.0		SURMERGED	191.0 YES		FSAR SECT. 3.6		/		AUTH. REFERENCES:
INSTALLED (Y/N):		PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTAL. REF:		OPERABILITY	O	REFERENCES:					
QUALIF EXEMPT:		TEMPERATURE	T						
QUALIF:		PRESSURE	P						
STATUS:		REL. HUMIDTY	H						
		CHEM. SPRAY	C						
PHYS DNG REF:		RADIATION	R					REVISION # :	
PHYS DNG LUC:		AGING	A					DATE :	
MOUNTING:		SURMERGENCE	S					SYSTEM : SAFETY INJECTION	
EQUIP. LUC: P.O. 189501		FSAR ENV CAT:						TAG : TE ISI 0910 BS SB	
		10588 CATEG.:							
		APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF.	N/M	UNITS	ACCEL TIME
	PARAMETER	ACTUAL	DEM.	QUALIF.	METHOD		ITEMS	
TAG NO: TE ISI 0910B6 SB	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP) MTR.	TEMPERATURE	104°F NORM 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M	REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.						MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A						
FUNCTIONS & SERVICE	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 100% BETA 1.89 ES			FSAR FIG. 3.11B-20 ZONE RS		H	
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	SUBMERGED	191.0 YES			FSAR SECT. 3.6			AUTH. REFERENCE

INSTALL (Y/N)	PARA-METER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. REF:	OPERABILITY	O	REFERENCES:	REVISION # DATE SYSTEM SAFETY INJECTION TAG : TE ISI 0910B. SB
QUALIF EXEMPTN:	TEMPERATURE	T		
QUALIF STATUS:	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
	LACING	A		
	SUBMERGENCE	S		
PHYS DNG REF:	FSAR ENV CAT:			
PHYS DNG LUC:	1958 CATEG.			
MOUNTING:	APPENDIX E			
EQ. DUC. LUC: N/P.O. 189501				



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	ACCEL TIME
	PARAMETER	ACTUAL	DEM. QUANT.	ACTUAL	DEM. QUALIF.			
TAG NO: TE ISI 0911A SA	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW		/		
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP. MTR.)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		/	M	REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.				/		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE							M	SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		/	M	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A				/		
ACCUM. SPEC: N/A	R GAMMA	1.89 E4		FSAR FIG. 3.11B-20		/		
ACCUM. DEM.: N/A	A BETA	100% BETA		ZONERS			H	
SPECIFICATIONS:	D SHIELD	T.I.D. 1.89 E5						
P.O. # 189501 CHD # SH.# 220	AGE- INST LIFE	40 YEARS (PER 323-1979 DEF.)		110 CFR 50 PARAGRAPH 50.51		/		SAFETY FUNCTION
PLANT LOC.: AB 21	SUBMERGED	191° O YES		FSAR SECT. 3.6		/		AUTH. REFERENCE
COORDINATES X= 1485.0 Y= 1593.0 Z= 276.0								

INSTALL. REFI	PARAMETER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIF EXEMPTN:	OPERABILITY	O	REFERENCES:	
QUALIF:	TEMPERATURE	T		
STATUS:	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
PHYS DNG REFI	AGING	A		
PHYS DNG LUCI	SUBMERGENCE	S		
MOUNTING				
EQ. DUC. LUC: N/R. 189501	FSAR ENV CAT: 19588 CATEG. 1 APPENDIX E			

REVISION # :
DATE :
SYSTEM SAFETY FUNCTION
TAG : TE ISI 0911A SA

UTILITIES	MOLINA PUMPER & LIGHT		COMPONENT EVALUAT.	HEET	CAPACITY	900 MW(E)	CESP
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QU.	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	UITS ITEMS
TAG NO : TE ISI 0911B SA	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT TYPE : MOTOR	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT : TEMP. ELEMENT (FOR CHARGING PMP. MTR.)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M	REPLACEMENT
MANUFACTURER :	PRESSURE	ATMOS. NORM. DBA NORM.				M	MAINTAIN.
MAJOR SUPPLIER : WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A					
FUNCTIONS & SERVICE	R GAMMA A BETA SHIELD	8.9 E 4 100% BETA T.I.D. 11.89 E 5		FSAR FIG. 3.11B-20 ZONE R5		H	
ACCUM. SPEC : N/A	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION
ACCUM. DEM. : N/A	SUBMERGED	191-0 YES		FSAR SECT. 3.6			AUTH. REFERENCE
SPECIFICATIONS :	INSTALL. REFS						
P.O # 189501 CND # 1220	PLANT LOC. : AB 21						
COORDINATES X= 1532.0 Y= 1593.0 Z= 236.0	OTHER EQUIPMENT THIS CES APPLIES TO :			REFERENCES :			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE :
INSTALLED (Y/N) :	PARA-METER	SUPPL. REVIEW					REVISION # :
QUALIF EXEMPT :	OPERABILITY	O					DATE :
QUALIFI :	TEMPERATURE	T					SYSTEM : SAFETY INJECTION
STATUS :	PRESSURE	P					TAG : TE ISI 0911B SA
:	REL. HUMIDTY	H					
:	CHEM. SPRAY	C					
:	RADIATION	R					
PHYS DRG REFS :	AGING	A					
PHYS DRG LUCI :	SUBMERGENCE	S					
MOUNTING :	FSAR ENV CAT :						
EV.DUC.LUCI W/ P.O. 189501	10588 CATEG. :						
	APPENDIX E :						



2.

71



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/HI	OUTS ITEMS	CESP-
	PARAMETER	ACTUAL					
TAG NO: TE ISI 0912 A SA	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP MTR)	TEMPERATURE	104°F NORM 104°F DBA	IFSAR TABLE 9.4.0-1 IFSAR FIG. 3.11B-2		M		REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.			M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	IFSAR TABLE 9.4.0-1 NORM IFSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					
ACCUR. SPEC: N/A	R GAMMA	8.9E4	IFSAR FIG. 3.11B-20				
ACCUR. DEM.: N/A	A BETA	100% BETA	ZONE RS		H		
SPECIFICATIONS:	D SHIELD	T.I.D. 1.89E5					
P.O. # 189501 CND # 220	AGE-INST LIFE (PER 323-1978 DEF.)	40 YEARS	110 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTION
PLANT LOC.: AB21	SUBMERGED	191.0 YES	IFSAR SECT. 3.6				AUTH. REFERENCE
COORDINATES X= 1485.0 Y= 1593.0 Z= 236.0							
INSTALLED (Y/H):	PARAMETER	SUPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
INITIAL REFS:	OPERABILITY	O	REFERENCES:				
QUALIF EXEMPTN:	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R:					
PHYS DNG REFS:	AGING	A				REVISION # :	
PHYS DNG LOCS:	SUBMERGENCE	S				DATE :	
MOUNTING :						SYSTEM : SAFETY INJECTION	
EN.DUC.LUC: w/ RO.189501	IFSAR ENV CAT:					TAG : TE ISI 0912 A SA	
	19588 CATEG.:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QU.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.				
TAG NO: TE ISI 0912 B SB	OPENABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: MOTOR TYPE	NDHM/TEST DBA	NORMAL 1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP. MTR)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2			M	REPLACEMENT	
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.						MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M	SUBCOMPONENTS	
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A							
FUNCTIONS & SERVICE	R GAMMA	8.9E4		FSAR FIG. 3.11B-20					
ACCUM. SPEC: N/A	A BETA D SHIELD	100% BETA		ZONERS			H		
ACCUM. DEN.: N/A	T.I.D.	1.89E5							
SPECIFICATIONS:	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
P.O. # 189501 END # 220	SUBMERGED	191.0 YES		FSAR SECT. 3.6				AUTH. REFERENCE	
PLANT LOC.: AB21									
COORDINATES X= 1532.0 Y= 1593.0 Z= 236.0									
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTAL. NEP:	OPERABILITY	O	REFERENCES:						
QUALIF. EXEMPT:	TEMPERATURE	T							
QUALIF. STATUS:	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG NEP:	AGING	A					REVISION #		
PHYS DNG LUC:	SUBMERGENCE	S					DATE		
MOUNTING:							SYSTEM: SAFETY INJECTION		
EDUC. LUC: by RO.189501	FSAR ENY CAT:						TAG: TE ISI 0912 B SB		
	10500 CATEG.								
	APPENDIX E								

10
12


14

16

18



DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI	OUTS ITEMS
	PARAMETER	ACTUAL	DEM.	ACTUAL			
TAG NO: TE ISI 0914-15	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: MOTOR TYPE	INDHM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMP
COMPONENT: TEMP ELEMENT (FOR CHARGING PMP MTR)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M	REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.					MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE						M	SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					
ACCUM. SPEC: N/A							
ACCUM. DEM.: N/A	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 100% BETA 1.89 E5		FSAR FIG. 3.11B-20 ZONE RS		H	
SPECIFICATIONS:							
P.O. # 189501 CND # 1220	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: AB21							
COORDINATES X= 1508.0 Y= 1593.0 Z= 236.0	SUBMERGED	191.0 YES		FSAR SECT. 3.6			AUTH. REFERENCE
INSTALLED (Y/H):							
INSTALL. REFS:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE	
QUALIF. EXEMPT:	OPERABILITY	O	REFERENCES:				
QUALIF. STATUS:	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	LAGING	A					
PHYS DNG REFS:	SUBMERGENCE	S				REVISION # :	
PHYS DNG LOCS:						DATE :	
MOUNTING:						SYSTEM : SAFETY INJECTION	
EN. DUC. LUCI: by P.O. 189501	FSAR ENV CAT:					TAG : TE ISI 0914-15	
	1958 CATEG.:						
	APPENDIX E						



EQUIPMENT DESCRIPTION	ENVIRONMENT PARAMETER	ACTUAL	DEM. N	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	H/M	OUTS ITEMS		
TAG NO: TE ISI 0914-2S	OPERABILITY	40 YEARS		OPERABILITY REVIEW					ACCEL TIME	
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA							ACCEL TEMP	
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP. MTR)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2			M		REPLACEMENT	
MANUFACTURER	PRESSURE	ATMOS. NORM. DBA NORM.							MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE							M		SUBCOMPONENTS	
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.9 (DBA)			M			
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A								
ACCUM. SPEC: N/A										
ACCUM. DEM.: N/A	R GAMMA A BETA D SHIELD T.I.D.	8.9E4 100% BETA 1.89E5		FSAR FIG. 3.11B-20 ZONE RS			H			
SPECIFICATIONS:	AGE-INST LIFE (PER 323-1978 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTION	
P.O. # 189501 CND # 220	SUBMERGED	191.0 YES		FSAR SECT. 3.6					AUTH. REFERENCE	
PLANT LOC.: AB21										
COORDINATES X= Y= 1593.0 Z= 236.0										
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
INSTAL. REF:	OPERABILITY	O	REFERENCES:							
QUALIF EXEMPT:	TEMPERATURE	T								
QUALIF:	PRESSURE	P								
STATUS:	REL. HUMIDTY	H								
	CHEM. SPRAY	C								
	RADIATION	R					REVISION # : DATE :			
	LAGING	A								
	SUBMERGENCE	S								
PHYS DNG REF:	FSAR ENH CAT:						SYSTEM : SAFETY INJECTION			
PHYS DNG LUG:	1958 CATEG.:									
MOUNTING:	APPENDIX E						TAG : TE ISI 0914-2S			
EN. DUC. LUG: P.O. 189501										

ENVIRONMENTAL PARAMETER	ENVIRONMENTAL ACTUAL	DEM. Q	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	H/M	UTS	ITEMS	
TAG NO: TE ISI 0914-35	OPERABILITY	40 YEARS	OPERABILITY REVIEW						ACCEL TIME
EQUIPMENT: MOTOR TYPE	DBA	NORMAL							ACCEL TEMP
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP MTR)	TEMPERATURE	1 YEAR 104° F NORM 104° F DBA	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2			M			REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.				M			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)			M			SUBCOMPONENTS:
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A							
ACCUM. SPEC: N/A	R GAMMA	18.9E4	FSAR FIG. 3.11B-20						
ACCUM. DEM.: N/A	A BETA	100% BETA	ZONE R5			H			
SPECIFICATIONS:	D SHIELD	1.89 E5							
P.O. # 189501 CND # 220	AGE-INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51						SAFETY FUNCTIONS
PLANT LOC.: AB21	(PER 323-1978 DEF.)								
COORDINATES X= 1508.0 Y= 1593.0 Z= 236.0	SUBMERGED	191.0 YES	FSAR SECT. 3.6						AUTH. REFERENCE:

INSTALL. NEF:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPTN:	OPERABILITY	O	REFERENCES:	
QUALIF:	TEMPERATURE	T		
STATUS:	PRESSURE	P		
	REL. HUMIDTY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
PHYS DRG NEF:	TAGING	A		
PHYS DRG LUG:	SUBMERGENCE	S		
MOUNTING:	FSAR ENV CAT:		REVISION #:	
ENV. DRG LUG: by PO. 189501	10588 CATEG.:		DATE:	
	APPENDIX E		SYSTEM: SAFETY INJECTION	
			TAG: TE ISI 0914-35	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	ACTUAL	QUALIF.				
TAG NO: TE ISI 0914-45	OPERABILITY	40 YEARS		OPERABILITY				ACCEL TIME	
EQUIPMENT: MOTOR	ITY	NORMAL		REVIEW				ACCEL TEMP	
EQUIPMENT TYPE	NORM/TEST	1 YEAR						REPLACEMENT	
COMPONENT: TEMP ELEMENT (FOR CHARGING PMP MTR)	IDBA	POST DBA						MAINTAIN.	
MANUFACTURER:	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M		SUBCOMPONENTS	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.				M			
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M			
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A							
ACCUM. SPEC: N/A	R GAMMA	8.9 E4		FSAR FIG. 3.11B-20					
ACCUM. DEM.: N/A	A BETA			ZONE RS		H			
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 189501 CND # 220	T.I.D.	1.89 E5							
PLANT LOC.: AB21	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
COORDINATES: X= 1508.0 Y= 1593.0 Z= 236.0	(PER 323-1974 DEF.)								
	SUBMERGED	191.0 YES		FSAR SECT. 3.6				AUTH. REFERENCES	
INSTALLED (Y/II):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTALL. REF:	OPERABILITY	O	REFERENCES:						
QUALIF. EXEMPT:	TEMPERATURE	T							
QUALIFI:	PRESSURE	P							
STATUS:	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF:	AGING	A					REVISION #:		
PHYS DNG LUC:	SUBMERGENCE	S					DATE:		
MOUNTING:							SYSTEM: SAFETY INJECTION		
EDUC. LUC: by P.O. 189501	FSAR ENV CAT:						TAG: TE ISI 0914-45		
	1958B CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS	ITEMS
	PARAMETER	ACTUAL	DEM.	ACTUAL	DEM.	QUALIF.		
TAG NO: TE ISI 0914-5 S-	OPERABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: MOTOR TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA						ACCEL TEMP
COMPONENT: TEMP ELEMENT (FOR CHARGING PMP MTR)	TEMPERATURE	104°F NORM 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT
MANUFACTURER:	PRESSURE	ATMOS. NORM. DBA NORM.				M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A						
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD T.I.D.	8.9 E4 100% BETA 1.89 E5		FSAR FIG. 3.11B-20 ZONE RS		H		
ACCUM. DEM.: N/A	AGE-INST LIFE	40 YEARS (PER 323-11979 DEF.)		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
P.O. # 189501 CND # 220	SUBMERGED	191.0 YES		FSAR SECT. 3.6				AUTH. REFERENCES
PLANT LOC.: AB21								
COORDINATES X= Y= 1593.0 Z= 236.0								


QUALIF. STATUS	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
.....	OPERABILITY	O		
.....	TEMPERATURE	T		
.....	PRESSURE	P		
.....	REL. HUMIDITY	H		
.....	CHEM. SPRAY	C		
.....	RADIATION	R		
.....	AGING	A		
.....	SUBMERGENCE	S		
.....	FSAR ENV CAT: 10588 CATEG. 1			
.....	APPENDIX E			

REVISION # :
 DATE :
 SYSTEM : SAFETY INJECTION
 TAG : TE ISI 0914-5S


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	UNITS	ITEMS	
	PARAMETER	ACTUAL	DEM.	ACTUAL					DEM.
TAG NO: TE ISI 0914-65	OPERABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME	
EQUIPMENT: MOTOR TYPE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: TEMP. ELEMENT (FOR CHARGING PMP. MTR)	TEMPERATURE	104° F NORM 104° F DBA		FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2		M		REPLACEMENT	
MAINT. ALTERNATE	PRESSURE	ATMOS. NORM. DBA NORM.				M		MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		SUBCOMPONENTS	
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A							
ACCUM. SPEC: N/A	R GAMMA	18.9 E4		FSAR FIG. 3.11B-20					
ACCUM. DEM.: N/A	A BETA	100% BETA		ZONE RS		H			
SPECIFICATIONS:	D SHIELD	100% BETA							
P.O. # 189501 CND # 220	T.I.D.	1.89 E5							
PLANT LOC.: AB21	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
COORDINATES X= 1508.0 Y= 1593.0 Z= 236.0	SUBMERGED	191.0 YES		FSAR SECT. 3.6				AUTH. REFERENCES	
INSTALLED (Y/H):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
INSTAL. REFI:	OPERABILITY	O	REFERENCES:						
QUALIF. EXEMPTN:	TEMPERATURE	T							
QUALIF:	PRESSURE	P							
STATUS:	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REFI:	AGING	A					REVISION #		
PHYS DNG LUCI:	SUBMERGENCE	S					DATE		
MOUNTING:							SYSTEM: SAFETY INJECTION		
EN.DUC.LUCI: by RO.189501	FSAR ENV CAT: 10588 CATEG. 1	APPENDIX E					TAG: TE ISI 0914-65		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	UNITS	
	PARAMETER	ACTUAL					
TAG NO: TE ISI 0915 SAT	OPERABILITY	40 YEARS	OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: MOTOR	MTY	NORMAL					ACCEL TEMP
TYPE	NDHM/TEST	1 YEAR					REPLACEMENT
COMPONENT: TEMP ELEMENT (FOR CHARGING PMP MTR)	DBA	POST DBA					MAINTENANCE
MAINT. ALTERS:	TEMPERATURE	104° F NORM 104° F DBA	FSAR TABLE 19.4.0-1 FSAR FIG. 3.11B-2		M		SUBCOMPONENTS
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.			M		
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M		
FUNCTIONS & SERVICE	CHEMICAL SPRAY	N/A					
ACCUM. SPEC: N/A	R GAMMA	8.9 E4	FSAR FIG. 3.11B-20				
ACCUM. DEM.: N/A	A BETA		ZONERS		H		
SPECIFICATIONS:	D SHIELD	100% BETA					
P.O. # 189501 CND # 220	T.I.D.	1.89 E5					SAFETY FUNCTIONS
PLANT LOC.: AB21	AGE-INST LIFE	40 YEARS	110 CFR 50 PARAGRAPH 50.51				
COORDINATES X= 1508.0 Y= 1593.0 Z= 236.0	(PER 323-1974 DEF.)						
	SUBMERGED	191.0 YES	FSAR SECT. 3.6				AUTH. REFERENCES

QUALIF. EXEMPTN:	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES:
QUALIF. STATUS	OPERABILITY	O	REFERENCES:	REVISION #
	TEMPERATURE	T		DATE
	PRESSURE	P		SYSTEM: SAFETY INJECTION
	REL. HUMIDTY	H		TAG: TE ISI 0915 SAT
	CHEM. SPRAY	C		
	RADIATION	R		
PHYS DNG NEF:	AGING	A		
PHYS DNG LUC:	SUBMERGENCE	S		
INSTALLING:				
ED. DUC. LUC: by P.O. 189501	FSAR ENV CAT:			
	10500 CATEG.:			
	APPENDIX E			



EQUIPMENT DESCRIPTION		ENVIRONMENTAL PARAMETER ACTUAL		DEH. DEF.	DOCUMENTATION ACTUAL	QUALIF. METHOD	H/M	OUTS ITEMS
TAG NO: TE ISI 0916 SAB		OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: MOTOR TYPE		NORM/TEST DBA	NORMAL 1 YEAR POST DBA					ACCEL TEMPS
COMPONENT: TEMP. ELEMENT (FOR CHARGING PWR MTR)		TEMPERATURE	104°F NORM 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11B-2		M	REPLACEMENTS
MANUFACTURER:		PRESSURE	ATMOS. NORM. DBA NORM.					MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE		RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL #		CHEMICAL SPRAY	N/A					
FUNCTIONS & SERVICE		R GAMMA	8.9 E4		FSAR FIG. 3.11B-20 ZONE RS		H	
ACCUM. SPEC: N/A		A BETA	100% BETA					
ACCUM. DEM.: N/A		YIELD	11.89 E4					
SPECIFICATIONS:		AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. # 189501 CND # 220		(PER 323-1979 DEF.)						
PLANT LOC.: AB21		SUBMERGED	191.0 YES		FSAR SECT. 3.6			AUTH. REFERENCES
COORDINATES X= Y= 1593.0 Z= 236.0								
INSTALLED (Y/II):		PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. REF:		OPERABILITY	O	REFERENCES:				
QUALIF EXEMPT:		TEMPERATURE	T					
QUALIFI:		PRESSURE	P					
STATUS:		REL. HUMIDTY	H					
		CHEM. SPRAY	C					
		RADIATION	R					
PHYS DNG REF:		AGING	A					REVISION # :
PHYS DNG LUC:		SUBMERGENCE	S					DATE :
MOUNTING :								
EQUIP. LUC: w/ P.O. 189501		FSAR ENV CAT:						SYSTEM : SAFETY INJECTION
		10500 CATEG.:						TAG : TE ISI 0916 SAB
		APPENDIX E						




EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ N/A	ITEMS	
	PARAMETER	ACTUAL	DESIGN	QUALIF.				ACTUAL
TAG NO: 125I-V500SA-1	OPERABILITY	140 YEARS			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NDRH/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL: SMB 000 279709	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE	R GAMMA	2.0 E4			FSAR FIG. 3.11.5-			
ACCUM. SPEC: N/A	A BETA	7.2 E4			RAD. ZONE			
ACCUM. DES: N/A	D SHIELD	100% BETA			RG			
SPECIFICATIONS: PROJ. E-SPEC. 952065,R5 GEN. E-SPEC. 678852,R2	T.I.D.	3.0 E4						
P.O. #173662 CND # 1	AGE-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: AB 21	(PER 325-1979 DEF.)							
COORDINATES X= 1452-0 Y= 1648-0 Z= 236-0	SURGEHEAD	191'0"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCE

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS. DRG. HFF: CAR 2165 G 152
 PHYS. DRG. LIC: E-7
 MOUNTING:
 EV. DOC. LUC: W.P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
TAGING	A
NUMERICAL	S
1958 CATEG.	
API ENVI E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DWG. 6378D38, 1364-4480
 FLOW DIAG. CAR 2165 G 808 (F-14)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: SAFETY INJECTION
 TAG: 125I-V500SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : 2SI-V502 SA-1	OPERABIL- ITY	140 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIMES
EQUIPMENT VALVE TYPE	NOHM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2SI-V502 SA-1	R GAMMA A BETA D SHIELD T.I.D.	2.0E4 7.2E4 100% BETA 3.0E4		FSAR FIG. 3.11B- RAD. ZONE RG			
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	BURMEQUEN	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 952065, RE GEN. E-SPEC. 678852, R2							
P.O. # 173662 END # 1							
PLANT LOC.: A.B.21							
COORDINATES X= 1568.0 Y= 1679.0 Z= 236.0							

QUALIF. EXEMPT	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
BY FIELD	OPERABILITY	O		
N/A	TEMPERATURE	T		
	PRESSURE	P		
	REL. HUMIDITY	H		
	CHEM. SPRAY	C		
	RADIATION	R		
	AGING	A		
	BURMEQUEN	S		
	1950B CATEG.			
	APPENDIX E			

REFERENCES: VENDOR DWG. 8378D38, 1364-4480
 FLOW DIAG. CAR 2165 G 808 (F-11)

REVISION # :
 DATE :
 SYSTEM SAFETY INJECTION
 TAG : 2SI-V502SA-1



1
2
3



4



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/ U/D	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEN. QUALIF.			
TAG NO: 2SI-V503 SA-1	OPERABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MAINT ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL: SMB 279713	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTION: SERVING VALVE & SERVICE 2SI-V503 SA-1	R GAMMA A BETA D SHIELD T.I.D.	3.3E4 1.0E3 100% BETA 3.4E4		FSAR FIG. 3.11B- RAD. ZONE R3				SAFETY FUNCTIONS
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				
ACCUM. DEN.: N/A PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	BURNED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCE
SPECIFICATIONS: P.O. 173662 CND # 1	INSTALL. (Y/N): BY FIELD			OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
PLANT LOC.: A.B.11	COORDINATES X= 1548.0 Y= 1604.0 Z= 217.0			REFERENCES: VENDOR DWG. 8378D38, 1364-4480 FLOW DIAG. CAR 2165 G808 (M-5)				REVISION # DATE
COORDINATES X= 1548.0 Y= 1604.0 Z= 217.0	INSTALL. EXEMPT: N/A							SYSTEM SAFETY INJECTION
QUALIFI: STATUS	OPERABILITY TEMPERATURE PRESSURE REL. HUMIDITY CHEM. SPRAY RADIATION AGING INTERFERENCE	0 T P H C R A S						TAG: 2SI-V503 SA-1
PHYS DNG MFG: CAR-2165 G153 PHYS DNG LUCI: D-S MOUNTING: EN. DUC. LUCI W.P.O. 173662	1958 CATEG. 1 APPENDIX E							

1
2
3



1992



AS



EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUALIF.	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	N/M/OUTS	ITEMS
TAG NO: 2SI-V504-SB-1	OPENABILITY	140 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 19.4.0-1 FSAR FIG.				REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
MODEL AND SERIAL #: SMB00	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
FUNCTION: SERVING VALVE & SERVICE 2SI-V504-SB-1	R GAMMA	3.3 E4		FSAR FIG. 13.11B-				
ACCUM. SPEC: N/A	A BETA	7.2 E4		RAD. ZONE R3				
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 952065, RS GEN. E-SPEC. 678852, R2	T.I.D.	3.4 E4						
P.O. # 173662 CND # 1	ACC-INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
PLANT LOC.: A-P. 11	BURNED	19150"	N/A	FSAR SECT. 3.6	N/A			
COORDINATES X=1550.0 Y=1604.0 Z= 217.0								AUTH. REFERENCE

INSTALLED (Y/II):
 INSTAL. NEP: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS DNG HFF: CAR 2165 G153
 PHYS DNG LIC: D-5
 MOUNTING:
 EDUC. LUC: W.P.O. 173662


PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
INTERFERENCE	S
19500 CATEG. 1	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES:
 VENDOR DWG. 8378D38,
 1364-4480
 FLOW DIAG. CAR 2165 G808 (D-5)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM SAFETY INJECTION
 TAG: 2SI-V504-SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	UTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALITY					ACTUAL
TAG NO 12SI-V506 SA-1	OPENABILITY	40 YEARS			OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT VALVE TYPE	TRY	NORMAL							ACCEL TEMP
COMPONENT MOTOR OPERATOR	NORM/TEST DBA	1 YEAR POST DBA							REPLACEMENT
MANUFACTURER LIMITORQUE	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 19.4.0-1 FSAR FIG.				MAINTAIN.
MAJOR SUPPLIER WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.				SUBCOMPONENTS
MODEL AND SERIAL NO SMTB 00	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				
FUNCTION SERVING VALVE & SERVICE	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-				
ACCUM. SPEC N/A	R GAMMA	3.3 E4			FSAR FIG. 3.11B-				
ACCUM. DEM. N/A	A BETA	7.2 E4			RAD. ZONE. R3				
SPECIFICATIONS: GEN. E-SPEC. 678852, R2	D SHIELD	100% BETA							SAFETY FUNCTIONS
P.O. # 173662 CND # 1	T.I.D.	3.4 E4							
PLANT LOC. A.B.11	ACC-INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51				
COORDINATES X=1539.0 Y=1630.0 Z=230.0	(PER 323-1979 DEF.)								
INSTALLED (Y/M):	SURGE	191'0"	N/A		FSAR SECT. 3.6	N/A			AUTH. REFERENCE
INITIAL. REPT BY FIELD	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF EXEMPT N/A	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378D38, 1304-4480 FLOW DIAG. CAR 2165 G 808 (G-3)					REVISION # : DATE :	
QUALIF	TEMPERATURE	T							
STATUS	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
PHYS DNG NFFI CAR 2165 G 151	RADIATION	R							
PHYS DNG LUCI F-10	AGING	A							
MOUNTING	EMERGENCY	S							
EW. OUC. LUC: W P.O. 173662	10500 CATEG.								
	APPENDIX E								
								SYSTEM SAFETY INJECTION	
								TAG 12SI-V506 SA-1	


UTILITIES	LINA PUMPER & LEAK	COMPONENT EVALUATION	REF	CAPACITY	900 MW (E)	CRSD				
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUAL.	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	M/M/ W/TS	W/TS	ITEMS	
TAG NO: 2SI-V515SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW					ACCEL TIME	
EQUIPMENT: AIR OPERATED VALVE	INDRM/TEST DBA	1 YEAR POST DBA							ACCEL TEMP	
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					REPLACEMENT	
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.					MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					SUBCOMPONENTS	
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-						
FUNCTION: SERVING VALVE & SERVICE 2SI-V515SA-1	R GAMMA	3.3E4		FSAR FIG. 3.11B-RAD. ZONE R3						
ACCUM. SPEC: N/A	A BETA	7.2E4								
ACCUM. DEM.: N/A	D SHIELD	100% BETA								
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	T.I.D.	3.4E4								
P.O. # 183622 CND # 1	AGE - INST LIFE (PER 525-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTIONS	
PLANT LOC.: A.B.11	BURGEON	191'0"	N/A	FSAR SECT. 3.6	N/A					
COORDINATES X=1545.0 Y=1604.0 Z=221.0		YES							AUTH. REFERENCES	
INSTALLED (Y/N): INSTAL. MFR: BY FIELD QUALIF. CRMP: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE			
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165963, 136A-2929 FLOW DIAG. CAR 2165 9803 (4-5)				REVISION # DATE SYSTEM: SAFETY INJECTION TAG: 2SI-V515SA-1			
	TEMPERATURE	T								
	PRESSURE	P								
	REL. HUMIDITY	H								
	CHEM. SPRAY	C								
	RADIATION	R								
	AGING	A								
	BURGEON	S								
	1950 CATEG.									
	APPENDIX E									



UTILITIES	INSTRUMENT & LIGHT	COMPONENT EVALUATION	TEST	CAPACITY	900 NM(E)	CESS	
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUAL.	DOCUMENTATION ACTUAL	QUALIF. METHOD	N/M/ NUTS / ITEMS	
TAG NO : 2SI-V515 SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
FUNCTION: SERVING VALVE & SERVICE 2SI-V515 SA-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
ACCUM. SPEC: N/A	R GAMMA	3.3 E4		FSAR FIG. 3.11B-			
ACCUM. DEM.: N/A	A BETA	7.2 E4		RAD. ZONE R3			
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	D SHIELD	100% BETA					
P.O. # 183622 CND # 1	T.I.D.	3.4 E4					
PLANT LOC.: A.B.11	ACC-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
COORDINATES X=1545.0 Y=1604.0 Z=221.0	EMERGENCY	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
INSTAL. NEP: BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165963 1364-2929 FLOW DIAG. CAR 2165 9008 (H-S)			REVISION # : DATE : SYSTEM SAFETY INJECTION TAG : 2SI-V515 SA-1	
QUALIF EXEMPT: N/A	TEMPERATURE	T					
QUALIF:	PRESSURE	P					
STATUS:	REL. HUMIDITY	H					
:	CHEM. SPRAY	C					
:	RADIATION	R					
PHYS DWG REF: CAR 2165 9153	AGING	A					
PHYS DWG LUCI: D-4	EMERGENCY	S					
MOUNTING:							
EO. OUC. LUC: w/ P.O. 183622	1950 CATEG. 1 APPENDIX E						


EQUIPMENT DESCRIPTION		ENVIRONMENTAL PARAMETER ACTUAL		DEM. QUALITY	DOCUMENTATION ACTUAL		QUALIF. METHOD	N/M/ UITS	ITEMS
TAG NO: 2SI-V516SB-1		OPENABILITY	40 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE		NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: SOLENOID VALVE		TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				REPLACEMENT
MANUFACTURER: ASCO		PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE		RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)				SUBCOMPONENTS
FUNCTION: SERVING VALVE & SERVICE 2SI-V516SB-1		CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-				
ACCUM. SPEC: N/A		R GAMMA	3.3E4		FSAR FIG. 3.11B-				
ACCUM. DEM.: N/A		A BETA	7.2E4		RAD. ZONE B3				
SPECIFICATIONS: GEN. E-SPEC. 678844, R2		D SHIELD	100% BETA						
P.O. #183622 CND #1		T.I.D.	3.4E4		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS
PLANT LOC.: A.B.11		AGE-IND. LIFE (PER 323-1974 DEF.)	40 YEARS						
COORDINATES X=1543.0 Y=1604.0 Z=221.0		SURMERGED	191'0" YES	N/A	FSAR SECT. 3.6		N/A		AUTH. REFERENCES
INSTALLED (Y/II): INSTAL. NEP: BY FIELD QUALIF. EXEMPT: N/A STATUS: PHYS DNG HFF: CAR-2165 G153 PHYS DNG LUCI: D-3 MOUNTING: EN. DNG. LUCI: w/ P.O. 183622		PARA-METER OPERABILITY TEMPERATURE PRESSURE REL. HUMIDITY CHEM. SPRAY RADIATION IMAGING SURMERGENCE 1950B CATEG. 1 APPENDIX E	SUPPL. REVIEW O T P H C R A S	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: VENDOR DWG. D-165963, 1364-2929 FLOW DIAG. CAR-2165 G808 (I-5)				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION #: DATE: SYSTEM SAFETY INJECTION TAG: 2SI-V516SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUA	DOCUMENTATION ACTUAL	QUALIF. METHOD	H/M/ UITS	ITEMS
TAG NO.: 2SI-V516SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT TYPE: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENTS: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 2SI-V516SB-1	R GAMMA	3.3 E4		FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	7.2 E4		RAD. ZONE R3			
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS: PROJ. E-SPEC. 678959, RZ GEN. E-SPEC. 678844, RZ	T.I.D.	3.4 E4					
P.O. # 183622 CND # 1	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A.B.11	(PER 325-1979 DEF.)						
COORDINATES X= 1543.0 Y= 1604.0 Z= 221.0	SURGEHEAD	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
YES							
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. KEPT BY FIELD	OPERABILITY	O	REFERENCES:				
QUALIF. EXEMPT: N/A	TEMPERATURE	T	VENDOR DWG. D-165963,				
QUALIFI:	PRESSURE	P	1364-2929				
STATUS:	REL. HUMIDITY	H	FLOW DIAG. CAR-2165 9808 (I-S)				REVISION #:
	CHEM. SPRAY	C					DATE:
	RADIATION	R					
	AGING	A					
PHYS DWG HFF: CAR-2165 9153	EMERGENCY	S					
PHYS DWG LUC: D-3							
MOUNTING:							
EN. DUC. LUC: W, P.O. 183622	1958 CATEG.:						
	APPENDIX E						
							SYSTEM SAFETY INJECTION
							TAG: 2SI-V516SB-1




UTILITIES	LINE NUMBER & LENGTH	COMPONENT EVALUATION	MEET	CAPACITY	900 MM(E)	CESD
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER	ACTUAL	DEM. QUALITY	DOCUMENTATION ACTUAL	QUALIF. METHOD	H/WI QUIS ITEMS
TAG NO: 2SI-VS17SA-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NDHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.		REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-		
FUNCTION & SERVICE: SERVING VALVE 2SI-VS17SA-1	R GAMMA	3.3E4		FSAR FIG. 3.11B-		
ACCUM. SPEC: N/A	A BETA	7.2E4		RAD. ZONE TR3		
ACCUM. DEM.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: GEN. E-SPEC. 678844, R2 PROJ. E-SPEC. 678959, R2	T.I.D.	3.4E4				
P.O. #183622 CND # 1	ACCUM. LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTIONS
PLANT LOC.: A.B.11	EMERGENCY	191'0"	N/A	FSAR SECT. 3.6	N/A	
COORDINATES: X=1541.0 Y=1604.0 Z=217.0	SURGE	YES				AUTH. REFERENCES
INSTALLED (Y/N): INSTALL. NEP BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165963, 1364-2929 FLOW DIAG. CAR 2165 G808 (L-G)			REVISION # DATE
	TEMPERATURE	T				
	PRESSURE	P				
	REL. HUMIDITY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
	AGING	A				
	EMERGENCY	S				
PHYS DWG HFF: CAR 2165 G153	1958 CATEG.:					
PHYS DWG LUC: K-3	API ENCL E					
MOUNTING						
EQUIP. LUC: w/P.O. 183622						
						SYSTEM SAFETY INJECTION
						TAG 2SI-VS17SA-1

EQUIP. DESC. 104	ENVIRONMENT		DEM. QUAL.	DOCUMENTATION		QUALIF. METHOD	H/M/ UITS	ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO: 2SI-V517SA-1	OPENABIL-140 YEARS			OPERABILITY				ACCEL TIMES	
EQUIPMENT: AIR OPERATED VALVE	ITY NORMAL			REVIEW				ACCEL TEMP	
COMPONENTS: LIMIT SW.	NORM/TEST DBA	1 YEAR POST DBA						REPLACEMENT	
MANUFACTURER: NAMCO	TEMPERAT-URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.				MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				SUBCOMPONENTS	
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)					
FUNCTIONS: SERVING VALVE & SERVICE 2SI-V517SA-1	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-					
ACCUM. SPEC: N/A	R-GAMMA A BETA D SHIELD T.I.D.	3.3E4 7.2E4 100% BETA 3.4E4		FSAR FIG. 3.11B- IRAD ZONE IR3					
ACCUM. DEM.: N/A GEN. E-SPEC. 678842, R2 SPECIFICATIONS: PROJ. E-SPEC. 678959, R2	ACC- INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51				SAFETY FUNCTIONS	
P.O. #183622 CND # 1	BURNEGED	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES	
PLANT LOC.: ATB.11		YES							
COORDINATES X= 1541.0 Y= 1604.0 Z= 217.0									
INSTALLED (Y/M):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTALL. NEP: BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165963, 136A-2929 FLOW DIAG. CAR 2165 6808 (L-6)						
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
STATUS:	PRESSURE	P							
	REL. HUMIDITY	H							
	CHEM. SPRAY	C							
	IRRADIATION	R							
PHYS DNG NFF: CAR-2165 G153	AGING	A					REVISION # :		
PHYS DNG LIC: K-3	EMERGENCY	S					DATE :		
MOUNTING :							SYSTEM : SAFETY INJECTION		
EN. DUC. LUC: W/RO. 183622	1958 CATEG.:						TAG 2SI-V517SA-1		
	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER ACTUAL	DEM. QUALITY	DOCUMENTATION ACTUAL	DEM. QUALIF.	QUALIF. METHOD	M/M	UNITS	ITEMS	
TAG NO: 2SI-V530 SB-1	UPHABIL-40 YEARS		OPERABILITY REVIEW					ACCEL TIME	
EQUIPMENT: AIR OPERATED VALVE TYPE	1TY NORMAL							ACCEL TEMP	
COMPONENT: SOLENOID VALVE	NORM/TEST 1 YEAR POST DBA							REPLACEMENT	
MANUFACTURER: ASCO	TEMPERATURE 104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.					MAINTAIN.	
MAJOR SUPPLIER: WESTINGHOUSE	PRESSURE ATMOS. NORM. DBA NORM.		FSAR SECT.					SUBCOMPONENTS	
MODEL AND SERIAL #	RELATIVE HUMIDITY 20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)						
FUNCTION: SERVING VALVE & SERVICE 2SI-V530SB-1	CHEMICAL SPRAY N/A		FSAR SECT. 3.11-						
ACCUM. SPEC: N/A	R GAMMA 2.0E4		FSAR FIG. 3.11B-						
ACCUM. DEM.: N/A	A BETA 7.2 E4		RAD. ZONE RC						
SPECIFICATIONS: PROJ. E-SPEC. 678959,R2 GEN. E-SPEC. 678844,R2	D SHIELD 100% BETA							SAFETY FUNCTIONS	
P.O. #183622 CND # 1	T.I.D. 3.0E4								
PLANT LOC.: A.B.21	AGE- 40 YEARS		10 CFR 50 PARAGRAPH 50.51						
COORDINATES X= 1511.0 Y= 1626.0 Z= 255.0	INST LIFE (PER 32-1979 DEF.)								
	BURNED 19150°	N/A	FSAR SECT. 3.6	N/A				AUTH. REFERENCES	
INSTALLED (Y/II):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTALL. NEP BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165993, 136A-2929 FLOW DIAG. CAR-2165 4808 (D-12)				REVISION # : DATE : SYSTEM : SAFETY INJECTION TAG : 2SI-V530 SB-1		
QUALIF. EXEMPT: N/A	TEMPERATURE	T							
QUALIFI	PRESSURE	P							
STATUS	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG HFF: CAR 2165 4152	AGING	A							
PHYS DNG LIC: D-12	EMERGENCY	S							
MOUNTING :									
EW.DUC.LUC: W/P.O.183622	1958B CATEG.1								
	APPENDIX E								



UTILITIES	INSTRUMENT & LIGHT	COMPONENT EVALUATION	TEST	CAPACITY	900 MW (E)	CESD
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER ACTUAL	DEM. QUALITY	DOCUMENTATION ACTUAL DEM. QUALIF.	QUALIF. METHOD	N/M/ NUIS	ITEMS
TAG NO: 2SI-V530SB-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA				ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2SI-V530SB-1	R GAMMA	2.0E4	FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA	7.2E4	RAD. ZONE RC			
ACCUM. DEM.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	T.I.D.	13.0E4				
P.O. # 183622, CND # 1	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC. 1A.B-21	EMERGENCY	191'0"	FSAR SECT. 3.6	N/A		
COORDINATES X=1511.0 Y=1626.0 Z=255.0		YES				AUTH. REFERENCES
INSTALLED (Y/II): INSTAL. MFR: BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
OPERABILITY	TEMPERATURE	O	REFERENCES: VENDOR DWG. D-165993, 1364-2929 FLOW DIAG. CAR 2165 G808 (D-12)			REVISION # DATE SYSTEM (SAFETY INJECTION) TAG 2SI-V530SB-1
TEMPERATURE	PRESSURE	T				
PRESSURE	REL. HUMIDITY	P				
REL. HUMIDITY	CHEM. SPRAY	H				
CHEM. SPRAY	RADIATION	C				
RADIATION	AGING	R				
AGING	EMERGENCY	A				
EMERGENCY		S				
1958 CATEG. 1 APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A/ Q/IS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAB NO: 2SI-V550SB-1	OPENABIL	140 YEARS			OPERABILITY			ACCEL TIME
	ITY	NORMAL			REVIEW			
EQUIPMENT: AIR OPERATED TYPE	INDM/TEST	1 YEAR POST						ACCEL TEMP
	DBA	DBA						
COMPONENT: LIMIT SWITCH	TEMPERAT-URE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2SI-V550SB-1	R GAMMA	2.0 E4			FSAR FIG. 3.11B-			
	A BETA	7.2 E4			RAD. ZONE			
	D SHIELD	100% BETA			IRG			
	T.I.D.	3.0 E4						
ACCUM. SPEC: N/A	AGE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
	INST LIFE							
	(PER 323-1979 DEF.)							
ACCUM. DEM.: N/A	BURNEGED	1910'	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES
	YES							

INSTALLED (Y/N):
 INSTAL. NEPS BY FIELD
 QUALIF EXEMPT: N/A
 QUALIFI:
 STATUS:
 PHYS ENG OFFICAR 2165 G152
 PHYS ENG LIC E-15
 MOUNTING:
 EN. OUC. LUCI w/ PO-183622

PARA- SUPPL. REVEN
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 EMERGENCY S
 1950B CATEG. 1
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIED TO:

 REFERENCES:
 VENDOR DWG. D-166121, 1364-2937
 FLOW DIAG. CAR-2165 G809 (D-4)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

 REVISION #:
 DATE:
 SYSTEM SAFETY INJECTION
 TAG: 2SI-V550SB-1

EQUIP. DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	U/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEH.	QUALIF.	ACTUAL	DEH.	QUALIF.	
TAG NO: 2SI-V535SA-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11, SEC. 3.6 & 4.6 PAGE 11 & 25			ACCEL TIME: 15092 HOURS
EQUIPMENT TYPE: VALVE GATE	NORM/TEST DBA	1 YEAR	1 YEAR					ACCEL TEMP: 180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1 FOR DBA	SRS TABLE PAGE 1C THRU 6C			REPLACEMENT: 40 YEARS
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. & FIG. 3.11.6-1 (DBA)	REPORT 600454 PAGE 10 & 14			MAINTAIN.
MAJOR SUPPLIER: WESTHS.	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 9.4.0-1 NORM	TEST REPORT SECT. 4.4.3 PAGE 18			SUBCOMPONENTS: TORQUE (LIMIT SW.
MODEL AND SERIAL #	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17			
FUNCTIONS & SERVICE: SAFETY INJ. - SERVING VALVE 2SI-V535SA-1	ACCUM. SPEC: N/A							
	ACCUM. DEH.: N/A							
SPECIFICATIONS: W. PROJ. SPEC. 952065 05 W.E. SPEC. 678852 02	R GAMMA	1.2 EG	130 EG	FSAR APP 3.11.8 -20	TEST REPORT SECT. 4.3 PAGE 12			
P.O. # 173662 CND # 15H.0456	U SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TAB D FIG THRU 3G			
PLANT LOC.: C.B. 21	AGE-INST LIFE (PER 323-1979 DEF.)	40 YEARS	456 YEARS	110 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3			SAFETY FUNCTIONS: SEE TAB "B" OF HE-1
COORDINATES X=1537.0 Y=1736.0 Z=254.0	SUBMERGED	228.3	N/A	FSAR SECTION 3.6	N/A			
INSTALLED (Y/M):								
INSTAL. REF: BY P.L.D.								

QUALIF EXEMPT: N/A
 QUALIF: QUALIFIED, AWAITING
 STATUS CONFIRMATORY DATA
 PHYS DMG EFF: CAR-2165 G-156
 PHYS DMG LUC: TOTAL EQUIP. LIST
 MOUNTING
 EQ. DUC. LUC: W.P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O HE-1
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
FSAR ENV CAT: 10500 CATEG. 1A	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES: FLOW DIAG. CAR-2165 G-809
 LIMITORQUE TEST REPORT 600454

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1
 REVISION # 10
 DATE 14-21-84
 SYSTEM: SAFETY INJ.
 TAG: 2SI-535SA-1

SAFETY FUNCTIONS: SEE TAB "B" OF HE-1

AUTH. REFERENCE: M.J.H.

EQUIP. DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M/OUTS	ITEMS
	PARAMETER	ACTUAL	DEH.	QUALIF.			
TAG NO: 2SI-V5365B-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY	TEST REPORT		ACCEL TIME:
	ITY	NORMAL	NORMAL	REVIEW	SEC. 4.1 PAGE		15092 HOURS
EQUIPMENT TYPE: VALVE GATE	NORM/ICST	1 YEAR	1 YEAR		11, SEC. 3.6		ACCEL TEMP:
	DBA	POST DBA	POST DBA		4.6 PAGE	NONE	180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM.	FSAR TABLE	SRS TAB E	COMB. TYPE	REPLACEMENT:
				19.4.0-1	PAGE 1C THRU	REVIEW	40 YEARS
MANUFACTURER: LIMITORQUE		FSAR FIG. 3.11.4.11	385°F DBA	FSAR FIG.	6C		MAINTAIN.
	FOR DBA			3.11.4-1		NONE	
MAJOR SUPPLIER: WESTHS.	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT.	REPORT 600456	COMB. TYPE	SUBCOMPONENTS:
				3.11.6 NORM.	PAGE 10 & 14	TEST &	TORQUE & LIMIT SW.
		FSAR FIG. 3.11.8-1	70 PSIG DBA	FIG.		SUPP. REVIEW	
	FOR DBA			3.11.6-1 (DBA)	SRS TAB E		
				PAGE 2B		NONE	
MODEL AND SERIAL: WESTHS.	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR TABLE	TEST REPORT	COMB. TYPE	SEE TAB
		100% DBA	100% DBA	19.4.0-1 NORM.	SEC. 4.4.3	TEST &	E, PAGE
				FSAR SECT.	PAGE 18	SUPP.	IE
FUNCTIONS: SAFETY INJ. & SERVICE SERVING VALVE				3.11.4.3 (DBA)	SRS TAB E	REVIEW	
				PAGE 1E			
	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT.	TEST REPORT	COMB. TYPE	
		PH 8.5-11.0	PH 10.5-11.1	3.11.5.1	SEC. 4.4.2	TEST &	
					PAGE 17	SUPP.	NONE
					SRS TAB E	REVIEW	
ACCUM. SPEC: N/A					PAGE 1D		
	R GAMMA	1.2 EG	130 EG	FSAR APP.	TEST REPORT	COMB. TYPE	SEE
	A BETA	3.3 EG	74 EG	3.11.8-20	SEC. 4.3	TEST &	TAB E
	D SHIELD	100% BETA	100 BETA	CONT. RAD.	PAGE 12	SUPP.	PAGE 1G
	T.I.D.	1.2 EG	1204 EG	ZONE C3	SRS TAB E	REVIEW	
					PAGE 1G THRU 3G		
SPECIFICATIONS: W.P.O. SPEC. 952065 OR 678862 OR	AGE-INST LIFE	40 YEARS	456 YEARS	10 CFR 50	TEST REPORT	COMB. TYPE	SEE TAB
	(PER 523-1974 DEF.)			PARAGRAPH	SEC. 3.1.1	TEST &	IE, PAGE
				50.51	PAGE 3	SUPP.	IF
P.O. #: 173662 CHD # 15K#0456					SRS TAB E	REVIEW	
PLANT LOC.: C.B. 21					PAGE 1F THRU 3F		
COORDINATES X- 1518.0	SURMERGED	228.3	N/A	FSAR SECTION 3.6	N/A		
Y- 1652.0							
Z- 249.0	YES				SRS TAB E	N/A	SAFETY FUNCTIONS: SEE TAB "B" OF ME-1
					PAGE 1A		
INSTALLED (Y/N): BY FLD.	OTHER EQUIPMENT THIS CES APPLIES TO:						AUTH. REFERENCE: M.J.H.
QUALIF EXEMPTN: N/A							
QUALIFI: QUALIFIED, AWAITING STATUS CONFIRMATORY DATA	PARA-METER	SUPPL. REVIEW					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: ME-1
	OPERABILITY	O HE-1					
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
	SURMERGENCE	S					
PHYS DNG REF: CAR-2165G-156	FSAR ENV CAT:						REVISION #: 0
PHYS DNG LUC: TOTAL EQUIP. LIST	19580 CATEG. 1A						DATE: 14-21-84
HOUNTING	APPENDIX E						SYSTEM: SAFETY INJ.
EQU. DUC. LUC: W.P.O. 173662							TAG: 2SI-V5365B-1

REFERENCES: FLOW DIAG. CAR-2165G-809
LIMITORQUE TEST REPORT 600456


EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH.	QUALIF.			
TAG NO: 2SI-V537SA-1	OPERABILITY	40 YEARS	40 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11	TEST	ACCEL TIME: 15092 HOURS
EQUIPMENT TYPE: VALVE GATE	NORM/TEST DBA	1 YEAR	1 YEAR		SEC. 3.6 & 4.6 PAGE 11 & 25		ACCEL TEMP: 180°C
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	REPLACEMENT: 40 YEARS
MANUFACTURER: LIMITORQUE		FSAR FIG. 3.11.4-1 FOR DBA	385°F DBA	3.11.4-1		H	MAINTAIN.
MAJOR SUPPLIER: WESTNS.	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM & FIG.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	SUBCOMPONENTS: TORQUE & LIMIT SW.
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM	100% NORM	FSAR TABLE 9.4.0-1 NORM	TEST REPORT SECT. 4.4.3 PAGE 18	COMB. TYPE TEST & SUPP. REVIEW	SEE TAB E, PAGE 1E
FUNCTION & SERVICE: SAFETY INJ. SERVING VALVE 2SI-V537SA-1		100% DBA	100% DBA	FSAR SECT. 3.11.4.3 (DBA)	SRS TABLE PAGE 1E	H	
	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	H NONE
ACCUR. SPEC: N/A		PH 8.5-11.0	PH 10.5-11.1		SRS TABLE PAGE 1D	H	
ACCUR. DEH.: N/A	R GAMMA	1.2 EG	130 EG	FSAR APP. 3.11.8-20	TEST REPORT SECT. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H SEE TAB E PAGE 1G
SPECIFICATIONS: W. PROJ. SPEC. 952065.05 W. E. SPEC. 677752.02	U SHIELD	100% BETA	100% BETA	CONT. RAD. ZONE C3	SRS TABLE PAGE 1G THRU 3G	H	
P.O. # 173662	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SEC. 3.1.1 PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	H SEE TAB E, PAGE 1F
PLANT LOC.: C.B.					SRS TABLE PAGE 1F THRU 3F		SAFETY FUNCTIONS: SEE TAB 'B' OF HG-1
COORDINATES X=1448.0 Y=1716.0 Z=250.0	SUBMERGED	228.3	N/A	FSAR SECTION 3.6	N/A	N/A	AUTH. REFERENCE: M.J.H.
		YES			SRS TABLE PAGE 1A		

INSTALLED (Y/N):
 INSTAL. REF: BY FLD.
 QUALIF EXEMPTN: N/A
 QUALIF: QUALIFIED, AWAITING
 STATUS CONFIRMATORY DATA
 PHYS DNG REF: CAP-2165 G-156
 PHYS DNG LUC: TOTAL EQUIP. LIST
 MOUNTING
 EV. DUC. LUC: W.P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O HE-1
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
FSAR ENV CAT:	
19588 CATEG. 1A	
APPENDIX E	

OTHER EQUIPMENT THIS CES. APPLIES TO:
 REFERENCES: FLOW DIAG. CAP-2165 G-809
 LIMITORQUE TEST REPORT 600456

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE HE-1
 REVISION # : 0
 DATE : 14-21-84
 SYSTEM : SAFETY INJ.
 TAG : 2SI-V537SA-1



EQUIPMENT DESCRIPTION	PARAMETER ACTUAL	ENVIRONMENTAL DEN. QUANT.	DOCUMENTATION ACTUAL DEN. QUALIF.	QUALIF. METHOD	N/M/OUTS	ITEMS
TAG NO : 2SI-V550 SB-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NDHM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
FUNCTION: SERVING VALVE & SERVICE 2SI-V550SB-1	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11			
ACCUM. SPEC: N/A	R GAMMA A BETA D SHIELD	2.0E4 7.2E4 100% BETA T.I.D. 3.0E4	FSAR FIG. 3.11B- RAD. ZONE RC			
ACCUM. DEN.: N/A	AGE - INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	SURMERGENCE	191'0" YES	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
P.O. # 183622 END # 1						
PLANT LOC.: A.B. 21						
COORDINATES X= 1546.0 Y= 1645.0 Z= 236.0						

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF. EXAMPLE: N/A
 QUALIF:
 STATUS:
 PHYS DNG MFC: CAR 2165 G 152
 PHYS DNG LUC: E-15
 MOUNTING:
 EN. DUC. LUC: w/ P.O. 183622


PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURMERGENCE	S
19500 CATEG. 1	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

 REFERENCES:
 VENDOR DWG. D-166121, 1364-2937
 FLOW DIAG. CAR 2165 G 809 (D-4)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

 REVISION #:
 DATE:
 SYSTEM: SAFETY INJECTION
 TAG: 2SI-V550 SB-1



UTILITIES	INSTRUMENT & LIGHT	COMPONENT EVALUATION	TEST	CAPACITY	900 MW(E)	CEC#
EQUIPMENT DESCRIPTION	ENVIRONMENTAL PARAMETER ACTUAL	DEN. QUALITY	DOCUMENTATION ACTUAL DEN. QUALIF.	QUALIF. METHOD	N/A UNITS	STENS
TAG NO: 25I-V554-SB-1	OPERABILITY	140 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA	FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENT
MAIN/ACTUATOR: ASCO SOLENOID VALVE	PRESSURE	ATMOS. NORM. DBA NORM.	FSAR SECT.			MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA	FSAR TABLE 19.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A	FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 25I-V554-SB-1	R GAMMA	2.0 E4	FSAR FIG. 13.11B-			
ACCUM. SPEC: N/A	A BETA	7.2 E4	RAD. ZONE RC			
ACCUM. DEN.: N/A	D SHIELD	100% BETA				
SPECIFICATIONS: PROJE-SPEC. 678959,R2 GEN. E-SPEC. 678844,R2	T.I.D.	3.0 E4	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. #183622 END # 1	AGE-INST LIFE	40 YEARS				
PLANT LOC.: A.D. 21	(PER 323-1974 DEF.)					
COORDINATES X=1543.0 Y=1644.0 Z=249.0	EMERGENCY	191'0" YES	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
INSTALLED (Y/N): INSTALL. NEP: BY FIELD QUALIF. EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CEC APPLIED TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF. STATUS	OPERABILITY	O	REFERENCES: VENDOR DWG. D-165963, 1364-29291 FLOW DIAG. CAR 2165 609 (K-7)			REVISION #
	TEMPERATURE	T				DATE
	PRESSURE	P				
	REL. HUMIDITY	H				
	CHEM. SPRAY	C				
	RADIATION	R	SYSTEM SAFETY INJECTION			
	AGING	A	TAG 025I-V554-SB-1			
	EMERGENCY	S				
	1958 CATEG. 1 APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M QUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2SI-V554-SB-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: AIR OPERATED VALVE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MAINTAL TUNER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 2SI-V554-SB-1	R GAMMA	2.0E4		FSAR FIG. 13.11B-			
ACCUM. SPEC: N/A	A BETA	17.2E4		RAD. ZONE TRG			
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS: PROJ.E-SPEC. 678959,R2 GEN.E-SPEC. 678844,R2	T.I.D.	13.0E4					
P.O. #183622 END # 1	AGE-INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A-D. 21	(PER 323-1979 DEF.)						
COORDINATES X=1543.0 Y=1644.0 Z=249.0	BURNGEN	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
		YES					

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIFI:
 STATUS:
 PMS DNG HFF: CAR-2165 G152
 PMS DNG LUCI E-15
 MOUNTING:
 EDUC. LUCI w/ P.O. 183622


PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
BURNGEN	S
1950B CATEG.	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIED TO:


REFERENCES:
 VENDOR DWG. D-165963, 1364-2929
 FLOW DIAG. CAR 2165 G809 (K7)

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

REVISION #:
 DATE:
 SYSTEM SAFETY INJECTION
 TAG: 2SI-V554-SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	N/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2SI-V555 SA-1	OPERABILITY	40 YEARS NORMAL	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA				ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	120°F NORM	FSAR TABLE 9.4.0-1			REPLACEMENT
MANUFACTURER: NAMCO		385°F FOR DBA	FSAR FIG. 3.11.4-1			MAINTAIN.
MAJOR SUPPLIER: COPEL VULCAN	PRESSURE	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM. FIG.			SUBCOMPONENTS
MODEL AND SERIAL #: EA170-11302		52 PSIA FOR DBA	FSAR SECT. 3.11.6-1 (DBA)			
FUNCTIONS & SERVICE	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM			
			FSAR SECT. 3.11.4.3 (DBA)			
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
ACCUR. DEM.: N/A	R GAMMA	1.1E6	FSAR FIG. 3.11B-18			
	A BETA	1.7E7	CONT. RAD. ZONE			
SPECIFICATIONS: PROJ. E-SPEC. 678959, RZ	D SHIELD	100% BETA				
	T.I.D.	1.15E6				
P.O. # 183622 CHD # 1 SH. # 421	AGE		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: CONTAINMENT ISOLATION
PLANT LOC.: C.B.	INST LIFE (PER 523-1974 DEF.)	40 YEARS				
COORDINATES X=1540.0 Y=1651.0 Z=255.0	SUBMERGED	228.3	FSAR SECTION 3.6			AUTH. REFERENCE
INSTALLED (Y/N): INSTAL. REF: QUALIF EXEMPT: ***** QUALIF: STATUS: ***** PHYS DWG REF: CAR 2165 G154 PHYS DWG LUC: MOUNTING: EQ. DUC. LUC: w/ P.O. 183622	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 G809 VENDOR DWG. 1364-2937			REVISION #: DATE: SYSTEM: SAFETY INJECTION TAG: 2 SI V555 SA-1
	TEMPERATURE	T				
	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
	RADIATION	R				
	AGING	A				
	SUBMERGENCE	S				
	FSAR ENV CAT:	A				
	10588 CATEG.:					
	APPENDIX E.					



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION	QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL				
TAG NO: 2SI-V555SA-1	OPERABILITY	40 YEARS	OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL 1 YEAR POST DBA				ACCEL TEMP
COMPONENT: SOLENOID V.	TEMPERATURE	120° F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1			REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. 52 PSIA FOR DBA	FSAR SECT. 3.11.6 NORM. FIG.			MAINTAIN.
MAJOR SUPPLIER: COPES VULCAN		52 PSIA FOR DBA	3.11.6-1 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	RELATIVE HUMIDITY	40% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM			
FUNCTIONS & SERVICE			FSAR SECT. 3.11.4.3 (DBA)			
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0	FSAR SECT. 3.11.5.1			
ACCUR. DEH.: N/A	R GAMMA	1.1 EG	FSAR FIG. 3.11B-18			
SPECIFICATIONS: PROJ. E-SPEC. 678959, R2 GEN. E-SPEC. 678844, R2	A BETA	1.7 E7	CONT. RAD. ZONE C3			
	D SHIELD	100% BETA				
P.O. # 183622 CHD # : SH. # 421	AGE- INST LIFE	40 YEARS	10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTION: CONTAINMENT ISOLATION
PLANT LOC.: C.B.	(PER 323-1979 DEF.)					
COORDINATES X= 1540.0 Y= 1651.0 Z= 255.0	SUBMERGED	228.3 YES	FSAR SECTION 3.6			AUTH. REFERENCE
INSTALLED (Y/H):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
INSTALL. REF:	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165. G809.. VENDOR DWG. 1364-2937			REVISION # : DATE : SYSTEM : SAFETY INJECTION
QUALIF. EXEMPTN:	TEMPERATURE	T				
QUALIF. STATUS	PRESSURE	P				
	REL. HUMIDTY	H				
	CHEM. SPRAY	C				
PHYS DNG REF: CAR 2165 G154	RADIATION	R				
PHYS DNG LUCI MOUNTING	AGING	A				
EQ. DUC. LUCI P.O. 183622	SUBMERGENCE	S				
	FSAR ENV CAT:	A				
	10588 CATEG.:					
	APPENDIX E.					TAG : 2SI V555SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	DUIS ITEMS		
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL					DEH. QUALIF.
TAG NO: 2SI-V5705B-1	OPERABILITY	40 YEARS NORMAL	40 YEARS NORMAL	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE 11	TYPE TEST	NONE	ACCEL TIME: 15092 HOURS	
EQUIPMENT TYPE: VALVE GATE	NDIM/TEST DUA	1 YEAR POST DBA	1 YEAR POST DBA		SEC. 3.6 (4.6) PAGE 11 & 25			ACCEL TEMP: 180°C	
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	NONE	REPLACEMENT: 40 YEARS	
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM	ATMOS. NORM	FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	NONE	MAINTAIN.	
MAJOR SUPPLIER: WESTHS.		FSAR FIG. 3.11.8-1 FOR DBA	70 PSIG DBA		SRS TABLE PAGE 2B			SUBCOMPONENTS: TORQUE & LIMIT SW.	
MODEL AND SERIAL: SB-1	RELATIVE HUMIDITY	40% NORM 100% DBA	100% NORM 100% DBA	FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4-3 (DBA)	TEST REPORT SECT. 4.4.3 PAGE 18 SRS TABLE PAGE 1E	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1E		
FUNCTION & SERVICE: SAFETY INJ. SERVING VALVE 2SI-V5705B-1	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0	3000 PPM BORON PH 10.5-11.1	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17 SRS TABLE PAGE 1D	COMB. TYPE TEST & SUPP. REVIEW	NONE		
ACCUR. SPEC: N/A	R GAMMA	6.2 ES	130 EG	FSAR APP. 3.11.B-20	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1G		
ACCUR. DEH.: N/A	A BETA	1.8 E7	74 EG	CONT. RAD. ZONE C2	SRS TABLE PAGE 1F THRU 3F				
SPECIFICATIONS: W. PROJ. SPEC. 932065 02 WE. SPEC. 678852 02	T.I.D.	6.7 ES	204 EG						
P.O. #173662 CHD # 15H.#0417	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	456 YEARS	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 3.1.1 PAGE 3 SRS TABLE PAGE 1G THRU 3G	COMB. TYPE TEST & SUPP. REVIEW	SEE TABLE PAGE 1F	SAFETY FUNCTION: SEE TAB 'B' OF HE-1	
PLANT LOC.: C.B.	SUBMERGED	228.3	N/A	FSAR SECTION 3.6	N/A				
COORDINATES X-1545.0 Y-1644.0 Z-190.0		NO	N/A		SRS TABLE PAGE 1A	N/A	NONE	AUTH. REFERENCE: M.J.H.	
INSTALLED (Y/M): BY FLD.	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE HE-1		
QUALIF EXEMPT: N/A	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-810 LIMITORQUE TEST REPORT 600F56				REVISION # 10 DATE 14-21-84 SYSTEM SAFETY INJ. TAG 2SI-V5705B-1		
QUALIF: QUALIFIED, AWAITING STATUS CONFIRMATORY DATA	TEMPERATURE	T							
	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: CAR-2165 G-151	AGING	A							
PHYS DNG LUCI TOTAL EQUIP. LIST	SUBMERGENCE	S							
MOUNTING	FSAR ENV CAT: 10500 CATEG. 1A								
ED. DUC. LUCI W/ P.O. 173662	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M	OUTS	ACCEL TIME: 15092 HOURS	
	PARAMETER	ACTUAL	DEH.	QUALIF.	ACTUAL	DEH.	QUALIF.		ITEMS
TAG NO: 2SI-V5715A-1	OPERABILITY	40 YEARS	140 YEARS	OPERABILITY REVIEW	TEST REPORT SEC. 4.1 PAGE III, SEC. 3.6	TEST	/	NONE	
EQUIPMENT: VALVE TYPE: GATE	NORM/TEST DBA	1 YEAR	1 YEAR	FSAR TABLE 19.4.0-1	SRS TABLE PAGE 1C THRU 6C	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
COMPONENT: MOTOR	TEMPERATURE	120°F NORM	144°F NORM	FSAR FIG. 3.11.4-III	FSAR FIG. 3.11.4-1	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
MAINT. ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM.	ATMOS. NORM.	FSAR SECT. 3.11.6 NORM.	REPORT 600456 PAGE 10 & 14	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
MAJIN SUPPLER: WESTHS.	RELATIVE HUMIDITY	40% NORM	100% NORM.	FSAR SECT. 19.4.0-1 NORM.	SRS TABLE PAGE 2B	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E, PAGE 1E	
MODEL AND SERIAL: SB-1	CHEMICAL SPRAY	2000-2100 PPM BORON	3000 PPM BORON	FSAR SECT. 3.11.5.1	TEST REPORT SECT. 4.4.2 PAGE 17	COMB. TYPE TEST & SUPP. REVIEW	H	NONE	
FUNCTIONS: SAFETY INJ. & SERVICE SERVING VALVE 2SI-V5715A-1	R GAMMA	6.2ES	130 EG	FSAR APP. 3.11.8-20	TEST REPORT SEC. 4.3 PAGE 12	COMB. TYPE TEST & SUPP. REVIEW	H	SEE TAB E, PAGE 1G	
ACCUM. SPEC: N/A	D BETA	1.8E7	74 EG	CONT. RAD. ZONE C2	SRS TABLE FIG THRU 3G	COMB. TYPE TEST & SUPP. REVIEW	/	SEE TAB E, PAGE 1F	
ACCUM. DEN: N/A	T.I.D.	6.7ES	204 EG	10 CFR 50 PARAGRAPH 50.51	TEST REPORT SECT. 3.1.1 PAGE 3	COMB. TYPE TEST & SUPP. REVIEW	/	SEE TAB E, PAGE 1F	
SPECIFICATIONS: W.E. SPEC. 678852 02	AGC								
P.O. #173662 CHD # 1SH#0416	INST LIFE (PER 323-1974 DEF.)	40 YEARS	456 YEARS						
PLANT LOC.: C.B.	SUBMERGED	228.3		FSAR SECTION 3.6	N/A		/	NONE	
COORDINATES X-1455.0 Y-1644.0 Z-190.0		NO	N/A		SRS TABLE PAGE 1A		/	NONE	
INSTALLED (Y/N):	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1		
INSTALL. REF: BY FLD.	OPERABILITY	O HE-1	REFERENCES: FLOW DIAG. CAR-2165 G-810 LIMITORQUE TEST REPORT 600456				REVISION # 10 DATE 14-21-84 SYSTEM: SAFETY INJ. TAG: 2SI-V5715A-1		
QUALIF EXEMPT: N/A	TEMPERATURE	T							
QUALIF: QUALIFIED, AWAITING STATUS CONFIRMATORY DATA	PRESSURE	P							
	REL. HUMIDTY	H							
	CHEM. SPRAY	C							
	RADIATION	R							
PHYS DNG REF: CAR-2165 G-151	AGING	A							
PHYS DNG LUCI: TOTAL EQUIP. LIST	SUBMERGENCE	S							
HOUSING	FSAR ENY CAT: 1958B CATEG. 1A								
EV. DUC. LUCI: W.P.O. 173662	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO 25I-V572 SB-1	OPERABIL- ITY	140 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA			FSAR TABLE 19.4.0-1 FSAR FIG.			REPLACEMENT
MAINT ALTIME R LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 19.4.0-1 NORM FSAR SECT. 13.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL SB-1 274746	CHEMICAL SPRAY	N/A			FSAR SECT. 13.11-			
FUNCTIONS SERVING VALVE & SERVICE 25IV572 SB-1	R GAMMA A BETA D SHIELD T.I.D.	12.8 E4 17.2 E4 100% BETA 12.9 E4			FSAR FIG. 13.11B- RAD. ZONE IRI			SAFETY FUNCTIONS
ACCUM. SPEC N/A	AGE- INST LIFE (PER 323- 1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			
ACCUM. DEM. N/A PROJ. E-SPEC. 952065, R5 SPECIFICATIONS: GEN. E-SPEC.	BURNEGED	191'0"	N/A		FSAR SECT. 13.6	N/A		AUTH. REFERENCE
P.O. # 173662 CND # 1	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
PLANT LOC. A.B.01	OPERABILITY	O	REFERENCES: VENDOR DWG. 8763DB0, 1364-4482 FLOW DIAG. CAR 21659810 (M-7)				REVISION # 1 DATE 1 SYSTEM SAFETY INJECTION TAG 25I-V571 SB-1	
CORRDINATES X=1548.0 Y=1634.0 Z=190.0	TEMPERATURE	T						
INSTALLED (Y/11)	PRESSURE	P						
INSTAL. NEPS BY FIELD	REL. HUMIDTY	H						
QUALIF EXEMPTING N/A	CHEM. SPRAY	C						
QUALIF STATUS	RADIATION	R						
PHYS DNG HFF CAR 2165 9151	AGING	A						
PHYS DNG LIC I-13	NUMERUENCE	S						
MOUNTING	1958 CATEG.							
ED.DUC.LUCI w/P.O. 173662	APPENDIX E							

A/E/C (BA) UTILTY	FACILITY: BSEARCH COMPONENT EVALUAT	IS 100.1	CAPACITY: 900 MW(E)	REV: CES-			
EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/AI UNITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.		
TAG NO: 2SI-V573 SA-1	OPERABILITY	140 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	NORMAL					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM.		FSAR TABLE 9.4.0-1			REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	104°F DBA		FSAR FIG.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	ATMOS. NORM.		FSAR SECT.			SUBCOMPONENTS
MODEL AND SERIAL: SE-1 277444	CHEMICAL SPRAY	DBA NORM.		FSAR SECT.			
FUNCT. USE: SERVING VALVE & SERVICE 2SI-V573 SA-1	R GAMMA	20-90% NORM.		FSAR TABLE 9.4.0-1 NORM.			
ACCUM. SPEC: N/A	A BETA	100% DBA		FSAR SECT. 3.11.3 (DBA)			
ACCUM. DEM.: N/A	D SHIELD	N/A		FSAR SECT. 3.11-			
SPECIFICATIONS: PROJ.-E-SPEC. 952065, RS GEN.-E-SPEC. 678852, RZ	INST LIFE (PER 323-1979 DEF.)	40 YEARS		FSAR FIG. 13.11B- RAD ZONE 1R1			SAFETY FUNCTIONS
P.O. #173662 CND #1	SURGENED	191'0"	N/A	10 CFR 50 PARAGRAPH 50.51			
PLANT LOC.: A.B.01	PARAMETER			FSAR SECT. 3.6	N/A		AUTH. REFERENCE
COORDINATES X=1452.0 Y=1634.0 Z=190.0	SUPPL. REVIEW						
INSTALLED (Y/M):	OPERABILITY	O		OTHER EQUIPMENT THIS CES APPLIED TO:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INITIAL. REPT: BY FIELD	TEMPERATURE	T		REFERENCES:			
QUALIF. EXEMPT: N/A	PRESSURE	P		VENDOR DWG. 8376D80,			
QUALIFI:	REL. HUMIDTY	H		1364-4482			
STATUS:	CHEM. SPRAY	C		FLOW DIAG. CAR 2165 G 810(N-7)			
PHYS DNG EFFICAR-2165 G151	RADIATION	R					REVISION #
PHYS DNG LUCI H-4	AGING	A					DATE
MOUNTING:	IRUMMERUENCE.	S					SYSTEM SAFETY INJECTION
EN.DUC.LUCI W/P.O.173662	1950B CATEG. 1 APPENDIX E						TAG 2SI-V537 SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	OUTS	ITEMS
	PARAMETER	ACTUAL	GEN. QUALIF.	ACTUAL				
TAG NO: 2SI-V574SB-1	OPENABILITY	40 YEARS NORMAL		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP.
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.		M		REPLACEMENT
MAINT ALTERN: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.				MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE						M		SUBCOMPONENTS
MODEL AND SERIAL: SB-1 305490	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		M		
FUNCT. USE: SERVING VALVE & SERVICE 2SI-V574SB-1	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11-		N/A	N/A	
ACCUM. SPEC: N/A	R GAMMA	2.8E4		FSAR FIG. 3.11B-			H	
ACCUM. DEN.: N/A	A BETA	7.2E4		RAD. ZONE TRI				
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	D SHIELD	100% BETA						SAFETY FUNCTIONS
P.O. # 173662 CND # 1	AGE - INST LIFE	40 YEARS		10 CFR 50 (PARAGRAPH 50.51)				
PLANT LOC. I.A.T.S. 01	(PER 323-1974 DEF.)							
COORDINATES X=1548.0 Y=1626.0 Z=190.0	SURGEHEAD	191'0"	N/A	FSAR SECT. 3.6	N/A			AUTH. REFERENCES

INSTALLED (Y/N):
 INSTAL. REF: BY FIELD
 QUALIF. CRAMPIN: N/A
 QUALIF. STATUS:
 PHYS DNG REF: CAR2165 G151
 PHYS DNG LIC: I-14
 MOUNTING:
 EQ. DOC. LUC: w/P.O. 173662


PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SURGEHEAD	S
19500 CATEG.	C
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIED TO:

 REFERENCES:
 VENDOR DWG. 8378D69, 1364-4530
 FLOW DIAG. CAR 2165 G810 (E-6)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE HE-1

 REVISION # : 0
 DATE : 19-20-84
 SYSTEM : SAFETY INJECTION
 TAG : 2SI-V574SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ UITS	ITEMS
	PARAMETER	ACTUAL	DEM.	QUALIF.			
TAG NO: 2SI-V575 SA-1	OPERABILITY	40 YEARS NORMAL					ACCEL TIMES
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.		REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-		
FUNCTIONS: SERVING VALVE & SERVICE 2SI-V575 SA-1	R GAMMA	2.8E4			FSAR FIG. 3.11B-22		
ACCUM. SPEC: N/A	A BETA	7.2E4			RAD. ZONE R1		
ACCUM. DEM.: N/A	D SHIELD	100% BETA					
SPECIFICATIONS: GEN. E-SPEC. 952065, R5 678852, R2	T. I. D.	2.9E4					
P.O. # 173662 CMD # 1	AGE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		SAFETY FUNCTIONS
PLANT LOC.: AB 01	INST LIFE (PER 523-1974 DEF.)						
COORDINATES X= 1548.0 Y= 1626.0 Z= 190.0	SUBMERGED	191'0"	N/A		FSAR SECT. 3.6	N/A	AUTH. REFERENCES
INSTALLED (Y/N): INSTAL. MFP: BY FIELD QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGES
QUALIFI	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR 2165 G810 (N-10) VENDOR DWG. 1364-4530				REVISION: 0
STATUS	TEMPERATURE	T					DATE: 01/01/01
	PRESSURE	P					SYSTEM: SAFETY INJ.
	REL. HUMIDTY	H					TAG: 12SI-V575 SA-1
	CHEM. SPRAY	C					
	RADIATION	R					
PHYS DNG MFP	AGING	A					
PHYS DNG LUCI	SUBMERGENCE	S					
MOUNTING	FSAR ENV CAT:						
EV. DUC. LUCI w/ P.O. 173662	1958 CATEG.:						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M UITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL DEM. QUALIF.			
TAG NO: 2SI-V576SB-1	OPENABIL- ITY	40 YEARS NORMAL		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.		M	REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.		M	MAINTAIN
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL: SMB-1 309032	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11-	N/A	N/A	
FUNCTION: SERVING VALVE & SERVICE 2SI-V576SB-1	R GAMMA A BETA D SHIELD T.I.D.	2.0E4 7.2E4 100% BETA 3.0E4		FSAR FIG. 3.11B- RAD. ZONE RG		H	SAFETY FUNCTIONS
ACCUM. SPEC: N/A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			
ACCUM. DEM.: N/A	SUBMERGED	191'0"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCE
SPECIFICATIONS: PROJ. E-SPEC. 962065,RS GEN. E-SPEC. 67885Z,RZ							
P.O. #173662 CND # 1							
PLANT LOC.: A.B.21							
COORDINATES X= 1570.0 Y= 1632.0 Z= 236.0							

INSTALLED (Y/N):
 INSTAL. NEP: BY FIELD
 QUALIF EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG HFF: CAR 2165 G152
 PHYS DNG LIC: F-17
 MOUNTING:
 ED. DUC. LUC: w/ P.O. 173662

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMIDITY H
 CHEM. SPRAY C
 RADIATION R
 LAGING A
 SUBMERGENCE S
 1958 CATEG.: C
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 VENDOR DWG. 8378D42,
 1364-4483
 FLOW DIAG. CAR 2165 G810 (E-G)

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: HE-1

REVISION # : 0
 DATE : 9-20-84
 SYSTEM : SAFETY INJECTION
 TAG : 2SI-V576SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/ U/S	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2SI-V577SA-1	OPENABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIMES
EQUIPMENT: VALVE TYPE	NDHM/TEST DBA	1 YEAR POST DBA						ACCEL TEMPS
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.		M	REPLACEMENT
MAINTENANCE: LIMIT TORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.		M	MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11-3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL: SMB-1 309031	CHEMICAL SPRAY	N/A	N/A		FSAR SECT. 3.11-	N/A	N/A	
FUNCTION: SERVING VALVE & SERVICE 2SI-V577SA-1	R GAMMA	2.0 E4			FSAR FIG. 3.11B-		H	
ACCUM. SPEC: N/A	A BETA	7.2 E4			RAD. ZONE			
ACCUM. DEM.: N/A	D SHIELD	100% BETA			IRG			
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678862, R2	T.I.D.	3.0 E4			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
P.O. # 173662 CND # 1	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS						
PLANT LOC.: A.B.21	BURNED	19150"	N/A		FSAR SECT. 3.6	N/A	N/A	
COORDINATES X= 1525.0 Y= 1626.0 Z= 236.0								AUTH. REFERENCES

INSTALLED (Y/II):
 INSTAL. NEP: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS. Dwg. NFF: CAR2165 G152
 PHYS. Dwg. LUC: G-14
 MOUNTING:
 EV. DUC. LUC: w/ P.O. 173662

PARAMETER	SUPPL. REVIEW
OPENABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDITY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
EMERGENCY	S
10500 CATEG. 1	C
APPENDIX E	

OTHER EQUIPMENT THIS CED APPLIES TO:

 REFERENCES:
 VENDOR DWG. 8378D42,
 1364-4483
 FLOW DIAG. CAR2165 G-810 (D-6)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1

 REVISION # : 0
 DATE : 19-20-84
 SYSTEM : SAFETY INJECTION
 TAG : 2SI-V577SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEN.	QUALIF.	DOCUMENTATION		QUALIF.	M/M	OUTS	ITEMS
	PARAMETER	ACTUAL			ACTUAL	DEN.				
TAG NO: 25I-V578 SB-1	OPENABIL-ITY	140 YEARS NORMAL			OPERABILITY REVIEW					ACCEL TIME
EQUIPMENT: VALVE TYPE	INDM/TEST DBA	1 YEAR POST DBA								ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			M		REPLACEMENT
MAINTENANCE: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			M		MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			M		SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A	N/A		FSAR SECT. 3.11-		N/A	N/A		
FUNCTION: SERVING VALVE & SERVICE 25I-V578 SB-1	R GAMMA	2.0E4			FSAR FIG. 3.11B-1 RAD. ZONE RC			H		
ACCUM. SPEC: N/A	A BETA	7.2E4								
ACCUM. DEN.: N/A	D SHIELD	100% BETA								
SPECIFICATIONS: PROJ. E-SPEC. 952065, R5 GEN. E-SPEC. 678852, R2	T.I.D.	3.0E4								
P.O. #173662 CND # 1	AGE	40 YEARS			10 CFR 50 PARAGRAPH 50.51					SAFETY FUNCTIONS
PLANT LOC.: A.D. 21	INST LIFE (PER 325-1979 DEF.)									
COORDINATES X=1564.0 Y=1660.0 Z=236.0	BURNED	1910"	N/A		FSAR SECT. 3.6	N/A	N/A			AUTH. REFERENCE

INSTALLED (Y/N):
 INSTAL. KEYS BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF:
 STATUS:
 PHYS DNG OFFICAR 2165 G152
 PHYS DNG LICI C-17
 MOUNTING:
 EM.DUC.LUC: W.P.O. 173662

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
INTERFERENCE	S
19500 CATEG.	C
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES:
 VENDOR DWG. 8378D53,
 1364-4487
 FLOW DIAG. CAR 2165 G810 (E-4)

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: HE-1
 REVISION # : 0
 DATE : 9-20-84
 SYSTEM : SAFETY INJECTION
 TAG : 25I-V578 SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/A	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2SI-V5795A-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	MON/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.		M	REPLACEMENT
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.		M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)		M	SUBCOMPONENTS
MODEL AND SERIAL: SB-2 284458	CHEMICAL SPRAY	N/A	N/A		FSAR SECT. 3.11-	N/A	N/A	
FUNCTION: SERVING VALVE & SERVICE 2SI-V5795A-1	R GAMMA	2.0E4			FSAR FIG. 3.11B- RAD. ZONE R6		H	
ACCUM. SPEC: N/A	A BETA	7.2E4						
ACCUM. DEM.: N/A	D SHIELD	100% BETA						
SPECIFICATIONS: PROJ. E-SPEC. 952065.R5 GEN. E-SPEC. 678852.R2	T.I.D.	3.0E4						
P.O. # 173662 CND # 1	AGE - INST LIFE (PER 325-1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A.B.21	BURNEGED	1910°	N/A		FSAR SECT. 3.6	N/A	N/A	
COORDINATES X=1516.0 Y=1627.0 Z=236.0								AUTH. REFERENCES
INSTALLED (Y/N):	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIED TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: HE-1	
INSTALL. MFG BY FIELD	OPERABILITY	O	REFERENCES: VENDOR DWG. 8378D53, 1364-4487 FLOW DIAG. CAR 2165 9810 (C-4)				REVISION # : 0 DATE : 19-20-84 SYSTEM : SAFETY INJECTION TAG : 2SI-V5795A-1	
QUALIF EXEMPT: N/A	TEMPERATURE	T						
QUALIF:	PRESSURE	P						
STATUS:	REL. HUMIDITY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
PHYS DNG MFG: CAR 2165 9152	AGING	A						
PHYS DNG LUCI: 9-9	NUMERICAL	S						
MOUNTING:								
EN.DUC.LUCI: P.O. 173662	1958 CATEG.:	C						
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOC. QUALIF.	DOCUMENTATION		QUALIF. METHOD	N/M/UTS	ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO: 2SI-V587 SA-1	OPENABIL-ITY	140 YEARS		OPERABILITY REVIEW				ACCEL TIME
EQUIPMENT: VALVE TYPE	INDRM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104°F NORM. 104°F DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			M	REPLACEMENT
MAINT ALTHM: LIMITORQUE	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			M	MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			M	SUBCOMPONENTS
MODEL AND SERIAL: SB-2 284456	CHEMICAL SPRAY	N/A	N/A	FSAR SECT. 3.11-		N/A	N/A	
FUNCTION: SERVING VALVE & SERVICE 2SI-V587 SA-1	R GAMMA A BETA D SHIELD T.I.D.	18.9E4 NEGL. 100% BETA 1.89E5		FSAR FIG. 13.11B-IRAD. ZONE TRC			H	SAFETY FUNCTIONS
ACCUM. SPEC: N/A	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS		110 CFR 50 PARAGRAPH 50.51				
ACCUM. DEM.: N/A	BURNENGD	191'-0"	N/A	FSAR SECT. 13.6	N/A	N/A		AUTH. REFERENCE
SPECIFICATIONS: GEN. E-SPEC. 952065, R5 678852, R2	INSTALL. NEP: BY FIELD							
P.O # 173662 CND # 1	QUALIF EXEMPT: N/A							
PLANT LOC.: A.T. 21	OPERABILITY	O						
COORDINATES X= 1430.0 Y= 1627.0 Z= 245.0	TEMPERATURE	T						
INSTALLED (Y/M):	PRESSURE	P						
OTHER EQUIPMENT THIS CES APPLIES TO:	REL. HUMIDITY	H						
REFERENCES:	CHEM. SPRAY	C						
VENDOR DWG. 8378D53, 1364-4487	IRRADIATION	R						
FLOW DIAG. CAR 2165 G 810 (TS-3)	AGING	A						
REVISION # 0 DATE 19-20-84	FREQUENCY	S						
SYSTEM SAFETY INJECTION TAG 2SI-V587 SA-1	1958 CATEG. C	C						
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENTAL		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2WG-2915B-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP
COMPONENT: SOLENOID VALVE	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL #	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2WG-D2915B-1	R GAMMA A BETA D SHIELD T.I.D.				FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM.: N/A	SUBMERGED	9120'	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCED
SPECIFICATIONS: PROJ. E-SPEC. 952067,R2 GEN. E-SPEC. 678845,R1								
P.O. # 191003 CMD # 1								
PLANT LOC.: A.B.								
COORDINATES X- Y- Z-								

INSTALLED (Y/II):
 INSTAL. MFR: BY FIELD
 QUALIF. EXEMPT: N/A
 QUALIF. STATUS:
 PHYS DNG MFR:
 PHYS DNG LUC:
 MOUNTING:
 ED. DOC. LUC: P.O. 191003

PARA-METER: SUPPL. REVIEW
 OPERABILITY: O
 TEMPERATURE: T
 PRESSURE: P
 REL. HUMIDITY: H
 CHEM. SPRAY: C
 RADIATION: R
 FACING: A
 SUBMERGENCE: S
 ISAR ENV CAT: S
 ISAR CAT: S
 APPENDIX E

OTHER EQUIPMENT THIS CES APPLIES TO:

 REFERENCED: FLOW DIAG. 21659813 (D-16)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

 REVISION #:
 DATE:
 SYSTEM: WASTE GAS
 TAG: 2WG-2915B-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	W/H OUTS	ITEMS	
	PARAMETER	ACTUAL	DEM.	QUALIF.				ACTUAL
TAG NO: 2WG-D291SB-1	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT: VALVE TYPE	NDM/TEST DBA	1 YEAR POST DBA						ACCEL TEMPS
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM. 104°F DBA			FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. DBA NORM.			FSAR SECT.			MAINTAIN.
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. 100% DBA			FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL: EA170	CHEMICAL SPRAY	N/A			FSAR SECT. 3.11-			
FUNCTIONS: SERVING VALVE & SERVICE 2WG-D291SB-1	R GAMMA				FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	A BETA							
ACCUM. DEM.: N/A	D SHIELD							
SPECIFICATIONS: PROJ. E-SPEC. 952067,R2 GEN. E-SPEC. 678845,R1	T.I.D.							
P.O. #: 191003 CND # 1	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
PLANT LOC.: A.B.	(PER 323-1979 DEP.)							
COORDINATES X- Y- Z-	SURGEON	19150"	N/A		FSAR SECT. 3.6	N/A		AUTH. REFERENCES

INSTALLED (Y/II):
INITAL. NEP: BY FIELD
QUALIF. EXEMPT: N/A
STATUS:
PHYS DNG HFF:
PHYS DNG LHC:
MOUNTING:
EV. DUC. LUC: W/ P.O. 191003

PARAMETER SUPPL. REVIEW
OPERABILITY O
TEMPERATURE T
PRESSURE P
REL. HUMIDITY H
CHEM. SPRAY C
RADIATION R
FACTIO A
EMERGENCE E
ENV. CAT: A
SPEC. Y
EX. F.

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES: FLOW DIAG. 21659813 (D-16)

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

REVISION #:
DATE:
SYSTEM: WASTE GAS
TAG: 12WG-D291SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	OUTS ITEMS		
	PARAMETER	ACTUAL	DEH.	QUALIF.					ACTUAL
TAG NO: 2WG-D590SA-1	OPERABILITY	40 YEARS			OPERABILITY REVIEW			ACCEL TIME	
EQUIPMENT TYPE: VALVE DIAPH.	NORM/TEST DBA	1 YEAR POST DBA						ACCEL TEMP	
COMPONENT: SOLENOID	TEMPERATURE	120° F NORM FSAR FIG. 3.11.4-1 FOR DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		/ H	REPLACEMENT	
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA			FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1(DBA)		/ H	MAINTAIN.	
MAJOR SUPPLIER: GRINNELL	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3(DBA)		/ H	SUBCOMPONENTS	
MODEL AND SERIAL #: FT 831654	CHEMICAL SPRAY	2000-2100 PPM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1		/ H		
FUNCTIONS & SERVICE: WASTE PROC. (GAS) SERVING VALVE 2WG-D590SA-1	R GAMMA A BETA D SHIELD	1.2 EG 3.3 E7 T.I.D.			FSAR APP 3.11.B-18 CONT. RAD. ZONE C3		/ H		
ACCUR. SPEC: N/A	AGE - INST LIFE	40 YEARS			10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION	
ACCUR. DEH.: N/A	SUBMERGED	228.3 YES		N/A	FSAR SECTION		N/A /	AUTH. REFERENCE	
SPECIFICATIONS: W. PROJ. SPEC. 952067 02 W.E. SPEC. 67845 01	PARA-METER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE		
P.O. #: 191003 CHD # 15M#0563	OPERABILITY	O	REFERENCES: FLOW DIAG. CAR-2165 G-813				REVISION # : DATE : SYSTEM : WASTE PROC. (GAS) TAG : 2WG-D590SA-1		
PLANT LOC.: C.B.-21	TEMPERATURE	T							
COORDINATES X- 1507.0 Y- 1638.0 Z- 242.0	PRESSURE	P							
INSTALLED (Y/N): BY FLD.	REL. HUMIDTY	H							
QUALIF. EXEMPT: N/A	CHEM. SPRAY	C							
STATUS	RADIATION	R							
	AGING	A							
	SURVIVANCE	S							
	FSAR ENV CAT:	A							
	1988 CATEG.:								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/H	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: 2WG-D590SA-1	OPERABILITY	40 YEARS NORMAL		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT TYPE: VALVE DIAPH.	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: LIMIT SW.	TEMPERATURE	120° F NORM FSAR FIG. 3.11.4-1 FOR DBA		FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1		H	REPLACEMENT
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	MAINTAIN.
MAJOR SUPPLIER: GRINNELL	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)		H	SUBCOMPONENTS
MODEL AND SERIAL #: EA170-14302	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
FUNCTIONS & SERVICE: WASTE PROC. (GAS) SERVING VALVE 2WG-D590SA-1	R GAMMA A BETA D SHIELD	1.2 E6 3.3 E7 T.I.D.		FSAR APP. 3.11.8-18 CONT. RAD. ZONE		H	
ACCUR. SPEC: N/A	AGE - INST LIFE	40 YEARS (PER 323-1974 DEF.)		110 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTIONS
ACCUR. DEH.: N/A	SUBMERGED	228.3 YES	N/A	FSAR SECTION		N/A	AUTH. REFERENCE
SPECIFICATIONS: N. PROJ. SPEC. 952067 02 W.E. SPEC. 678845 01							
P.O. # 191003 CND # ISH # 0563							
PLANT LOC.: C.B21							
COORDINATES X-1507.0 Y-1638.0 Z-242.0							

INSTALLED (Y/N):
 INSTAL. REF: BY FLD.
 QUALIF EXEMPT: N/A
 QUALIF STATUS:
 PHYS DNG REF: CAR-2166 G450
 PHYS DNG LUG: TOTAL EQUIP. LIST
 MOUNTING: N/A
 EQ. DUC. LUG: 9.2

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
FSAR ENV CAT:	A
10588 CATEG.:	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:

REFERENCES: FLOW DIAG. CAR-2165 G-813

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

REVISION #:
 DATE:

SYSTEM: WASTE PROC. (GAS)

TAG: 2WG-D590SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH. QUALIF.	ACTUAL DEH. QUALIF.			
TAG NO: 2WL-L6005A-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW		/	ACCEL TIME
EQUIPMENT TYPE: VALVE LEVEL CONTR.	NORM/TEST DBA	1 YEAR POST DBA				/	ACCEL TEMP
COMPONENT: SOLENOID	TEMPERATURE	120°F NORM		FSAR TABLE 9.4.0-1		H	INSTALLMENT
MANUFACTURER: ASCO	FSAR FIG.	3.11.4-1		FSAR FIG. 3.11.4-1			MAINTENANCE
MAJOR SUPPLIER: COPE'S VULCAN	FOR DBA						SUBCOMPONENTS
MODEL AND SERIAL #: HT 8300864-RF	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1		FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)		H	
FUNCTION & SERVICE: WASTE PROC. (LIQUID) SERVING VALVE 2WL-L6005A-1	RELATIVE HUMIDITY	40% NORM 100% DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.4.3 (DBA)		H	
ACCUR. SPEC: N/A	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0		FSAR SECT. 3.11.5.1		H	
ACCUR. DEH.: N/A	R GAMMA A BETA D SHIELD T.I.D.			FSAR APP. 3.11.8 CONT. RAD. ZONE		H	
SPECIFICATIONS: W. PROJ. SPEC. 678959.02 W.E. SPEC. 678844.02	AGE - INST LIFE	40 YEARS		10 CFR 50 PARAGRAPH 50.51		/	SAFETY FUNCTION
P.O. #: 183622 CHD # ISH.#05621	(PER 523-1974 DEF.)						
PLANT LOC.: C.B. 11	SUBMERGED	228.3		FSAR SECTION		N/A	AUTH. REFERENCE
COORDINATES: X-1497.0 Y-1638.0 Z-230.0	YES		N/A				

INSTALLED (Y/N):
 INSTAL. REF: **BY FLD.**
 QUALIF EXEMPT: **N/A**
 QUALIF STATUS: **N/A**
 PHYS DNG REF: **TOTAL EQUIP. LIST**
 PHYS DNG LUC: **N/A**
 MOUNTING: **N/A**
 E.U.DUC. LUC: **3-2**


PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
FSAR ENV CAT	A
FSAR CATEG.	
APPENDIX E	

OTHER EQUIPMENT THIS CES APPLIES TO:
 REFERENCES: **FLOW DIAG. CAP-2165 G-813**

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 REVISION #:
 DATE:
 SYSTEM: **WASTE PROC. (LIQUID)**
 TAG: **2WL-L6005A-1**

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEH.	QUALIF.			
TAG NO: <i>RWL-LG005A-1</i>	OPERABILITY	40 YEARS NORMAL			OPERABILITY REVIEW	/	ACCEL TIME
EQUIPMENT TYPE: <i>VALVE LEVEL CONTR.</i>	NORM/TEST DBA	1 YEAR POST DBA					ACCEL TEMP
COMPONENT: <i>LIMIT SW.</i>	TEMPERATURE	120°F NORM FSAR FIG. 3.11.4-1 FOR DBA			FSAR TABLE 9.4.0-1 FSAR FIG. 3.11.4-1	/ H	REPLACEMENT
MANUFACTURER: <i>NAMCO</i>	PRESSURE	ATMOS. NORM. SEE FSAR FIG. 3.11.6-1 FOR DBA			FSAR SECT. 3.11.6 NORM. FIG. 3.11.6-1 (DBA)	/ H	MAINTAIN.
MAJOR SUPPLIER: <i>COPE'S VULCAN</i>	RELATIVE HUMIDITY	40% NORM 100% DBA			FSAR TABLE 9.4.0-1 NORM FSAR SECT. 3.11.4.3 (DBA)	/ H	SUBCOMPONENTS
MODEL AND SERIAL #: <i>DR400X</i>	CHEMICAL SPRAY	2000-2100 PRM BORON PH 8.5-11.0			FSAR SECT. 3.11.5.1	/ H	
FUNCTIONS & SERVICE: <i>WASTE PROC. (LIQUID) SERVING VALVE RWL-LG005A-1</i>	R GAMMA				FSAR APP. 3.11.8 CONT. RAD. ZONE	/ H	
ACCUR. SPEC: <i>N/A</i>	AGE-INST LIFE	40 YEARS (PER 323-1979 DEF.)			10 CFR 50 PARAGRAPH 50.51	/	SAFETY FUNCTIONS
ACCUR. DEH.: <i>N/A</i>	SUBMERGED	228.3 YES	<i>N/A</i>		FSAR SECTION	<i>N/A</i> /	AUTH. REFERENCE
SPECIFICATIONS: <i>W.P.R.J. SPEC. 678959 02 W.E. SPEC. 678844 02</i>							
P.O. # <i>483622</i> CHD # <i>ISM#0562</i>							
PLANT LOC.: <i>C.B.11</i>							
COORDINATES: <i>X-1497.0 Y-1638.0 Z-230.0</i>							

INSTALLED (Y/N): INSTAL. REF: <i>BY FLD.</i> QUALIF EXEMPT: <i>N/A</i>	PARA-METER SUPPL. REVIEW OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S FSAR ENV CAT: A FSAR CATEG: 1 APPENDIX E	OTHER EQUIPMENT THIS CES APPLIES TO: REFERENCES: <i>FLOW DIAG. CAR-21659-813</i>	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: REVISION # : DATE : SYSTEM: <i>WASTE PROC. (GAS)</i> TAG: <i>RWL-LG005A-1</i>
--	---	---	---



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/MI UITS	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO: 2WL-D650 SB-1	OPERABILITY	40 YEARS		OPERABILITY REVIEW			ACCEL TIME
EQUIPMENT VALVE TYPE	INDM/TEST DBA	NORMAL DBA					ACCEL TEMP
COMPONENT: SOLENOID V.	TEMPERATURE	104°F NORM. DBA		FSAR TABLE 9.4.0-1 FSAR FIG.			REPLACEMENT
MANUFACTURER: ASEA	PRESSURE	ATMOS. NORM. DBA NORM.		FSAR SECT.			MAINTENANCE
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM. DBA		FSAR TABLE 9.4.0-1 NORM. FSAR SECT. 3.11.3 (DBA)			SUBCOMPONENTS
MODEL AND SERIAL: FT 831654	CHEMICAL SPRAY	N/A		FSAR SECT. 3.11-			
FUNCTION: SERVING VALVE & SERVICE 2WL-D650 SB-1	R GAMMA A BETA D SHIELD T.I.D.			FSAR FIG. 3.11B-			
ACCUM. SPEC: N/A	AGE - INST LIFE (PER 323-1979 DEF.)	40 YEARS		10 CFR 50 PARAGRAPH 50.51			SAFETY FUNCTIONS
ACCUM. DEM: N/A	BURGEON	19150"	N/A	FSAR SECT. 3.6	N/A		AUTH. REFERENCES
SPECIFICATIONS: PROJ. E-SPEC. 952067, R2. GEN. E. SPEC. 678945, R1	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
P.O. #191003 END # 1	OPERABILITY	O.	REFERENCES: FLOW DIAG. 216S-9813 (D-13)				
PLANT LOC: AB.	TEMPERATURE	T					
COORDINATES X-Y-Z	PRESSURE	P					
	REL. HUMIDTY	H					
	CHEM. SPRAY	C					
	RADIATION	R					
	AGING	A					
	BURGEON	S					
INSTALLED (Y/N):	ISAN ENV CAT: 19500 CATEG. 1 APPENDIX E						REVISION #
INSTAL. MFP: BY FIELD							DATE
QUALIF EXEMPT: N/A							SYSTEM WASTE LIQUID
QUALIF:							TAG 12WL-D650 SB-1
STATUS:							
PHYS DNG MFP:							
PHYS DNG LUC:							
MOUNTING:							
EV.DUC.LUC: w/ P.O. 191003							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	N/M/OUTS ITEMS	
	PARAMETER	ACTUAL	GEN. QUALIF.	ACTUAL			
TAG NO: ZWL-DG505B-1	WEARABLE	40 YEARS		OPERABILITY			ACCEL TIME
	ITY	NORMAL		REVIEW			
EQUIPMENT VALVE TYPE	MON/TEST	1 YEAR POST					ACCEL TEMP
	ORA	DBA					
COMPONENT: LIMIT SW.	TEMPERATURE	104°F NORM.		FSAR TABLE			REPLACEMENT
		104°F DBA		9.4.0-1			
				FSAR FIG.			
MANUFACTURER: NAMCO	PRESSURE	ATMOS. NORM.		FSAR SECT.			MAINTAIN.
		DBA NORM.					
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM		FSAR TABLE			SUBCOMPONENTS
		100% DBA		9.4.0-1 NORM.			
				FSAR SECT.			
MODEL AND SERIAL #				3.11.3 (DBA)			
FUNCTION: SERVING VALVE & SERVICE	CHEMICAL SPRAY	N/A		FSAR SECT.			
				3.11-			
ACCUM. SPEC: N/A	R GAMMA			FSAR FIG.			
	A BETA			3.11B-			
	D SHIELD						
	T.I.D.						
SPECIFICATIONS: PROJ. E-SPEC. 952067, R2	AGE	40 YEARS		10 CFR 50			SAFETY FUNCTIONS
	INST LIFE (PER 325-1979 DEF.)			PARAGRAPH 50.51			
P.O. # 191003 END # 1	BURNAGED	1910"	N/A	FSAR SECT.	N/A		
				3.6			
PLANT LOC: A-13							AUTH. REFERENCES
COORDINATES X- Y- Z-							
QUALIF EXEMPT: N/A	PARAMETER	SUPPL. REVIEW	OTHER EQUIPMENT THIS CES APPLIES TO:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE
QUALIF STATUS	OPERABILITY	O	REFERENCES: FLOW DIAG. 2165 9813 (D-13)				
	TEMPERATURE	T					
	PRESSURE	P					
	REL. HUMIDITY	H					
	CHEM. SPRAY	C					
	RADIATION	R		REVISION #			
PHYS DNG HFF:	AGING	A		DATE			
PHYS DNG LUC:	EMERGENCY	S					
PHYS DNG MOUNTING							
PHYS DNG LUC: w/ P.O. 191003	ISAN ENV CAT:						
	19580 CATEG.						
	APPENDIX E						
					SYSTEM: WASTE LIQUID		
					TAG: ZWL-DG505B-1		

SYSTEM # & NAME: 0050-AC POWER DISTR.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
480V MCC# 1A21- SA	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1461.0 1615.0 286.0	H	A	SS		2685	00
480V MCC# 1A22- SA	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB21	1545.0 1769.0 236.0	H	A	SS		2686	00
480V MCC# 1A31- SA	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1473.0 1619.0 286.0	H	A	SS		2688	00
480V MCC# 1A34- SA	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1474.0 1633.0 286.0	H	A	SS		2690	00
480V MCC# 1A36- SA	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB51	1628.0 1670.0 305.0	H	A	SS		2692	00
480V MCC# 1B21- SB	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1537.0 1615.0 286.0	H	A	SS		2693	00
480V MCC# 1B31- SB	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1527.0 1618.0 286.0	H	A	SS		2696	00
480V MCC# 1B34- SB	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB41	1527.0 1630.0 286.0	H	A	SS		2698	00
480V MCC# 1B36- SB	SEE NOTE (1)) OFCES	DISTRIBUTES AC POWER	GOULD	SERIES 5600	AB51	1595.0 1660.0 305.0	H	A	SS		2700	00

24-12070220

SYSTEM # & NAME: AFO019-AUXILIARY

FEEDWTR

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACT'JR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
CP AUX FW P 1x-SAB	CONTROL PANEL	LATER	TERRY	LATER	AB21	1525.0 1520.0 236.0	H	A	CRHR		2318	00
PT 1AF 2170 SB	PRESSURE TRANSMITTER	AUX FW TURB P DISCH PRES	ROSEMOUNT	1153699	AB21	1508.0 1545.0 236.0	H	A	CRHR		0212	00
PT 1AF 2250A SA	PRESSURE TRANSMITTER	AUX FW PMP SUCT PRES	ROSEMOUNT	1153687	AB21	1475.0 1528.0 236.0	H	A	CRHR		0227	00
PT 1AF 2250B SB	PRESSURE TRANSMITTER	B AUX FW PMP SUCT PRES	ROSEMOUNT	1153687	AB21	1492.0 1545.0 236.0	H	A	CRHR		0228	00
PT 1AF 2270 SB	PRESSURE TRANSMITTER	AUX FW TURB P SUCT PRES	ROSEMOUNT	1153687	AB21	1508.0 1545.0 236.0	H	A	CRHR		0232	00
P1X-SAB AUX FW TD	AUX. FEED PUMP TURBIN	DRIVER OF TURBINE OPER AUX FEED PUMP	TERRY CORP	GS-2M	AB21	1520.0 1529.0 236.0	H	A	CRHR		2116	00
3AF-P1SA-1	HYDRA MOTOR	LATER	ITT HANDEL DAHL/CONJFL	LATER	AB21	1484.0 1521.0 248.0	H	A	CRHR		3214	00
3AF-P1SA-1	LIMIT SWITCH HW1(1 OF 2)	LATER	ITT HANDEL DAHL/CONJFL	LATER	AB21	1484.0 1521.0 248.0	H	A	CRHR		3215	00
3AF-P1SA-1	LIMIT SWITCH HW2(2 OF 2)	LATER	ITT HANDEL DAHL/CONJFL	LATER	AB21	1484.0 1521.0 248.0	H	A	CRHR		5130	00
3AF-P2SB-1	HYDRA MOTOR	AUX FEED PUMPS MOTOR 1B-SB OUTLET	ITT HANDEL DAHL/C7	NM72K6002 FIL218	AB21	1499.0 1520.0 248.0	H	A	CRHR		3216	00
3AF-P2SB-1	LIMIT SWITCH HW2(2 OF 2)	LATER	ITT HANDEL DAHL/CONJFL	LATER	AB21	1499.0 1520.0 248.0	H	A	CRHR		3217	00
3AF-P2SB-1	LIMIT SWITCH HW2(2 OF 2)	LATER	ITT HANDEL DAHL/CONJFL	LATER	AB21	1499.0 1520.0 248.0	H	A	CRHR		5131	00

TAGS INCLUDED: CP AUX FW P 1x-----3AF-P2SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: AF0019-AUXILIARY

FEEDWTR

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACT'JR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3AF-V187SA-1	MOTOR OPERATOR	LATER	LIMITORQUE	S43-00-15	AB21	1478.0 1533.0 236.0	H	A	CRHR		3218	00
3AF-V188SB-1	MOTOR OPERATOR	AUX FEED PUMP 1B-SB RECIRC TO COND STOR	LIMITORQUE	S49-00-15	AB21	1493.0 1533.0 236.0	H	A	CRHR		3220	00
PIA-SA AUX FW	AUX. FEED PUMP MOTOR	DRIVER OF MOTOR OPER. AUX. FEED PUMP.	WESTING-HOUSE	FRAME 5810H	AB 21	1488.0 1523.0 236.0	H	A	CRHR		2105	00
PIB-SB AUX FW	AUX FEED.	DRIVER OF MOTOR OPER. AUX FEED PUMP	WESTING-HOUSE	FRAME 5810H	AB 21	1504.0 1523.0 236.0	H	A	CRHR		2111	00



SYSTEM # & NAME: 800023-BLOWDOWN

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
PT 18D 8405A2 B	S PRESSURE TRANSMITTER	STM GEN 1A RAB LINE LEAK DET	ROSEMOUNT	1153GB9	AB21	1552.0 1520.0 236.0	H	A	CI		1018	00
PT 18D 8405B1 A	S PRESSURE TRANSMITTER	STM GEN 1B RAB LINE BREAK DET	ROSEMOUNT	1153GB9	AB21	1502.0 1626.0 236.0	H	A	CI		1023	00
PT 18D 8405B2 B	S PRESSURE TRANSMITTER	STM GEN 1B RAB LINE BREAK DET	ROSEMOUNT	1153GB9	AB21	1552.0 1520.0 236.0	H	A	CI		1021	00
PT 18D 8405C1 A	S PRESSURE TRANSMITTER	STM GEN 1C RAB LINE BREAK DET	ROSEMOUNT	1153GB9	AB21	1575.00 1676.00 236.0	H	A	CI		1020	00
PT 18D 8405C2 B	S PRESSURE TRANSMITTER	STM GEN 1C RAB LINE BREAK DET	ROSEMOUNT	1153GB9	AB21	1552.0 1520.0 236.0	H	A	CI		1022	00
28D-V11SA-1	SOLENOID VALVE	S/G A BLDWN TO ISOLATION VAV 28D-V11SN	ASCO	MP3320A185E	AB21	1426.0 1688.0 255.0	H	A	CI	*	2826	00
28D-V11SA-1	LIMIT SWITCH	LATER H (1 OF 2)	NAMCO	EA-180-1130 2	AB21	1426.0 1688.0 255.0	H	A	CI	*	2827	00
28D-V11SA-1	LIMIT SWITCH	LATER H (2 OF 2)	NAMCO	EA-180-1130 2	AB21	1426.0 1688.0 255.0	H	A	CI	*	5089	00
28D-V15SA-1	SOLENOID VALVE	S/G B BLDWN TO ISOLATION VLV 28D-V15SN	ASCO	MP3320A185E	AB21	1494.0 1623.0 253.0	H	A	CI	*	2828	00
28D-V15SA-1	LIMIT SWITCH	S/G B BLDWN TO ISOLATION VLV 28D-V15SN	NAMCO	EA-180-1130 2	AB21	1494.0 1623.0 253.0	H	A	CI	*	2829	00
28D-V15SA-1	LIMIT SWITCH	S/G B BLDWN TO ISOLATION VLV 28D-V15SN	NAMCO	EA-180-1130 2	AB21	1494.0 1623.0 253.0	H	A	CI	*	5090	00
28D-V19SA-1	SOLENOID VALVE	FAIL CLOSE	ASCO	MP-3320A185E	AB21	1574.0 1689.0 255.0	H	A	CI	*	2830	00

TAGS INCLUDED: PT 18D 8405A2 S---28D-V19SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SHEARON HARPIS 1 - MASTER LIST

PAGE NO- 73

SYSTEM # & NAME: BD0023-BLOWDOWN

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X, Y, Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
280-V195A-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB21	1574.0 1689.0 255.0	H	A	CI	•	2831	00
280-V195A-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA-180-1130 2	AB21	1574.0 1689.0 255.0	H	A	CI	•	5088	00

SYSTEM # & NAME : 0174- CHLORINE LEAK DETECTION

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X, Y, Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AE-1CZ-7816-A1-SA	PROBE UNIT	MONITOR CHLORINE LEAKAGE	ANACON	LATER	TA11	1381.0 1521.0 308.0	H	A	SS		0896	00
AE-1CZ-7816-B1-SB	PROBE UNIT	MONITOR CHLORINE LEAKAGE	ANACON	LATER	TA11	1381.0 1518.0 310.0	H	A	SS		0898	00
AE 1CZ 7829A SA	PROBE UNIT	CNTRL RM NRHL OAI CHLORINE DET	ANACON	LATER	AB51	1596.0 1676.0 308.0	H	A	SS		0970	00
AE 1CZ 7829B SB	PROBE UNIT	CNTRL RM NRHL OAI CHLORINE DET	ANACON	LATER	AB51	1594.0 1676.0 309.0	H	A	SS		0969	00

SYSTEM # R NAME: SE0034-CNTRL BOARDSR PNL(I&C)

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
A1-C7-ESF-A	TERMINAL BL OCK	LATER	GE	LATER	AB31	1435.0 1660.0 261.0	H	A	SS		2477	00
A1-C7-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB31	1565.0 1660.0 261.0	H	A	SS		4086	00
A1-R1-ESF-A	TERMINAL BL OCK	LATER	GE	LATER	AB11	1527.0 1624.0 216.0	H	A	SS		3891	00
A1-R11-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB21	1584.0 1529.0 236.0	H	A	SS		2314	00
A1-R29-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB21	1508.0 1545.0 236.0	H	A	SS		4056	00
A1-R30-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB21	1531.0 1568.0 236.0	H	A	SS		4057	00
A1-R31-ESF-A	TERMINAL BL OCK	LATER	GE	LATER	AB11	1414.0 1609.0 216.0	H	A	SS		2315	00
A1-R32-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB11	1584.0 1613.0 216.0	H	A	SS		4058	00
A1-R35-ESF-P	TERMINAL BL OCK	LATER	GE	LATER	AB21	1620.0 1568.0 236.0	H	A	SS		4060	00
A1-R4-ESF-A	TERMINAL BL OCK	LATER	GE	LATER	AB11	1414.0 1630.0 216.0	H	A	SS		4061	00
A1-R41-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB21	1552.0 1520.0 236.0	H	A	SS		4062	00
A1-R5-ESF-B	TERMINAL BL OCK	LATER	GE	LATER	AB11	1584.0 1622.0 216.0	H	A	SS		4063	00

TAGS INCLUDED: A1-C7-ESF-A ---A1-R5-ESF-B
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME:EE0084-CTRL BOARD& PNL(IRC)

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
CP 21AV-3509SA		LATER		RY FIELD	AB51		H	A			4076	00
ISOL-TRANM RACK A1-R45A	LATER	LATER	LATER	LATFR	AB21	1571.0 1710.0 236.0	H	A	SS		4925	00
ISOL-TRANM RACK A1-R45B	LATER	LATER	LATER	LATER	AB21	1581.0 1687.0 236.0	H	A	SS		4926	00

SYSTEM # & NAME:CC0014-COMP.COOLING WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
FS 1CC 7001A SA	304,316 SST	CLG WTR TO RCP OIL COOLER	FLUID COMP RTMENTS	12-64-4	AB21	1577.0 1658.0 243.6	H	A	CI		3936	00
FS 1CC 7001B SB	304,316 SST	CLG WTR TO RCP OIL COOLER	FLUID COMP RTMENTS	12-64-4	AB21	1577.0 1641.0 243.6	H	A	CI		3941	00
REM 1CC3501A SA	RADIATION MONITOR SKID	COMP COOLING WATER RAD	GENERAL ATOMIC	94-80	AB21	1415.0 1521.0 236.0	H	A	CI		0245	00
REM 1CC3501B SB	RADIATION MONITOR SKID	COMP COOLING WATER RAD	GENERAL ATOMIC	94-80	AB21	1560.0 1521.0 236.0	H	A	CI		0246	00
3CC-V285SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-D14	AB21	1421.0 1540.0 236.0	H	A	CI		3588	00
3CC-V287SB-1	SOLENOID VALVE	LATER	TARGET ROCK	792-D14	AB21	1544.0 1533.0 237.0	H	A	CI		3589	00

SYSTEM # & NAME: CPU061-CONT. ATMOSPHERE PRG/MKUP

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTURER	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CP-B2SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA-180-31302	AB21	1430.0 1665.0 255.0	H	A	CI	*	2133	00
2CP-B2SB-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	4721C-SR60-12	AB21	1430.0 1665.0 255.0	H	A	CI	*	2134	00
2CP-B2SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	4P3321A6E	AB21	1430.0 1665.0 255.0	H	A	CI	*	2135	00
2CP-B2SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA-180-32302	AB21	1430.0 1665.0 255.0	H	A	CI	*	4168	00
2CP-B4SR-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA-180-31302	AB21	1429.0 1664.0 255.0	H	A	CI	*	2139	00
2CP-B4SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA-180-32302	AB21	1429.0 1664.0 255.0	H	A	CI	*	4170	00
2CP-B4SB-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	4720-SR-4-12-5	AB21	1429.0 1664.0 255.0	H	A	CI	*	2140	00
2CP-B4SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE FOR PNEUMATIC OPERATOR	ASCO	4P33166SE	AB21	1429.00 1664.00 255.0	H	A	CI	*	2141	00
2CP-B6SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA180-31302	AB21	1573.0 1718.0 244.0	H	A	CI	*	2145	00
2CP-B6SB-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	4721C-SR60-12	AB21	1573.0 1718.0 244.0	H	A	CI	*	2146	00
2CP-B6SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE FOR PNEUMATIC OPERATOR	ASCO	4P3321A6E	AB21	1573.00 1718.00 244.0	H	A	CI	*	2147	00
2CP-B6SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	HAMCO	EA-180-32302	AB21	1573.0 1718.0 244.0	H	A	CI	*	4172	00

TAGS INCLUDED: 2CP-B2SB-1 ---2CP-B6SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CP0061-CONT. ATMOSPHERE PRG/MKUP

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CP-88SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	NAMCO	FA-1A0-3130 2	AB21	1574.0 1718.0 244.0	H	A	CI	*	2151	00
2CP-88SB-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	NT320-SR-4-12-S	AB21	1574.0 1718.0 244.0	H	A	CI	*	2152	00
2CP-88SB-1	SOLENOID VALVE	CONTROL AIR PRESS FOR PNEUMATIC OPERATOR	ASCO	40-83166SE	AB21	1574.0 1718.0 244.0	H	A	CI	*	2153	00
2CP-88SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION IO	NAMCO	FA-1A0-3230 2	AB21	1574.0 1718.0 244.0	H	A	CI	*	4174	00

SYSTEM # & NAME: C30125-CONT. VACUUM RELIEF

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
CB-D1SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1396.0 1641.0 295.0	H	A	PRRM		1900	00
CB-D1SA-1	PNEUMATIC OPERATOR	HOLD DAMPER ON REQUIRED POSITION	BETTIS	CB-415SR	AB41	1396.0 1641.0 295.0	H	A	PRRM		1901	00
CB-D1SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB41	1396.0 1641.0 295.0	H	A	PRRM		1902	00
CB-D1SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1396.0 1641.0 295.0	H	A	PRRM		5043	00
CB-D2SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1573.0 1686.0 295.0	H	A	PRRM		1903	00
CB-D2SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-415SR	AB41	1573.0 1686.0 295.0	H	A	PRRM		1904	00
CB-D2SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB41	1573.0 1686.0 295.0	H	A	PRRM		1905	00
CB-D2SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1573.0 1686.0 295.0	H	A	PRRM		5044	00
PDT 1CB7680A SA	PRESSURE TRANSMITTER	CONT OUTSIDE DIFF PRESS. S. A	GOULD	LATER	AB41	1470.0 1635.0 291.0	H	A	PRRM		0892	00
PDT 1CB7680B SB	PRESSURE TRANSMITTER	CONT OUTSIDE DIFF PRESS. S. B	GOULD	LATER	AB41	1564.0 1666.0 291.0	H	A	PRRM		0893	00
PS 1CB 7682A SA	PRESS. ELECT. SWITCH	LOW PRESSURE SIGNAL FOR ACCUMULATR TANK TK	LATER	LATER	AB41	1462.0 1634.0 295.0	H	A	PRRM		2118	00
PS 1CB 7682B SB	PRESS. ELECT. SWITCH	LOW PRESSURE SIGNAL FOR ACCUMULATR TANK	LATER	LATER	AB41	1575.0 1686.0 295.0	H	A	PRRM	*	2122	00

TAGS INCLUDED: CB-D1SA-1 -----PS 2CB 7682B SB
SORT TYPE: GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: C90125-CONT. VACUUM RELIEF

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CB-B1SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION	NAMCO	EA-180-3130-2	AB41	1462.0 1634.0 295.0	H	A	PRRM	*	2115	00
2CB-B1SA-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	MT-3169-SR2-12	AB41	1462.0 1634.0 295.0	H	A	PRRM	*	2116	00
2CB-B1SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE FOR PNEUMATIC OPERATOR	ASCO	MP3316SE	AB41	1462.0 1634.0 295.0	H	A	PRRM	*	2117	00
2CB-B1SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180-3230-2	AB41	1462.0 1634.0 295.0	H	A	PRRM	*	5054	00
2CB-B2SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180-3230-2	AB41	1575.0 1686.0 295.0	H	A	PRRM	*	5055	00
2CB-B2SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF VALVE POSITION	NAMCO	EA180-31302	AB41	1575.0 1686.0 295.0	H	A	PRRM	*	2119	00
2CB-B2SB-1	PNEUMATIC OPERATOR	ACTUATE VALVE AND CONTROL POSITION	BETTIS	MT-3168-SR2-12	AB41	1575.0 1686.0 295.0	H	A	PRRM	*	2120	00
2CB-B2SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE FOR PNEUMATIC OPERATOR	ASCO	MP3316RE	AB41	1575.0 1686.0 295.0	H	A	PRRM	*	2121	00



SYSTEM # & NAME: CT0007-CONTAINMENT SPRAY

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
FT 1CT 7122A SA	FLOW TRANSMITTER	CNMT SPRAY FLOW	ROSEMOUNT	1153DB5	AB21	1458.0 1627.0 240.0	H	A	CI		3965	00
FT 1CT 7122B SB	FLOW TRANSMITTER	CNMT SPRAY FLOW	ROSEMOUNT	1153DB5	AB21	1459.0 1627.0 240.0	H	A	CI		3966	00
FT 1CT 7152 SB	FLOW TRANSMITTER	CNMT SPRAY ADDITIVE FLOW	ROSEMOUNT	1153DB4	AB11	1528.0 1602.0 217.0	H	A	CI		0849	00
LIT 1CT7160A SA	LEVEL TRANSMITTER	CS CONT SUMP A LVL	TRANSAMERICA-DELAVAL	RE-36562	AB31	1435.0 1660.0 261.0	H	A	CI		4483	00
LIT 1CT7160B SB	LEVEL TRANSMITTER	CS CONT SUMP B LVL	TRANSAMERICA-DELAVAL	RE-36562	AB31	1565.0 1660.0 261.0	H	A	CI	*	0855	00
LIT 1CT7161A SA	LEVEL TRANSMITTER	CONTAINMENT WTR LEVEL (NARROW RANGE)	TRANSAMERICA-DELAVAL	RE-36562	AB31	1435.0 1660.0 261.0	H	A	CI		4484	00
LIT 1CT7161B SB	LEVEL TRANSMITTER	CONTAINMENT WTR LEVEL (NARROW RANGE)	TRANSAMERICA-DELAVAL	RE-36562	AB31	1565.0 1660.0 261.0	H	A	CI		0859	00
LIT 1CT7162A SA	LEVEL TRANSMITTER	CONTAINMENT WTR LEVEL (WIDE RANGE)	TRANSAMERICA-DELAVAL	RE-36562	AB31	1435.0 1660.0 261.0	H	A	CI	*	0867	00
LIT 1CT7162B SB	LEVEL TRANSMITTER	CONTAINMENT WTR LEVEL (WIDE RANGE)	TRANSAMERICA-DELAVAL	RE-36562	AB31	1565.0 1660.0 261.0	H	A	CI	*	0868	00
LT 1CT 7150 SA	LEVEL TRANSMITTER	CNMT SPRAY ADDITIVE TANK LEVEL	ROSEMOUNT	1153DB4	AB11	1504.0 1611.0 216.0	H	A	CI	*	0846	00
PT 1CT 7131A SA	PRESSURE TRANSMITTER	CNMT SPRAY PMP A DISCHARGE PRESS	ROSEMOUNT	1153GB2	AB31	1414.0 1630.0 261.0	H	A	CI		0837	00
PT 1CT 7131B SB	PRESSURE TRANSMITTER	CNMT SPRAY PMP B DISCHARGE PRESS	ROSEMOUNT	1153GB2	AB31	1584.0 1622.0 261.0	H	A	CI		0838	00

TAGS INCLUDED: FT 1CT 7122A SA----P1B-SB CT SP HT
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CT0007-CONTAINMENT SPRAY

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2CT-V145SB-1	MOTOR OPERATOR	LATER	LIMITORQUE	S43-00-15	AB11	1522.0 1603.0 219.0	H	A	CI		2892	00
2CT-V25A-1	MOTOR OPERATOR	LATER	LIMITORQUE	S43-000	AB11	1451.0 1606.0 219.0	H	A	CI		2922	00
2CT-V21SA-1	MOTOR OPERATOR	ISOLATION VALVE	LIMITORQUE	S9-00	AB21	1466.0 1637.0 251.0	H	A	CI		2924	00
2CT-V25SA-1	MOTOR OPERATOR	INLET ON RWST 1X-SAB INLET FROM PUMP 1A-SA	LIMITORQUE	S43-00	AB21	1432.0 1608.0 238.0	H	A	CI		2926	00
2CT-V35SB-1	MOTOR OPERATOR	LATER	LIMITORQUE	S43-000	AB11	1530.0 1606.0 219.0	H	A	CI		2928	00
2CT-V43SB-1	MOTOR OPERATOR	ISOLATION VALVE	LIMITORQUE	S9-00	AB21	1536.0 1637.0 251.0	H	A	CI		2930	00
2CT-V49SB-1	MOTOR OPERATOR	INLET ON RWST 1X-SAB INLET FROM PUMP 1B-SB	LIMITORQUE	S43-00	AB21	1568.0 1609.0 238.0	H	A	CI		2932	00
2CT-V8SA-1	MOTOR OPERATOR	LATER	LIMITORQUE	S43-00-15	AB11	1526.0 1603.0 219.0	H	A	CI		2938	00
3CT-V85SA-1	MOTOR OPERATOR	CONN BETWEEN 3 CT2-26SAB-1 & 3CT2-33SAB-1	LIMITORQUE	S43-00-15	AB11	1519.0 1603.0 219.0	H	A	CI		3262	00
3CT-V88SB-1	MOTOR OPERATOR	CONN BETWEEN 3 CT2-26SAB-1 & 3CT2-33SAB-1	LIMITORQUE	S43-00-15	AB11	1515.0 1603.0 219.0	H	A	CI		3264	00
PIA-SA CT	CONT SPRAY PUMP MOTOR	DRIVER OF CONT. SPRAY PUMP	WESTINGHOUSE	LATE R	AB01	1444.0 1444.0 190.0	H	A	CI		2107	00
PIB-CP CT	CONT SPRAY PUMP MOTOR	DRIVER OF CONT. SPRAY PUMP	WESTINGHOUSE	LATE R	AB01	1565.0 1444.0 190.0	H	A	CJ		3268	00

SYSTEM # 3 NAME: C20064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AH-15(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB51	1614.0 1580.0 305.0	H	A	SS		1556	00
AH-15(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB51	1610.0 1663.0 305.0	H	A	SS		1556	00
AS 1CZ 7829A SA	ANALYSIS SW ITCH	CNTL RM NRML O A1 CHLORINE DET	ANACON	LATER	AB51	1620.0 1671.0 310.0	H	A	SS		0974	00
AS 1CZ 7829B SB	ANALYSIS SW ITCH	CNTL RM NRML O A1 CHLORINE DET	ANACON	LATER	AB51	1618.0 1669.0 310.0	H	A	SS		0973	00
CP EHC24 1X-SA RAB	CONTROL PAN EL	LATER	BRASCH	LATER	AB51	1602.0 1669.0 305.0	H	A	SS		2323	00
CP EHC26 1X-SB RAB	CONTROL PAN EL	LATER	BRASCH	LATER	AB51	1621.0 1660.0 305.0	H	A	SS		2324	00
CP E6 1B SB F D ET	FIRE DET.PA NEL	LATER	BRASCH	LATER	AB31	1582.0 1740.0 261.0	H	A	SS		2332	00
CP-EHC-72(1A-SA)	HEATER CONT ROL PANEL	MAINTAIN REL. HUMIDITY & TEM P.OF AIR	BRASCH	XS-78-09579	AB51	1627.0 1692.0 305.0	H	A	SS		2006	00
CP-EHC-72(1B-SB)	HEATER CONT ROL PANEL	MAINTAIN REL. HUMIDITY & TEM P.OF AIR	BRASCH	XS-78-09579	AB51	1631.0 1692.0 305.0	H	A	SS		2008	00
CZ-D1SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITI ON OF DAMPER	ITT	NH-95	AB51	1606.0 1674.0 314.0	H	A	SS		1930	00
CZ-D1SA-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB51	1606.0 1674.0 314.0	H	A	SS		1931	00
CZ-D1SA-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	FA-180	AB51	1606.0 1674.0 314.0	H	A	SS		5121	00

TAGS INCLUDED: AH-15(1A-SA) ----CZ-D1SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: CZ0064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
CZ-D10SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	WH-91	AB51	1641.0 1667.0 315.0	H	A	SS		1932	00
CZ-D10SB-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1641.0 1667.0 315.0	H	A	SS		1933	00
CZ-D10SB-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1641.0 1667.0 315.0	H	A	SS		5120	00
CZ-D19SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	WH-96	AB51	1626.0 1657.0 305.0	H	A	SS		1941	00
CZ-D19SA-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1626.0 1657.0 305.0	H	A	SS		1942	00
CZ-D19SA-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1626.0 1657.0 305.0	H	A	SS		5119	00
CZ-D25SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	WH-96	AB51	1606.0 1667.0 314.0	H	A	SS		1943	00
CZ-D25SB-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1606.0 1667.0 314.0	H	A	SS		1944	00
CZ-D25SB-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1606.0 1667.0 314.0	H	A	SS		5114	00
CZ-D20SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	WH-96	AB51	1626.0 1655.0 305.0	H	A	SS		1945	00
CZ-D20SB-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1626.0 1655.0 305.0	H	A	SS		1946	00
CZ-D20SB-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB51	1626.0 1655.0 305.0	H	A	SS		5115	00

TAGS INCLUDED: CZ-D10SB-1 ---CZ-D20SB-1
SORT TYPE: GLOBAL REV#- U 09/05/84

SYSTEM # & NAME: CZ0064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
CZ-D23SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	44-96	AB51	1645.0 1655.0 305.0	H	A	SS		1947	00
CZ-D23SA-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF POSITION	NAMCO	EA-1R0	AB51	1645.0 1655.0 305.0	H	A	SS		1948	00
CZ-D23SA-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB51	1645.0 1655.0 305.0	H	A	SS		5116	00
CZ-D24SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	44-95	AB51	1645.0 1653.0 305.0	H	A	SS		1949	00
CZ-D24SB-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB51	1645.0 1653.0 305.0	H	A	SS		1950	00
CZ-D24SB-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB51	1645.0 1653.0 305.0	H	A	SS		5117	00
CZ-D9SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	44-91	AB51	1638.0 1672.0 314.0	H	A	SS		1955	00
CZ-D9SA-1	LIMIT SWITCH H (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB51	1638.0 1672.0 314.0	H	A	SS		1956	00
CZ-D9SA-1	LIMIT SWITCH H (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB51	1638.0 1672.0 314.0	H	A	SS		5118	00
E/I 1CZ3504A	VOLT OR DIRECT IN	ELECTRICAL CONTROL ROOM NORM OUTSIDE AIR INTAKE RAD	GENERAL MIC	ATO/LATER	AB51	1594.0 1669.0 309.0	H	A	SS		1979	00
E/I 1CZ 3504A	CURRENT TRANSMITTER	LATER	GENERAL MIC	ATO/LATER	AB51	1594.0 1663.0 305.0	H	A	SS		4902	00
E/I-1CZ-3504B	CURRENT TRANSMITTER	LATER	GENERAL MIC	ATO/LATER	AB51	1606.0 1696.0 305.0	H	A	SS		4903	00

TAGS INCLUDED: CZ-D23SA-1 ----E/I-1CZ-3504B-S
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: C20064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M CATEG.	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
EHC-24(1X-SA)	ELECTRIC HEATING COIL	MAINTAIN REL. HUMIDITY & TEMP. OF AIR	BRASCH	LATER	AB51	1614.0 1680.0 305.0	H	A	SS		1997	00
EHC-26(1X-SB)	ELECTRIC HEATING COIL	MAINTAIN REL. HUMIDITY & TEMP. OF AIR	BRASCH	LATER	AB51	1611.0 1662.0 305.0	H	A	SS		1999	00
EHC-72(1A-SA)	ELECTRIC HEATING COIL	MAINTAIN REL. HUMIDITY & TEMP. OF AIR	BRASCH	XS-7A-09579	AB51	1627.0 1692.0 305.0	H	A	SS		2005	00
EHC-72(1B-SB)	ELECTRIC HEATING COIL	MAINTAIN REL. HUMIDITY & TEMP. OF AIR	BRASCH	XS-7B-09579	AB51	1631.0 1692.0 305.0	H	A	SS		2007	00
FT 1CZ 7817A SA	FLOW TRANSMITTER	POST ACCIDENT OA1 FLOW	GOULD	LATER	AB51	1626.0 1655.0 310.0	H	A	SS		0908	00
FT 1CZ 7817B SB	FLOW TRANSMITTER	POST ACCIDENT OA1 FLOW	GOULD	LATER	AB51	1626.0 1665.0 310.0	H	A	SS		0907	00
FT 1CZ 7819A SA	FLOW TRANSMITTER	EMER FLTR FAN R2 (1A-SA) DISCH FLOW	GOULD	LATER	AB51	1630.0 1696.0 317.0	H	A	SS		0915	00
FT 1CZ 7819B SB	FLOW TRANSMITTER	EMER FLTR FAN R2 (1B-SB) DISCH FLOW	GOULD	LATER	AB51	1637.0 1694.0 310.0	H	A	SS		0916	00
PDT 1CZ7823A SA	PRESSURE TRANSMITTER	CNTL RM EMER FLTR HEPAFLTR DIFF PRES	ROSEMOUNT	11530	AB51	1623.0 1687.0 308.0	H	A	SS		0936	00
PDT 1CZ7827A SA	PRESSURE TRANSMITTER	CNTL RM EMER FLTR OVERALL DIFF PRES	ROSEMOUNT	11530	AB51	1638.0 1687.0 308.0	H	A	SS		0961	00
R-2 (1A-SA)	DOOR SWITCH (1 OF 4)	REMOTE INDICATION OF DOOR POSITION	HAMCO	EA-180-1130	AB51	1620.0 1693.0 305.0	H	A	SS		2060	00
R-2 (1A-SA)	MOTOR	DRIVE FAN	RELIANCE LEC. CO	ERM INSULATION	AB51	1620.0 1693.0 305.0	H	A	SS		2061	00

TAGS INCLUDED: EHC-24(1X-SA) ---R-2 (1A-SA)

SORT TYPE:

GLOBAL REV#- 0 09/05/94

SYSTEM # & NAME: C20C64-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
R-2 (1A-SA)	ELECTRO-HYDR OPERATOR	OPERATE INLET VANES REGULATE FAN VOLUME	ITT	NH-94	AB51	1620.0 1693.0 305.0	H	A	SS		2062	00
R-2 (1A-SA)	DOOR SWITCH (2 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1620.0 1693.0 305.0	H	A	SS		5125	00
R-2 (1A-SA)	DOOR SWITCH (3 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1620.0 1693.0 305.0	H	A	SS		5126	00
R-2 (1A-SA)	DOOR SWITCH (4 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1620.0 1693.0 305.0	H	A	SS		5127	00
R-2 (1B-SB)	DOOR SWITCH (1 OF 4)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180-1130 2	AB51	1634.0 1693.0 305.0	H	A	SS		2063	00
R-2 (1B-SB)	MOTOR	DRIVE FAN	RELIANCE ELECTRIC	EIRN INSULATION	AB51	1634.0 1693.0 305.0	H	A	SS		2064	00
R-2 (1B-SB)	ELECTRO-HYDR OPERATOR	OPERATE INLET VANES-REGULATE FAN VOLUME	ITT	NH-94	AB51	1634.0 1693.0 305.0	H	A	SS		2065	00
R-2 (1B-SB)	DOOR SWITCH (2 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1634.0 1693.0 305.0	H	A	SS		5122	00
R-2 (1B-SB)	DOOR SWITCH (3 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1634.0 1693.0 305.0	H	A	SS		5123	00
R-2 (1B-SB)	DOOR SWITCH (4 OF 4)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-1130 2	AB51	1634.0 1693.0 305.0	H	A	SS		5124	00
RE 1CZ 3504A SA	RADIATION PRIMARY ELEMENT	CONTROL ROOM NORM OPERATIONAL AIR INTAKE RAD	GENERAL ATOMIC	LATER	AB51	1599.0 1681.0 309.0	H	A	SS		0249	00
RE 1CZ 3504B SB	RADIATION PRIMARY ELEMENT	CONTROL ROOM NORM OPERATIONAL AIR INTAKE RAD	GENERAL ATOMIC	LATER	AB51	1608.0 1692.0 308.5	H	A	SS		0443	00

TAGS INCLUDED: R-2 (1A-SA) ---RE 1CZ 3504B SB
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # 3 NAME: CZ0064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODFL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
RM 1CZ 3504A SA	MICROPROCES SOR	CNTL RM NORM O UTSDEAIR INTAK E RAD	GENERAL ATOMIC	LATER	AB51	1594.0 1669.0 309.0	H	A	SS		0250	00
RM 1CZ 3504B SP	MICROPROCES SOR	CNTL RM NORM O UTSDEAIR INTAK E RAD	GENERAL ATOMIC	LATER	AB51	1604.0 1694.0 309.0	H	A	SS		0251	00
TE 1CZ 7821A SA	TEMPERATURE PRIMARY EL	CNTL RM EMER F LTR EHC INLET TEMP	COMAX	2310-9458-0 1	AB51	1634.0 1691.0 310.0	H	A	SS		0919	00
TE 1CZ 7824A SA	TEMPERATURE PRIMARY EL	CNTL RM EMER F LTR CHAR FLTR IN TEMP	COMAX	2310-9458-0 1	AB51	1619.0 1691.0 310.0	H	A	SS		0942	00
3CZ-B15A-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S43-00-10	AB51	1595.0 1675.0 305.0	H	A	SS		2177	00
3CZ-B17SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S43-00-15	AB51	1600.00 1684.00 305.0	H	A	SS		2189	00
3CZ-B18SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S43-00-15	AB51	1600.0 1680.0 305.0	H	A	SS		2191	00
3CZ-B19SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S4C-04-5	AB51	1621.00 1677.00 305.0	H	A	SS		2193	00
3CZ-B25B-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S43-00-10	AB51	1595.0 1668.0 305.0	H	A	SS		2195	00
3CZ-B20SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S4C-04-5	AB51	1630.0 1677.0 305.0	H	A	SS		2197	00
3CZ-B21SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S4C-04-5	AB51	1530.0 1677.0 305.0	H	A	SS		2199	00
3CZ-B22SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSI TION	LIMITORQUE	S4C-04-5	AB51	1644.0 1690.0 305.0	H	A	SS		2201	00

TAGS INCLUDED: RM 1CZ 3504A SA---3CZ-B23SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # ME: C20064-CONTROL ROOM HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CZ-B23SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-04-5	AB51	1625.00 1693.00 305.0	H	A	SS		2203	00
3CZ-B24SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-04-5	AB51	1630.0 1693.0 305.0	H	A	SS		2209	00
3CZ-B25SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-15	AB51	1609.0 1683.0 305.0	H	A	SS		2207	00
3CZ-B26SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-15	AB51	1605.0 1660.0 305.0	H	A	SS		2209	00
3CZ-B32SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-15	AB51	1600.0 1695.0 305.0	H	A	SS		2213	00
3CZ-B33SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-15	AB51	1600.0 1690.0 305.0	H	A	SS		2215	00
3CZ-B55A--1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-5	AB51	1604.0 1696.0 305.0	H	A	SS		2222	00
3CZ-B68B-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-5	AB51	1607.0 1696.0 305.0	H	A	SS		2224	00
3CZ-B75A-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-5	AB51	1596.0 1655.0 305.0	H	A	SS		2226	00
3CZ-B85B-1	MOTOR OPERATOR	VALVE AND CONTROL POSITION	LIMITORQUE	S43-00-5	AB51	1596.0 1653.0 305.0	H	A	SS		2229	00
TE ICZ 7835A SA	TEMP PRIMARY EL	CNTRL RM AH-15 (1A-SB)EHC EXH	WEED INSTRUM BMS	E482506-(L) AS	AB51	1613.0 1617.0 319.0	H	A	SS		0979	00
TE ICZ 7835B SB	TEMP PRIMARY EL	CNTRL RM AH15 (1B-SB)EHC EXH	WEED INSTRUMENTS	E482506(L) AS	AB51	1609.0 1660.0 319.0	H	A	SS		0980	00
TE ICZ 78218 SB	TEMP PRIMARY ELEMENT	CONTROL RM EMER FLTR EHC INLET TEMP.	CONAX	2310-9458-01	AB51	1634.0 1692.0 310.0	H	A	SS		0920	00
TE ICZ 78243 SB	TEMP PRIMARY ELEMENT	CONTROL RM EMER FLTR EHC INLET TEMP	CONAX	2310-9458-01	AB51	1619.0 1692.0 310.0	H	A	SS		0943	00

SYSTEM # & NAME: 0051-DC POWER DISTR.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
125V DC MCC DP-1A2	DC DISTRIBUTION PANEL	DISTRIBUTES DC POWER	GOULD	LATER	AB41	1461.0 1628.0 286.0	H	A	SS		2661	00
125V DC MCC DP-1B2	D.C. DISTRIBUTION PANEL	DISTRIBUTES DC POWER	GOULD	LATER	AB41	1537.0 1628.0 286.0	H	A	SS		2662	00

SYSTEM # & NAME: CX0145-ESS.SER.CHILLWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CX-B2SA-1	LIMIT SWITCH (2 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1567.0 1520.0 245.0	H	A	SS		5006	00
3CH-B1SB-1	LIMIT SWITCH (1 OF 2)	ESSENTIAL SER CH FOR MAIN TO (NMS)	NAMCO	E4180-11302	AB21	1572.0 1519.0 245.0	H	A	SS		3243	00
3CH-B1SB-1	LIMIT SWITCH (2 OF 2)	ESSENTIAL SER CH FOR MAIN TO (NMS)	NAMCO	E4180-11302	AB21	1572.0 1519.0 245.0	H	A	SS		5011	00
3CH-B1SB-1	SOL. VALVE	LATER	ASCO	MP3320A175E	AB21	1484.0 1521.0 248.0	H	A	SS		5012	00
3CH-B2SA-1	SOLENOID VALVE	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1574.0 1519.0 245.0	H	A	SS		3244	00
3CH-B2SA-1	LIMIT SWITCH (1 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1574.0 1519.0 245.0	H	A	SS		3245	00
3CH-B2SA-1	LIMIT SWITCH (2 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1574.0 1519.0 245.0	H	A	SS		5008	00
3CH-B3SA-1	SOLENOID VALVE	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1574.0 1519.0 245.0	H	A	SS		3246	00
3CH-B3SA-1	LIMIT SWITCH (1 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1574.0 1519.0 245.0	H	A	SS		3247	00
3CH-B3SA-1	LIMIT SWITCH (2 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1574.0 1519.0 245.0	H	A	SS		5010	00
3CH-B4SB-1	SOLENOID VALVE	ESSENTIAL SER CH FOR MAIN TO (NMS)	ASCO	MP3320A175E	AB21	1584.0 1521.0 245.0	H	A	SS		3248	00
3CH-B4SB-1	LIMIT SWITCH (1 OF 2)	ISOLATION VALV E	NAMCO	E4180-11302	AB21	1584.0 1521.0 245.0	H	A	SS		3249	00

TAGS INCLUDED: CX-B2SB-1 -----3CH-B4SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CH0063-ESS. SER. CHILLWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CH-B45B-1	LIMIT SWITC H (2 OF 2)	ISOLATION VALV E	NAMCO	EA180-11302	AB51	1584.0 1521.0 245.0	H	A	SS		5009	00
3CH-V128SA-1	SOLENOID VA LVE	LATER	ASCO	NP320A175E	AB51	1648.0 1689.0 305.0	H	A	SS		3252	00
3CH-V128SA-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA-180-11302	AB51	1648.0 1689.0 305.0	H	A	SS		3253	00
3CH-V129SA-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA-180-11302	AB51	305.0	H	A	SS		5144	00
3CH-V129SB-1	SOLENOID VA LVE	LATER	ASCO	NP320A175E	AB51	1648.0 1687.0 305.0	H	A	SS		3254	00
3CH-V129SB-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA180-11302	AB51	1648.0 1687.0 305.0	H	A	SS		3255	00
3CH-V129SB-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA-180-11302	AB51	1648.0 1687.0 305.0	H	A	SS		5109	00
3CH-V130SA-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CH FOR AH-17 (1-4A-SA)	NAMCO	EA-180	AB51	1648.0 1687.0 305.0	H	A	SS		3256	00
3CH-V130SA-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-17 (1-4A-SA)	NAMCO	EA-180	AB51	1648.0 1687.0 305.0	H	A	SS		5107	00
3CH-V85SB-1	SOLENOID VA LVE	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	ASCO	NP320A175E	AB51	1648.0 1665.0 305.0	H	A	SS		3258	00
3CH-V85SB-1	LIMIT SWITC H (1 OF 2)	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	NAMCO	EA-180-11302	AB51	1648.0 1665.0 305.0	H	A	SS		3259	00
3CH-V85SB-1	LIMIT SWITC H (2 OF 2)	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	NAMCO	EA-180-11302	AB51	1648.0 1665.0 305.0	H	A	SS		5108	00
3CH-V86SA-1	SOLENOID VA LVE	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	ASCO	NP320A175E	AB51	1648.0 1667.0 305.0	H	A	SS		3260	00

TAGS INCLUDED: 3CH-B45B-1 ---3CH-V86SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CH0063-ESS, SER. CHILLDWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CH-V86SA-1	LIMIT SWITC H (1 OF 2)	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	NAMCO	EA180-11302	AB51	1648.0 1667.0 305.0	H	A	SS		3261	00
3CH-V86SA-1	LIMIT SWITC H (2 OF 2)	ISOL VALVE FOR TEMPORARY PIPING TO UNIT	NAMCO	EA-180-1130 2	AB51	1648.0 1667.0 305.0	H	A	SS		5104	00
3CX-B1SB-1	SOLENOID VA LVE	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1569.0 1520.0 245.0	H	A	SS		3266	00
3CX-B1SB-1	LIMIT SWITC H (1 OF 2)	ESSENTAIL SER CX FOR MAIN TO MNS UNITS	NAMCO	EA180-11302	AB21	1569.0 1520.0 245.0	H	A	SS		3267	00
3CX-B1SB-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR MAIN TO MNS UNITS	NAMCO	EA180-11302	AB21	1569.0 1520.0 245.0	H	A	SS		5008	00
3CX-B2SA-1	SOLENOID VA LVE(1 OF 2)	ISOLATION VALV E	ASCO	MP3320B175E	AB21	1567.0 1520.0 245.0	H	A	SS		3268	00
3CX-B2SA-1	LIMIT SWITC H (1 OF 2)	ISOLATION VALV E	NAMCO	EA-180-1130 2	AB21	1567.0 1520.0 245.0	H	A	SS		3269	00
3CX-B2SA-1	SOLENOID VA LVE(2 OF 2)	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1567.0 1520.0 245.0	H	A	SS		5007	00
3CX-B3SB-1	SOLENOID VA LVE(1 OF 2)	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1582.0 1535.0 245.0	H	A	SS		3270	00
3CX-B3SB-1	LIMIT SWITC H (1 OF 2)	ISOLATION VALV E	NAMCO	EA180-11302	AB21	1582.0 1535.0 245.0	H	A	SS		3271	00
3CX-B3SB-1	LIMIT SWITC H (2 OF 2)	ISOLATION VALV E	NAMCO	EA180-11302	AB21	1582.0 1535.0 245.0	H	A	SS		5004	00
3CX-B3SB-1	SOLENOID VA LVE(2 OF 2)	ISOLATION VALV E	ASCO	MP3320A175E	AB21	1582.0 1535.0 245.0	H	A	SS		5005	00

TAGS INCLUDED: 3CH-V86SA-1 ----3CX-B3SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CX0145-ESS. SER. CHILLWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONMENT H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CX-B4SA-1	SOLENOID VALVE	ISOLATION VALVE	ASCO	NP320A175E	AB21	1582.0 1537.0 245.0	H	A	SS		3272	00
3CX-B4SA-1	LIMIT SWITCH H (1 OF 2)	ESSENTIAL SER CX FOR MAIN	NAMCO	EA180-11302	AB21	1582.0 1537.0 245.0	H	A	SS		3273	00
3CX-B4SA-1	LIMIT SWITCH H (2 OF 2)	ESSENTIAL SER CX FOR MAIN	NAMCO	EA180-11302	AB21	1582.0 1537.0 245.0	H	A	SS		5000	00
3CX-V111SA-1	SOLENOID VALVE	LATER	ASCO	NP320A175E	AB51	1647.0 1654.0 307.0	H	A	SS		3276	00
3CX-V111SA-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	EA-180-11302	AB51	1647.0 1654.0 307.0	H	A	SS		3277	00
3CX-V111SA-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	EA-180-11302	AB51	1647.0 1654.0 307.0	H	A	SS		5113	00
3CX-V113SA-1	LIMIT SWITCH H (1 OF 2)	ESSENTIAL SER CX FOR AH-15 (1A-SA)	NAMCO	EA-180	AB51	1607.0 1687.0 305.0	H	A	SS		3278	00
3CX-V113SA-1	LIMIT SWITCH H (2 OF 2)	ESSENTIAL SER CX FOR AH-15(1A-SA)	NAMCO	EA-180	AB51	1607.0 1687.0 305.0	H	A	SS		5112	00
3CX-V114SA-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-15(2A-SA)	ASCO	NP320A175E	AB51	1648.0 1681.0 305.0	H	A	SS		3280	00
3CX-V114SA-1	LIMIT SWITCH H (1 OF 2)	ESSENTIAL SER CX FOR AH-15(2A-SA)	NAMCO	EA-180-11302	AB51	1648.0 1681.0 305.0	H	A	SS		3281	00
3CX-V114SA-1	LIMIT SWITCH H (2 OF 2)	ESSENTIAL SER CX FOR AH-15(2A-SA)	NAMCO	EA-180-11302	AB51	1648.0 1681.0 305.0	H	A	SS		5111	00
3CX-V115SP-1	SOLENOID VALVE	LATER	ASCO	NP320A175E	AB51	1648.0 1683.0 305.0	H	A	SS		3282	00

TAGS INCLUDED: 3CX-B4SA-1

----3CX-V115SB-1

SORT TYPE:

GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: CX0145-ESS.SER.CHILLDWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CX-V115SB-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB31	1648.0 1683.0 305.0	H	A	SS		3283	00
3CX-V115SB-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA-180-1130 2	AB31	1648.0 1683.0 305.0	H	A	SS		3110	00
3CX-V122SA-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-24(1X-SA)	ASCO	MP9320A175E	AB31	1447.0 1626.0 264.0	H	A	SS		3286	00
3CX-V122SA-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CX FOR AH-24(1X-SA)	NAMCO	EA180-11302	AB31	1447.0 1626.0 264.0	H	A	SS		3287	00
3CX-V122SA-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-24 (1X-SA)	NAMCO	EA180-11302	AB31	1447.0 1626.0 264.0	H	A	SS		5002	00
3CX-V243SB-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-8 (1X-SB)	ASCO	MP9320A175E	AB21	1607.0 1579.0 250.0	H	A	SS		3290	00
3CX-V243SB-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CX FOR AH-8 (1X-SB)	NAMCO	EA180-11302	AB21	1607.0 1579.0 250.0	H	A	SS		3291	00
3CX-V243SB-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-8 (1X-SB)	NAMCO	EA180-11320	AB21	1607.0 1579.0 250.0	H	A	SS		4999	00
3CX-V244SB-1	SOLENOID VA LVE	ESSENTIAL SER CX FOR AH-25(1X-SB)	ASCO	MP9320A175E	AB31	1546.0 1626.0 263.0	H	A	SS		3292	00
3CX-V244SB-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CX FOR AH-25(1X-SB)	NAMCO	EA-180-1130 2	AB31	1546.0 1626.0 263.0	H	A	SS		3293	00
3CX-V244SB-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-25 (1X-SB)	NAMCO	EA-180-1130 2	AB31	1546.0 1626.0 263.0	H	A	SS		5132	00
3CX-V245SB-1	SOLENOID VALVE	LATER	ASCO	MP9320A175E	AB31	1550.0 1762.0 265.0	H	A	SS		3294	00

TAGS INCLUDED: 3CX-V115SB-1 ---3CX-V245SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CX0145-ESS.SER.CHILLWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CX-V245SB-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA180-11302	AB31	1550.0 1762.0 265.0	H	A	SS		3295	00
3CX-V245SB-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA180-11302	AB31	1550.0 1762.0 265.0	H	A	SS		5003	00
3CX-V63SB-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-11(1B-SB)	ASCO	MP3320A175E	AB21	1489.0 1606.0 239.0	H	A	SS		3304	00
3CX-V63SB-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CX FOR AH-11(1B-SB)	NAMCO	EA-180-1130 2	AB21	1489.0 1606.0 239.0	H	A	SS		3305	00
3CX-V63SB-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-11 (1B-SB)	NAMCO	EA-180-1130 2	AB21	1489.0 1606.0 239.0	H	A	SS		5075	00
3CX-V83SA-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-11 (1A-SA)	ASCO	MP3320A175E	AB21	1471.0 1620.0 240.0	H	A	SS		3306	00
3CX-V83SA-1	LIMIT SWITC H(1 OF 2)	ESSENTIAL SER CX FOR AH-11 (1A-SA)	NAMCO	EA-180-1130 2	AB21	1471.0 1620.0 240.0	H	A	SS		3307	00
3CX-V83SA-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-11 (1A-SA)	NAMCO	EA-180-1130 2	AB21	1471.0 1620.0 240.0	H	A	SS		5074	00
3CX-W10SB-1	SOLENOID VAL LVE	LATER	ASCO	MP3320A175E	AB21	1453.0 1546.0 240.0	H	A	SS		3310	00
3CX-W12SB-1	SOLENOID VALVE	LATER	ASCO	MP3320A175E	AB21	1522.0 1609.0 260.0	H	A	SS		3312	00
3CX-W13SB-1	SOLENOID VALVE	LATER	ASCO	MP3320A175E	AB21	1515.0 1609.0 240.0	H	A	SS		3314	00
3CX-W14SB-1	SOLENOID VALVE	LATER	ASCO	MP3320A175E	AB21	1544.0 1547.0 240.0	H	A	SS		3316	00

TAGS INCLUDED: 3CX-V245SB-1 ----3CX-W14SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: CX0145-ESS, SER. CHILLWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3CX-W15SA-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB21	1636.0 1667.0 240.0	H	A	SS		3318	00
3CX-W16SA-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB41	1561.0 1635.0 286.0	H	A	SS		3320	00
3CX-W17SA-1	MOTOR OPERATOR	ESSENTIAL SER CX FOR AH-15 (1A-SA)	ITT HANNEL DAHL/CONOFL	NH01K4002F1 -L220	AB51	1605.00 1686.00 305.0	H	A	SS		3322	00
3CX-W17SA-1	LIMIT SWITCH H (1 OF 2)	ESSENTIAL SER CX FOR AH-15 (1A-SA)	ITT HANNEL DAHL/CONOFL	LATER	AB51	1607.0 1687.0 305.0	H	A	SS		3323	00
3CX-W17SA-1	LIMIT SWITCH H (2 OF 2)	ESSENTIAL SER CX FOR AH-15 (1A-SA)	ITT HANNEL DAHL/CONOFL	LATER	AB51	1607.0 1687.0 305.0	H	A	SS		3105	00
3CX-W18SA-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB51	1626.0 1683.0 305.0	H	A	SS		3324	00
3CX-W18SA-1	LIMIT SWITCH H	LATER	NAMCO	LATER	AB51	1626.0 1683.0 305.0	H	A	SS		3325	00
3CX-W2SA-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB11	1434.0 1634.0 218.0	H	A	SS		3328	00
3CX-W21SA-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB01	1565.0 1612.0 192.0	H	A	SS		3332	00
3CX-W22SB-1	SOLENOID VALVE	ESSENTIAL SER CX FOR AH-12 (1A-SA)&	ASCO	NP3320A175E	AB41	1458.0 1626.0 286.0	H	A	SS		3334	00
3CX-W23SB-1	SOLENOID VALVE	LATER	ASCO	NP3320A175E	AB41	1561.0 1627.0 286.0	H	A	SS		3336	00
3CX-W24SB-1	MOTOR OPERATOR	ESSENTIAL SER CX FOR AH-15 (1B-SB)	ITT HANNEL DAHL/CONOFL	NH01K4002F1 -L220	AB51	1607.0 1652.0 305.0	H	A	SS		3338	00

TAGS INCLUDED: 3CX-W15SA-1 ----3CX-W24SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/94

SYSTEM # & NAME: CXD145-ESS, SER. CHILLDWATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1-97	CES #	REV #
3CX-W24SB-1	LIMIT SWITC H (1 OF 2)	ESSENTIAL SER CX FOR AH-15 (1B-SB)	ITT HANDEL DAHL/CONJFL	LATER	AB51	1607.0 1652.0 305.0	H	A	SS		3339	00
3CX-W24SR-1	LIMIT SWITC H (2 OF 2)	ESSENTIAL SER CX FOR AH-15 (1B-SB)	ITT HANDEL DAHL/CONJFL	LATER	AB51	1607.0 1652.0 305.0	H	A	SS		5106	00
3CX-W25SB-1	SOLENOID VA LVE	LATER	ASCO	MP3320A175E	AB51	1624.0 1652.0 305.0	H	A	SS		3340	00
3CX-W3SB-1	SOLENOID VALVE	LATER	ASCO	RY FIELD	AB01	1565.0 1612.0 192.0	H	A	SS		3346	00
3CX-W32SA-1	SOL. VALVE	LATER	ASCO	MP3320B175E	A931	1565.0 1660.0 261.0	H	A	SS		3348	00
3CX-W34SA-1	SOLENOID VA LVE	LATER	ASCO	MP-3320B175 E	AB51	1571.0 1612.0 305.0	H	A	SS		2286	01
3CX-W4SB-1	SOLENOID VA LVE	LATER	ASCO	MP3320A175E	AB11	1567.0 1639.0 217.0	H	A	SS		3351	00
3CX-W5SA-1	SOLENOID VA LVE	LATER	ASCO	MP3320A175E	AB21	1445.0 1610.0 240.0	H	A	SS		3353	00
3CX-W7SA-1	SOLENOID VALVE	LATER	ASCO	MP3320A175E	AB21	1417.0 1547.0 240.0	H	A	SS		3355	00
3CX-W8SA-1	SOLENOID VA LVE	LATER	ASCO	MP3320A175E	AB21	1506.0 1579.0 250.0	H	A	SS		3357	00
3CX-W9SA-1	SOLENOID VALVE	LATER	ASCO	MP3320A175E	AB21	1519.0 1546.0 240.0	H	A	SS		3359	00

SYSTEM # & NAME: FPCD71-FIRE PROTECT.

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2FP-V44SA-1	SOLENOID VALVE	FAIL CLOSE	ASCO	NP3320A175E	AB21	1451.0 1648.0 241.0	H	A	SS	*	2940	00
2FP-V44SA-1	LIMIT SWITC H (1 OF 2)	FAIL CLOSE	NAMCO	EA-180-1130 2	AB21	1451.0 1648.0 241.0	H	A	SS	*	2941	00
2FP-V44SA-1	LIMIT SWITC H (2 OF 2)	FAIL CLOSE	NAMCO	EA-180-1130 2	AB21	1451.0 1648.0 241.0	H	A	SS	*	5087	00
2FP-V45SA-1	SOLENOID VALVE	FAIL CLOSE	ASCO	NP3320A175E	AB21	1482.0 1629.0 255.0	H	A	SS	*	2942	00
2FP-V45SA-1	LIMIT SWITC H (1 OF 2)	FAIL CLOSE	NAMCO	EA180-11302	AB21	1482.0 1629.0 255.0	H	A	SS	*	2943	00
2FP-V45SA-1	LIMIT SWITC H (2 OF 2)	FAIL CLOSE	NAMCO	EA-180-1130 2	AB21	1482.0 1629.0 255.0	H	A	SS	*	5086	00

SYSTEM # & NAME: FLD147-FUEL HNDL. BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
TE 1AV 6537A-SA	THERMOCOUPLE	FHB AH-17 SA SPENT FUEL POOL PMP AREA	WEED INSTRUMENTCO	E49250-2A2	FH21	1639.0 1792.0 236.0	H	A	SS		0626	00
TE 1AV 6537A1 SA	THERMOCOUPLE	FHB AH-17 SA SPENT FUEL POOL PMP AREA	WEED INSTRUMENTCO	E49250G-2A2	FH21	1659.0 1792.0 236.0	H	A	SS		0628	00
TE 1AV 6537B SB	THERMOCOUPLE	FHB AH-17 SB SPENT FUEL POOL PMP AREA	WEED INSTRUMENTCO	E49250G-2A2	FH21	1641.0 1792.0 236.0	H	A	SS		0629	00
TE 1AV 6537B1 SB	THERMOCOUPLE	FHB AH-17 SB SPENT FUEL POOL PMP AREA	WEED INSTRUMENTCO	E49250G-2A2	FH21	1661.0 1792.0 236.0	H	A	SS		0627	00

SYSTEM # & NAME: 1A0018-INSTRUMENT AIR

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
21A-V34SA-1	SOLENOID VALVE	ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13	PARKER HANNIFIN	H232-MC-50	AB21	1470.0 1636.0 236.0	H	A	CI	*	2974	00
21A-V34SA-1	LIMIT SWITCH H (10F 2)	ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13	NAMCO	D2600X-2	AB21	1470.0 1636.0 236.0	H	A	CI	*	2975	00
21A-V34SA-1	LIMIT SWITCH H (2 OF 2)	ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13	NAMCO	D2600X-2SR	AB21	1470.0 1636.0 236.0	H	A	CI	*	5085	00

SYSTEM # & NAME:LT000-LEAK RATE TESTING

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
REM 1LT3502A SA	RADIATION MONITOR SKID	CONTAINMENT LEAK DET SYS R	GENERAL ATOMIC	LATER	AB21	1453.0 1624.0 236.0	H	A	PRPM		0247	00
REM 1LT3502B SB	RADIATION MONITOR SKID	CONTAINMENT LEAK DET SYS R	GENERAL ATOMIC	LATER	AB21	1547.0 1624.0 236.0	H	A	PRPM		0248	00

SYSTEM # & NAME:MS030R-MAIN STEAM

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1-97	CES #	REV #
3MS-V17SAB-1	SOLENOID VALVE (1 OF 2)	LATER	ASCO	4P3320A175E	AB21	1515.0 1520.0 238.0	H	A	CI		3088	00
3MS-V17SAB-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1520.0 238.0	H	A	CI		3089	00
3MS-V17SAB-1	SOLENOID VALVE (2 OF 2)	LATER	ASCO	4P3320A175E	AB21	1515.0 1520.0 238.0	H	A	CI		5065	00
3MS-V17SAB-1	LIMIT SWITCH H (2 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1520.0 238.0	H	A	CI		5067	00
3MS-V17SAB-1	LIMIT SWITCH H (3 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1520.0 238.0	H	A	CI		5068	00
3MS-V17SAB-1	LIMIT SWITCH H (4 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1520.0 238.0	H	A	CI		5069	00
3MS-V18SAB-1	SOLENOID VALVE (1 OF 2)	LATER	ASCO	4P3320A175E	AB21	1515.0 1528.0 238.0	H	A	CI		3090	00
3MS-V18SAB-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1528.0 238.0	H	A	CI		3091	00
3MS-V18SAB-1	SOLENOID VALVE (2 OF 2)	LATER	ASCO	4P3320A175E	AB21	1515.0 1528.0 238.0	H	A	CI		5066	00
3MS-V18SAB-1	LIMIT SWITCH H (2 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1528.0 238.0	H	A	CI		5070	00
3MS-V18SAB-1	LIMIT SWITCH H (3 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1528.0 238.0	H	A	CI		5071	00
3MS-V18SAB-1	LIMIT SWITCH H (4 OF 4)	LATER	NAMCO	EA-180-1130 2	AB21	1515.0 1528.0 238.0	H	A	CI		5072	00

SYSTEM # & NAME: MDD024-MISC. DRAINS

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2ND-V775B-1	MOTOR OPERA TOR	LATER	LIMITORQUE	S43-000	AB11	1558.0 1656.0 230.0	H	A	SS	*	2978	00

SYSTEM # & NAME: CR026-RAD. MONITORING

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
E/I 1CR 3561A S A	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1421.0 1675.0 261.0	H	A	PRRM		4896	00
E/I 1CR 3561B S B	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1567.0 1660.0 261.0	H	A	PRRM		4897	00
E/I 1CR 3561C S A	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1439.0 1640.0 261.0	H	A	PRRM		4898	00
E/I 1CR 3561D S B	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1579.0 1678.0 261.0	H	A	PRRM		4899	00
E/I 1CR 3563A S A	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1418.0 1657.0 261.0	H	A	PRRM		4900	00
E/I 1CR 3563B S B	CURRENT TRANSMITTER J	LATER	GENERAL MIC	ATO	LATER	AB31 1582.0 1658.0 261.0	H	A	PRRM		4901	00
E/I*1FR3565A SA	CURRENT TRANSMITTER J	SPENT FUEL POOL (SOUTH) AREA RAD MONITOR	GENERAL MIC	ATO	LATER	AB31 1594.0 1669.0 309.0	H	A	PRRM		1180	00
ISOLATION BOX -1	LATER	LATER	LATER	LATER	LATER	AB31 1628.0 1654.0 305.0	H	A	PRRM		4088	00
JB RM 1CR-3561A -SA	SAFETY FUSE	LATER	GENERAL MIC	ATO	LATER	AB31 1421.0 1678.0 265.0	H	A	PRRM		4089	00
JB RM 1CR-3561B -SB	SAFETY FUSE	LATER	GENERAL MIC	ATO	LATER	AB31 1567.0 1654.0 261.0	H	A	PRRM		4090	00
JB RM 1CR-3561C -SA	SAFETY FUSE	LATER	GENERAL MIC	ATO	LATER	AB31 1443.0 1625.0 265.0	H	A	PRRM		4091	00
JB RM 1CR-3561D -SB	SAFETY FUSE	LATER	GENERAL MIC	ATO	LATER	AB31 1579.0 1674.0 261.0	H	A	PRRM		4092	00

TAGS INCLUDED: E/I 1CR 3561A S----JB RM 1CR-3561D
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: CRO026-RAD. MONITORING

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
RE 1CR 3563A SA	RADIATION P RIMARY ELEM	CONTAINMENT PO ST- LOCA	GENERAL ATD MIC	LATER	AB31	1458.0 1638.0 265.0	H	A	PRRM		0279	00
RE 1CR 3563B SB	RADIATION P RIMARY ELEM	CONTAINMENT PO ST- LOCA	GENERAL ATD MIC	LATER	AB31	1542.0 1637.0 265.5	H	A	PRRM		0278	00
RM 1CR 3561A SA	MICROPROCES SOR	CONTAINMENT IS CL SYS	GENERAL ATD MIC	LATER	AB31	1421.0 1676.0 265.0	H	A	PRRM		0274	00
RM 1CR 3561B SB	MICROPROCES SOR	CONTAINMENT IS OL SYS	GENERAL ATD MIC	LATER	AB31	1567.0 1658.0 265.0	H	A	PRRM		0277	00
RM 1CR 3561C SA	MICROPROCES SOR	CONTAINMENT IS OL SYS	GENERAL ATD MIC	LATER	AB31	1438.0 1641.0 265.0	H	A	PRRM		0275	00
RM 1CR 3561D SB	MICROPROCES SOR	CONTAINMENT IS OL SYS	GENERAL ATD MIC	LATER	AB31	1579.0 1676.0 265.0	H	A	PRRM		0276	00
RM 1CR 3563A SA	MICROPROCES SOR	LATER	GENERAL ATD MIC	LATER	AB31	1421.0 1655.0 265.0	H	A	PRRM		0280	00
RM 1CR 3563B SB	MICROPROCES SOR	LATER	GENERAL ATD MIC	LATER	AB31	1581.0 1658.0 265.0	H	A	PRRM		0281	00
RM 1CR 3589 SA	RADIATION M ONITOR	IN-CONTMT POST ACCIDENT MONITOR MICR	GENERAL ATD MIC	LATER	AB31	1408.0 1656.0 305.0	H	A	PRRM		4505	00
RM 1CR 3590 SB	RADIATION M ONITOR	IN-CONTMT POST ACCIDENT MONITOR MICR	GENERAL ATD MIC	LATER	AB31	1416.0 1656.0 305.0	H	A	PRRM		4506	00
T ASSY RM 3504A -SA	LATER	LATER	LATER	LATER	AB31	1594.0 1663.0 305.0	H	A	PRRM		4098	00

SYSTEM # & NAME: AC0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AC-D10SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH-96	AB41	1557.0 1616.0 295.0	H	A	SS		1505	00
AC-D10SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1557.0 1616.0 295.0	H	A	SS		1506	00
AC-D10SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1557.0 1616.0 295.0	H	A	SS		5056	00
AC-D17SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	LATER	AB41	1427.0 1604.0 298.0	H	A	SS		1511	00
AC-D17SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1427.0 1604.0 298.0	H	A	SS		1512	00
AC-D17SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1427.0 1604.0 298.0	H	A	SS		5059	00
AC-D18SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	LATER	AB41	1422.0 1607.0 300.0	H	A	SS		1513	00
AC-D18SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1422.0 1607.0 300.0	H	A	SS		1514	00
AC-D18SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	LATER	AB41	1422.0 1607.0 300.0	H	A	SS		5060	00
AC-D19SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	LATER	AB41	1565.0 1632.0 294.0	H	A	SS		1515	00
AC-D19SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1565.0 1632.0 294.0	H	A	SS		1516	00
AC-D19SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1565.0 1632.0 294.0	H	A	SS		5062	00

TAGS INCLUDED: AC-D10SB-1 ---AC-D19SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AC0045-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AC-D20SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	LATER	AB41	1571.0 1683.0 294.0	H	A	SS		1517	00
AC-D20SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1571.0 1683.0 294.0	H	A	SS		1518	00
AC-D20SP-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1571.0 1683.0 294.0	H	A	SS		5064	00
AC-D5SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH-96	AB41	1574.0 1688.0 297.0	H	A	SS		1527	00
AC-D5SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1574.0 1688.0 297.0	H	A	SS		1528	00
AC-D5SSB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1574.0 1688.0 297.0	H	A	SS		5061	00
AC-D7SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH-96	AB41	1442.0 1618.0 295.0	H	A	SS		1531	00
AC-D7SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1442.0 1618.0 295.0	H	A	SS		1532	00
AC-D7SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1442.0 1618.0 295.0	H	A	SS		5058	00
AC-D8SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH-96	AB41	1456.0 1618.0 295.0	H	A	SS		1533	00
AC-D8SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB41	1456.0 1618.0 295.0	H	A	SS		1534	00
AC-D8SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180	AB41	1456.0 1618.0 295.0	H	A	SS		5063	00

TAGS INCLUDED: AC-D20SB-1 -----AC-D8SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AC0046-RFAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AC-D9SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	MM-06	AB41	1545.0 1616.0 295.0	H	A	SS		1535	00
AC-D9SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-170	AB41	1545.0 1616.0 295.0	H	A	SS		1536	00
AC-D9SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-170	AB41	1545.0 1616.0 295.0	H	A	SS		5057	00
AH-10(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB21	1450.0 1614.0 236.0	H	A	SS		1538	00
AH-10(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB21	1510.0 1614.0 236.0	H	A	SS		1540	00
AH-11(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB21	1479.0 1613.0 236.0	H	A	SS		1542	00
AH-11(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB21	1496.0 1613.0 236.0	H	A	SS		1544	00
AH-12(1A-SA)	DOOR SWITCH	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-170	AB41	1438.0 1616.0 286.0	H	A	SS		1545	00
AH-12(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB41	1438.0 1616.0 286.0	H	A	SS		1546	00
AH-12(1B-SA)	DOOR SWITCH	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-170	AB41	1458.0 1616.0 286.0	H	A	SS		1547	00
AH-12(1B-SA)	MOTOR	DRIVE FAN	RELIANCE	RM INSULATION	AB41	1458.0 1616.0 286.0	H	A	SS		1548	00
AH-13(1A-SR)	DOOR SWITCH	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-170	AB41	1542.0 1615.0 286.0	H	A	SS		1549	00

TAGS INCLUDED: AC-D9SB-1 ----AH-13(1A-SR)
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: 0171-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AH-13(1A-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB41	1542.0 1615.0 286.0	H	A	SS		1550	00
AH-13(1B-SB)	DOOR SWITCH	REMOTE INDICAT ION OF DOOR POS ITION	NAMCO	EA-170	AB41	1561.0 1616.0 286.0	H	A	SS		1551	00
AH-13(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB41	1561.0 1615.0 286.0	H	A	SS		1552	00
AH-16(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB51	1637.0 1680.0 305.0	H	A	SS		1558	00
AH-16(1P-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB51	1637.0 1663.0 305.0	H	A	SS		1560	00
AH-23(1X-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB21	1545.0 1760.0 236.0	H	A	SS		1574	00
AH-24(1X-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB31	1451.0 1623.0 261.0	H	A	SS		1576	00
AH-25(1X-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB31	1553.0 1623.0 263.0	H	A	SS		1578	00
AH-26(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB31	1552.0 1758.0 261.0	H	A	SS		1582	00
AH-28(1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB11	1424.0 1650.0 216.0	H	A	SS		1584	00
AH-28(1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB11	1575.0 1636.0 216.0	H	A	SS		1586	00
AH-5 (1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI 0M	AB01	1428.0 1614.0 191.2	H	A	SS		1590	00

TAGS INCLUDED: AH-13(1A-SB) ----AH-5 (1B-SB)
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: 0162-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AH-5 (1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB01	1573.0 1614.0 191.2	H	A	SS		1592	00
AH-6 (1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1423.0 1549.0 236.0	H	A	SS		1594	00
AH-6 (1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1446.0 1549.0 236.0	H	A	SS		1596	00
AH-7 (1A-SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1534.0 1554.0 236.0	H	A	SS		1598	00
AH-7 (1B-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1561.0 1546.0 236.0	H	A	SS		1600	00
AH-8 (1X-SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1601.0 1575.0 251.0	H	A	SS		1602	00
AH-9(1A- SA)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1500.0 1585.0 247.0	H	A	SS		1616	00
AH-9(1B- SB)	MOTOR	DRIVE FAN	RELIANCE	RH INSULATI ON	AB21	1530.0 1614.0 236.0	H	A	SS		1618	00
AV-010SB-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-1R0	AB31	1414.0 1694.0 271.0	H	A	SS		1706	00
AV-010SB-1	PNEUMATIC O PERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	CB-415	AB31	1414.0 1694.0 271.0	H	A	SS		1707	00
AV-010SB-1	SOLENOID VA LVE	CONTROL AIR-PR ESSURE IN PNEU MATIC OPERATOR	ASCO	NPR120A173E	AB31	1414.0 1694.0 271.0	H	A	SS		1708	00
AV-010SB-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-1R0	AB31	1414.0 1694.0 271.0	H	A	SS		3031	00

TAGS INCLUDED: AH-5 (1B-SB) ----AV-010SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # 8 NAME:AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D11SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1497.0 1597.0 247.0	H	A	SS		1709	00
AV-D11SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1497.0 1597.0 247.0	H	A	SS		1710	00
AV-D11SA-1	SOLENOID VALVE	CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB21	1497.0 1597.0 247.0	H	A	SS		1711	00
AV-D11SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1497.0 1597.0 247.0	H	A	SS		5036	00
AV-D12SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1493.0 1603.0 246.0	H	A	SS		1712	00
AV-D12SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1493.0 1603.0 246.0	H	A	SS		1713	00
AV-D12SB-1	SOLENOID VALVE	CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB21	1493.0 1603.0 246.0	H	A	SS		1714	00
AV-D12SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1493.0 1603.0 246.0	H	A	SS		5077	00
AV-D13SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1417.0 1597.0 236.0	H	A	SS		1715	00
AV-D13SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1417.0 1597.0 236.0	H	A	SS		1716	00
AV-D13SA-1	SOLENOID VALVE	CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB21	1417.0 1597.0 236.0	H	A	SS		1717	00
AV-D13SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1417.0 1597.0 236.0	H	A	SS		5026	00

TAGS INCLUDED: AV-D11SA-1 -----AV-D13SA-1
SORT TYPE: GLOBAL REV# 0 09/05/84

SYSTEM # 3 NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D14SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1420.0 1605.0 245.0	H	A	SS		1718	00
AV-D14SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1420.0 1605.0 245.0	H	A	SS		1719	00
AV-D14SB-1	SOLENOID VALVE	CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1420.0 1605.0 245.0	H	A	SS		1720	00
AV-D14SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1420.0 1605.0 245.0	H	A	SS		5076	00
AV-D15SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1595.0 1695.0 244.0	H	A	SS		1721	00
AV-D15SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1595.0 1695.0 244.0	H	A	SS		1722	00
AV-D15SA-1	SOLENOID VALVE	CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1595.0 1695.0 244.0	H	A	SS		1723	00
AV-D15SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1595.0 1695.0 244.0	H	A	SS		5141	00
AV-D16SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1582.0 1706.0 236.0	H	A	SS		1724	00
AV-D16SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1582.0 1706.0 236.0	H	A	SS		1725	00
AV-D16SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1582.0 1706.0 236.0	H	A	SS		1726	00
AV-D16SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1RD	AB21	1582.0 1706.0 236.0	H	A	SS		5078	00

TAGS INCLUDED: AV-D14SB-1 ----AV-D16SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV3046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/W	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D17SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1429.0 1678.0 236.0	H	A	SS		1727	00
AV-D17SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1429.0 1678.0 236.0	H	A	SS		1728	00
AV-D17SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1429.0 1678.0 236.0	H	A	SS		1729	00
AV-D17SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1429.0 1678.0 236.0	H	A	SS		5080	00
AV-D18SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1429.0 1674.0 236.0	H	A	SS		1730	00
AV-D18SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1429.0 1674.0 236.0	H	A	SS		1731	00
AV-D18SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1429.0 1674.0 236.0	H	A	SS		1732	00
AV-D18SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1429.0 1674.0 236.0	H	A	SS		5079	00
AV-D19SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1476.0 1569.0 236.0	H	A	SS		1733	00
AV-D19SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1476.0 1569.0 236.0	H	A	SS		1734	00
AV-D19SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1476.0 1569.0 236.0	H	A	SS		1735	00
AV-D19SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1476.0 1569.0 236.0	H	A	SS		5030	00

TAGS INCLUDED: AV-D17SA-1 -----AV-D19SA-1
SORT TYPE: GLOBAL REV#- U 09/05/84

SYSTEM # 8 NAME:AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D20SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1476.0 1567.0 236.0	H	A	SS		1736	00
AV-D20SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1476.0 1567.0 236.0	H	A	SS		1737	00
AV-D20SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP320A173E	AB21	1476.0 1567.0 236.0	H	A	SS		1738	00
AV-D20SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1476.0 1567.0 236.0	H	A	SS		5029	00
AV-D21SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1522.0 1568.0 242.0	H	A	SS		1739	00
AV-D21SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1522.0 1568.0 242.0	H	A	SS		1740	00
AV-D21SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP320A173E	AB21	1522.0 1568.0 242.0	H	A	SS		1741	00
AV-D21SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1522.0 1568.0 242.0	H	A	SS		5015	00
AV-D23SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1499.0 1568.0 242.0	H	A	SS		1745	00
AV-D23SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1499.0 1568.0 242.0	H	A	SS		1746	00
AV-D23SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP320A173E	AB21	1499.0 1568.0 242.0	H	A	SS		1747	00
AV-D23SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-1R0	AB21	1499.0 1568.0 242.0	H	A	SS		5019	00

TAGS INCLUDED: AV-D20SB-1 -----AV-D23SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AVOC46-REAC.AUX.3LDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D24SB-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1499.0 1567.0 236.0	H	A	SS		1748	00
AV-D24SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	C9-315	AB21	1499.0 1567.0 236.0	H	A	SS		1749	00
AV-D24SB-1	SOLENOID VA LVE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR	ASCO	MPR320A173E	AB21	1499.0 1567.0 236.0	H	A	SS		1750	00
AV-D24SB-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1499.0 1567.0 236.0	H	A	SS		5020	00
AV-D25SA-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1452.0 1568.0 242.0	H	A	SS		1751	00
AV-D25SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	C9-315	AB21	1452.0 1568.0 242.0	H	A	SS		1752	00
AV-D25SA-1	SOLENOID VA LVE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR	ASCO	MPR320A173E	AB21	1452.0 1568.0 242.0	H	A	SS		1753	00
AV-D25SA-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1452.0 1568.0 242.0	H	A	SS		5024	00
AV-D26SB-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1452.0 1567.0 236.0	H	A	SS		1754	00
AV-D26SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	C9-315	AB21	1452.0 1567.0 236.0	H	A	SS		1755	00
AV-D26SB-1	SOLENOID VA LVE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR	ASCO	MPR320A173E	AB21	1452.0 1567.0 236.0	H	A	SS		1756	00
AV-D26SB-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1452.0 1567.0 236.0	H	A	SS		5022	00

TAGS INCLUDED: AV-D24SB-1 ---AV-D26SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/94

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D27SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	FA-180	AB21	1543.0 1565.0 236.0	H	A	SS		1757	00
AV-D27SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1543.0 1565.0 236.0	H	A	SS		1758	00
AV-D27SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB21	1543.0 1565.0 236.0	H	A	SS		1759	00
AV-D27SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	FA-180	AB21	1543.0 1565.0 236.0	H	A	SS		5021	00
AV-D28SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1572.0 236.0	H	A	SS		1760	00
AV-D28SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1543.0 1572.0 236.0	H	A	SS		1761	00
AV-D28SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB21	1543.0 1572.0 236.0	H	A	SS		1762	00
AV-D28SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1572.0 236.0	H	A	SS		5028	00
AV-D29SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1410.0 1691.0 221.0	H	A	SS		1763	00
AV-D29SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB11	1410.0 1691.0 221.0	H	A	SS		1764	00
AV-D29SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP9320A173E	AB11	1410.0 1691.0 221.0	H	A	SS		1765	00
AV-D29SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	FA-180	AB11	1410.0 1691.0 221.0	H	A	SS		5100	00

TAGS INCLUDED: AV-D27SA-1 ---AV-D29SA-1
SORT TYPE: GLOBAL REV#- 0 09/03/84

SYSTEM # 8 NAME:AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D30SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1414.0 1691.0 221.0	H	A	SS		1769	00
AV-D30SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CA-315	AB11	1414.0 1691.0 221.0	H	A	SS		1770	00
AV-D30SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB11	1414.0 1691.0 221.0	H	A	SS		1771	00
AV-D30SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1414.0 1691.0 221.0	H	A	SS		5103	00
AV-D31SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1587.0 1710.0 216.0	H	A	SS		1772	00
AV-D31SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CA-415-SR	AB11	1587.0 1710.0 216.0	H	A	SS		1773	00
AV-D31SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB11	1587.0 1710.0 216.0	H	A	SS		1774	00
AV-D31SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1587.0 1710.0 216.0	H	A	SS		5102	00
AV-D32SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1580.0 1692.0 216.0	H	A	SS		1775	00
AV-D32SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CA-415-SR	AB11	1580.0 1692.0 216.0	H	A	SS		1776	00
AV-D32SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB11	1580.0 1692.0 216.0	H	A	SS		1777	00
AV-D32SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB11	1580.0 1692.0 216.0	H	A	SS		5101	00

TAGS INCLUDED: AV-D30SB-1 ---AV-D32SB-1
SORT TYPE: GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: AV0046-PEAC.AUX.BLOG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D34SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1553.0 1603.0 236.0	H	A	SS		1781	00
AV-D34SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1553.0 1603.0 236.0	H	A	SS		1782	00
AV-D34SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1553.0 1603.0 236.0	H	A	SS		1783	00
AV-D34SB-1	LIMIT SWITCH	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA180	AB21	1553.0 1603.0 236.0	H	A	SS		4156	00
AV-D35SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB01	1584.0 1643.0 206.0	H	A	SS		1784	00
AV-D35SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB01	1584.0 1643.0 206.0	H	A	SS		1785	00
AV-D35SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB01	1584.0 1643.0 206.0	H	A	SS		1786	00
AV-D35SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB01	1584.0 1643.0 206.0	H	A	SS		5023	00
AV-D36S9-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB01	1581.0 1638.0 190.0	H	A	SS		1787	00
AV-D36SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB01	1581.0 1638.0 190.0	H	A	SS		1788	00
AV-D36SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB01	1581.0 1638.0 190.0	H	A	SS		1789	00
AV-D36SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB01	1581.0 1638.0 190.0	H	A	SS		5142	00

TAGS INCLUDED: AV-D34SB-1 ----AV-D36SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.9LDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D37SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1458.0 1594.0 249.0	H	A	SS		1790	00
AV-D37SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1458.0 1594.0 249.0	H	A	SS		1791	00
AV-D37SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1458.0 1594.0 249.0	H	A	SS		1792	00
AV-D37SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1458.0 1594.0 249.0	H	A	SS		5025	00
AV-D38SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA180-21302	AB21	1464.0 1603.0 236.0	H	A	SS		1793	00
AV-D38SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1464.0 1603.0 236.0	H	A	SS		1794	00
AV-D38SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1464.0 1603.0 236.0	H	A	SS		1795	00
AV-D38SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA180	AB21	1464.0 1603.0 236.0	H	A	SS		4155	00
AV-D4SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1580.0 1603.0 268.0	H	A	SS		1796	00
AV-D4SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB31	1580.0 1603.0 268.0	H	A	SS		1797	00
AV-D4SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB31	1580.0 1603.0 268.0	H	A	SS		1798	00
AV-D4SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1580.0 1603.0 268.0	H	A	SS		5027	00

TAGS INCLUDED: AV-D37SA-1

----AV-04SB-1

SORT TYPE:

GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: AV0746-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D52SA-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1595.0 1685.0 245.0	H	A	SS		1802	00
AV-D52SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	CR-315	AB21	1595.0 1685.0 245.0	H	A	SS		1803	00
AV-D52SA-1	SOLENOID VA LVE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR	ASCO	NP3320A173E	AB21	1595.0 1685.0 245.0	H	A	SS		1804	00
AV-D52SA-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1595.0 1685.0 245.0	H	A	SS		5143	00
AV-D53SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSI TION	BETTIS	CR-315	AB21	1585.0 1685.0 247.0	H	A	SS		1806	00
AV-D53SB-1	SOLENOID VA LVE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR	ASCO	NP3320A173E	AB21	1585.0 1685.0 247.0	H	A	SS		1807	00
AV-D53SB-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1585.0 1685.0 247.0	H	A	SS		5081	00
AV-D53SB-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1585.0 1685.0 247.0	H	A	SS		5082	00
AV-D56SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITI ON OF DAMPER	ITT	LATER	AB21	1465.0 1595.0 248.0	H	A	SS		1808	00
AV-D56SA-1	LIMIT SWITC H (1 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1465.0 1595.0 248.0	H	A	SS		1809	00
AV-D56SA-1	LIMIT SWITC H (2 OF 2)	REMOTE INDICAT ION OF DAMPER POSITION	NAMCO	EA-180	AB21	1465.0 1595.0 248.0	H	A	SS		5032	00
AV-D57SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITI ON OF DAMPER	ITT	LATER	AB21	1465.0 1574.0 248.0	H	A	SS		1810	00

TAGS INCLUDED: AV-D52SA-1 ---AV-D57SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC. AUX. BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-057SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1465.0 1574.0 248.0	H	A	SS		1811	00
AV-057SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1465.0 1574.0 248.0	H	A	SS		5033	00
AV-058SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1467.0 1586.0 247.0	H	A	SS		1812	00
AV-058SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1467.0 1586.0 247.0	H	A	SS		1813	00
AV-058SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1467.0 1586.0 247.0	H	A	SS		1814	00
AV-058SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1467.0 1586.0 247.0	H	A	SS		5034	00
AV-059SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1468.0 1586.0 247.0	H	A	SS		1815	00
AV-059SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1468.0 1586.0 247.0	H	A	SS		1817	00
AV-059SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1468.0 1586.0 247.0	H	A	SS		5035	00
AV-060SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	M426	AB21	1516.0 1595.0 248.0	H	A	SS		1821	00
AV-060SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1516.0 1595.0 248.0	H	A	SS		1822	00
AV-060SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1516.0 1595.0 248.0	H	A	SS		5052	00

TAGS INCLUDED: AV-057SB-1 ----AV-060SA-1
SORT TYPE: GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D61SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH76	AB21	1516.0 1574.0 248.0	H	A	SS		1823	00
AV-D61SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1516.0 1574.0 248.0	H	A	SS		1824	00
AV-D61SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1516.0 1574.0 248.0	H	A	SS		5051	00
AV-D62SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2130 2	AB21	1515.0 1586.0 247.0	H	A	SS		1825	00
AV-D62SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1515.0 1586.0 247.0	H	A	SS		1826	00
AV-D62SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	VP4320A173E	AB21	1515.0 1586.0 247.0	H	A	SS		1827	00
AV-D62SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230 2	AB21	1515.0 1586.0 247.0	H	A	SS		4159	00
AV-D63SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2130 2	AB21	1512.0 1586.0 247.0	H	A	SS		1828	00
AV-D63SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1512.0 1586.0 247.0	H	A	SS		1829	00
AV-D63SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	VP4320A173E	AB21	1512.0 1586.0 247.0	H	A	SS		1830	00
AV-D63SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230 2	AB21	1512.0 1586.0 247.0	H	A	SS		4160	00
AV-D64SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH76	AB21	1482.0 1595.0 247.0	H	A	SS		1831	00

TAGS INCLUDED: AV-D61SB-1 -----AV-D64SA-1
 SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D64SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1482.0 1595.0 247.0	H	A	SS		1832	00
AV-D64SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1482.0 1595.0 247.0	H	A	SS		5045	00
AV-D65SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	NH76	AB21	1479.0 1590.0 247.0	H	A	SS		1833	00
AV-D65SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1479.0 1590.0 247.0	H	A	SS		1834	00
AV-D65SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1479.0 1590.0 247.0	H	A	SS		5042	00
AV-D66SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1486.0 1586.0 247.0	H	A	SS		1835	00
AV-D66SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1486.0 1586.0 247.0	H	A	SS		1836	00
AV-D66SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP320A173E	AB21	1486.0 1586.0 247.0	H	A	SS		1837	00
AV-D66SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230 2	AB21	1486.0 1586.0 247.0	H	A	SS		4161	00
AV-D67SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1488.0 1586.0 247.0	H	A	SS		1838	00
AV-D67SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1488.0 1586.0 247.0	H	A	SS		1839	00
AV-D67SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP320A173E	AB21	1488.0 1586.0 247.0	H	A	SS		1840	00

TAGS INCLUDED: AV-D64SA-1 ---AV-D67SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/94

SYSTEM # & NAME: AV0044-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D67SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230	AB21	1498.0 1586.0 247.0	H	A	SS		4162	00
AV-D68SA-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	4H96	AB21	1538.0 1595.0 248.0	H	A	SS		1841	00
AV-D68SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1538.0 1595.0 248.0	H	A	SS		1842	00
AV-D68SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1538.0 1595.0 248.0	H	A	SS		5041	00
AV-D69SB-1	ELECTRO-HYD OPERATOR	CONTROL POSITION OF DAMPER	ITT	4H96	AB21	1538.0 1574.0 248.0	H	A	SS		1843	00
AV-D69SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1538.0 1574.0 248.0	H	A	SS		1844	00
AV-D69SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1538.0 1574.0 248.0	H	A	SS		5040	00
AV-D7SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1427.0 1595.0 236.0	H	A	SS		1845	00
AV-D7SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1427.0 1595.0 236.0	H	A	SS		1846	00
AV-D7SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP332DA173E	AB21	1427.0 1595.0 236.0	H	A	SS		1847	00
AV-D7SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1427.0 1595.0 236.0	H	A	SS		5039	00
AV-D70SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2130	AB21	1537.0 1586.0 247.0	H	A	SS		1848	00

TAGS INCLUDED: AV-067SB-1 -----AV-070SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D70SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1537.0 1586.0 247.0	H	A	SS		1849	00
AV-D70SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1537.0 1586.0 247.0	H	A	SS		1850	00
AV-D70SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230 2	AB21	1537.0 1586.0 247.0	H	A	SS		4163	00
AV-D71SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2130 2	AB21	1537.0 1585.0 247.0	H	A	SS		1851	00
AV-D71SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1537.0 1585.0 247.0	H	A	SS		1852	00
AV-D71SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	NP3320A173E	AB21	1537.0 1585.0 247.0	H	A	SS		1853	00
AV-D71SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180-2230 2	AB21	1537.0 1585.0 247.0	H	A	SS		4164	00
AV-D72SA-1	ELECTRO-HYDRAULIC OPERATOR	CONTROL POSITION OF DAMPER	ITT	HM 96	AB21	1546.0 1595.0 248.0	H	A	SS		1854	00
AV-D72SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1546.0 1595.0 248.0	H	A	SS		1855	00
AV-D72SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1546.0 1595.0 248.0	H	A	SS		5050	00
AV-D73SB-1	ELECTRO-HYDRAULIC OPERATOR	CONTROL POSITION OF DAMPER	ITT	HM-96	AB21	1543.0 1578.0 248.0	H	A	SS		1856	00
AV-D73SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1578.0 248.0	H	A	SS		1857	00

TAGS INCLUDED: AV-D70SA-1 ---AV-D73SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D73SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1578.0 248.0	H	A	SS		5048	00
AV-D74SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1548.0 1586.0 247.0	H	A	SS		1858	00
AV-D74SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1548.0 1586.0 247.0	H	A	SS		1859	00
AV-D74SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1548.0 1586.0 247.0	H	A	SS		1860	00
AV-D74SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1548.0 1586.0 247.0	H	A	SS		5047	00
AV-D75SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1585.0 247.0	H	A	SS		1861	00
AV-D75SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB21	1543.0 1585.0 247.0	H	A	SS		1862	00
AV-D75SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1543.0 1585.0 247.0	H	A	SS		1863	00
AV-D75SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1543.0 1585.0 247.0	H	A	SS		5049	00
AV-D78SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB21	1602.0 1630.0 250.0	H	A	SS		1864	00
AV-D78SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-415-SR	AB21	1602.0 1630.0 250.0	H	A	SS		1865	00
AV-D78SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1602.0 1630.0 250.0	H	A	SS		1866	00

TAGS INCLUDED: AV-D73SB-1

----AV-D78SA-1

SORT TYPE:

GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D78SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB21	1602.0 1630.0 250.0	H	A	SS		5128	00
AV-D79SB- 1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB21	1585.0 1630.0 247.0	H	A	SS		1867	00
AV-D79SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-415-SR	AB21	1585.0 1630.0 247.0	H	A	SS		1868	00
AV-D79SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1585.0 1630.0 247.0	H	A	SS		1869	00
AV-D79SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB21	1585.0 1630.0 247.0	H	A	SS		5083	00
AV-D83SB-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB21	1589.0 1727.0 254.0	H	A	SS		1873	00
AV-D83SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB21	1589.0 1727.0 254.0	H	A	SS		1874	00
AV-D83SB-1	SOLENOID VALVE	SERVING DAMPER AV-D83SB-1 PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB21	1589.0 1727.0 254.0	H	A	SS		1875	00
AV-D83SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB21	1589.0 1727.0 254.0	H	A	SS		5084	00
AV-D86SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-190	AB31	1580.0 1705.0 270.0	H	A	SS		1876	00
AV-D86SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	C9-315	AB31	1580.0 1705.0 270.0	H	A	SS		1877	00
AV-D86SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MP3320A173E	AB31	1580.0 1705.0 270.0	H	A	SS		1878	00

TAGS INCLUDED: AV-D78SA-1

----AV-D86SA-1

SORT TYPE:

GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIROM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
AV-D86SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1580.0 1705.0 270.0	H	A	SS		5046	00
AV-D87SB 1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1580.0 1690.0 272.0	H	A	SS		1879	00
AV-D87SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-315	AB31	1580.0 1690.0 272.0	H	A	SS		1880	00
AV-D87SB-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MPR320A173E	AB31	1580.0 1690.0 272.0	H	A	SS		1881	00
AV-D87SB-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1580.0 1690.0 272.0	H	A	SS		5037	00
AV-D9SA-1	LIMIT SWITCH (1 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1410.0 1694.0 271.0	H	A	SS		1885	00
AV-D9SA-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CR-415	AB31	1410.0 1694.0 271.0	H	A	SS		1886	00
AV-D9SA-1	SOLENOID VALVE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR	ASCO	MPR320A173E	AB31	1410.0 1694.0 271.0	H	A	SS		1887	00
AV-D9SA-1	LIMIT SWITCH (2 OF 2)	REMOTE INDICATION OF DAMPER POSITION	NAMCO	EA-180	AB31	1410.0 1694.0 271.0	H	A	SS		5038	00
CP EMC30 1B-SR RAB	CONTROL PANEL	LATER	BRASCH	CP-7R-00386	AB31	1574.0 1730.0 261.0	H	A	SS		2326	00
E-6 (1B-SB)	DOOR SWITCH (1 OF 2)	REMOTE INDICATION OF DOOR POSITION	NAMCO	EA-180-1130 2	AB31	1584.0 1756.0 261.0	H	A	SS		1981	00
E-6 (1B-SB)	ELECTRO-HYDRAULIC OPERATOR	OPERATE INLET VANES-REGULATE FAN VOLUME	ITT	MH-94	AB31	1584.0 1766.0 261.0	H	A	SS		1983	00

TAGS INCLUDED: AV-D86SA-1 -----E-6 (1B-SB)
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: AV0046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
E-6 (1B-SB)	MOTOR	DRIVE FAN	RELIANCE LECT CO	ERM INSULATI ON	AB31	1584.0 1766.0 261.0	H	A	SS		1984	00
E-6(1B-SB)	DOOR SWITCH (2 OF 2)	REMOTE INDICAT ION OF DOOR POSITION	NAMCO	EA-180-3130 2	AB31	1584.0 1766.0 261.0	H	A	SS		5053	00
EHC-30(1B-SB)	ELECTRIC HE ATING COIL	MAINTAIN REL. HUMIDITY & TEM P.OF AIR	BRASCH	LATER	AB31	1582.0 1730.0 261.0	H	A	SS		2003	00
FT 1AV 4842B SR	FLOW TRANSM ITTER	FAN E6(1B-SB) DISCHFLOW	GOULD	LATER	AB31	1586.0 1765.0 261.0	H	A	SS		0367	00
FT 21AV 3509 SA	FLOW TRANSM ITTER	PLANT STACK ISOKINETI C FLOW	LATER	LATER	AB51	1650.0 1760.0 305.0	H	A	SS		1318	00
PDT 1AV4834A1SA	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES S.	GOULD	LATER	AB01	1580.0 1640.0 195.0	H	A	SS		0335	00
PDT 1AV4834A2SA	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB11	1580.0 1640.0 221.0	H	A	SS		0337	00
PDT 1AV4834A3SA	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB31	1582.0 1640.0 265.0	H	A	SS		0338	00
PDT 1AV4834A4SA	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB21	1581.0 1640.0 240.0	H	A	SS		0339	00
PDT 1AV4834B1SR	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB01	1581.0 1640.0 195.0	H	A	SS		0336	00
PDT 1AV4834B2SR	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB11	1581.0 1640.0 221.0	H	A	SS		0340	00
PDT 1AV4834B3SR	PRESSURE TR ANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB31	1580.0 1640.0 265.0	H	A	SS		0333	00

TAGS INCLUDED: E-6 (1B-SB) -----PDT 1AV4834B3SR
SORT TYPE: GLOBAL REV# 0 09/05/84

SYSTEM # & NAME: AVU046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
PDT 1AV4834B4SB	PRESSURE TRANSMITTER	RAB TO OUTSIDE DIFF PRES	GOULD	LATER	AB21	1582.0 1640.0 240.0	H	A	SS		0334	00
PDT 1AV4838B SB	PRESSURE TRANSMITTER	RAB EMER FLTR E6 HEPAFLTR DIFF PRES	ROSEMOUNT	1153 SERIES B	AB31	1582.0 1740.0 261.0	H	A	SS		0351	00
PDT 1AV4843B SB	PRESSURE TRANSMITTER	RAB EMER FLTR E6 OVERALL DIFF PRES	ROSEMOUNT	1153 SERIES B	AB31	1582.0 1722.0 261.0	H	A	SS		0371	00
REM-1AV 3509 SA	RADIATION MONITOR SKID	PLANT VENT RAD STACK 1	GENERAL ATOMIC	LATER	AB51	1650.0 1735.0 305.0	H	A	SS		0264	00
S-64(1X-SA)	MOTOR	PROVIDE VENT FOR ESF EQUIPMENT	RELIANCE	RH INSULATION	AB51	1473.0 1629.0 305.0	H	A	SS		2761	00
S-65(1X-SB)	MOTOR	PROVIDE VENT FOR ESF EQUIPMENT	RELIANCE	RH INSULATION	AB51	1544.0 1627.0 305.0	H	A	SS		2762	00
TE 1AV 4836B SB	TEMPERATURE PRIMARY ELEMENT	RAB EMER FLTR E6 ENC INLET TEMP	COMAX	2310-9458-0 1	AB31	1582.0 1730.0 261.1	H	A	SS		0343	00
TE 1AV 4839B SB	TEMPERATURE PRIMARY ELEMENT	RAB EMER FLTR E6 CHAR FLTR IN TEMP	COMAX	2310-9458-0 1	AB31	1582.0 1730.0 261.2	H	A	SS		0356	00
TE 1AV 6502A SA	THERMOCOUPLE	RHR PMP ROOM AH-5 1A-SA FAN IN TEMP	WEED INSTRUMENT	E43250G-2A2	AB01	1444.0 1604.0 197.0	H	A	SS		0569	00
TE 1AV 6502B-SB	THERMOCOUPLE	RHR PMP ROOM AH-5 1B-SB FAN IN TEMP	WEED INSTRUMENT	E43250G-2A2	A901	1557.0 1604.0 197.0	H	A	SS		0570	00
TE 1AV 6507A-SA	THERMOCOUPLE	CC HX AREA AH-6 1A-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1410.0 1518.0 236.0	H	A	SS		0578	00
TE 1AV 6507B-SB	THERMOCOUPLE	CC HX AREA AH-6 1B-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	A921	1438.0 1518.0 236.0	H	A	SS		0577	00

TAGS INCLUDED: PDT 1AV4834B4SB----TE 1AV 6507B-SB
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # 3 NAME:AVD046-REAC.AUX.BLDG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG. 1.97	CES #	REV #
TE 1AV 6512A-SA	THERMOCOUPLE	CC HX AREA AH-7 1A-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1539.0 1518.0 236.0	H	A	SS		0585	00
TE 1AV 6512B-SB	THERMOCOUPLE	CC HX AREA AH-7 1B-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1575.0 1518.0 236.0	H	A	SS		0586	00
TE 1AV 6517X-SB	THERMOCOUPLE	SW BSTR PMP AREA AH-8 1X-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1601.0 1575.0 251.0	H	A	SS		0593	00
TE 1AV 6532A-SA	THERMOCOUPLE	MECH PENTRTM AH-11 1A-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1458.0 1622.0 236.0	H	A	SS		0615	00
TE 1AV 6532B-SB	THERMOCOUPLE	MECH PENTRTM AH-11 1B-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1479.0 1603.0 236.0	H	A	SS		0614	00
TE 1AV 6542A-SA	THERMOCOUPLE	AUX PMP RMS-HVAC CHILLER AH-19 ASA AREA	WEED INSTRUMENT	E43250G-2A2	AB31	1432.0 1570.0 267.0	H	A	SS		0642	00
TE 1AV 6552X SA	THERMOCOUPLE	MECH PENTRTM AH-23 1X-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB21	1532.0 1773.0 236.0	H	A	SS		0658	00
TE 1AV 6557X SA	THERMOCOUPLE	ELEC PENTRTM AH-24 1X-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB31	1441.0 1622.0 266.0	H	A	SS		0662	00
TE 1AV 6562X SB	THERMOCOUPLE	ELEC PENTRTM AH-25 1X-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB31	1542.0 1622.0 261.0	H	A	SS		0666	00
TE 1AV 6575X1 SA	THERMOCOUPLE	ROD CNTL CAB RM 1Y-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB51	1565.0 1587.0 305.0	H	A	SS		0679	00
TE 1AV 6577A SA	THERMOCOUPLE	MECH PENTRTM AH-28 1A-SA AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB11	1480.0 1627.0 220.0	H	A	SS		0680	00
TE 1AV 6577B SB	THERMOCOUPLE	POROV INJ PMP AH-28 1B-SB AREA TEMP	WEED INSTRUMENT	E43250G-2A2	AB11	1523.0 1627.0 220.0	H	A	SS		0681	00

TAGS INCLUDED: TE 1AV 6512A-SA---JAC-81SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84



SYSTEM # & NAME: AC0046-REAC.AUX.BLOG HVAC

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3AC-B1SA-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	SM3-0-25 W/H39C	AB51	1464.0 1581.0 307.0	H	A	SS		2155	00
3AC-B3SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	SM3-0-25 W/H39C	AB51	1536.0 1581.0 307.0	H	A	SS		2159	00
3AV-B4S9-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	SMC-04-5	AB31	1585.0 1724.0 261.0	H	A	SS		2168	00
3AV-B5SB-1	MOTOR OPERATOR	ACTUATE VALVE AND CONTROL POSITION	LIMITORQUE	SMC-04-5	AB31	1584.0 1759.0 261.0	H	A	SS		2170	00
AV-D59SB-1	PNEUMATIC OPERATOR	HOLD DAMPER IN REQUIRED POSITION	BETTIS	CB-315	AB21	1468.0 1586.0 247.0	H	A	SS		1816	00
E-10 (1A-5A) FXH. FAN	MOTOR	VENTILLATION OF SPACES CONTAINING ESF EQ PSI EQUIP.	WESTINGHOUSE	FRAME 143T	AB51	1595.0 1665.0 315.0	H	A	SS		2737	00
E-10 (1B-5B)	MOTOR	↓	WESTINGHOUSE	FRAME 143T	AB51	1595.0 1658.0 315.0	H	A	SS		2738	00

SYSTEM # & NAME: RH0003-RESIDUAL HEAT REMOVAL

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONN. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2RH-V71SA-1	SOLENOID VALVE	POST ACCIDENT SAMPLE POINT	TARGET ROCK	LATER	AB21	1438.0 1605.0 236.0	H	A	CRHR		3828	00
2RH-V72SB-1	SOLENOID VALVE	POST ACCIDENT SAMPLE POINT	TARGET ROCK	LATER	AB21	1561.0 1605.0 236.0	H	A	CRHR		4017	00

SYSTEM # & NAME: SP005A-SAMPLING SYSTEM

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SP-V116SA-1	SOLENOID VALVE	ACCUMULATOR SAMPLE HEADER	TARGET ROCK	792-005	AB21	1520.0 1635.0 236.0	H	A	CI	*	1486	00
2SP-V12SA-1	SOLENOID VALVE	VALVE ON TUBING RUN FROM RCS PRESSURIZER	TARGET ROCK	792-006	AB21	1511.0 1610.0 251.0	H	A	CI	*	1455	00
2SP-V120SA-1	SOLENOID VALVE	S/G-A BLOWN TO SIG SAMPLE COOLER-A	TARGET ROCK	792-005	AB21	1430.0 1687.0 255.0	H	A	CI	*	1475	00
2SP-V121SA-1	SOLENOID VALVE	S/G-B BLOWN TO S/G SAMPLE COOLER-B	TARGET ROCK	792-005	AB21	1492.0 1630.0 255.0	H	A	CI	*	1476	00
2SP-V122SA-1	SOLENOID VALVE	S/G-C BLOWN TO S/G SAMPLE COOLER-C	TARGET ROCK	792-005	AB21	1580.0 1687.0 255.0	H	A	CI	*	1477	00
2SP-V2SA-1	SOLENOID VALVE	VALVE ON TUBING RUN FROM RCS PRESSURIZER	TARGET ROCK	792-006	AB21	1518.0 1630.0 236.0	H	A	CI	*	1453	00
2SP-V23SA-1	SOLENOID VALVE	VALVE ON TUBING RUN FROM RCS HOT LEGS OUTST	TARGET ROCK	792-006	AB21	1511.0 1630.0 236.0	H	A	CI	*	1473	00
2SP-V302SB-1	SOLENOID VALVE	LATER	TARGET ROCK	792-018	AB21	1455.0 1645.0 255.1	H	A	CI	*	1488	00
2SP-V303SB-1	SOLENOID VALVE	LATER	TARGET ROCK	792-018	AB21	1455.0 1645.0 255.2	H	A	CI	*	1491	00
2SP-V304SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-018	AB21	1455.0 1645.0 255.5	H	A	CI	*	1489	00
2SP-V305SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-018	AB21	1455.0 1645.0 255.6	H	A	CI	*	1492	00
2SP-V314SB-1	SOLENOID VALVE	LATER	TARGET ROCK	792-018	AB21	1560.0 1662.0 255.3	H	A	CI	*	1497	00

TAGS INCLUDED: 2SP-V116SA-1 ----2SP-V315-1 SB
 SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: SPC05A-SAMPLING SYSTEM

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SP-V315SP-1	SOLENOID VALVE	SP LINE FROM H Y ANALYZER SKI D-SB	TARGET ROCK	LATER	AB21	1560.0 1662.0 255.4	H	A	CI	*	3748	00
2SP-V348SA-1	SOLENOID VALVE	SP LINE FROM S AMPLING HDR - ASSEMBLY TO HY	TARGET ROCK	LATER	AB21	1454.0 1647.0 255.0	H	A	CI	*	3747	00
2SP-V409SA-1	SOLENOID VALVE	POST ACC SAMPL E RETURN (GAS) CONTAM ISOLATI	TARGET ROCK	LATER	AB21	1444.0 1658.0 251.0	H	A	CI		3753	00

SYSTEM # & NAME: SW0015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
FT 1SW 9112A SA	FLOW TRANSMITTER	SW BSTR PMP A DISCH FLOW	ROSEMOUNT	1153DB5	AB21	1412.0 1568.0 236.0	H	A	SS		1110	00
FT 1SW 9112B SB	FLOW TRANSMITTER	SW BSTR PMP B DISCH FLOW	ROSEMOUNT	1153DB5	AB21	1620.0 1568.0 236.0	H	A	SS		1111	00
FT 1SW 9205A SA	FLOW TRANSMITTER	SW FROM RAB A CHILLER WC-2 FLOW	ROSEMOUNT	1153DB4	AB21	1412.0 1568.0 236.0	H	A	SS		1126	00
FT 1SW 9205B SB	FLOW TRANSMITTER	SW FROM RAB B CHILLER WC-2 FLOW	ROSEMOUNT	1153DB4	AB21	1531.0 1568.0 236.0	H	A	SS		1127	00
FT 1SW 9275A SB	FLOW TRANSMITTER	SW FROM CONT FAN CLR AH-1 FLOW	ROSEMOUNT	1153DB4	AB11	1473.0 1624.0 216.0	H	A	SS		1157	00
FT 1SW 9275B SA	FLOW TRANSMITTER	SW FROM CONT FAN COOLER AH-2	ROSEMOUNT	1153DB4	AB11	1527.0 1624.0 216.0	H	A	SS		1159	00
FT 1SW 9275C SA	FLOW TRANSMITTER	SW FROM CONT FAN COOLER AH-3	ROSEMOUNT	1153DB4	AB11	1527.0 1624.0 216.0	H	A	SS		1158	00
FT 1SW 9275D SB	FLOW TRANSMITTER	SW FROM CONT FAN COOLER AH-4	ROSEMOUNT	1153DB4	AB11	1584.0 1622.0 216.0	H	A	SS		1160	00
PT 1SW 9112A SA	PRESSURE TRANSMITTER	SW BSTR PMP DISC PRES	ROSEMOUNT	1153GB8	AB21	1412.0 1568.0 236.0	H	A	SS		1117	00
PT 1SW 9112B SB	PRESSURE TRANSMITTER	SW BSTR PMP B DISC PRES	ROSEMOUNT	1153GB8	AB21	1620.0 1568.0 236.0	H	A	SS		1116	00
P1A-SA SW BOOSTER	MOTOR	PROVIDE ESW TO CONT FAN COOLERS	SIEMENS ALLIS	FL-R-5103-9 7237-2	AB21	1419.0 1578.0 236.0	H	A	SS		2763	00
P1B-SB SW BOOSTER	MOTOR	PROVIDE ESW TO CONT FAN COOLERS	SIEMENS ALLIS	EL-R-5103-9 7232-2	AB21	1602.0 1571.0 236.0	H	A	SS		2765	00

TAGS INCLUDED: FT 1SW 9112A SA---P19-S3 SW B SP
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: S40015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
REM 1SW3500A SB	RADIATION MONITOR SKID	SW FROM CONT F AN CLR AH-1 RAD	GENERAL ATO MIC	LATER	AB11	1458.0 1637.0 220.0	H	A	PRRM		0243	00
REM 1SW3500B SA	RADIATION MONITOR SKID	SW FROM CONT F AN CLR AH-2 RAD	GENERAL ATO MIC	LATER	AB11	1520.0 1627.0 220.0	H	A	PRRM		0241	00
REM 1SW3500C SA	RADIATION MONITOR SKID	SW FROM CONT F AN CLR AH-3 RAD	GENERAL ATO MIC	LATER	AB11	1483.0 1627.0 220.0	H	A	SS		0244	00
REM 1SW3500D SB	RADIATION MONITOR SKID	SW FROM CONT F AN CLR AH-4 RAD	GENERAL ATO MIC	LATER	AB11	1533.0 1637.0 220.0	H	A	PRRM		0262	00
2SW-B45SA-1	MOTOR OPERATOR	SW SUPPLY TO CONTM FAN COOLER AH-2	LIMITORQUE	SMC-04-S-HO 9C	AB11	1545.0 1645.0 230.0	H	A	SS		3172	00
2SW-B46SA-1	MOTOR OPERATOR	SW SUPPLY TO CONTM FAN COOLER AH-3	LIMITORQUE	SMC-04-S-HO 9C	AB11	1455.0 1645.0 230.0	H	A	SS		3174	00
2SW-B47SA-1	MOTOR OPERATOR	SW RETURN FROM CONTM FAN COOLER AH-3	LIMITORQUE	SMC-04-S-HO 9C	AB11	1470.0 1635.0 230.0	H	A	SS		3176	00
2SW-B48SB-1	MOTOR OPERATOR	SW RETURN FROM CONTM FAN COOLER AH-1	LIMITORQUE	SMC-04-S-HO 9C	AB11	1453.0 1648.0 230.0	H	A	SS		3178	00
2SW-B49SA-1	MOTOR OPERATOR	SW RETURN FROM CONTM FAN COOLER AH-2	LIMITORQUE	SMC-04-S-HO 9C	AB11	1529.0 1635.0 230.0	H	A	SS		3180	00
2SW-B50SB-1	MOTOR OPERATOR	SW RETURN FROM CONTM FAN COOLER AH-4	LIMITORQUE	SMC-04-S-HO 9C	AB11	1550.0 1649.0 230.0	H	A	SS		3182	00
2SW-B51SB-1	MOTOR OPERATOR	SW SUPPLY TO CONTM FAN COOLER AH-4	LIMITORQUE	SMC-04-S-HO 9C	AB11	1552.0 1653.0 230.0	H	A	SS		3184	00
2SW-B52SB-1	MOTOR OPERATOR	SW SUPPLY TO CONTM FAN COOLER AH-1	LIMITORQUE	SMC-04-S-HO 9C	AB11	1448.0 1652.0 230.0	H	A	SS		3186	00

TAGS INCLUDED: REM 1SW3500A SB----2SW-B52SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # 2, NAME: SW0015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
2SW-888SAB-1	SOLENOID VALVE (1 OF 2)	SW SUPPLY TO NON SAFETY HVAC COOLERS	ASCO	NP320A175E	AB11	1430.0 1693.0 233.0	H	A	SS	*	3188	00
2SW-888SAB-1	LIMIT SWITCH H (1 OF 4)	SW SUPPLY TO NON SAFETY HVAC COOLERS	NAMCO	EA-180-1130 2	AB11	1430.0 1693.0 233.0	H	A	SS	*	3189	00
2SW-888SAB-1	LIMIT SWITCH H (2 OF 4)	SW SUPPLY TO NON SAFETY HVAC COOLERS	NAMCO	EA-180-1130 2	AB11	1430.0 1693.0 233.0	H	A	SS	*	5096	00
2SW-888SAB-1	LIMIT SWITCH H (3 OF 4)	SW SUPPLY TO NON SAFETY HVAC COOLERS	NAMCO	EA-180-1130 2	AB11	1430.0 1693.0 233.0	H	A	SS	*	5097	00
2SW-888SAB-1	LIMIT SWITCH H (4 OF 4)	SW SUPPLY TO NON SAFETY HVAC COOLERS	NAMCO	EA-180-1130 2	AB11	1430.0 1693.0 233.0	H	A	SS	*	5098	00
2SW-888SAB-1	SOLENOID VALVE (2 OF 2)	SW SUPPLY TO NON SAFETY HVAC COOLERS	ASCO	NP320175E	AB11	1430.0 1693.0 233.0	H	A	SS	*	5099	00
2SW-890SB-1	SOLENOID VALVE	FAIL CLOSED	ASCO	NP320A175E	AB11	1435.0 1660.0 230.0	H	A	SS	*	3192	00
2SW-890SB-1	LIMIT SWITCH H (1 OF 2)	FAIL CLOSED	NAMCO	EA-180-1130 2	AB11	1435.0 1660.0 230.0	H	A	SS	*	3193	00
2SW-890SB-1	LIMIT SWITCH H (2 OF 2)	FAIL CLOSED	NAMCO	EA-180-1130 2	AB11	1435.0 1660.0 230.0	H	A	SS	*	5094	00
3SW-813SB-1	MOTOR OPERATOR	SW RETURN HDR A TO NORM SW DISCH HDR	LIMITORQUE	SM3-00-10-H 29C	AB21	1636.0 1578.0 239.0	H	A	SS		3102	00
3SW-814SB-1	MOTOR OPERATOR	SW RETURN HDR P TO NORM SW DISCH HDR	LIMITORQUE	SM3-00-10-H 29C	AB21	1636.0 1575.0 240.0	H	A	SS		3104	00
3SW-864SA-1	SOLENOID VALVE	FAIL CLOSED	ASCO	NP320A-175 E	AB11	1447.0 1608.0 218.0	H	A	SS		3124	00

TAGS INCLUDED: 2SW-988SAB-1 ----3SW-864SA-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: SW0015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3SW-B64SA-1	LIMIT SWITC H (1 OF 2)	SW RETURN FROM CONTMT FAN COOLER AH-2	NAMCO	EA-180-1130 2	AB11	1447.0 1608.0 218.0	H	A	SS		3125	00
3SW-B64SA-1	LIMIT SWITC H (2 OF 2)	SW RETURN FROM CONTMT FAN COOLER AH-2	NAMCO	EA-180-1130 2	AB11	1447.0 1608.0 218.0	H	A	SS		5095	00
3SW-B65SB-1	SOLENOID VAL LVE	LATER	ASCO	MP1320A175E	AB11	1558.0 1614.0 228.0	H	A	SS		3126	00
3SW-B65SB-1	LIMIT SWITC H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1558.0 1614.0 228.0	H	A	SS		3127	00
3SW-B65SB-1	LIMIT SWITC H (2 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1558.0 1614.0 228.0	H	A	SS		5095	00
3SW-B70SA-1	MOTOR OPERA TOR	SW FROM SW SUP PLY HDR A TO A UX FW PMP 1X-S	LIMITORQUE	SMC-04-2-HO RC	AB21	1496.0 1548.0 240.0	H	A	SS		3130	00
3SW-B71SA-1	MOTOR OPERA TOR	LATER	LIMITORQUE	SMC-04-2-HO RC	AB21	1506.0 1548.0 240.0	H	A	SS		3132	00
3SW-B72SB-1	MOTOR OPERA TOR	SW FROM SW SUP PLY HDR B TO A UX FW PUMP 1X-	LIMITORQUE	SMC-04-2-HO RC	AB21	1518.0 1548.0 240.0	H	A	CI		3134	00
3SW-B73SB-1	MOTOR OPERA TOR	LATER	LIMITORQUE	SMC-04-2-HO RC	AB21	1510.0 1548.0 240.0	H	A	CI		3136	00
3SW-B74SA-1	MOTOR OPERA TOR	FROM 3SW10-68S A-1 TO AUX FW PUMP 1A-SA SUC	LIMITORQUE	SMC-04-2-HO RC	AB21	1493.0 1521.0 238.0	H	A	SS		3138	00
3SW-B75SA-1	MOTOR OPERA TOR	LATER	LIMITORQUE	SMC-04-2-HO RC	AB21	1493.0 1520.0 238.0	H	A	SS		3140	00
3SW-B76SB-1	MOTOR OPERA TOR	FROM 3SW10-74S B-1 TO AUX FW PUMP 1P-SB SUC	LIMITORQUE	SMC-04-2-HO RC	AB21	1509.0 1526.0 238.0	H	A	SS		3142	00

TAGS INCLUDED: 3SW-B64SA-1 ----3SW-B76SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # & NAME: SW0015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3SW-B77SB-1	MOTOR OPERATOR	LATER	LIMITORQUE	54C-04-2-HO RC	AB21	1509.0 1521.0 238.0	H	A	SS		3144	00
3SW-B85A-1	MOTOR OPERATOR	SW RETURN FROM AUX BLDG HDR B TO SW RETURN	LIMITORQUE	SM3-00-10/H RC	AB21	1636.0 1574.0 240.0	H	A	SS		3146	00
3SW-V237SA-1	SOLENOID VALVE	LATER	PARKER HANNIFIN	H232 NC-50	AB21	1646.0 1538.0 236.0	H	A	SS		3154	00
3SW-V237SA-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	D2600X-2	AB21	1646.0 1538.0 236.0	H	A	SS		3155	00
3SW-V237SA-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	D2600X-2SR	AB21	1646.0 1538.0 236.0	H	A	SS		4998	00
3SW-V238SB-1	SOLENOID VALVE	LATER	PARKER HANNIFIN	H232 NC-50	AB21	1645.0 1538.0 236.0	H	A	SS		3156	00
3SW-V238SB-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	D2600X-2	AB21	1645.0 1538.0 236.0	H	A	SS		3157	00
3SW-V238SB-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	D2600X-2SR	AB21	1645.0 1538.0 236.0	H	A	SS		4995	00
3SW-V266SA-1	SOLENOID VALVE	LATER	PARKER HANNIFIN	H232 NC-50	AB21	1646.0 1549.0 237.0	H	A	SS		3158	00
3SW-V266SA-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	D2600X-2	AB21	1646.0 1549.0 237.0	H	A	SS		3159	00
3SW-V266SA-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	D2600X-2SR	AB21	1646.0 1549.0 237.0	H	A	SS		4996	00
3SW-V267SB-1	SOLENOID VALVE	LATER	PARKER HANNIFIN	H232 NC-50	AB21	1646.0 1548.0 237.0	H	A	SS		3160	00

TAGS INCLUDED: 3SW-B77SB-1 -----3SW-V267SB-1
SORT TYPE: GLOBAL REV#- 0 09/05/84

SYSTEM # ME:SW0015-SERVICE WATER

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
3SW-V267SB-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	02600X-2	AB21	1646.0 1548.0 237.0	H	A	SS		3161	00
3SW-V267SB-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	02600X-2SR	AB21	1646.0 1548.0 237.0	H	A	SS		4997	00
3SW-V480SB-1	SOLENOID VALVE	LATER	ASCO	MP320A175E	AB11	1393.0 1615.0 216.0	H	A	SS		3162	00
3SW-V480SB-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1393.0 1615.0 216.0	H	A	SS		3163	00
3SW-V480SB-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1393.0 1615.0 216.0	H	A	SS		5092	00
3SW-V481SA-1	SOLENOID VALVE	LATER	ASCO	MP320A175E	AB11	1393.0 1609.0 216.0	H	A	SS		3164	00
3SW-V481SA-1	LIMIT SWITCH H (1 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1393.0 1609.0 216.0	H	A	SS		3165	00
3SW-V481SA-1	LIMIT SWITCH H (2 OF 2)	LATER	NAMCO	EA-180-1130 2	AB11	1393.0 1609.0 216.0	H	A	SS		5091	00
3SW-V597SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-014	AB21	1452.0 1620.0 237.0	H	A	SS		3791	00
3SW-V599SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-014	AB21	1529.0 1619.0 237.0	H	A	SS		3792	00
3SW-V601SA-1	SOLENOID VALVE	LATER	TARGET ROCK	792-014	AB21	1427.0 1612.0 237.0	H	A	SS		3793	00
3SW-V603SB-1	SOLENOID VALVE	LATER	TARGET ROCK	792-014	AB21	1552.0 1619.0 237.0	H	A	SS		3794	00
3SW-P15SA-1	MOTOR GENERATOR	LATER	LIMITORQUE	SM2-00-10 H2PC	TA12	1947.0 1573.0 226.0	H	A	SS		3106	00
3SW-P16SA-1	MOTOR GENERATOR	LATER	LIMITORQUE	SM2-00-10 H2PC	TA12	1947.0 1554.0 226.0	H	A	SS		3108	00

SYSTEM # 2 E:SF0004-SPNT FUEL POOL COOL&CLNUP

TAG NO	COMPONENT NAME	FUNCTION & SERVICE	MANUFACTUR.	MODEL/SER	PLANT LOCATION	LOCATION X,Y,Z	ENVIRONM. H/M	FUNCT. CATEG.	SAFETY FUNCTION	REG 1.97	CES #	REV #
FP CLG P1 & 4A- SA	MOTOR	FUEL POOL COOLING PUMP DRIVE	SIEMENS-ALL IS	EL-8-5103-9 0232-1	FH21	1621.0 1816.0 236.0	H	A	SS		4985	00
FP CLG P1 & 4B- SB	MOTOR	FUEL POOL COOLING PUMP DRIVE	SIEMENS-ALL IS	EL-8-5103-9 0232-1	FH21	1633.0 1816.0 236.0	H	A	SS		4986	00
FP CLG P2 & 3A- SA	MOTOR	FUEL POOL COOLING PUMP DRIVE	SIEMENS-ALL IS	EL-8-5103-9 0232-1	FH21	1695.0 1816.0 236.0	H	A	SS		4987	00
FP CLG P2 & 3B- SB	MOTOR	FUEL POOL COOLING PUMP DRIVE	SIEMENS-ALL IS	EL-8-5103-9 0232-1	FH21	1665.0 1816.0 236.0	H	A	SS		4988	00

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : REM 1SW350GD SB	OPERABIL- ITY	LATER NORM N/A	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT: TYPE	PRIMARY ELEMENT DBA	DBA (SEE NOTE 1)			SRSO 8.7SH1	REVIEW		
COMPONENT:	RADIATION MONIT OR SKID	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER:	GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : SUPPLIER	GENERAL ATOMIC	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SERIAL #	LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	SW FROM CONT F AN CLR AH-4 RAD	ACCUR. SPEC:	NOT APPLICABLE					
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS:	N-29	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #:	435220	PLANT LOC.:	AB11			SRSA 8.7SH1		
COORDINATES X- Y- Z-	1533. 1637. 220.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW					
INSTAL. REF:	BY-FLD	OPERABILITY	O	8.7SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T	8.7SH1	REFERENCES: NOTE 1: NOT REQUIRED FOR THE SHUTDOWN OF THE PLANT DURING A DBA * INCLUDES A 10% MARGIN			CES#-0242
*QUALIF:	LATER	PRESSURE	P	8.7SH1				
*STATUS		REL. HUMDTY	H	8.7SH1				
*		CHEM. SPRAY	C	8.7SH1				
*		RADIATION	R	8.7SH1				
*****		AGING	A	8.7SH1				
		SUBMERGENCE	S	8.7SH1		REVISION # :00 DATE :		
EQ. PCK # :	8.7SH1	OS88 CATEG.:	A			SYSTEM : SERVICE WATER		
		APPENDIX E				TAG : REM 1SW3500D SB		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : REM 1SW350GA SB	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY FLEMENT TYPE	NORM/TEST DBA				SRSO 8.7SH1				
COMPONENT: RADIATION MONITOR SKID	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	ACCUR. SPEC:	NOT APPLICABLE							
SW FROM CONT F AN CLR AH-1 RAD	ACCUR. DEM.:	NOT APPLICABLE							
	SPECIFICATIONS:	M-29							
	P.O #:	435220							
	PLANT LOC.:	AB11							
	COORDINATES	X- 1458. Y- 1637. Z- 220.0							
	INSTALLED (Y/N):	LTR							
	INSTAL. REF:	BY-FLO							
	QUALIF EXEMPTN:	NOT APPLIC							
	*QUALIF:	LATER							
	*STATUS								
	*RADIATION	P 8.7SH1							
	*AGING	A 8.7SH1							
	*SURMERGENCE	S 8.7SH1							
	EQ. PCK # :	8.7SH1							
	0588 CATEG.:	A							
	APPENDIX	E							
FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1			
REFERENCES: NOTE 1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA * INCLUDES A 10% MARGIN						CESN-0243			
						REVISION # : 00			
						DATE :			
						SYSTEM : SERVICE WATER			
						TAG : REM 1SW350GA SB			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : REM 1SW3500C SA	OPERABIL- ITY	LATER NORM 4/A	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA (SEF)			SRSO 8.7SH1					
COMPONENT: RADIATION MONIT OR SKID	TEMPERAT- URE	104F NORM 104F 09A	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : GENERAL ATOMIC SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% 09A	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE					SRS6 8.7SH1					
ACCUR. SPEC: NOT APPLICABLE					SRSR 8.7SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: N-29	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435220					SRSA 8.7SH1					
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1483. Y- 1627. Z- 220.0					SRSS 8.7SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW		FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY	O 8.7SH1						CES#-0244		
*QUALIF: LATER	*TEMPERATURE	T 8.7SH1								
*STATUS	*PRESSURE	P 8.7SH1								
*	*REL. HUMDTY	H 8.7SH1								
*	*CHEM. SPRAY	C 8.7SH1								
*****	*RADIATION	R 8.7SH1								
	*AGING	A 8.7SH1								
	*SUBMERGENCE	S 8.7SH1								
EQ. PCK # : 8.7SH1	0588 CATEG.: A APPENDIX E			REFERENCES: NOTE 1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA * INCLUDES A 10% MARGIN				REVISION # : 00 DATE :		
								SYSTEM : SERVICE WATER		
								TAG : REM 1SW3500C SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : REM 1CC3501A SA	OPERABILITY	40 YRS		OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	DBA (SEE NOTE 1)			SRSO					
COMPONENT: RADIATION MONITOR OR SKID	TEMPERATURE	104F NOPM 104F DBA		TAB21A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:	
MAJOR SUPPLIER: GENERAL ATOMIC					SRSP				SUBCOMPONENTS:	
MODEL AND SERIAL #: RM-80	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: COMP COOLING WATER RAD	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4		RAB21R7 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: N-29					SRSR					
P.O #: 435220	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB21					SRSA					
COORDINATES X- 1415. Y- 1521. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O					CES#-0245			
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SURMERGENCE	S								
EQ. PCK # :	0528 CATEG.: A	APPENDIX E	REFERENCES: NOTE 1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA * INCLUDES A 10% MARGIN				REVISION # : 00 DATE :			
							SYSTEM : COMP. COOLING WATER TAG : REM 1CC3501A SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO : REM 1CC3501B SE	OPERABIL-ITY	40 YRS NORM N/A		OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	DRA (SEE NOTE 1)			SRSO			
COMPONENT: RADIATION MONITOR OR SKID	TEMPERATURE	104F NORM 104F DRA		TAB21A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: GENERAL ATOMIC					SRST			
MAJOR SUPPLIER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA		PAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE
MODEL AND SERIAL #: RP-80	RELATIVE HUMIDITY	20-90% NORM 100% DRA		HAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: COMP COOLING WATER & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSP			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4		RAB21R7 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: N-29					SRSH			
P.O #: 435220	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSA			
COORDINATES X- Y- Z-: 1560. 1521. 236.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR					SRSS			

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: CI

QUALIF EXEMPTN: NOT APPLIC

*QUALIF:
*STATUS
*
*

PARAMETER	SUPPL. REVIEW
OPERABILITY	O
TEMPERATURE	T
PRESSURE	P
REL. HUMIDTY	H
CHEM. SPRAY	C
RADIATION	R
AGING	A
SUBMERGENCE	S
G588 CATEG.: A	
APPENDIX E	

FOR PUNCLIST ITEMS SEE SHEET PACKAGE:

REFERENCES: NOTE -1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA * INCLUDES A 10% MARGIN

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

CS9-0246

REVISION #: 00
DATE:

SYSTEM: COMP. COOLING WATER
TAG: REM 1CC3501B SB

EQ. PCK #:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : REM 1LT3502A SA	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	NORM N/A DBA (SFE NOTE 1)							
COMPONENT: RADIATION MONITOR OR SKID	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	ACCUR. SPEC:	CONTAINMENT LEAK DET SYS R AD							
	ACCUR. DEM.:	NOT APPLICABLE							
	SPECIFICATIONS:	N-29							
P.O. #: 435220	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
PLANT LOC.: A821	A BETA	7.2E4							
	D B SHIELD	100X							
	S T.I.D.	3.0E4							
COORDINATES X- 1453.	AGE- INST LIFE	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
Y- 1624.	(PER 323-1974 DEF.)								
Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 8.7SH1							
QUALIF EXEMPTH: NOT APPLIC	TEMPERATURE	T 8.7SH1							
	PRESSURE	P 8.7SH1							
	REL. HUMDTY	H 8.7SH1							
	CHEM. SPRAY	C 8.7SH1							
	RADIATION	R 8.7SH1							
	AGING	A 8.7SH1							
	SUBMERGENCE	S 8.7SH1							
EQ. PCK # : 8.7SH1	U588 CATEG.:	A							
	APPENDIX	E							

FOP PUNCLIST ITEMS SEE SH EO PACKAGE: 8.7SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1

CES#-0247

REFERENCES: NOTE 1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT

REVISION # : 00
 DATE :

SYSTEM : LEAK RATE TESTING
 TAG : REM 1LT3502A SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : PEM 1LT3502B SB	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	SENSORS								
COMPONENT:	RADIATION MONIT OR SKID	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER:	GENERAL ATOMIC								MAINTAIN.:
MAJOR : SUPPLIER	GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS: .
MODEL AND: SERIAL #	LATER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CONTAINMENT LE AK DET SYS R AD	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE								
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	N-29								
P.O #:	435220	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.:	AB21								
COORDINATES X- Y- Z-	1547. 1624. 236.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR								
INSTAL. REF:	BY-FLD								
QUALIF EXEMPTN:	NOT APPLIC	PARA- METER	SUPPL. REVIEW						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1
*****		OPERABILITY O	8.7SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
*QUALIF:	LATER	*TEMPERATURE T	8.7SH1						
*STATUS		*PRESSURE P	8.7SH1						
*		*REL. HUMIDTY H	8.7SH1						CES#-0248
*		*CHEM. SPRAY C	8.7SH1						
*****		*RADIATION R	8.7SH1						REFERENCES: NOTE 1: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA
		*AGING A	8.7SH1						
		*SUBMERGENCE S	8.7SH1						REVISION # :00 DATE :
EQ. PCK # :	8.7SH1								SYSTEM : LEAK RATE TESTING
		058E CATEG.:	A						TAG : REM 1LT3502B SB
		APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : RE 1CZ 3504A SA	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA	NORM 1 YR DBA (SEE NOTE 1)								
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: CNTL RM NORM O UTSDEAIR INTAKE RAD	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%								
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4								
SPECIFICATIONS: N-29	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435220	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB51										
COORDINATES X- 1599. Y- 1681. Z- 309.0										
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1	
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	8.7SH1		REFERENCES: * INCLUDES 10X MARGIN					CESN-0249	
*QUALIF: LATER	TEMPERATURE T	8.7SH1								
*STATUS	PRESSURE P	8.7SH1								
*	REL. HUMIDTY H	8.7SH1								
*	CHEM. SPRAY C	8.7SH1								
*****	RADIATION R	8.7SH1								
	AGING A	8.7SH1						REVISION # :00		
	SUBMERGENCE S	8.7SH1						DATE :		
EQ. PCK # : 8.7SH1	OS88 CATEG.: A	APPENDIX E						SYSTEM : CONTROL ROOM HVAC		
								TAG : RE 1CZ 3504A SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : RM 1CZ 3504A SA	OPERABILITY	LATER NORM 1 YP DBA (SEE NOTE 10)	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: PRIMARY ELEMENT	TEMPERATURE	104F NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:				
COMPONENT: MICROPROCESSOR	PRESSURE	ATMOS NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:				
MANUFACTURER: GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MAJOR SUPPLIER: GENERAL ATOMIC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MODEL AND SERIAL #: LATER	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: CNTL RM NORM 0 UTSDE AIR INTAKE RAD	D B SHIELD	100%		SRSR 8.7SH1									
ACCUR. SPEC: NOT APPLICABLE	S T.I.D.	3.7E4		SRSA 8.7SH1									
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
SPECIFICATIONS: N-29	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
P.O #: 435220	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1			
PLANT LOC.: AB51	OPERABILITY	O 8.7SH1		REFERENCES: * INCLUDES 10% MARGIN						CES#-0250			
COORDINATES X= 1594. Y= 1669. Z= 309.0	TEMPERATURE	T 8.7SH1											
INSTALLED (Y/N): LTP	PRESSURE	P 8.7SH1											
INSTAL. REF: BY-FLD	REL. HUMIDTY	H 8.7SH1											
QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C 8.7SH1											
*****	RADIATION	R 8.7SH1											
*QUALIF: LATER	AGING	A 8.7SH1											
*STATUS	SUBMERGENCE	S 8.7SH1											
*	0588 CATEG.: A												
*	APPENDIX E												

EQ. PCK #: 8.7SH1									REVISION #: 00				
									DATE :				
									SYSTEM: CONTROL ROOM				
									HVAC				
									TAG: RM 1CZ 3504A SA				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : RM 1CR 3561A SA	OPERABIL-ITY	LATER 15MIN DBA	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	1HR MARGIN			SRSO 8.7SH1				
COMPONENT: MICROPROCESSOR	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: N-29	S T.I.D.	2.6E4							
P.O #: 435220	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1421. Y- 1676. Z- 265.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY O	8.7SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
INSTAL. REF: BY-FLD	TEMPERATURE T	8.7SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE P	8.7SH1							
*****	REL. HUMDTY H	8.7SH1							CESN-0274
*QUALIF: LATER	CHEM. SPRAY C	8.7SH1							
*STATUS	RADIATION R	8.7SH1							
*	AGING A	8.7SH1							
*	SUBMERGENCE S	8.7SH1							

EQ. PCK # : 8.7SH1	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : RAD. MONITORING
									TAG : RM 1CR 3561A SA

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PY 1CR 3561C SA	OPERABIL- ITY	LATER. 15MIN DBA+	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1HR MARGIN			SRSO 8.7SH1					
COMPONENT: MICROPROCESSOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE	CONTAINMENT IS OL SYS			SRSR 8.7SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: N-29	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
P.O #: 435220	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB31	COORDINATES X- Y- Z-	1438. 1641. 265.0			SRSS 8.7SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY	O 8.7SH1		REFERENCES:				CESN-0275		
*QUALIF: LATER	*TEMPERATURE	T 8.7SH1								
*STATUS	*PRESSURE	P 8.7SH1								
*	*REL. HUMDTY	H 8.7SH1								
*	*CHEM. SPRAY	C 8.7SH1								
*****	RADIATION	R 8.7SH1								
	AGING	A 8.7SH1								
	SURMERGENCE	S 8.7SH1								
EQ. PCK # : 8.7SH1	OS8R CATEG.: A APPENDIX E							REVISION # : 00 DATE :		
								SYSTEM : RAD. MONITORING TAG : RM 1CR 3561C SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : RM 1CR 3561D SB	OPERABILITY	LATER 15MIN DRA+ NORM/TEST 1HR MARGIN	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	DBA				SRSO 8.7SH1				
COMPONENT: MICROPROCESSOR	TEMPERATURE	104F NORM 104F DRA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTAINMENT ISOL SYS	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: N-29	S T.I.D.	2.6E4							
P.O #: 435220	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1579. Y- 1676. Z- 265.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 8.7SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 8.7SH1							
*****	PRESSURE	P 8.7SH1							CES#-0276
*QUALIF: LATER	REL. HUMIDTY	H 8.7SH1							
*STATUS	CHEM. SPRAY	C 8.7SH1							
*	RADIATION	R 8.7SH1							
*	AGING	A 8.7SH1							REVISION # :00
*****	SUBMERGENCE	S 8.7SH1							DATE :
EQ. PCK # : 8.7SH1									SYSTEM : RAD. MONITORING
	0588 CATEG.: A								TAG : RM 1CR 3561D SB
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : RM 1CR 3561B SB	OPERABILITY	LATER 15MIN DBA	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	1HR MARGIN			[SRSO 8.7SH1]			
COMPONENT: MICORPROCESSOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES & SERVICE : CONTAINMENT IS OL SYS	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: N-29	S T.I.D.	2.6E4				[SRSR 8.7SH1]		
P.O #: 435220	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1567. Y- 1658. Z- 265.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR	OPERABILITY	O 8.7SH1						
INSTAL. REF: BY-FLD	TEMPERATURE	T 8.7SH1						
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 8.7SH1						
*QUALIF: LATER	REL. HUMPTY	H 8.7SH1						
*STATUS	CHEM. SPRAY	C 8.7SH1						
*	RADIATION	R 8.7SH1						
*	AGING	A 8.7SH1						
*	SUBMERGENCE	S 8.7SH1						
EQ. PCK # : 8.7SH1	OS88 CATEG.: A							
	APPENDIX E							

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1.

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1

REFERENCES:

CSN-0277

REVISION # : 00
 DATE :

SYSTEM : RAD. MONITORING

TAG : RM 1CR 3561B SB

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : RE 1CR 3563B SB	OPERABILITY	LATER N/A DRA	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA	(SEE NOTE 1)			SRSO 8.7SH1				
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE	104F NORM 104F DRA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA	LATEP	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTAINMENT POST- LOCA	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD S T.I.D.	100% 2.6E4			SRSR 8.7SH1				
SPECIFICATIONS: H-29	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #: 435220	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB31	PARA-METER	SUPPL. REVIEW							
COORDINATES X- 1542. Y- 1637. Z- 265.5	OPERABILITY	O 8.7SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1
INSTALLED (Y/N): LTR	TEMPERATURE	T 8.7SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
INSTAL. REF: BY-FLD	PRESSURE	P 8.7SH1							CES#-0278
QUALIF EXEMPT: NOT APPLIC	REL. HUMIDTY	H 8.7SH1							
*****	CHEM. SPRAY	C 8.7SH1							
*QUALIF: LATER	RADIATION	R 8.7SH1							
*STATUS	AGING	A 8.7SH1							
*	SUBMERGENCE	S 8.7SH1							
*									

EQ. PCK # : 8.7SH1	0588 CATEG.: A								REFERENCES:
	APPENDIX E								
									REVISION # : 00
									DATE :
									SYSTEM : RAD. MONITORING
									TAG : RE 1CR 3563B SB

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : RE 1CR 3563A SA	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: SENSORS	NORM/TEST DBA	N/A DBA (SEE NOTE 1)			SRSO 8.7SH1							
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	REPLACEMENT:			
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:			
MAJOR SUPPLIER: GENERAL ATOMIC					SRSP 8.7SH1				SUBCOMPONENTS:			
MODEL AND SERIAL #: LATER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES: CONTAINMENT POST- LOCA	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: 1. NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA			
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE				
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM			
SPECIFICATIONS: N-29	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
P.O #: 435220					SRSS 8.7SH1							
PLANT LOC.: AR31												
COORDINATES X- 145P. Y- 1638. Z- 265.0												
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1			
INSTAL. REF: BY-FLD	OPERABILITY	O 8.7SH1		REFERENCES:					CES#-0279			
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 8.7SH1										
*QUALIF: LATER	PRESSURE	P 8.7SH1										
*STATUS	REL. HUMIDTY	H 8.7SH1										
*	CHEM. SPRAY	C 8.7SH1										
*	RADIATION	R 8.7SH1										
*****	AGING	A 8.7SH1										
	SUBMERGENCE	S 8.7SH1										
EQ. PCK #: 8.7SH1	0588 CATEG.: A								REVISION #: 00			
	APPENDIX E								DATE :			
									SYSTEM: RAD. MONITORING			
									TAG : RE 1CR 3563A SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.					
TAG NO : RM 1CR 3563A SA	OPERABIL-ITY	LATER N/A DBA	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT	NORM/TEST DBA	(SEE NOTE 1)			SRSO 8.7SH1					
COMPONENT: MICORPROCESSOR	TEMPERAT-URE	104F NORM 104F DBA	LATEP	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATEP	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATEP	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:	
FUNCT. DES. & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSR 8.7SH1				.NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: N-29	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRM	
P.O #: 435220	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB31	COORDINATES X- Y- Z-	1421. 1655. 265.0			SRSS 8.7SH1					
COORDINATES X- Y- Z-	INSTALLED (Y/N): LTR									
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY O	8.7SH1		REFERENCES:				CESN-0280		
*QUALIF: LATER	*TEMPERATURE T	8.7SH1								
*STATUS	*PRESSURE P	8.7SH1								
*	*REL. HUMDTY H	8.7SH1								
*	*CHEM. SPRAY C	8.7SH1								
*****	*RADIATION R	8.7SH1								
	*AGING A	8.7SH1								
	*SUBMERGENCE S	8.7SH1								
EQ. PCK # : 8.7SH1	OS88 CATEG.: A	APPENDIX E							REVISION # : 30	
									DATE :	
									SYSTEM : RAD. MONITORING	
									TAG : RM 1CR 3563A SA	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : RM 1CR 3563B SB	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	N/A DBA (SEE NOTE 1)			SRSO 8.7SH1								
COMPONENT: MICROPROCESSOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:				
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:				
MAJOR SUPPLIER : GENERAL ATOMIC	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 10DX 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE: NOT REQUIRED FOR THE SAFE SHUTDOWN OF THE PLANT DURING A DBA				
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR5J PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM				
SPECIFICATIONS: N-29	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1			
P.O #: 435220	OPERABILITY	O 8.7SH1		REFERENCES:						CES4-C281			
PLANT LOC.: AB31	TEMPERATURE	T 8.7SH1											
COORDINATES X- 1581. Y- 1658. Z- 265.0	PRESSURE	P 8.7SH1											
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 8.7SH1											
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 8.7SH1											
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 8.7SH1											
*QUALIF: LATER	AGING	A 8.7SH1											
*STATUS	SUBMERGENCE	S 8.7SH1											
* *****	OS88 CATEG.: A												
* *****	APPENDIX E												
EQ. PCK # : 8.7SH1									REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : RM 1CR 3563B SB				

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : PDT 1AV4834B3SB	OPERABILITY			OPER. REVIEW	COMP. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO		
COMPONENT: PRESSURE TRANSDUCER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	#	NONE
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	#	NONE
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB31 FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: RAB TO OUTSIDE & SERVICE DIFF PRES	ACCUR. SPEC: NOT APPLICABLE				SRSP		
	R GAMMA	2.6E4		RAB3111 FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	H	NONE
ACCUR. DEM.: NOT APPLICABLE	A BETA	4.4E5					
SPECIFICATIONS: IN34	D B SHIELD	100%					
P.O #: 435266	S T.I.D.	2.6E4			SRSH		
PLANT LOC.: AB31	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51	COMP. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1580. Y- 164C. Z- 265.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B	COMP. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA-METER	SUPPL. REVIEW			SRSA		
*****	OPERABILITY	O		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:			
*QUALIF:	TEMPERATURE	T		REFERENCES:			
*STATUS	PRESSURE	P		QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*	REL. HUMIDTY	H		CES#-0333			
*	CHEM. SPRAY	C		REVISION # : 00			
*****	RADIATION	R		DATE :			
	AGING	A		SYSTEM : REAC.AUX.BLDG			
EQ. PCK # :	SUBMERGENCE	S		HVAC			
	OS88 CATEG.: A			TAG : PDT 1AV4834B3SB			
	APPENDIX E						

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : FDT 1AV4834B4SB	OPERABIL- ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA			SRSO			
COMPONENT: PRESSURE TRANSP ITTER	TEMPERAT- UPE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: GOULD				SRST			REPLACEMENT:
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
				SRSP			MAINTAIN.:
MODEL AND: LATER SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: RAB TO OUTSIDE & SERVICE DIFF PRES				SRSH			NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
				SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4		RAB21R6 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: IN34				SRSR			
P.O #: 435266	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21				SRSA			SAFETY FUNCTION: SS
COORDINATES X- 1582. Y- 164C. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
				SRSS			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O				CES#-0334	
*QUALIF:	*TEMPERATURE	T					
*STATUS	*PRESSURE	P					
*	*REL. HUMIDTY	H					
*	*CHEM. SPRAY	C					
*****	*RADIATION	R					
	AGING	A					
	SUBMERGENCE	S					
EQ. PCK # :	OS88 CATEG.: A APPENDIX E		REFERENCES:			REVISION # : 00 DATE :	
						SYSTEM : REAC. AUX. BLDG HVAC TAG : PDT 1AV4834B4SB	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.						
TAG NO : PDT 1AV4834A1SA	OPERABIL- ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO						
COMPONENT: PRESSURE TRANSM ITTER	TEMPERAT- URE	104F NORM 104F DBA		TAB01A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:		
MANUFACTURER: GOULD					SRST				MAINTAIN.:		
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA		PAB01 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:		
MODEL AND: LATER SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB01 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
FUNCT. DES: RAB TO OUTSIDE & SERVICE DIFF PRES S.	CHEMICAL SPRAY	NOT APPLICABLE		CAB01 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE			
ACCUR. SPEC: NOT APPLICABLE					SRSC						
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100X 2.9E4		RAB01R1 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE			
SPECIFICATIONS: IN34					SRSR						
P.O #: 435266	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
PLANT LOC.: AB01					SRSA						
COORDINATES X- 1580. Y- 1640. Z- 195.0	SUBMERGED LEVEL	191.0 FEET		SAB01 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	N	NONE			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC					SRSS						
***** *QUALIF: *STATUS * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
	OPERABILITY O			REFERENCES:					CES#-0335		
	TEMPERATURE T										
	PRESSURE P										
	REL. HUMIDTY H										
	CHEM. SPRAY C										
	RADIATION R										
	AGING A										
	SUBMERGENCE S										
EQ. PCK # :	058E CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : REAC. AUX. BLDG HVAC TAG : PDT 1AV4834A1SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : PDT 1AV4834B1SB	OPERABILITY			OPER. REVIEW		/	NONE
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO		
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM		TAB01A FSAR SEC 3.11B		P	NONE
MANUFACTURER: GOULD	UPE	104F DBA			SRST		
MAJOR SUPPLIER	PRESSURE	ATMOS NORM		PAB01 FSAR SEC 3.11B		P	NONE
	ATMOS DBA				SRSP		
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM		HAB01 FSAR SEC 3.11B		/	NONE
FUNCT. DES: RAB TO OUTSIDE & SERVICE DIFF PRES		100% DBA			SRSH		
	CHEMICAL SPRAY	NOT APPLICABLE		CAB01 FSAR SEC 3.11B		/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.9E4		RAB01R1 FSAR SEC 3.11B		H	NONE
SPECIFICATIONS: IN34	A BETA	7.2E4			SRSR		
P.O #: 435266	D B SHIELD	100%					
PLANT LOC.: ABD1	S T.I.D.	2.9E4					
	AGE- INST LIFE	40 YEARS		1D CFR50 PARA. 5D. 51		/	NONE
COORDINATES X- 1581. Y- 164C. Z- 195.0	(PER 323-1974 DEF.)				SRSA		
	SUBMERGED LEVEL	191.0 FEET		SABU1 FSAR SEC 3.11B		M	NONE
					SRSS		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O	REFERENCES:			CES#-0336	
*QUALIF:	TEMPERATURE	T					
*STATUS	PRESSURE	P					
*	REL. HUMIDTY	H					
*	CHEM. SPRAY	C					
*****	RADIATION	R					
	AGING	A				REVISION # : 00	
	SUBMERGENCE	S				DATE :	
EQ. PCK # :	0588 CATEG.: A	APPENDIX E				SYSTEM : REAC.AUX.BLDG HVAC	
						TAG : PDT 1AV4834B1SB	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : PDT 1AV4R34A2SA	OPERABIL-ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO			
COMPONENT: PRESSURE TRANSP ITTER	TEMPERAT-URE	104F NORM 104F DRA		TAB11A FSAR SEC 3.11B		M	NONE	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DRA		PAB11 FSAR SEC 3.11B		M	NONE	
MAJOR : SUPPLIER					SRSO			
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DRA		HAB11 FSAR SEC 3.11B		/	NONE	
FUNCT. DES: & SERVICE					SRSO			
	CHEMICAL SPRAY	NOT APPLICABLE		CAB11 FSAR SEC 3.11B		/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4		RAB11R3 FSAR SEC 3.11B		H	NONE	
SPECIFICATIONS: IN34					SRSR			
P.O #: 435266	AGE- INST LIFE (PER .323- 1974 DEF.)	40 YEARS		1U CFR50 PARA.50.51		/	NONE	
PLANT LOC.: AB11					SRSA			
COORDINATES X- 1580. Y- 164C. Z- 221.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB11 FSAR SEC 3.11B		/	NONE	
INSTALLED (Y/N): LTR					SRSS			
INSTAL. REF: BY-FLD	PARA-METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	REFERENCES:				CES#-0337	
*QUALIF:	TEMPERATURE	T						
*STATUS	PRESSURE	P						
*	REL. HUMIDTY	H						
*	CHEM. SPRAY	C						
*****	RADIATION	R						
	AGING	A					REVISION # : 00	
	SUBMERGENCE	S					DATE :	
EQ. PCK # :	0588 CATEG.: A						SYSTEM : REAC.AUX.BLDG HVAC	
	APPENDIX E						TAG : PDT 1AV4R34A2SA	

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEFM. QUALIF.					
TAG NO : PDT 1AV4834A3SA	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO					
COMPONENT: PRESSURE TRANSDUCER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER :					SRSR				SUBCOMPONENTS:	
MODEL AND SERIAL # : LATER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		PAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : RAB TO OUTSIDE DIFF PRES	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSO					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4		RAB3111		COMB. TEST & SUPPL. REVIEW	M	NONE		
	A BETA	4.4E5		FSAR SEC						
	D B SHIELD	100%		3.11B						
SPECIFICATIONS: IN34	S T.I.D.	2.6E4			SRSR					
P.O #: 435I34	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31					SRSA					
COORDINATES X- 1582. Y- 164C. Z- 265.C	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O		REFERENCES:				CESW-0338			
*QUALIF:	*TEMPERATURE T									
*STATUS	*PRESSURE P									
*	*REL. HUMIDTY H									
*	*CHEM. SPRAY C									
*****	*RADIATION R									
	AGING A						REVISION # : 00			
	SUBMERGENCE S						DATE :			
EQ. PCK # :	OSBR CATEG.: A						SYSTEM : REAC.AUX.BLDG HVAC			
	APPENDIX E						TAG : PDT 1AV4834A3SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : PDT 1AV4834A4SA	OPERABILITY			OPER. REVIEW		/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO			
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B		P	NONE	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B		P	NONE	
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B		/	NONE	
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		/	NONE	
FUNCT. DES: RAB TO OUTSIDE & SERVICE' DIFF PRES	R GAMMA	3.0E4		RAB21R6 FSAR SEC 3.11B		H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4						
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%			SRSR			
SPECIFICATIONS: IN34	S T.I.D.	3.0E4						
P.O #: 435266	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		/	NONE	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE			SRSA			
COORDINATES X- 1581. Y- 164C. Z- 240.0				SAB21 FSAR SEC 3.11B		/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA-METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O	REFERENCES:				CES#-0339	
*QUALIF:	TEMPERATURE	T						
*STATUS	PRESSURE	P						
*	REL. HUMIDTY	H						
*	CHEM. SPRAY	C						
*****	RADIATION	R						
	AGING	A					REVISION # : 00	
	SUBMERGENCE	S					DATE :	
EQ. PCK # :	US88 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : PDT 1AV4834A4SA	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : PDT 1AV4834B2SB	OPERABIL-ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO				
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB11A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB11 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB11 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB11 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	ACCUR. SPEC:	NOT APPLICABLE			SRSP				
RAB TO OUTSIDE DIFF PRES	ACCUR. DEF.:	NOT APPLICABLE			SRSC				
	R GAMMA	3.4E4		RAB11R3		COMB. TEST & SUPPL. REVIEW	H	NONE	
	A BETA	7.2E4		FSAR SEC 3.11B					
	D B SHIELD	100%			SRSR				
	S T.I.D.	3.4E4							
SPECIFICATIONS: IN34	AGE-	40 YEARS		10 CFR50		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION:
P.O # : 435266	INST LIFE (PER 323-1974 DEF.)			PARA. 50.51					SS
PLANT LOC. : AB11	SUBMERGED LEVEL	NOT APPLICABLE		SAB11 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 15R1. Y- 1640. Z- 221.0					SRSS				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O		REFERENCES:			CES#-0340		
*QUALIF:	TEMPERATURE	T					REVISION # : 00		
*STATUS	PRESSURE	P					DATE :		
*	REL. HUMDITY	H					SYSTEM : REAC. AUX. BLDG		
*	CHEM. SPRAY	C					HVAC		
*****	RADIATION	R					TAG : PDT 1AV4834B2SB		
	AGING	A							
	SUBMERGENCE	S							
EQ. PCK # :	0588 CATEG. : A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PDT 1AV4838B SB	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS TYPE					SRSO 8.4SH1					
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	104F NORM 318F PEAK DBA	TAB31A FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & D21	
MANUFACTURER: ROSEMOUNT					SIRST 8.4SH1				MAINTAIN.: SEE PG.020 & D21	
MAJOR SUPPLIER : N/A	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB31 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: 1153 SERIES B	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB31 FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: RAB EMER FLTR & SERVICE E6 HEPAFLTR DIFF PRES	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: +.25X					SRSC 8.4SH1					
ACCUR. DEM.: +.25X	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	22 MRADS TID	RAB3111 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE31					SRSR 8.4SH1					
P.O #: 435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31					SRSA 8.4SH1					
COORDINATES X- 1582. Y- 174C. Z- 261.0	SUBMERGED LEVL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE		
INSTALLED (Y/N): LTR					SRSS 8.4SH1					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 8.4SH1								
*****	TEMPERATURE	T 8.4SH1								
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 8.4SH1								
*STATUS CONFIRMATORY DATA	REL. HUMDITY	H 8.4SH1								
*	CHEM. SPRAY	C 8.4SH1					CES#-0351			
*	RADIATION	R 8.4SH1								
*****	AGING	A 8.4SH1								
	SUBMERGENCE	S 8.4SH1								
EQ. PKC #: 8.4SH1	Q58R CATEG.: A	APPENDIX E	REFERENCES: (1)ROSEMOUNT REPORT 108026,REV A,VOL I:TEST RESULTS. (2)ROSEMOUNT REPORT 108025,REV B,QUAL.REPORT FOR 1153 SERIES B TRANSMITTER.				REVISION #: 00 DATE: 09/25/84			
							SYSTEM : REAC.AUX.BLDG HVAC TAG : PDT 1AV4838B SB			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : FT 1AV 4842B SP	OPERABIL- ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA			SRSO				
COMPONENT: FLOW TRANSMITTE R	TEMPERAT- URE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B SRST	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B SRSP	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA		HAB31 FSAR SEC 3.11B SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: LATER SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: FAN E6(1P-SB) & SERVICE DISCHFLOW	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4		RAB3111 FSAR SEC 3.11B SRSR	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51 SRSA	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS: IN34								
P.O #: 435266								
PLANT LOC.: A831								
COORDINATES X- 1586. Y- 1765. Z- 261.0								
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTH: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
***** *QUALIF: *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMPTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S		REFERENCES:				CES#-0367	
EQ. PCK # :	CS88 CATEG.: A APPENDIX E						REVISION # : 00 DATE :	
							SYSTEM : REAC.AUX.BLDG HVAC TAG : FT 1AV 4842B SB	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : PDT 1AV4843B SB	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO 8.4SH1	REVIEW			
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	174F NORM 319F PEAK DBA	TAB31A FSAR SEC 3.11B	PG.025 & 0133	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: SEE PG.02C & D21
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB31 FSAR SEC 3.11B	PG.0133 & 0143	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE PG.02O & D21
MAJOR SUPPLIER : N/A	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: 1153 SERIES B	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB31 FSAR SEC 3.11B	PG.025 & 0133	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: RAB EMER FLTR & SERVICE E6 OVERALL D IFF PRES					SRSR 8.4SH1	REVIEW			
ACCUR. SPEC: +.25%					SRSO 8.4SH1				
ACCUR. DEM.: +.25%	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	22 MRADS TID	RAB3111 FSAR SEC 3.11B	PG.044	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE31					SRSR 8.4SH1	REVIEW			
P.O #: 435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.033-043 PG.0111- 0125	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31					SRSA 8.4SH1	REVIEW			
COORDINATES X- 1582. Y- 1722. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING * *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1
	OPERABILITY	O 8.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
	TEMPERATURE	T 8.4SH1							CES#-0371
	PRESSURE	P 8.4SH1							
	REL. HUMIDTY	H 8.4SH1							
	CHEM. SPRAY	C 8.4SH1							
	RADIATION	R 8.4SH1							
	AGING	A 8.4SH1							
	SUBMERGENCE	S 8.4SH1							
EQ. PCK # : 8.4SH1									REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.
	OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/25/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : PDT 1AV4843B SB



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : RE 1CZ 3505A1 SA	OPERABILITY			OPER. REVIEW		/	NONE
EQUIPMENT TYPE: SENSORS	NORM/TEST DBA				SRSO		
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE					M	NONE
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		M	NONE
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY				SRSP		
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		/	NONE
FUNCT. DES. & SERVICE: CNTL RM EMER O UTSDEAIR INTAKE 10 RAD	R GAMMA	2.6E4		RAB5122 FSAR SEC 3.11B		M	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4			SRSH		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%					
SPECIFICATIONS: N-29	S T.I.D.	2.6E4			SRSC		
P.O #: 435220	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51		/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		/	NONE
COORDINATES X- 1404. Y- 1517. Z- 305.0	PARAMETER	SUPPL. REVIEW			SRSA		
INSTALLED (Y/N): LTR INSTAL. REF: 8Y-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O					
*QUALIF:	TEMPERATURE	T					
*STATUS	PRESSURE	P					
*	REL. HUMIDTY	H					
*	CHEM. SPRAY	C					
*****	RADIATION	R					
	AGING	A					
	SUBMERGENCE	S					
EQ. PCK # :	CS88 CATEG.: A APPENDIX E						

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

CES#-0447

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : RE 1CZ 3505A1 S

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : RE 1CZ 3505B1 S	OPERABIL-ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS	NOPP/TEST DRA				SRSO					
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE				SIRST	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC									MAINTAIN.:	
MAJOR SUPPLIER : GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA		PAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY				SRSR	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CNTL RM EMER O & SERVICE UTSDEAIR INTAKE 10 RAD	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA	2.6E4		RAB5122		COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA	7.2E4		FSAR SEC						
	D B SHIELD	10uX		3.11B						
	S T.I.D.	2.6E4			SRSR					
SPECIFICATIONS: N-29	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION:	
P.O #: 435220					SRSA					
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1404. Y- 1519. Z- 305.0					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O					CESA-0449			
*QUALIF:	*TEMPERATURE	T								
*STATUS	*PRESSURE	P								
*	*REL. HUMIDTY	H								
*	*CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :	CS88 CATEG.: A APPENDIX E		REFERENCES:				REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : RE 1CZ 3505B1 S			

AFE: EBASCO SERVICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEPON HARR
 COMPONENT EVALUATION S

PP - 1

NSSS: WESTINGHOUSE - PAR
 CAPACITY: 900 MW(E)

1-0569

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TF 1AV 6502A SA	OPERABILITY	40YRS PLUS 1YR POST DBA	40YRS PLUS 1YR POST DBA	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT									
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	123 DEGF NORMAL DBA FIG F1-39.1SH1	TAB01A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT									
MAJOR SUPPLIER: N/A	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB01 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:
MODEL AND SERIAL #: E4B250G-2A2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB01 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: PWR PMP ROOM AH-5 1A-SA FAN IN TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4F(32-60U) +3/8(60C-160D)									
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100% 2.9E4	REF T.I.D.	RAB01R1 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43									
P.O #: 435286	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: ABD1									
COORDINATES X- 1444. Y- 1604. Z- 197.0	SUBMERGED LEVEL	191.0 FEET	N/A	N/A FSAR SEC 3.11B	N/A	N/A	P	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED *STATUS * *****	PARAMETER	SUPPL. REVIEW							
	OPERABILITY	O 39.1SH1							
	TEMPERATURE	T 39.1SH1							
	PRESSURE	P 39.1SH1							
	REL. HUMIDTY	H 39.1SH1							
	CHEM. SPRAY	C 39.1SH1							
	RADIATION	R 39.1SH1							
	AGING	A 39.1SH1							
	SUBMERGENCE	S 39.1SH1							
EQ. PCK #: 39.1SH1	US88 CATEG.: A APPENDIX E								
					FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
					REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8P54 REV B, DATED 10/2182.				CES#-0569
									REVISION #: 01 DATE: 10/04/84
									SYSTEM: REAC. AUX. BLDG HVAC TAG: TE 1AV 6502A SA



A/E: EBASCO VICES INC.
 UTILITY: LINA POWER & LIGHT

FACILITY: SHEARON HARRIS P - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0570

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6502B SB	OPERABIL- ITY NORM/TEST DBA	40YRS PLUS 1YR POST DBA	4YRS PLUS 1YR POST DBA	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	PRIMARY ELEMENT								
COMPONENT: THERMOCOUPLE	TEMPERAT- URE	104F NORM 104F DBA	120 DEGF NORMAL DBA FIG E1-39.1SH1	TABU1A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT									
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PABU1 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST.MAN CAL.ONCE YR SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HABO1 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)									
ACCUR. DEP.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100%	3FR T.I.D.	RABO1R1 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43									
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: ABO1									
COORDINATES X- 1557. Y- 1604. Z- 197.0	SUBMERGED LEVEL	191.0 FEET	N/A	N/A FSAR SEC 3.11B	N/A	N/A	P	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1			
*****	OPERABILITY	O 39.1SH1							
*QUALIF: QUALIFIED	TEMPERATURE	T 39.1SH1							
*STATUS	PRESSURE	P 39.1SH1							
*	REL. HUMDTY	H 39.1SH1							
*	CHEM. SPRAY	C 39.1SH1							
*****	RADIATION	R 39.1SH1							
	AGING	A 39.1SH1							
	SUBMERGENCE	S 39.1SH1							
EQ. PCK # : 39.1SH1	OS&R CATEG.: A APPENDIX E		REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2182.			CES#-0570 REVISION # : C1 DATE : 10/04/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : TE 1AV 6502B SB			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : TE 1AV 6507A SA	OPERABIL- ITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	DBA	DBA		SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERAT- URE	104F NORM 104F DBA	120 DEG F NORMAL DBA FIG E1-70.1SH1	TAB21A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-70.1SH1	PAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST.MAN CAL.ONCE YR SUBCOMPONENTS:
MAJOR : SUPPLIER									
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1400F)					SRS039.1SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	3F3 T.T.D.	RAB21R7 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43									
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1410. Y- 1518. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
***** *QUALIF: QUALIFIED *STATUS * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O 39.1SH1 T 39.1SH1 P 39.1SH1 H 39.1SH1 C 39.1SH1 R 39.1SH1 A 39.1SH1 S 39.1SH1							CES#-0578
EQ. PCK # : 39.1SH1	G588 CATEG.: A APPENDIX E				REFERENCES: (1)TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2192.				REVISION # :01 DATE :10/04/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : TE 1AV 6507A SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHCD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6512A SA	OPERABIL- ITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERAT- URE	104F NORM 104F DBA	120 DEGF NORMAL DBA FIG E1-39.1SH1	TAB21A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE INST. PAN CAL ONCE YR SUBCOMPONENTS:
MAJOR : SUPPLIER					SRSP39.1SH1				
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CC HX AREA AH- 7 1A-SA AREA TEMP				SRSH39.1SH1				
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)					SRSC39.1SH1				
SPECIFICATIONS: IN43	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	3E8 T.I.D.	RAB21R7 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA39.1SH1				
COORDINATES X- 1539. Y- 1518. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1
*QUALIF: QUALIFIED	OPERABILITY C	39.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
*STATUS	TEMPERATURE T	39.1SH1							CES4-0585
	PRESSURE P	39.1SH1							
	REL. HUMDTY H	39.1SH1							
	CHEM. SPRAY C	39.1SH1							
	RADIATION R	39.1SH1							
	AGING A	39.1SH1							
	SUBMERGENCE S	39.1SH1							
EQ. PCK # : 39.1SH1	U588 CATEG.: A APPENDIX E								REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2182.
									REVISION # : 01 DATE : 10/04/84
									SYSTEM : REAC. AUX. BLDG HVAC TAG : TE 1AV 6512A SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : TE 1AV 6512B SB	OPERABILITY	41 YEARS	>43 YEARS	OPER. REVIEW PP.4.1	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRS039.2SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DRG	127 DEGF NORMAL	TAB21A FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DRG	ATMOS NORMAL	PAB21 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST.MAN CAL.ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DRG	100%	HAB21 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1) MODEL HAS SIMILARITY WITH MODEL THERMOCOUPLES PRESENTED IN HARSH ENVIRONMENT PKG 39.1SH1 WITH DIFFERENCE LENGTH OF SENSORS.
MODEL AND SERIAL #: E4R250G-2A2	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
FUNCT. DES. & SERVICE: CC HX AREA AH-7 1B-SB AREA TEMP	ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)				SRSC39.2SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA	2.6E4	3ER TTD	RAB21R7 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43	A BETA	100X			SRSR39.2SH1				
P.O #: 435286	S T.I.D.	2.6E4							
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>43 YEARS	10 CFR50 PARA.50.51	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1575. Y- 1518. Z- 236.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 39.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.2SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 39.2SH1							
*****	PRESSURE	P 39.2SH1							CES#-0586
*QUALIF: QUALIFIED	REL. HUMIDTY	H 39.2SH1							
*STATUS	CHEM. SPRAY	C 39.2SH1							
*	RADIATION	R 39.2SH1							
*	AGING	A 39.2SH1							
*****	SUBMERGENCE	S 39.2SH1							
EQ. PCK # : 39.2SH1	OS88 CATEG.: A								REVISION # : 00
	APPENDIX F								DATE : 05/30/84
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : TE 1AV 6512B SB

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.2SH1

- REFERENCES:
1. WEED INSTRUMENT REPORT 548-8854-2 REV B.
 2. HARSH ENVIRONMENT DOCUMENTATION PACKAGE 39.1SH1

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HAF MPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

VN- 0
 VN-0614

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6532B SB	OPERABIL-ITY	40YRS PLUS 1YR POST	140YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERAT-URE	104F NORM DBA	120 DEGF NORMAL DBA FIG	TAB21A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM DBA	ATMOS NORMAL DBA FIG	PAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:
MAJOR : N/A SUPPLIER					SRS39.1SH1				
MODEL AND: E4B250G-2A2 SERIAL #	RELATIVE HUMIDITY	20-90% NORM DBA	100%	HAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: PECH PENTRTM & SERVICE AH-11 1B-SB AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)					SRSC39.1SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA	3.0E4	3FB	RAB21R6 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43	A BETA	7.2E4	T.I.D.						
P.O #: 435286	D B SHIELD	100%			SRSR39.1SH1				
PLANT LOC.: AB21	S T.I.D.	3.0E4							
COORDINATES X- 1479. Y- 1603. Z- 236.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA. 50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A	N/A	/	NONE	
***** *QUALIF: QUALIFIED *STATUS *****	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1
	OPERABILITY	O 39.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
	TEMPERATURE	T 39.1SH1							CES#-0614
	PRESSURE	P 39.1SH1							
	REL. HUMDTY	H 39.1SH1							
	CHEM. SPRAY	C 39.1SH1							
	RADIATION	R 39.1SH1							
	AGING	A 39.1SH1							
	SUBMERGENCE	S 39.1SH1							
EQ. PCK # : 39.1SH1	0588 CATEG.: A APPENDIX E								REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/21/82.
									REVISION # : 01 DATE : 1C/G4/84 SYSTEM : REAC.AUX.BLOG HVAC TAG : TE 1AV 6532B SB



A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HAI
 COMPONENT EVALUATION

NPP - 1
 NSSS: WESTINGHOUSE - PWR
 CAPACITY: 930 MW(E)

VN- 0
 0615

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6532A SA	OPERABILITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 3 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	120 DEGF NORMAL DBA FIG E1-39.1SH1	TAB21A FSAR SEC 3.11B	REF(1) SRST39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB21 FSAR SEC 3.11B	REF(1) SRSP39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST.MAN CAL.ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF(1) SRSH39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: MECH PENRTN & SERVICE AH-11 1A-SA AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)	R GAMMA	3.0E4	3E4	RAB21R6 FSAR SEC 3.11B	REF(1) SRSR39.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	A BETA	7.2E4	T.I.D.						
SPECIFICATIONS: IN43	D B SHIELD	100%							
P.O #: 435286	S T.I.D.	3.0E4							
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA. 50.51	REF(1) SRSA39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1458. Y- 1622. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A SRSS39.1SH1	N/A	/	NONE	
INSTALLED (Y/H): LTR INSTAL. REF: 0Y-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
*****	OPERABILITY	O 39.1SH1							CES#-0615
*QUALIF: QUALIFIFD	TEMPERATURE	T 39.1SH1							
*STATUS	PRESSURE	P 39.1SH1							
*	REL. HUMDTY	H 39.1SH1							
*	CHEM. SPRAY	C 39.1SH1							
*****	RADIATION	R 39.1SH1							
	AGING	A 39.1SH1							
	SUBMERGENCE	S 39.1SH1							
EQ. PCK #: 39.1SH1	0588 CATEG.: A								REVISION #: 01 DATE: 10/04/84
	APPENDIX E								SYSTEM: REAC.AUX.BLOG HVAC TAG: TE 1AV 6532A SA

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1

REFERENCES: (1) TEST REPORT WEED INSTRUMENT
 #548-8854 REV B, DATED
 10/21/82.



A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HAP. NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

4-0
 0626

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6537A SA	OPERABILITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	120 DEGF NORMAL DBA FIG E1-39.1SH1	TFH21A FSAR SEC 3.11B	REF(1) SRST39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT CO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PFH21 FSAR SEC 3.11B	REF(1) SRSP39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER: N/A									
MODEL AND SERIAL #: E4R250-2A2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORMAL	RFH21 FSAR SEC 3.11B	REF(1) SRSH39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: FHB AH-17 SA & SERVICE: SPENT FUEL POOL PMP AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-60F) +3/4(60C-160F)					SRSC39.1SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100%	1.1E4 T.I.D.	RFH21F1 FSAR SEC 3.11B	REF(1) SRSR39.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43									
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.5G.51	REF(1) SRSA39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: FH21									
COORDINATES X- 1639. Y- 1792. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	*N/A FSAR SEC 3.11B	N/A SRSS39.1SH1	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1		
***** *QUALIF: QUALIFIED *STATUS * *****	OPERABILITY O	39.1SH1					CES#-0626		
	TEMPERATURE T	39.1SH1							
	PRESSURE P	39.1SH1							
	REL. HUMDTY H	39.1SH1							
	CHEM. SPRAY C	39.1SH1							
	RADIATION R	39.1SH1							
	AGING A	39.1SH1							
	SUBMERGENCE S	39.1SH1							
EQ. PCK # : 39.1SH1	USBR CATEG.: A APPENDIX E			REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2182.			REVISION # : 01 DATE : 10/04/84 SYSTEM : FUEL HNDL. BLDG HVAC TAG : TE 1AV 6537A SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1AV 6537B1 S E	OPERABILITY	4CYRS PLUS 1YR POST	4CYRS PLUS 1YR POST	SPEC IN43 PAPA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA	DBA	DBA		SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	120 DEGF NORMAL DBA FIG E1-39.1SH1	TFH21A FSAR SEC 3.11B	REF(1) SRST39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT CO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PFH21 FSAR SEC 3.11B	REF(1) SRSP39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST.MAN CAL.ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER : N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HFH21 FSAR SEC 3.11B	REF(1) SRSH39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: E4B2506-2A2	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
FUNCT.DES: FHB AH-17 SB & SERVICE SPENT FUEL POOL PMP AREA TEMP	ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)				SRSC39.1SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA	1.1E4	1E9	PFH21F1 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43	A BETA		T.T.D.						
P.O #: 435286	D.B SHIELD	100%			SRSR39.1SH1				
PLANT LOC.: FH21	S T.I.D.	1.1E4							
COORDINATES X- 1661. Y- 1792. Z- 236.0	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1) SRSA39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SURMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A	N/A	/	NONE	
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1		
*QUALIF: QUALIFIED	OPERABILITY	O 39.1SH1							CES#-0627
*STATUS	TEMPERATURE	T 39.1SH1							
*****	PRESSURE	F 39.1SH1							
	REL. HUMIDTY	H 39.1SH1							
	CHEM. SPRAY	C 39.1SH1							
	RADIATION	F 39.1SH1							
	AGING	A 39.1SH1							
	SURMERGENCE	S 39.1SH1							
EQ. PCK # : 39.1SH1	0588 CATEG.: A APPENDIX F								REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2182.
									REVISION # : 01 DATE : 10/04/84
									SYSTEM : FUEL HDL.BLDG HVAC
									TAG : TE 1AV 6537B1 S

A/E: EBASL SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HAR. NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

#- 0
 7-0628

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : TE 1AV 6537A1 S A	OPERABILITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRS039.1SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	120 DEG F NORMAL DBA FIG E1-79.1SH1	TFH21A FSAR SEC 3.11B	REF(1) SRST39.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT CO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E7-79.1SH1	PFH21 FSAR SEC 3.11B	REF(1) SRSP39.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE INST. PAN CAL. ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER: N/A									
MODEL AND SERIAL #: E4B250G-2A2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HFH21 FSAR SEC 3.11B	REF(1) SRSH39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: FHB AH-17 SA SPENT FUEL POOL PMP AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)					SRSC39.1SH1				
ACCUR. DEP.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100%	3ER T.I.D.	RFH21F1 FSAR SEC 3.11B	REF(1) SRSR39.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43									
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1) SRSA39.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: FH21									
COORDINATES X- 1659. Y- 1792. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	*N/A FSAR SEC 3.11B	N/A SRSS39.1SH1	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1
*****	OPERABILITY	O 39.1SH1							CES#-0628
*QUALIF: QUALIFIED	TEMPERATURE	T 39.1SH1							
*STATUS	PRESSURE	F 39.1SH1							
*	REL. HUMDTY	H 39.1SH1							
*	CHEM. SPRAY	C 39.1SH1							
*****	RADIATION	R 39.1SH1							
	AGING	A 39.1SH1							
	SUBMERGENCE	S 39.1SH1							
EQ. PCK #: 39.1SH1	0588 CATEG.: A APPENDIX E								REVISION # :01 DATE :10/04/84 SYSTEM : FUEL HNDL. BLDG HVAC TAG : TE 1AV 6537A1 S

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1

REFERENCES:

(1) TEST REPORT WEED INSTRUMENT
 #548-8854 REV B, DATED
 10/21/82.



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : TE 1AV 6562X SB	OPERABILITY	4YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA	DBA	DBA	PP 4.1	SRS039.1SH1	REVIEW				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	123 DEGF NORMAL DBA FIG E1-39.1SH1	TAB31A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A	
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB31 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:	
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% DBA FIG E2-39.1SH1	HAB31 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: ELEC PENTRN AH-25 1X-SB AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE		
ACCUR. SPEC: +2-1/4(32-60DF) +3/8(600-160CF)						SRSC39.1SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA A RETA DB SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	3E5 T.I.D.	RAB3111 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: IN43	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435286						SRSA39.1SH1				
PLANT LOC.: AB31										
COORDINATES X- 1542. Y- 1622. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A	N/A	/	NONE		
						SRSS39.1SH1				
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.1SH1		
*****	OPERABILITY	O 39.1SH1						CES#-0666		
*QUALIF: QUALIFIED	*TEMPERATURE	T 39.1SH1								
*STATUS	*PRESSURE	P 39.1SH1								
*	*REL. HUMIDTY	H 39.1SH1								
*	*CHEM. SPRAY	C 39.1SH1								
*****	RADIATION	R 39.1SH1								
	AGING	A 39.1SH1								
	SURMERGENCE	S 39.1SH1								
EQ. PCK # : 39.1SH1	OS88 CATEG.: A APPENDIX E			REFERENCES: (1) TEST REPORT WEED INSTRUMENT #548-8854 REV B, DATED 10/2182.				REVISION # : 01 DATE : 10/04/84		
								SYSTEM : REAC. AUX. BLDG HVAC TAG : TE 1AV 6562X SB		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : TE 1AV 6575X1 S A	OPERABIL- ITY	40YRS PLUS 1YR POST	40YRS PLUS 1YR POST	SPEC IN43 PARA 8 PP 4.1	REF(1)	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA	DBA	DBA		SRS039.1SH1	REVIEW		
COMPONENT: THERMOCOUPLE	TEMPERAT- URE	8GF 400* 104F DBA	123 DEGF NORMAL DBA FIG E1-39.1SH1	TAB51J FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL.	H	NONE
MANUFACTURER: WEED INSTRUMENT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB51 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL.	M	NONE
MAJOR : SUPPLIER					SRSP39.1SH1	REVIEW		
MODEL AND: SERIAL #	RELATIVE HUMIDITY	40X NORM 100X DBA	1077	HAB51 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL.	/	NONE
FUNCT. DES: & SERVICE	ROD CNTRL CAB RM 1X-SA AREA TEMP				SRSH39.1SH1	REVIEW		
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)	CHEMICAL SPRAY	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)					SRSC39.1SH1			
SPECIFICATIONS: IN43	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	TE9 T.T.D.	RAB5122 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL.	H	NONE
P.O #: 435286	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47 YEARS	10 CFRSD PARA.50.51	REF(1)	COMB. TEST & SUPPL.	/	NONE
PLANT LOC.: AB51					SRSA39.1SH1	REVIEW		
COORDINATES X- 1565. Y- 1587. Z- 305.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC								

REPLACEMENT:
N/A

MAINTAIN.:
SEE INST. MAN
CAL. ONCE YR
SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.1SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 39.1SH1

CES#-0679

REFERENCES: (1) TEST REPORT WEED INSTRUMENT
#548-8854 REV B, DATED
10/2182.

REVISION # : 01
DATE : 10/04/84

EQ. PCK # : 39.1SH1

OS88 CATEG.: A
APPENDIX E

SYSTEM : REAC. AUX. BLDG
HVAC
TAG : TE 1AV 6575X1 S



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : TE 1AV 6577B SP	OPERABILITY	40YRS PLUS 1YR POST DBA	40YRS PLUS 1YR POST DBA	SPEC IN43 PARA 8 FP 4.1	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: PRIMARY ELEMENT					SRS039.1SH1					
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM DBA	120 DEG F NORMAL DBA FIG E1-39.1SH1	TAB11A FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A	
MANUFACTURER: WEED INSTRUMENT					SRST39.1SH1					
MAJOR SUPPLIER: N/A	PRESSURE	ATMOS NORM DBA	ATMOS NORMAL DBA FIG E2-39.1SH1	PAB11 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:	
MODEL AND SERIAL #: F4R250G-2A2	RELATIVE HUMIDITY	20-90% NORM DBA	100% DBA	HAB11 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: BORON INJ PMP AH-28 1B-SB & TK AREA TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE		
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)					SRSC39.1SH1					
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA	3.4E4	3E9	PAB11R3 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: IN43	A BETA	7.2E4	T.I.D.							
P.O #: 435286	D B SHIELD	100%			SRSR39.1SH1					
PLANT LOC.: AB11	S T.I.D.	3.4E4								
COORDINATES X= 1523. Y= 1627. Z= 220.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(1)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
INSTALLED (Y/N): LTR					SRSA39.1SH1					
QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE		
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:39.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:39.1SH1		
*QUALIF: QUALIFIED	OPERABILITY	O 39.1SH1		REFERENCES: (1) TEST REPORT WEED INSTRUMENT 7548-8854 REV B, DATED 10/2182.				CES#-0681		
*STATUS	TEMPERATURE	T 39.1SH1						REVISION # :01		
*	PRESSURE	P 39.1SH1						DATE :1G/04/84		
*	REL. HUMDTY	H 39.1SH1						SYSTEM :REAC.AUX.BLDG HVAC		
*****	CHEM. SPRAY	C 39.1SH1						TAG :TE 1AV 6577B SB		
	RADIATION	R 39.1SH1								
	AGING	A 39.1SH1								
EQ. PCK # : 39.1SH1	SUBMERGENCE	S 39.1SH1								
	USBR CATEG.: A									
	APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : PT 1CT 7131A SA	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1	REVIEW			
COMPONENT:	PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	104F NORM 318F PEAK DBA	TAB31A FSAR SEC 3.118	PG.025 & D133 COMB. TEST & SUPPL.	*	NONE	REPLACEMENT: SEE PG.020 & 021
MANUFACTURER:	ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB31 FSAR SEC 3.118	PG.0133 & D143 COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE PG.020 & 021
MAJOR : SUPPLIER	N/A				SRSO 8.4SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: SERIAL #	1153GB8	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB31 FSAR SEC 3.118	PG.025 & D133 COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CNMT SPRAY PMP & DISCHARGE PRESS	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.118	N/A	/	NONE	
ACCUR. SPEC:	+0.25X				SRSO 8.4SH1				
ACCUR. DEM.:	+0.25X	R GAMMA	2.6E4	27 MRADS	RAB3111 FSAR SEC 3.118	PG.044 COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	IND1	A BETA	4.4E5	TID					
P.O #:	435102	D B SHIELD	100%						
PLANT LOC.:	AB31	S T.I.D.	2.6E4			SRSR 8.4SH1			
COORDINATES	X- 1414. Y- 1630. Z- 261.0	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	140 YEARS	10 CFR50 PARA.50.51	PG.033-043 PG.0111- D125 COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: CI
		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.118	N/A	/	NONE	
INSTALLED (Y/N):	LTR								
INSTAL. REF:	BY-FLD	PARA-METER							
QUALIF EXEMPTN:	NOT APPLIC	SUPPL. REVIEW							
*****		OPERABILITY	O	8.4SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T	8.4SH1	REFERENCES: (1)ROSEMOUNT REPORT 108026,REV A,VOL I:TEST RESULTS. (2)ROSEMOUNT REPORT 108025,REV B,QUAL.REPORT FOR 1153 SERIES B TRANSMITTER.				CES#-0837
*STATUS	CONFIRMATORY DATA	PRESSURE	P	8.4SH1					REVISION # :00
*		REL. HUMDTY	H	8.4SH1					DATE :09/25/84
*		CHEM. SPRAY	C	8.4SH1					SYSTEM :CONTAINMENT SPRAY
*****		RADIATION	R	8.4SH1					TAG :PT 1CT 7131A SA
		AGING	A	8.4SH1					
		SUBMERGENCE	S	8.4SH1					
EQ. PCK # :	8.4SH1	0588 CATEG.:	A	APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : LT 1CT 715C SA	OPERABILITY	40YRS NORM 1YR DBA	120YPS NORM 12YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE					SRSO 8.4SH1				
COMPONENT: LEVEL TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	170F NORM 118F PEAK DBA	TAB11A FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & D21
MANUFACTURER: ROSEMOUNT					SRST 8.4SH1				
MAJOR SUPPLIER : N/A	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB11 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.020 & D21 SUBCOMPONENTS:
MODEL AND SERIAL #: 11530B4	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB11 FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CNMT SPRAY ADD & SERVICE ITIVE TANK LEVEL	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25%					SRSC 8.4SH1				
ACCUR. DEM.: +.25%	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4F4	122 MPADS TID	RAB11R3 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN01					SRSR 8.4SH1				
P.O #: 435102	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMP. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB11					SRSA 8.4SH1				
COORDINATES X- 1504. Y- 1611. Z- 216.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC					SRSS 8.4SH1				
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1	
*QUALIF: QUALIFIED-AWAITING	OPERABILITY	O 8.4SH1		REFERENCES: (1)ROSEMOUNT REPORT 108026, REV A, VOL 1:TEST RESULTS. (2)ROSEMOUNT REPORT 108025, REV B, QUAL.REPORT FOR 1153 SERIES B TRANSMITTER.				CES#-0846	
*STATUS CONFIRMATORY DATA	TEMPERATURE	T 8.4SH1						REVISION # :00	
*	PRESSURE	P 8.4SH1						DATE :09/25/84	
*	REL. HUMDTY	H 8.4SH1						SYSTEM :CONTAINMENT SPRAY	
*****	CHEM. SPRAY	C 8.4SH1						TAG :LT 1CT 7150 SA	
*****	RADIATION	R 8.4SH1							
	AGING	A 8.4SH1							
	SUBMERGENCE	S 8.4SH1							
EQ. PCK # : 8.4SH1	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 1CT 7152 SB	OPERABIL- ITY	40YRS NORM 1YR DBA	12YRS NORM 12YRS POST DBA	OPER. REVIEW	PG.044-049	COMP. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1				
COMPONENT:	FLOW TRANSMITTE R	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 319F PEAK DBA	TAB11A FSAR SEC 3.11B	PG.025 & D133 COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER:	ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB11 FSAR SEC 3.11B	PG.0133 & D143 COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB11 FSAR SEC 3.11B	PG.025 & D0133 COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT.DES: & SERVICE	CNMT SPRAY ADDITIVE FLO W	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A N/A N/A	/	NONE	
ACCUR. SPEC:	+ .25%	R GAMMA	3.4E4	22 MRADS	PAB11R3 FSAR SEC 3.11B	PG.044 COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	+ .25%	A BETA	7.2E4	TID					
SPECIFICATIONS:	IND1	D B SHIELD	100%		SRSR 8.4SH1	REVIEW			
P.O #:	435102	S T.I.D.	3.4E4						
PLANT LOC.:	AB11	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.033-043 PG.0111- D125 COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES	X- 1528. Y- 1602. Z- 217.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A N/A	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1	
INSTAL. REF:	BY-FLD	OPERABILITY	O 8.4SH1	REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.				CES#-0849	
QUALIF EXEMPTN:	NOT APPLIC	TEMPERATURE	T 8.4SH1					REVISION # : 00	
*****		PRESSURE	P 8.4SH1					DATE : 09/25/84	
*QUALIF:	QUALIFIED-AWAITING	REL. HUMDTY	H 8.4SH1					SYSTEM : CONTAINMENT	
*STATUS	CONFIRMATORY DATA	CHEM. SPRAY	C 8.4SH1					SPRAY	
*		RADIATION	R 8.4SH1					TAG : FT 1CT 7152 SB	
*		AGING	A 8.4SH1						
*****		SURMERGENCE	S 8.4SH1						
EQ. PCK # :	8.4SH1	0588 CATEG.:	A						
		APPENDIX	E						

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPARD HARBOR
 COMPONENT EVALUATION REPORT

NPP - 1
 NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

REV - 0
 -0855

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : LIT 1CT716CP SE	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LEVEL TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: TRNSAMERICA-DEL AVEL	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER					SRSP				SUBCOMPONENTS:
MODEL AND SERIAL #: RE-36562	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CS CONT SUMP B & SERVICE LVL	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4		RAB3111 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN33									
P.O #: 435275	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB31					SRSA				
COORDINATES X- 1565. Y- 1660. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CES#-0855
***** *QUALIF: *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S								REVISION # : 00 DATE :
EQ. PCK # :	0588 CATEG.: A APPENDIX E								SYSTEM : CONTAINMENT SPRAY TAG : LIT 1CT7160B SB

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : LIT 1CT7161B SB	OPERABIL-ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS	NORM/TEST DBA				SRSO			
COMPONENT: LEVEL TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	P	NONE	
MANUFACTURER: TPNSAMERICA-DEL AVEL	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER :					SRSO			
MODEL AND: RE-36562	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: CONTAINMENT WTR LEVEL (NARROW RANGE)	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4		RAB3111 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN33	D B SHIELD	100%						
P.O #: 435275	S T.I.D.	2.6E4			SRSR			
PLANT LOC.: AP31	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1565. Y- 1660. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR					SRSS			
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH E9 PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF EXEMPTH: NOT APPLIC	OPERABILITY	O	REFERENCES:				CES#-0859	
*QUALIF:	TEMPERATURE	T						
*STATUS	PRESSURE	P						
*	REL. HUMDITY	H						
*	CHEM. SPRAY	C						
*****	RADIATION	R						
	AGING	A						
	SUBMERGENCE	S					REVISION # : 00	
E9. PCK # :	USRB CATEG.: A						DATE :	
	APPENDIX E						SYSTEM : CONTAINMENT SPRAY	
							TAG : LIT 1CT7161B SB	

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: CI

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : LIT 1CT7162A SA	OPERABIL- ITY		2	3	4	5	6	7	
EQUIPMENT: TYPE	NORM/TEST DBA			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE	
COMPONENT: LEVEL TRANSMITT ER	TEMPERAT- URE	104F 104F	NORM DRA	TAB31A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: TRNSAMERICA-DEL AVEL	PRESSURE	ATMOS ATMOS	NORM DRA	PAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% 100%	NORM DRA	HAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE								
RE-36562	ACCUR. DEP.: NOT APPLICABLE								
CONTAINMENT WTR LEVEL (WIDE RANGE)	SPECIFICATIONS: IN33								
	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4		RAB3111 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE	
	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
ACCUR. SPEC: NOT APPLICABLE	PLANT LOC.: AB31								
ACCUR. DEP.: NOT APPLICABLE	COORDINATES X- 1435. Y- 166C. Z- 261.0								
SPECIFICATIONS: IN33	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435275	INSTALLLED (Y/N): LTR								
PLANT LOC.: AB31	INSTAL. REF: BY-FLD								
COORDINATES X- 1435. Y- 166C. Z- 261.0	QUALIF EXEMPTN: NOT APPLIC								
	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
	OPERABILITY O			REFERENCES:				CES#-0867	
	TEMPERATURE T							REVISION # :00	
	PRESSURE P							DATE :	
	REL. HUMDTY H							SYSTEM : CONTAINMENT	
	CHEM. SPRAY C							TAG : LIT 1CT7162A SA	
	RADIATION R								
	AGING A								
	SUBMERGENCE S								
	EQ. PCK # :								
	US28 CATEG.: A								
	APPENDIX E								

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL HPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

0
 -0868

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : LIT 1CT7162B SB	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SENSORS	NORM/TEST DBA				SRSO					
COMPONENT: LEVEL TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B	SRST	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: TRNSAMERICA-DEL AVEL	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B	SRSP	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB31 FSAR SEC 3.11B	SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: RE-36562	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B	SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: CONTAINMENT WTR LEVEL (WIDE RANGE)	R GAMMA	2.6E4		RAB3111 FSAR SEC 3.11B	SRSR	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: IN33	S T.I.D.	2.6E4								
P.O #: 435275	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51	SRSA	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B	SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1565. Y- 1660. Z- 261.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O		REFERENCES:				CES#-0868		
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :	0588 CATEG.: A								SYSTEM : CONTAINMENT SPRAY	
	APPENDIX E								TAG : LIT 1CT7162B SB	



A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HAF NPP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

CSW-0892

EQUIPMENT DESCRIPTION	PARAMETER	ENVIRONMENT		DEF. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
		ACTUAL	NORM		ACTUAL	DEM. QUALIF.			
TAG NO : PDT 1CB76RCA SA	OPERABIL-ITY				OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: SENSORS	NORM/TEST DBA					SRSO			
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F	NORM		TAB41A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: GOULD						SIRST			REPLACEMENT;
MAJOR SUPPLIER	PRESSURE	ATMOS	NORM		PAB41 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE
		ATMOS	DRR			SRSR			MAINTAIN.:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%	NORM		HAB41 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE			DRR			SRSR			SUBCOMPONENTS:
	CHEMICAL SPRAY	NOT APPLICABLE			CAB41 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE						SRSR			NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4			RAB4117 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE
	A BETA	7.2E4				SRSR			
SPECIFICATIONS: IN34	D B SHIELD	100%							
P.O #: 435134	S T.I.D.	2.6E4							
PLANT LOC.: AB41	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS			10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1470. Y- 1635. Z- 291.0	SUBMERGED LEVEL	NOT APPLICABLE			SAB41 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR						SRSS			SAFETY FUNCTION: PRRM

INSTAL. REF: RY-FLD
 QUALIF EXEMPTN: NOT APPLIC

 *OPERABILITY O
 *TEMPERATURE T
 *PRESSURE P
 *REL. HUMPTY H
 *CHEM. SPRAY C

 *RADIATION R
 *AGING A
 *SURMERGENCE S

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 TEMPERATURE T
 PRESSURE P
 REL. HUMPTY H
 CHEM. SPRAY C
 RADIATION R
 AGING A
 SURMERGENCE S

FOR PUNCLIST ITEMS SEE SHEET PACKAGE:

REFERENCES:

QUALIFICATION SIGN-O
 FOUND IN DOCUMENTATI
 PACKAGE:
 CESW-0892
 REVISION # : 00
 DATE :
 SYSTEM : CONT. VACU
 RELIEF
 TAG : PDT 1CB76

PK # :

0588 CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITFMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : FDT 1CB768CP SR	OPERABIL-ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO					
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DRG		TAB41A FSAR SEC 3.11B	SIRST	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DRG		PAB41 FSAR SEC 3.11B	SRSP	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DRG		HAB41 FSAR SEC 3.11B	SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #									NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE	CONT OUTSIDE DIFF PRES S.R									
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE									
SPECIFICATIONS: IN34	CHEMICAL SPRAY	NOT APPLICABLE		CAB41 FSAR SEC 3.11B	SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE		
P.O #: 435I34	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 10G% 2.6E4		PAB4117 FSAR SEC 3.11B	SRSR	COMB. TEST & SUPPL. REVIEW	M	NONE		
PLANT LOC.: AB41	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
COORDINATES X- Y- Z-	SUBMERGED LEVEL	NOT APPLICABLE		SAB41 FSAR SEC 3.11B	SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVTFW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTAL. REF: BY-FLD	OPERABILITY			REFERENCES:				CES#-0893		
QUALIF EXEMPTH: NOT APPLIC	TEMPERATURE									
*QUALIF:	PRESSURE									
*STATUS	REL. HUMIDTY									
*	CHEM. SPRAY									
*	RADIATION AGING SUBMERGENCE									
EQ. PCK # :	D58R CATEG.: A APPENDIX E							REVISION # : 00 DATE :		
								SYSTEM : CONT. VACUUM RELIEF TAG : PDT 1CB7680B SB		

A/E: EBASCO SERVICES INC.
 UTILITY: DELAWARE POWER & LIGHT

FACILITY: SHEARON HARP APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

U
 0907

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : FT 1CZ 7817B SB	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SENSORS	NORM/TEST DBA				SRSO					
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B	SRST	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B	SRSP	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B	SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B	SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: POST ACCIDENT 0A1 FLOW	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		RAB5125 FSAR SEC 3.11B	SRSR	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	SRSA	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B	SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE		
SPECIFICATIONS: IN34	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH ED PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
P.O #: 435134	OPERABILITY	O	REFERENCES:				CES#-0907			
PLANT LOC.: AB51	TEMPERATURE	T								
COORDINATES X- 1626.	PRESSURE	P								
Y- 1665.	REL. HUMIDTY	H								
Z- 310.0	CHEM. SPRAY	C								
INSTALLED (Y/N): LTR	RADIATION	R								
INSTAL. REF: BY-FLD	AGING	A	REVISION # : 00				DATE :			
QUALIF EXEMPTH: NOT APPLICABLE	SURMERGENCE	S	SYSTEM : CONTROL ROOM				HVAC			
*****	OSRP CATEG.: A		TAG : FT 1CZ 7817B SB							
*QUALIF:	APPENDIX E									
*STATUS										
*REL. HUMIDTY										
*CHEM. SPRAY										
*RADIATION										
*AGING										
*SURMERGENCE										

A/E: EBASCO SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1908

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : FT 1CZ 7817A SA	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SENSORS	NORM/TEST DRA				SFSO					
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	104F NORM 104F DRA		TAB51A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: GOULD					SRST					
MAJOR SUPPLIER:	PRESSURE	ATMOS NORM ATMOS DRA		PAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:	
MODEL AND SERIAL #: LATER					SRSP				SUBCOMPONENTS:	
FUNCT. DES. & SERVICE: POST ACCIDENT 0A1 FLOW	RELATIVE HUMIDITY	20-90% NORM 100% DRA		HAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
					SRSH					
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4		RAB5125 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA									
SPECIFICATIONS: IN34	O B SHIELD	100%								
	S T.I.D.	3.7E4			SRSR					
P.O #: 435134	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1626. Y- 1655. Z- 310.0	SURMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O		REFERENCES:				CES9-G908		
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMIDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SURMERGENCE	S								
EQ. PCK #.:	0588 CATEG.: A APPENDIX E							REVISION # :00 DATE :		
								SYSTEM : CONTROL ROOM HVAC TAG : FT 1CZ 7817A SA		

A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARRIS - P - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 C 0915

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : FT 1CZ 7819A SA	OPERABILITY			OPER. REVIEW		/	NONE	
EQUIPMENT: SENSORS	NORM/TEST DBA				SRSO			
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B		M	NONE	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		M	NONE	
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B		/	NONE	
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		/	NONE	
FUNCT. DES. & SERVICE : EMER FLTR FAN R2 (1A-SA) DISCH FLOW	R GAMMA	3.7E4		RAB5125 FSAR SEC 3.11B		M	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA							
ACCUR. DEP.: NOT APPLICABLE	D & B SHIELD	100%			SRSR			
SPECIFICATIONS: IN34	S T.I.D.	3.7E4						
P.O # : 435134	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		1C CFR50 PARA. 50.51		/	NONE	
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		/	NONE	
COORDINATES X- 1630. Y- 1696. Z- 317.0					SRSS			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY O		REFERENCES:				CES#-0915	
*QUALIF:	*TEMPERATURE T							
*STATUS	*PRESSURE P							
*	*REL. HUMDTY H							
*	*CHEM. SPRAY C							
*****	*RADIATION R							
	AGING A						REVISION # : 30	
	SURMERGENCE S						DATE :	
EQ. PCK # :	0588 CATEG.: A APPENDIX E						SYSTEM : CONTROL ROOM HVAC TAG : FT 1CZ 7819A SA	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:
 SS

A/E: EBASCO SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPARD HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1916

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : FT 1CZ 7819B SB	OPERABIL-ITY			OPER. REVIEW	COMB.	/	NONE
EQUIPMENT: SENSORS	NORM/TEST DBA				SRSO		
COMPONENT: FLOW TRANSMITTE P	TEMPERAT-URE	1J4F NORM 104F DBA		TAB51A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : SUPPLIER					SRSR		
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4		RAB5125 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: IN34	D B SHIELD	100%			SRSR		
P.O #: 435134	S T.I.D.	3.7E4					
PLANT LOC.: AB51	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1637. Y- 1694. Z- 310.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARA-METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O	REFERENCES:			CES#-0916	
*QUALIF:	TEMPERATURE	T					
*STATUS	PRESSURE	P					
*	REL. HUMIDTY	H					
*	CHEM. SPRAY	C					
*****	RADIATION	R					
	AGING	A				REVISION # : 00	
	SUBMERGENCE	S				DATE :	
EQ. PCK # :	OS&P CATEG.: A					SYSTEM : CONTROL ROOM HVAC	
	APPENDIX E					TAG : FT 1CZ 7819B SB	

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPSON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 0923

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1CZ 7821B SB	OPERABILITY	41 YEARS	>40 YEARS	OPER. REVIEW	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRS039.4SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	104F NORM 313F DBA	TAB51A FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: CONAX	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,2 CALIB REQ EVRY48MN SUBCOMPONENTS:
MAJOR SUPPLIER : CTI-NUCLEAR	RELATIVE HUMIDITY	20-90X NORM 100X DBA	100X	HAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: 2310-9458-01	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES & SERVICE: CNTL RM EMER FLTR EHC INLET TEMP	R GAMMA	3.7E4	2ER T.I.D.	RAB5125 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: +3F(0-600F) +5X(600-1600)	D B SHIELD	100X		SRSR39.4SH1					
ACCUR. DEM.: +1F OR +5X (32F-212F)	S T.I.D.	3.7E4							
SPECIFICATIONS: BE31	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION:
P.O #: 435162	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB51									
COORDINATES X- 1634. Y- 1692. Z- 310.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: 9Y-FLD	OPERABILITY	O 39.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.4SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 39.4SH1							CES#-0920
*QUALIF: QUALIFIED	PRESSURE	P 39.4SH1							
*STATUS	REL. HUMDTY	H 39.4SH1							
*	CHEM. SPRAY	C 39.4SH1							
*	RADIATION	R 39.4SH1							
*****	AGING	A 39.4SH1							
	SUBMERGENCE	S 39.4SH1							
EQ. PKX #: 39.4SH1	USRR CATEG.: A								
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.4SH1

REFERENCES: 1. CONAX CORP. TEST REPORT
 #IPS-266 DATED 8/23/78
 2. #IPS-263 DATED 4/6/78

REVISION #: 00
 DATE: 07/24/84

SYSTEM: CONTROL ROOM
 HVAC
 TAG: TE 1CZ 7821B SB



A/E: EBAS SERVICES INC.
 UTILITY: ELINA POWER & LIGHT

FACILITY: SHEARON HARBOR PP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

0
 0936

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PDT 1CZ7R23A SA	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	SENSORS									
COMPONENT:	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 319F PEAK DBA	TAB51A FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & 021	
MANUFACTURER:	ROSEMOUNT									
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB51 FSAR SEC 3.11B	PG.0133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.020 & 021 SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	40-90% NORM 100% DBA	HAB51 FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC:	+0.25%									
ACCUR. DEV.:	+0.25%									
SPECIFICATIONS:	BE31									
P.O #:	435162									
PLANT LOC.:	AB51									
COORDINATES X- Y- Z-	1623. 1687. 30R.0									
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTN:	NOT APPLIC									
*****	PAPA- METER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1		
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	8.4SH1						CES#-0936		
*STATUS CONFIRMATORY DATA	TEMPERATURE T	8.4SH1								
*	PRESSURE P	8.4SH1								
*	REL. HUMDTY H	8.4SH1								
*****	CHEM. SPRAY C	8.4SH1		REFERENCES:				REVISION # :JO		
	RADIATION R	8.4SH1		(1)ROSEMOUNT REPORT 108026,REV				DATE :09/25/84		
	AGING A	8.4SH1		(2)ROSEMOUNT REPCRT 108025,REV				SYSTEM :CONTROL ROOM		
	SUBMERGENCE S	8.4SH1		B,QUAL.REPORT FOR 1153 SERIES				HVAC		
EQ. PCK # :	8.4SH1		APPENDIX E				TAG :PDT 1CZ7R23A SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1CZ 7824A SA	OPERABILITY	41 YEARS	>40 YEARS	OPER. REVIEW	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	DBA				SRS039.4SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: CONAX	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,2 CALIB REQ EVRY 48MN SUBCOMPONENTS:
MAJOR SUPPLIER : CTI-NUCLEAR	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: 2310-9458-G1	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES & SERVICE : CNTL RM EMER FLTR CHAR FLTR IN TEMP	R GAPMA	3.7E4	2ER T.I.D.	RAB5125 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: +3F(0-600F) +5X(600-1600)	A BE1A								
ACCUR. DEM.: +1F OR +5X (32F-212F)	D B SHIELD	100%			SRSR39.4SH1				
SPECIFICATIONS: BE31	S T.I.D.	3.7E4							
P.O #: 435162	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.5C.51	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
COORDINATES X- 1619. Y- 1691. Z- 310.0	PARA-METER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	39.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.4SH1
*QUALIF: QUALIFIED	TEMPERATURE T	39.4SH1							CES#-0942
*STATUS	PRESSURE P	39.4SH1							
*REFERENCES:	REL. HUMDTY H	39.4SH1							
	CHEM. SPRAY C	39.4SH1							
	RADIATION R	39.4SH1							
	AGING A	39.4SH1							
	SUBMERGENCE S	39.4SH1							
EQ. PCK # : 39.4SH1	OSER CATEG.: A APPENDIX E								REVISION # : 00 DATE : 07/24/84
									SYSTEM : CONTROL ROOM HVAC TAG : TE 1CZ 7824A SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : TF 1CZ 7824B SB	OPERABILITY	41 YEARS	>41 YEARS	OPER. REVIEW	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT	NORM/TEST DBA				SRS039.4SH1					
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	104F NORM 117F DBA	TAB51A FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A	
MANUFACTURER: CONAX	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,2 CALIB REQ EVRY 48MN SUBCOMPONENTS:	
MAJOR : CTI-NUCLEAR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
FUNCT. DES: & SERVICE	ACCUR. SPEC: +3F(0-600F) +5X(600-1600)				SRSC39.4SH1					
FLTR RM EMER FLTR CHAR FLTR IN TEMP	ACCUR. DEM.: +1F OR +5X (32F-212F)									
	R GAMMA A RETA D B SHIELD S T.I.D.	3.7E4 100%	2F9 T.I.D.	RAB5125 FSAR SEC 3.11B	REF 1,2	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE31	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>41 YEARS	10 CFR 50 PARA. 50.51	REF 1,2	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435162	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
PLANT LOC.: AB51	COORDINATES X- 1619. Y- 1692. Z- 310.0				SRSS39.4SH1					
COORDINATES X- 1619. Y- 1692. Z- 310.0	INSTALLED (Y/N): LTP INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 39.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.4SH1		
	*****	OPERABILITY O	39.4SH1					CES#-0943		
	*QUALIF: QUALIFIED	*TEMPERATURE T	39.4SH1							
	*STATUS	*PRESSURE P	39.4SH1							
	*	*REL. HUMIDTY H	39.4SH1							
	*	*CHEM. SPRAY C	39.4SH1							
	*****	*RADIATION R	39.4SH1	REFERENCES: 1. CONAX CORP. TEST REPORT NIPS-266 DATED 8/23/78 2. NIPS-263 DATED 4/6/78				REVISION # : 00 DATE : 07/24/84		
		*AGING A	39.4SH1							
		*SUBMERGENCE S	39.4SH1					SYSTEM : CONTROL ROOM HVAC		
EQ. PCK # : 39.4SH1		US8R CATEG.: A						TAG : TE 1CZ 7824B SB		
		APPENDIX E								

A/E: EBA SERVICES INC.
UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEFARON HA NPP - 1
COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

58- J
-0973

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : AS 1CZ 7829B SB	OPERABIL- ITY		2-	3-	5-	6-	7-	
EQUIPMENT: TYPE	NORM/TEST DBA				COMB. TEST & SUPPL. REVIEW	/	NONE	
COMPONENT: ANALYSIS SWITCH	TEMPERAT- URE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: ANACON	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		RAB5125 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS: N-46	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
P.O #: 435281	OPERABILITY O		REFERENCES:				CESV-0973	
PLANT LOC.: AB51	TEMPERATURE T							
COORDINATES X- 1618.	PRESSURE P							
Y- 1669.	REL. HUMDTY H							
Z- 310.C	CHEM. SPRAY C							
	RADIATION R							
INSTALLED (Y/N): LTR	AGING A						REVISION # : 00	
INSTAL. REF: BY-FLD	SUBMERGENCE S						DATE :	
QUALIF EXEMPTN: NOT APPLIC	0588 CATEG.: A						SYSTEM : CONTROL ROOM	
*****	APPENDIX E						HVAC	
*QUALIF:							TAG : AS 1CZ 7829B SB	
*STATUS								
*								
*								



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : AS 1CZ 7829A SA	OPERABIL- ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SWITCHES TYPE	NORM/TEST DBA				SRSO					
COMPONENT: ANALYSIS SWITCH	TEMPERAT- URE	104F NORM 114F DBA		TAB51A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: ANACON	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER					SRSP				SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA		HAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	CNTL RM NRML O AI CHLORINE DET				SRSH					
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4		RAB5125 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: N-46	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435281					SRSA					
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1620. Y- 1671. Z- 310.0					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*QUALIF:	OPERABILITY O		REFERENCES:				CES#-0974			
*STATUS	TEMPERATURE T									
*	PRESSURE P									
*	REL. HUMIDTY H									
*	CHEM. SPRAY C									
*	RADIATION R									
	AGING A						REVISION # :00			
	SUBMERGENCE S						DATE :			
EQ. PCK # :	U588 CATEG.: A APPENDIX F						SYSTEM : CONTROL ROOM HVAC TAG : AS 1CZ 7929A SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : TE 1CZ 7835A SA	OPERABILITY	41 YEARS	>47 YEARS	OPER. REVIEW PP.4.1	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRS039.2SH1				
COMPONENT: THERMOCOUPLE	TEMPERATURE	104F NORM 104F DBA	120 DEGF NORMAL 397F DBA	TAB51A FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: N/A
MANUFACTURER: WEED INSTRUMENT CO	PRESSURE	ATMOS NORM ATMOS DBA	75PSIG DBA NORM ATMOS	PAB51 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INST. MAN CAL. ONCE YR SUBCOMPONENTS:
MAJOR SUPPLIER : N/A					SRSP39.2SH1				
MODEL AND SERIAL # : E48250G-2A2	RELATIVE HUMIDITY	20-40% NORM 100% DBA	170%	HAB51 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1) MODEL HAS SIMILARITY WITH MODEL THERMOCOUP- LES PRESENTED IN HARSH ENVIRONMENT PKG 39.1SH1 WITH DIFFERENCE LENGTH OF SENSORS.
FUNCT. DES. & SERVICE : CNTL RM AH-15 1A-SA EHC EXH TEMP	CHEMICAL SPRAY	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE	
ACCUR. SPEC: +2-1/4(32-600F) +3/8(600-1600F)					SRSC39.2SH1				
ACCUR. DEM.: (-33.4F-+34.6F) (32F-554F)	R GAMMA	3.7E4	3E3 TID	RAB51253	REF(2)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN43	A BETA	NEGLI 9		FSAR SEC 3.11B					
P.O #: 435286	D B SHIELD	100%			SRSR39.2SH1				
PLANT LOC.: AB51	S T.I.D.	3.7E4							
COORDINATES X- 1613. Y- 1677. Z- 319.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40 YEARS	10 CFR50 PARA.50.51	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	*N/A	N/A	N/A	/	NONE	
INSTAL. REF: BY-FLD					SRSA39.2SH1				
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 39.2SH1
*****	OPERABILITY	O 39.2SH1							
*QUALIF: QUALIFIED	TEMPERATURE	T 39.2SH1							
*STATUS	PRESSURE	P 39.2SH1							CES#-0979
*	REL. HUMIDTY	H 39.2SH1							
*	CHEM. SPRAY	C 39.2SH1							
*****	RADIATION	R 39.2SH1							
	AGING	A 39.2SH1							REFERENCES: 1. TEST REPORT WEED INSTRUMENT #548-8854-2REV B, DATED 10/21/82 2. HARSH ENVIRONMENT DOCUMENTATION PACKAGE 39.1SH1
	SUBMERGENCE	S 39.2SH1							REVISION # : 01 DATE : 10/05/84
EQ. PCK # : 39.2SH1	OS88 CATEG.: A APPENDIX E								SYSTEM : CONTROL ROOM HVAC TAG : TE 1CZ 7835A SA

A/E: EBASCO / JICES INC.
 UTILITY: CENNA POWER & LIGHT

FACILITY: SHEARON HARRIS P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

U
 CE 1018

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PT 18D 8405A2 S B	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1					
COMPONENT:	PRESSURE TRANSMITTER	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 119F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.D20 & D21	
MANUFACTURER:	ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.D20 & D21	
MAJOR : SUPPLIER	N/A								SUBCOMPONENTS:	
MODEL AND: SERIAL #	1153GB9	RELATIVE HUMIDITY	20-90%NORM 100% DBA	40-90% NORM 100% DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	STM GEN 1A RAB LINE LEAK DET	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A N/A REVIEW	/	NONE		
ACCUR. SPEC:	+0.25X									
ACCUR. DEM.:	+0.25X	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	22 MRADS TID	RAB21R7 FSAR SEC 3.11B	PG.D44 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	IN01									
P.O #:	435102	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1552. 152C. 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A N/A REVIEW	/	NONE		
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O 8.4SH1					CESN-1C18		
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T 8.4SH1							
*STATUS	CONFIRMATORY DATA	PRESSURE	P 8.4SH1							
*		REL. HUMIDTY	H 8.4SH1							
*		CHEM. SPRAY	C 8.4SH1							
*****		RADIATION	R 8.4SH1	REFERENCES:				(1)ROSEMOUNT REPORT 108026,REV A,VOL 1:TEST RESULTS.		
		AGING	A 8.4SH1					(2)ROSEMOUNT REPORT 108025,REV B,QUAL.REPORT FOR 1153 SERIES		
		SUBMERGENCE	S 8.4SH1					8 TRANSMITTER.		
EQ. PCK # :	8.4SH1							REVISION # :00 DATE :09/25/84		
		0588 CATEG.:	A					SYSTEM :BLOWDOWN		
		APPENDIX	E					TAG :PT 18D 8405A2 S		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : PT 18D 8405C1 S A	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 1YR DBA 1 YEAR (DBA)	20YRS NORM 2YRS POST DBA POST DBA	OPER. REVIEW	PG. D44-D49 D49 [SRSO 8.4SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	SENSORS									
COMPONENT:	PRESSURE TRANSMITTER									
MANUFACTURER:	ROSEMOUNT									
MAJOR : SUPPLIER	N/A									
MODEL AND: SERIAL #	1153G99									
FUNCT. DES: & SERVICE	STM GEN 1C RAB LINE BREAK DET									
ACCUR. SPEC:	±.25% CHANGE									
ACCUR. DEM.:	±.25%									
SPECIFICATIONS:	IND1									
P.O #:	435102									
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1575.0 1676.0 236.0									
INSTALLED (Y/H): INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	LTP BY-FLD NOT APPLIC									
*****	PARAMETER	SUPPL. REVIFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1		
*****	OPERABILITY O	8.4SH1						CES#-1020		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	8.4SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	8.4SH1								
*	REL. HUMDTY H	8.4SH1								
*	CHEM. SPRAY C	8.4SH1								
*****	RADIATION R	8.4SH1	REFERENCES: (1)ROSEMOUNT REPORT 108026, REV A, VOL 1: TEST RESULTS.					REVISION # :00		
	AGING A	8.4SH1	(2)ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.					DATE :09/25/84		
	SUBMERGENCE S	8.4SH1						SYSTEM :BLOWDOWN		
EQ. PCK # :	8.4SH1									
	USBP CATEG.: A. APPENDIX E									
	REPLACEMENT: SEE PG. D20 & D21 MAINTAIN.: SEE PG. D20 & D21 SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT SAFETY FUNCTION: CI									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 18D 8405B2 S B	OPERABILITY	40YRS NORM 1YR DR4	20YRS NORM 2YRS POST DR4	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE					SRSO 8.4SH1				
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	104F NORM 104F DR4	104F NORM 319F PEAK DR4	TAB21A FSAR SEC 3.11P	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	*	NONE	REPLACEMENT: SEE PG.020 & D21
MANUFACTURER: ROSEMOUNT					SRS1 8.4SH1				MAINTAIN.:
MAJOR : N/A SUPPLIER	PRESSURE	ATMOS NORM ATMOS DR4	ATMOS NORM 175 PSIG PEAK DR4	PAB21 FSAR SEC 3.11B	PG.0133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	SEE PG.D20 & D21 SUBCOMPONENTS:
MODEL AND: 1153GB9 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DR4	40-90% NORM 100% DR4	HAB21 FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: STM GEN 1B RAB & SERVICE LINE BREA K DET	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25%					SRSC 8.4SH1				
ACCUR. DEM.: +.25%	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	22 MRADS TTD	RAB21R7 FSAR SEC 3.11B	PG.044	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN01					SRSR 8.4SH1				
P.O #: 435102	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.033-043 PG.0111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA 8.4SH1				
COORDINATES X- 1552. Y- 1520. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 8.4SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 8.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
*STATUS CONFIRMATORY DATA	PRESSURE	P 8.4SH1							CES#-1021
*	REL. HUMDTY	H 8.4SH1							
*	CHEM. SPRAY	C 8.4SH1							
*****	RADIATION	R 8.4SH1							
	AGING	A 8.4SH1							
	SUBMERGENCE	S 8.4SH1							
EQ. PCK # : 8.4SH1									
	USBR CATEG.: A APPENDIX E								REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.
									REVISION # : 00 DATE : 09/25/84
									SYSTEM : BLOWDOWN
									TAG : PT 18D 8405B2 S

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : PT 180 8405C2 S B	OPERABIL-ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO 8.4SH1				
COMPONENT: PRESSURE TRANSMITTER	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 318F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.D20 & D21
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.D20 & D21
MAJOR : N/A SUPPLIER					SRSO 8.4SH1				SUBCOMPONENTS:
MODEL AND: 1153GB9 SERIAL #	RELATIVE HUMIDITY	20-90X NORM 100X DBA	40-90X NORM 100Y DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: STM GEN 1C RAB & SERVICE LINE BREA K DET	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25X					SRSC 8.4SH1				
ACCUR. DEM.: +.25X	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	27 MRADS TID	RAB21R7 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IND1					SRSR 8.4SH1				
P.O #: 435102	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	1G CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA 8.4SH1				
COORDINATES X- 1552. Y- 1520. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1
*****	OPERABILITY	O 8.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 8.4SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 8.4SH1							CES#-1022
*	REL. HUMDTY	H 8.4SH1							
*	CHEM. SPRAY	C 8.4SH1							
*****	RADIATION	R 8.4SH1							REFERENCES: (1) ROSEMOUNT REPORT 102026, REV A, VOL I: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.
	AGING	A 8.4SH1							REVISION # : J0 DATE : 09/25/84
	SUBMERGENCE	S 8.4SH1							SYSTEM : BLOWDOWN
EQ. PCK # : 8.4SH1	OS8B CATEG.: A APPENDIX E								TAG : PT 180 8405C2 S



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO : PT 180 8405B1 S A	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1					
COMPONENT: PRESSURE TRANSP ITTER	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 319F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.D20 & D21	
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.D20 & D21	
MAJOR : SUPPLIER	N/A				SRSO 8.4SH1				SUBCOMPONENTS:	
MODEL AND: SERIAL #	1153GB9	RELATIVE HUMIDITY	20-90%NORM 100% DBA	40-90% NORM 100% DBA	MAB21 FSAR SEC 3.11B	PG.D25 & &D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	STM GEN 1P RAB LINE BREA K DET	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25X					SRSO 8.4SH1					
ACCUR. DEM.: +.25X		R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	22 MRADS TID	RAB21R6 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: INDI					SRSR 8.4SH1					
P.O #: 435102		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA 8.4SH1					
COORDINATES X- Y- Z-	1502. 1626. 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1			
		OPERABILITY O	8.4SH1	REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.			CES#-1023			
		TEMPERATURE T	8.4SH1				REVISION # :00			
		PRESSURE P	8.4SH1				DATE :09/25/84			
		REL. HUMDTY H	8.4SH1				SYSTEM :9LOWDOWN			
		CHEM. SPRAY C	8.4SH1				TAG :PT 180 8405B1 S			
		RADIATION R	8.4SH1							
		AGING A	8.4SH1							
		SUBMERGENCE S	8.4SH1							
EQ. PCK # :	8.4SH1	0588 CATEG.: A APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 1SW 9112B SB	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE SENSORS	NORM/TEST DBA				SRSO 8.4SH1				
COMPONENT: FLOW TRANSMITTE R	TEMPERAT- URE	104F NORM 104F DBA	176F NORM 179F PEAK DBA	TAB21A FSAR SECT 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.D20 & D21
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 175 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.D20 & D21
MAJOR : N/A SUPPLIER	RELATIVE HUMIDITY	20-100% NORM 100% DBA	40-90% NORM 100% DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: SW BSTR PMP B & SERVICE DISCH FLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25%	R GAPMA A BETA D B SHIELD S T.I.D.	1.8E4 1COX 1.8E4	22 MRADS TTD	RAB21100 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. DEP.: +.25%	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	1C CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: INU1	SUBPERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O #: 435102					SRSA 8.4SH1				
PLANT LOC.: AB21									
COORDINATES X- 16G2. Y- 1562. Z- 236.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1							
EQ. PCK # : 8.4SH1	0586 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 8.4SH1

CES#-1111

REFERENCES: (1) ROSEMOUNT REPORT 108026, REV
 A, VOL I: TEST RESULTS.
 (2) ROSEMOUNT REPORT 108025, REV
 B, QUAL. REPORT FOR 1153 SERIES
 B TRANSMITTER.

REVISION # : 00
 DATE : 09/25/84

SYSTEM : SERVICE WATER

TAG : FT 1SW 9112B SB

A/E: EBASCO VICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARON HARRIS - P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0-1116

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : PT 1SW 9112B SP	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: SENSORS	NORM/TEST DBA				SRSO 8.4SH1			
COMPONENT: PRESSURE TRANSMITTER	TEMPERATURE	NOT AVAILABLE	104F NORM 119F PEAK DBA		PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-100% TABLE 3.11.0-1	40-90% NORM 100% DBA		PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: 1153G08	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES: SW BSTR PMP B & SERVICE DISC PRES	R GAMMA	1.8E4	22 MRADS TID	RAB2110 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: +.25%	D B SHIELD	100%						
ACCUR. DEP.: +.25%	S T.I.D.	1.8E4						
SPECIFICATIONS: IN01	AGE-INST LIFE	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435102	(PER 323-1974 DEF.)							
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE
COORDINATES X- 1620. Y- 1568. Z- 236.0								
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF: BY-FLD	OPERABILITY O	8.4SH1						
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	8.4SH1						
*****	PRESSURE P	8.4SH1						
QUALIF: QUALIFIED-AWAITING	REL. HUMDTY H	8.4SH1						
*STATUS CONFIRMATORY DATA	CHEM. SPRAY C	8.4SH1						
*	RADIATION R	8.4SH1						
*	AGING A	8.4SH1						
*****	SUBMERGENCE S	8.4SH1						
EQ. PCK # : 8.4SH1								

REPLACEMENT:
SEE PG.020 & D21
 MAINTAIN.:
SEE PG.020 & D21
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 8.4SH1

CES#-1116

REFERENCES:
 (1) ROSEMOUNT REPORT 1C8026, REV A, VOL I: TEST RESULTS.
 (2) ROSEMOUNT REPORT 1G8025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.

REVISION # : 00
 DATE : 09/25/84

SYSTEM : SERVICE WATER

TAG : PT 1SW 9112B SB

0588 CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PT 1SW 9112A SA	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1					
COMPONENT:	PRESSURE TRANSP ITTER	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 315F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.D20 & D21	
MANUFACTURER:	ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.D20 & D21	
MAJOR : SUPPLIER	N/A					SRSO 8.4SH1			SUBCOMPONENTS:	
MODEL AND: SERIAL #	1153GB8	RELATIVE HUMIDITY	20-90%NORM 100% DBA	40-90% NORM 100% DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	SW BSTR PMP DISC PRES	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A N/A COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC:	+ .25%					SRSO 8.4SH1				
ACCUR. DEM.:	+ .25%	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	22 MRADS T10	RAB21R7 FSAR SEC 3.11B	PG.D44 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	IN01	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #:	435102	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A N/A COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.:	AB21					SRSO 8.4SH1				
COORDINATES X- Y- Z-	1412. 1568. 236.0									
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O 8.4SH1							
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T 8.4SH1							
*STATUS	CONFIRMATORY DATA	PRESSURE	P 8.4SH1					CESW-1117		
*		REL. HUMDTY	H 8.4SH1							
*		CHEM. SPRAY	C 8.4SH1							
*****		RADIATION	R 8.4SH1							
		AGING	A 8.4SH1							
		SUBMERGENCE	S 8.4SH1							
EQ. PCK # :	8.4SH1			REFERENCES: (1)ROSEMOUNT REPORT 108026,REV A,VOL I:TEST RESULTS. (2)ROSEMOUNT REPORT 108025,REV B,QUAL.REPORT FOR 1153 SERIES B TRANSMITTER.				REVISION # :00 DATE :09/25/84		
		0588 CATEG.:	A					SYSTEM :SERVICE WATER		
		APPENDIX	E					TAG :PT 1SW 9112A SA		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : FT 1SW 9205A SA	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE									
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	104F NORM 118F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & D21
MANUFACTURER: ROSEMOUNT									MAINTAIN.: SEE PG.020 & D21
MAJOR : N/A SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 175 PSIG PEAK DBA	PAB21 FSAR SEC 3.11B	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:
MODEL AND: 1153DB4 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: SW FROM RAB A & SERVICE CHILLER WC-2 F LOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: +.25X									
ACCUR. DEM.: +.25X	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	22 MRADS TID	RAB21R7 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: INU1									
P.O #: 435102	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1412. Y- 1568. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1 8.4SH1							CES#-1126
EQ. PCK # : 8.4SH1									REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL 1: TEST RESULTS. (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.
	OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/25/84 SYSTEM : SERVICE WATER TAG : FT 1SW 9205A SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : FT 1SW 9205B SB	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.D44-D49	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SENSORS					SRSO 8.4SH1					
COMPONENT: FLOW TRANSMITTER	TEMPERATURE	104F NORM 104F DBA	104F NORM 319F PEAK DBA	TAB21A FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE PG.020 & D21	
MANUFACTURER: ROSEMOUNT					SRST 8.4SH1					
MAJOR SUPPLIER: N/A	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB21 FSAR SEC 3.11P	PG.D133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.020 & D21	
MODEL AND SERIAL #: 1153084	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 100% DBA	HAB21 FSAR SEC 3.11B	PG.D25 & D133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: SW FROM RAB B CHILLER WC-2 F LOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: +.25%					SRSC 8.4SH1					
ACCUR. DEM.: +.25%	R GAMMA	2.6E4	22 MRADS	RAB21R7 FSAR SEC 3.11B	PG.D44	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: IN01	A BETA		TID							
P.O #: 435102	D B SHIELD	100%			SRSR 8.4SH1					
PLANT LOC.: AB21	S T.I.D.	2.6E4								
COORDINATES X- 1531. Y- 1568. Z- 236.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.D33-D43 PG.D111-D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1		
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	8.4SH1		REFERENCES: (1)ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS. (2)ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.				CES#-1127		
*STATUS CONFIRMATORY DATA	TEMPERATURE T	8.4SH1						REVISION # : 00		
*	PRESSURE P	8.4SH1						DATE : 09/25/84		
*	REL. HUMIDTY H	8.4SH1						SYSTEM : SERVICE WATER		
*	CHEM. SPRAY C	8.4SH1						TAG : FT 1SW 9205B SB		
*****	RADIATION R	8.4SH1								
EQ. PCK # : 8.4SH1	AGING A	8.4SH1								
	SUBMERGENCE S	8.4SH1								
	OSRP CATEG.: A									
	APPENDIX E									





EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 1SW 9275C SA	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	SENSORS				SRSO 8.4SH1				
COMPONENT: FLOW TRANSMITTE R	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 319F PEAK DBA	TAB11A FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & D21
MANUFACTURER: ROSEMOUNT					SRST 8.4SH1				
MAJOR : SUPPLIER	N/A								MAINTAIN.: SEE PG.020 & D21
MODEL AND: SERIAL #	1153DB4								SUBCOMPONENTS:
FUNCT. DES: & SERVICE	SW FROM CONT F AN COOLER AH -3								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
ACCUR. SPEC: +.25%									
ACCUR. DEM.: +.25%									
SPECIFICATIONS: IN01									
P.O #: 435102									
PLANT LOC.: AB11									
COORDINATES X- Y- Z-	1527. 1624. 216.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****									
EQ. PCK # : R.4SH1									

REPLACEMENT:
SEE PG.020 &
D21
MAINTAIN.:
SEE PG.020 &
D21
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 8.4SH1

CESN-1158

REFERENCES:
 (1) ROSEMOUNT REPORT 108026, REV
 A, VOL 1: TEST RESULTS.
 (2) ROSEMOUNT REPORT 108025, REV
 B, QUAL. REPORT FOR 1153 SERIES
 B TRANSMITTER.

REVISION # : 00
 DATE : 09/25/84

SYSTEM : SERVICE WATER

TAG : FT 1SW 9275C SA

0588 CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 1SW 9275B SA	OPERABIL- ITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.4SH1				
COMPONENT: FLOW TRANSMITTE R	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 318F PEAK DBA	TAB11A FSAR SEC 3.11B	PG.025 & D133	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE PG.020 & 021
MANUFACTURER: ROSEMOUNT	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB11 FSAR SEC 3.11B	PG.0133 & D143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.020 & 021
MAJOR : N/A SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	40-90% NORM 100% DBA	HAB11 FSAR SEC 3.11B	PG.025 & D0133	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	SW FROM CONT F AN COOLER AH -2				SRSR 8.4SH1				
ACCUR. SPEC: +.25%	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. DEM.: +.25%	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	22 MRADS TID	RAB11R3 FSAR SEC 3.11B	PG.044	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN01	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.5C.51	PG.033-043 PG.0111- D125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435102	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB11					SRSS 8.4SH1				
COORDINATES X- 1527. Y- 1624. Z- 216.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
	OPERABILITY O	8.4SH1							CES#-1159
	TEMPERATURE T	8.4SH1							
	PRESSURE P	8.4SH1							
	REL. HUMDTY H	8.4SH1							
	CHEM. SPRAY C	8.4SH1							
	RADIATION R	8.4SH1							
	AGING A	8.4SH1							
	SURMERGENCE S	8.4SH1							
EQ. PCK # : 8.4SH1									
	0588 CATEG.: A APPENDIX E								
									REVISION # : 00 DATE : 09/25/84
									SYSTEM : SERVICE WATER
									TAG : FT 1SW 9275B SA

FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1

REFERENCES: (1) ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS.
 (2) ROSEMOUNT REPORT 108025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FT 1SW 9275D SB	OPERABILITY	40YRS NORM 1YR DBA	20YRS NORM 2YRS POST DBA	OPER. REVIEW	PG.044-049	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS	TEMPERATURE	104F NORM 104F DBA	104F NORM 119F PEAK DBA	TAB11A FSAR SEC 3.11B	PG.025 & 0133	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE PG.020 & D21
COMPONENT: FLOW TRANSMITTER	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM 75 PSIG PEAK DBA	PAB11 FSAR SEC 3.11B	PG.0133 & 0143	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE PG.02U & D21
MANUFACTURER: ROSEMOUNT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	40-90% NORM 107% DBA	HAB11 FSAR SEC 3.11B	PG.025 & 0133	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR. SUPPLIER : N/A	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: 1153084	R GAMMA	3.4E4	22 MRADS	RAB11R3 FSAR SEC 3.11B	PG.044	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE : SW FROM CONT F AN COOLER AN -4	D B SHIELD	100%							
ACCUR. SPEC: +.25X	S T.I.O.	3.4E4							
ACCUR. DEP.: +.25X	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	PG.033-043 PG.0111-0125	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: IN01	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O #: 435102	PARAMETER	SUPPL. REVIEW							
PLANT LOC.: AB11	OPERABILITY	O 8.4SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.4SH1
COORDINATES X- 1584. Y- 1622. Z- 216.0	TEMPERATURE	T 8.4SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.4SH1
INSTALLED (Y/N): LTR	PRESSURE	P 8.4SH1							CES#-1160
INSTAL. REF: BY-FLD	REL. HUMIDTY	H 8.4SH1							
QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C 8.4SH1							
*****	RADIATION	R 8.4SH1							
*QUALIF: QUALIFIED-AWAITING	AGING	A 8.4SH1							REFERENCES: (1)ROSEMOUNT REPORT 108026, REV A, VOL I: TEST RESULTS.
*STATUS CONFIRMATORY DATA	SUBMERGENCE	S 8.4SH1							(2)ROSEMOUNT REPORT 106025, REV B, QUAL. REPORT FOR 1153 SERIES B TRANSMITTER.
* *****									REVISION # :00 DATE :09/25/84
EQ. PCK # : 8.4SH1	US8F CATEG.: A APPENDIX E								SYSTEM : SERVICE WATER TAG : FT 1SW 9275D SB

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E/I*1FR3565A SA	OPERABIL- ITY	LATER N/A DRA*	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	SIGNAL CONDITIO NERS	NORM/TEST (SEE NOTE 1)			SRSO 8.7SH1	REVIEW				
COMPONENT:	CURRENT TRANSMI TTER J B ASSY	TEMPERAT- URE	104F NORM 104F DRA	LATER	TAB51A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	M	NONE	REPLACEMENT:	
MANUFACTURER:	GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA	LATER	FAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	GENERAL ATOMIC				SRSP 8.7SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	LATER	RELATIVE HUMIDITY	20-90%NORM 100% DRA	LATER	HAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:	
FUNCT. DES: & SERVICE	SPENT FUEL POO L (SOUTH) AREA RAD MONITOR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	/	NONE	1. THIS SUBCOMP BELONGS TO THE ENSEMBLE OF EQUIP WHICH INITIATES CLOSURE OF THE HVAC DAMPERS DUR-	
ACCUR. SPEC:	NOT APPLICABLE				SRSC 8.7SH1	REVIEW			ING THE INCIPIENCE OF A FUEL HANDLING BLDG ACCDNT AND IS NOT NEEDED THERE-	
ACCUR. DEP.:	NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	H	NONE	AFTER. SAFETY FUNCTION: PRRM	
SPECIFICATIONS:	N-29				SRSR 8.7SH1	REVIEW				
P.O #:	435220	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL.	/	NONE		
PLANT LOC.:	AB51				SRSA 8.7SH1	REVIEW				
COORDINATES X- Y- Z-	1594. 1669. 309.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N):	LTR				SRSS 8.7SH1	REVIEW				
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVTFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY O	8.7SH1	REFERENCES: *SIGNIFIES IN THIS CASE DESIGN BASIS FUEL HANDLING BUILDING ACCIDENT				CES#-1180		
*****		TEMPERATURE T	8.7SH1					REVISION # :00		
*QUALIF:	LATER	PRESSURE P	8.7SH1					DATE :		
*STATUS		REL. HUMDTY H	8.7SH1					SYSTEM :RAD.MONITORING		
*		CHEM. SPRAY C	8.7SH1					TAG :E/I*1FR3565A SA		
*		RADIATION R	8.7SH1							
*****		AGING A	8.7SH1							
		SUBMERGENCE S	8.7SH1							
EQ. PCK # :	8.7SH1	OSBR CATEG.:	A							
		APPFNDIX	E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : RE21AV 3509-1 S A	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO				
COMPONENT: RADIATION PRIMARY ELEMENT	TEMPERATURE				SRST	COMB. TEST & SUPPL. REVIEW	/	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: GENERAL ATOMIC	RELATIVE HUMIDITY				SRSP	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: PLANT STACK ACCIDENT RADIATION FILTER SYS	R GAMMA	3.7E4		RAB5125 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR				
SPECIFICATIONS: N-29	S T.I.D.	3.7E4							
P.O #: 435220	AGE-	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION:
PLANT LOC.: AB51	INST LIFE (PER 32-1974 DEF.)				SRSA				
COORDINATES X- 1650. Y- 1750. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY O								QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T								CES#-1312
*****	PRESSURE P								
*QUALIF:	REL. HUMDTY H								
*STATUS	CHEM. SPRAY C								
*	RADIATION R								
*	AGING A								
*****	SUBMERGENCE S								
EQ. PCK # :	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : RE21AV 3509-1 S

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : RE21AV 3509-2 S A	OPERABIL- ITY			OPER. REVIEW		/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO			
COMPONENT: RADIATION PRIMA RY ELEMENT	TEMPERAT- URE				SIRST	P	NONE	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		M	NONE	
MAJOR : GENERAL ATOMIC SUPPLIER					SRRP			
MODEL AND: SERIAL #	RELATIVE HUMIDITY					/	NONE	
FUNCT. DES: PLANT STACK & SERVICE ACCIDENT RADIATION ANAL YZER	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4		RAB5125 FSAR SEC 3.11B		H	NONE	
SPECIFICATIONS: N-29					SRSR			
P.O #: 435220	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		/	NONE	
PLANT LOC.: AB51					SRSA			
COORDINATES X- 1649. Y- 176C. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		/	NONE	
					SRSS			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH ER PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
***** *QUALIF: *STATUS * * *****	OPEPABILITY O *TEMPERATURE T *PRESSURE P *REL. HUMPTY H *CHEM. SFRAY C *RADIATION R *AGING A *SUBMERGENCE S		REFERENCES:				CES#-1313	
EQ. PCK # :	OS88 CATEG.: A APPENDIX E						REVISION # : JO DATE :	
							SYSTEM : REAC.AUX.BLDG HVAC TAG : RE21AV 3509-2 S	

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEV. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : FT 21AV 3509 SA	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO			
COMPONENT: FLOW TRANSMITTER	TEMPERATURE				SRSF	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: LATER	PRESSURE	ATMOS 40R* ATMOS DBA		PAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER	RELATIVE HUMIDITY				SRSF	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #								
FUNCT. DES: PLANT STACK & SERVICE ISOKINETIC FLOW	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		PAB5125 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: IN41					SRSR			
P.O # : 435141	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51					SRSA			SAFETY FUNCTION: SS
COORDINATES X- 1650.0 Y- 1760.0 Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PAPER METER	SUPPL. REVIEW						
*OPERABILITY O *TEMPERATURE T *PRESSURE P *REL. HUMIDTY H *CHEM. SPRAY C *RADIATION R *AGING A *SUBMERGENCE S								
EQ. PCK # :	OS88 CATEG.: A APPENDIX E							

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

CES#-1318

REVISION # : 00
 DATE :

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : FT 21AV 3509 SA

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SP-V2SA-1	OPERABILITY	4CYRS NORM 1YR POST	40YRS NORM 1000 CYC	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DRA	2R CYC 1YR POST DBA		SRSO 3.1SH1	REVIEW				
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAP SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NC UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: VALVE ON TUBING RUN FROM RCS PRESSURIZER STEAM SPACE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1)P.17 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 2483D. (2)POST DBA OPER- ATING CYCLES LIMIT -ED TO 28.	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2)	COMB. TEST & SUPPL. REVIEW	M	NONE		
ACCUR. DEP.: NOT APPLICABLE										
SPECIFICATIONS: M-73A	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
P.O #: 435243										
PLANT LOC.: AB21										
COORDINATES X- 151R. Y- 163C. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1				
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUPMERGENCE	O T P H C R A S	3.1SH1 3.1SH1 3.1SH1 3.1SH1 3.1SH1 3.1SH1 3.1SH1 3.1SH1	REFERENCES: (1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.			CES#-1453 REVISION # :00 DATE :09/18/84			
EQ. PCK # : 3.1SH1	OSPP CATEG.: A APPENDIX E								SYSTEM : SAMPLING SYSTEM TAG : 2SP-V2SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SP-V12SA-1	OPERABIL-ITY	40YRS NORM 1YR POST DBA	40YRS NORM 1200 CYC 2R CYC 1YR POST DBA	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE					SRSO 3.1SH1				
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: WESTINGHOUSE									SUBCOMPONENTS:
MODEL AND SERIAL #: 790-006	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: VALVE ON TUBING RUN FROM RCS PRESSURIZER STEAM SPACE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 24830. (2)POST DBA OPERATING CYCLES LIMITED TO 28.
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2) SRSR 3.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-73A									
P.O #: 435243	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21									
COORDINATES X- 1511.0 Y- 1610.0 Z- 251.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1
QUALIF EXEMPTN: NOT APPLICABLE	OPERABILITY	O 3.1SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.1SH1							CES#-1455
*	REL. HUMDITY	H 3.1SH1							
*	CHEM. SPRAY	C 3.1SH1							
*****	RADIATION	R 3.1SH1							REVISION # :00
	AGING	A 3.1SH1							DATE :09/18/84
	SUBMERGENCE	S 3.1SH1							SYSTEM : SAMPLING SYSTEM
EQ. PCK # : 3.1SH1									TAG : 2SP-V12SA-1
	OS88 CATEG.: A								
	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1

REFERENCES: (1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS.
 (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.

A/E: EBASCO SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARON HARRIS P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

REVISION: 0
 C 1473

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SP-V23SA-1	OPEFABIL-ITY	40YRS NORM 1YR POST	40YRS NORM 193% CYC	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA		28 CYC 1YR POST DBA		SRSO 3.1SH1					
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2R-REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSM 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND SERIAL #: 79Q-006	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 24830.	
FUNCT. DES. & SERVICE: VALVE ON TUBING RUN FROM RCS HOT LEGS OUTSIDE CONTAINMENT	ACCUR. SPEC: NOT APPLICABLE								(2)POST DBA OPERATING CYCLES LIMITED TO 28.	
ACCUR. DEP.: NOT APPLICABLE	R GAMMA	3.0E4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2) SRSR 3.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-73A	A BETA	7.2E4								
P.O #: 435243	D B SHIELD	100%								
PLANT LOC.: AB21	S T.I.D.	3.0E4								
COORDINATES X- 1511. Y- 1630. Z- 236.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	160 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	3.1SH1	REFERENCES: (1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.				CES#-1473		
*****	TEMPERATURE	T	3.1SH1							
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P	3.1SH1							
*STATUS CONFIRMATORY DATA	REL. HUMIDTY	H	3.1SH1							
*	CHEM. SPRAY	C	3.1SH1							
*	RADIATION	R	3.1SH1							
*****	AGING	A	3.1SH1							
	SUBMERGENCE	S	3.1SH1					REVISION # :00 DATE :09/18/84		
EQ. PCK # : 3.1SH1	0588 CATEG.: A							SYSTEM : SAMPLING SYSTEM		
	APPENDIX E							TAG : 2SP-V23SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SP-V120SA-1	OPERABIL- ITY	40YRS NORM 1YP POST	140YPS NORM 11970 CYC	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	DBA	28 CYC 1YR POST DBA		SRSO 3.1SH1	REVIEW			
COMPONENT:	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.6OF13REF (2)APP A DATA SHT 2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2)	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER					SRSO 3.1SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	107% NORM 107% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES:
FUNCT. DES: & SERVICE	S/G-A BLDWN TO SIG SAMPLE COOLER-A				SRSO 3.1SH1	REVIEW			(1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 2483D.
ACCUR. SPEC:	NOT APPLICABLE				SRSO 3.1SH1	REVIEW			(2)POST DBA OPER- ATING CYCLES LIMIT
ACCUR. DEP.:	NOT APPLICABLE								-ED TO 28.
SPECIFICATIONS:	M-73A								
P.O #:	435243								
PLANT LOC.:	AB21								
COORDINATES X- Y- Z-	1430. 1687. 255.0								
INSTALLED (Y/N):	LTR								
INSTAL. REF:	BY-FLO								
QUALIF EXEMPTN:	NOT APPLIC								

*QUALIF:	QUALIFIED-AWAITING								
*STATUS	CONFIRMATORY DATA								
* * *****									
EQ. PCK # :	3.1SH1								

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTES:

(1)P.19 OF 23 SECT
9.0 RPT 2804C &
TECH MANUAL RPT
2483D.

(2)POST DBA OPER-
ATING CYCLES LIMIT
-ED TO 28.

SAFETY FUNCTION:
CI

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.1SH1

CES#-1475

REFERENCES: (1)T-R REPORT 2804C AGING, SEIS
-MIC & ACCIDENT CONDITIONS.
(2)T-R REPORT 2375C AGING, SEIS
-MIC & ACCIDENT SIMULATION
TEST.

REVISION # :00
DATE :09/18/84

SYSTEM :SAMPLING
SYSTEM
TAG :2SP-V120SA-1

0588 CATEG.: A
APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SP-V121SA-1	OPERABIL-ITY	40YRS. NORM 1YR POST	40YRS NORM 1000 CYC	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA	20 CYC 1YR POST DBA		SRSO 3.1SH1				
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: WESTINGHOUSE									SUBCOMPONENTS:
MODEL AND SERIAL #: 790-005	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: S/G-B BLDWN TO S/G SAMPLE COOLER-B	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1) P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 2493D. (2) POST DBA OPERATING CYCLES LIMITED TO 2R.
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	1.75F8	PAR21R6 FSAR SEC 3.11B	APP C REF (2)	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-73A									
P.O #: 435243	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21									
COORDINATES X- 1492. Y- 163C. Z- 255.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD									
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1
*****	OPERABILITY	O 3.1SH1							CES#-1476
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.1SH1							
*	REL. HUMIDTY	H 3.1SH1							
*	CHEM. SPRAY	C 3.1SH1							
*****	RADIATION	R 3.1SH1							
	AGING	A 3.1SH1							
	SUBMERGENCE	S 3.1SH1							
EQ. PCK #: 3.1SH1				REFERENCES: (1) T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2) T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.					REVISION #: 00 DATE: 09/18/84
	Q588 CATEG.: A								SYSTEM: SAMPLING SYSTEM
	APPENDIX E								TAG: 2SP-V121SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SP-V122SA-1	OPERABILITY	40YRS NORM 1YR POST	40YRS NORM 1800 CYC	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA		12R CYC 1YR POST DBA		SRSO 3.1SH1				
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: WESTINGHOUSE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: S/G-C BLDWN TO S/G SAMPLE COOLER-C	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 24830. (2)POST DBA OPERATING CYCLES LIMITED TO 28.
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2) SRSR 3.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
SPECIFICATIONS:M-73A	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435243									
PLANT LOC.: AB21									
COORDINATES X- 1580. Y- 1687. Z- 255.0									
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1		
*****	OPERABILITY	O 3.1SH1		REFERENCES: (1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.			CESN-1477		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.1SH1							
*	REL. HUMDTY	H 3.1SH1							
*	CHEM. SPRAY	C 3.1SH1							
*****	RADIATION	R 3.1SH1							
	AGING	A 3.1SH1							
	SUBMERGENCE	S 3.1SH1							
EQ. PCK #: 3.1SH1	US88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: SAMPLING SYSTEM TAG: 2SP-V122SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SP-V116SA-1	OPERABILITY	40YRS NORM 1YR POST NORM/TEST DBA	140YRS NORM 1990 CYC 7R CYC 1YR POST DBA	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS					SRSO 3.1SH1				
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2, 2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: WESTINGHOUSE									SUBCOMPONENTS:
MODEL AND SERIAL #: 790-005	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES:
FUNCT. DES & SERVICE: ACCUMULATOR SAMPLE HEADER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	(1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 2483D. (2)POST DBA OPER- ATING CYCLES LIMIT -ED TO 25.
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	3.0E4 7.2E4 100X 3.0E4	1.35E8	RAB21R6 FSAP SEC 3.11B	APP C REF (2) SRSR 3.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-73A									
P.O #: 435243	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PAPA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21									
COORDINATES X- 1520. Y- 1635. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO									
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1
*****	OPERABILITY O	3.1SH1		REFERENCES: (1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.					CES#-1486
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.1SH1							REVISION # :00
*STATUS CONFIRMATORY DATA	PRESSURE P	3.1SH1							DATE :09/18/84
*	REL. HUMDTY H	3.1SH1							
*	CHEM. SPRAY C	3.1SH1							
*****	RADIATION R	3.1SH1							
	AGING A	3.1SH1							
	SUBMERGENCE S	3.1SH1							
EQ. PCK # : 3.1SH1								SYSTEM : SAMPLING SYSTEM	
	OSER CATEG.: A APPENDIX E							TAG : 2SP-V116SA-1	



A/E: EBASCO SERVICES INC.
 UTILITY: DELAWARE POWER & LIGHT

FACILITY: SHEARON HARBOR P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

R 0
 C 1488

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SP-V302SB-1	OPERABILITY	40YRS NORM 1YR POST	40YRS NORM 12R CYC 1YR POST DBA	OPEP. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVE OPERATORS					SRSO 3.1SH1					
COMPONENT: SOLENOID OPERATED VALVE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,24 & 28 REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: WESTINGHOUSE									SUBCOMPONENTS:	
MODEL AND SERIAL #: 79Q-018	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: LINE THROUGH CONT PEN M73B FROM REM 3502A -SA	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTES: (1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 2483D. (2)POST DBA OPER- ATING CYCLES LIMIT -ED TO 28.	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.1SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D R SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0F4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2)	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: P-73A					SRSR 3.1SH1					
P.O #: 435243	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB21										
COORDINATES X- 1455. Y- 1645. Z- 255.1	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1			
*****	OPERABILITY	O 3.1SH1					CES#-1488			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.1SH1								
*	REL. HUMIDTY	H 3.1SH1								
*	CHEM. SPRAY	C 3.1SH1								
*****	RADIATION	R 3.1SH1								
	AGING	A 3.1SH1								
	SUBMERGENCE	S 3.1SH1								
EQ. PCK # : 3.1SH1			REFERENCES: (1)T-R REPORT. 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS. (2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.				REVISION # : 00 DATE : 09/18/84			
	C588 CATEG.: A APPENDIX E						SYSTEM : SAMPLING SYSTEM TAG : 2SP-V302SB-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SP-V303SB-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 1YR POST DBA	40YRS NORM 1970 CYC 12P CYC 1YR POST DBA	OPER. REVIEW	REF (2)	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	VALVE OPERATORS				SRSO 3.1SH1					
COMPONENT:	SOLENOID OPERAT FD VALVE	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 1174F DBA	TAB21A FSAR SEC 3.11B	P.60F13REF (2)APP A DATA SHT 2 SRST 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	TARGET ROCK CORP	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	APP A DATA SHT 2,2A & 2B REF(2) SRSP 3.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	WESTINGH'SE									SUBCOMPONENTS:
MODEL AND: SERIAL #	79Q-018	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.6 OF 13 SECT 4.1.1APP A SRSH 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES:
FUNCT. DES: & SERVICE	CONT PEN M73A TO REM 1LT- 3502A-SA	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	(1)P.19 OF 23 SECT 9.0 RPT 2804C & TECH MANUAL RPT 24830.
ACCUR. SPEC:	NOT APPLICABLE					SRSC 3.1SH1				(2)POST DBA OPER- ATING CYCLES LIMIT
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	1.35E8	RAB21R6 FSAR SEC 3.11B	APP C REF (2)	COMB. TEST & SUPPL. REVIEW	H	NONE	-ED TO 28.
SPECIFICATIONS:	M-73A					SRSR 3.1SH1				
P.O #:	435243	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YPS	10 CFR50 PARA.50.51	REF(2) P.6 OF 13 APP A SRSA 3.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1455. 1645. 255.2	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.1SH1		
*****		OPERABILITY O	3.1SH1							
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE T	3.1SH1							
*STATUS	CONFIRMATORY DATA	PRESSURE P	3.1SH1							
*		REL. HUMDTY H	3.1SH1							
*		CHEM. SPRAY C	3.1SH1							
*****		RADIATION R	3.1SH1							
		AGING A	3.1SH1							
		SUBMERGENCE S	3.1SH1							
EQ. PCK # :	3.1SH1			REFERENCES:				(1)T-R REPORT 2804C AGING, SEIS -MIC & ACCIDENT CONDITIONS.		
								(2)T-R REPORT 2375C AGING, SEIS -MIC & ACCIDENT SIMULATION TEST.		
		OS28 CATEG.:	A					REVISION # :JO		
		APPENDIX E						DATE :09/18/84		
								SYSTEM :SAMPLING SYSTEM		
								TAG :2SP-V303SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AC-D10SB-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE : DAMPERS	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN. : SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MAJOR SUPPLIER : RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81				
MODEL AND SERIAL # : EA-180	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.74E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE : REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-1506			
P.O #: 435205	TEMPERATURE	T 9.1SH1											
PLANT LOC.: AB41	PRESSURE	P 9.1SH1											
COORDINATES X- 1557. Y- 1616. Z- 295.0	REL. HUMIDTY	H 9.1SH1											
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 9.1SH1											
INSTAL. REF: BY-FLD	RADIATION	R 9.1SH1											
QUALIF EXEMPTN: NOT APPLIC	AGING	A 9.1SH1											
*****	SUBMERGENCE	S 9.1SH1											
*QUALIF: QUALIFIED-AWAITING	OS88 CATEG.: A												
*STATUS CONFIRMATORY DATA	APPENDIX E												
* *****													
EQ. PCK # : 9.1SH1													
									REVISION # : 00 DATE : 09/18/84				
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D10SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AC-D17SA-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 9 DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	
MANUFACTURER: ITT					SRS3.10SH1			REPLACEMENT: REF(2)	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB41 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	
					SRSP3.10SH1			MAINTAIN.: REF(2)	
MODEL AND SERIAL #: NH96	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM & DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: DAMPER OPERATOR					SRSH3.10SH1			NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC3.10SH1				
ACCUR. DEF.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	5.0E6 NORM & DBA	RAB4117 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	P	NONE	
SPECIFICATIONS: RE-25					SRSR3.10SH1				
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AR41					SRSA3.10SH1			SAFETY FUNCTION: SS	
COORDINATES X- 1427. Y- 1604. Z- 298.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRSS3.10SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1	
*QUALIF: QUALIFIED	OPERABILITY	O 3.10SH1		REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.				CES#-1511	
*STATUS	TEMPERATURE	T 3.10SH1						REVISION # : 00	
*	PRESSURE	P 3.10SH1						DATE : 09/14/84	
*	REL. HUMIDTY	H 3.10SH1						SYSTEM : REAC.AUX.BLDG HVAC	
*	CHEM. SPRAY	C 3.10SH1						TAG : AC-D17SA-1	
*	RADIATION	R 3.10SH1							
*	AGING	A 3.10SH1							
	SUBMERGENCE	S 3.10SH1							
EQ. PCK # : 3.10SH1	GS88 CATEG.: A APPENDIX E								



A/E: EBASCO VICES INC.
 UTILITY: CHINA POWER & LIGHT

FACILITY: SHEARON HARRIS - P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 512

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D17SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-081 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: REMOTE INDICAT & SERVICE & SERVICE POSITION	R GAPMA	2.6E4	2.04E8	RAB4117 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%								
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6F4				SRSR 9.2SH1				
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB41	PARAMETER	SUPPL. REVIEW								
COORDINATES X- 1427. Y- 1604. Z- 298.0	OPERABILITY	O	9.2SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
INSTALLED (Y/N): LTR	TEMPERATURE	T	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1512		
INSTAL. REF: BY-FLD	PRESSURE	P	9.2SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H	9.2SH1							
*****	CHEM. SPRAY	C	9.2SH1							
*QUALIF: QUALIFIED-AWAITING	RADIATION	R	9.2SH1							
*STATUS CONFIRMATORY DATA	AGING	A	9.2SH1					REVISION # :00 DATE :09/18/84		
* *****	SURMERGENCE	S	9.2SH1					SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D17SA-1		
EQ. PCK # : 9.2SH1	OS88 CATEG.: A	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D18SA-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS				SRS03.10SH1					
COMPONENT:	ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM 4 DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2 SRST3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	9"470	PAB41 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF(2)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 4 DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	5.0E6 NORM & DBA	RAB4117 FSAR SEC 3.11E	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YPS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O #:	435205	PARAMETER								
PLANT LOC.:	AB41	SUPPL. REVIEW								
COORDINATES X- Y- Z-	1422. 1607. 300.0	OPERABILITY O								
INSTALLED (Y/N):	LTR	TEMPERATURE T								
INSTAL. REF:	BY-FLD	PRESSURE P								
QUALIF EXEMPTH:	NOT APPLIC	REL. HUMDTY H								
*QUALIF:	QUALIFIED	CHEM. SPRAY C								
*STATUS		RADIATION R								
*		AGING A								
*		SUBMERGENCE S								
EQ. PCK # :	3.10SH1	OS88 CATEG.:	A							
		APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:3.10SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE:3.10SH1

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
(2)NH91 & NH95 ACTUATOR MAIN-
TENANCE SCHEDULE #721.81.132.

CES#-1513
REVISION # :00
DATE :09/14/84
SYSTEM :REAC.AUX.BLDG
HVAC
TAG :AC-D18SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AC-D18SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	FAB41 FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : SUPPLIER	RUSKIN				SRSO 9.2SH1			
MODEL AND: SERIAL #	EA-180							
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION							
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	2.04E8	RAB4117 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	M	NONE
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AR41	COORDINATES X- Y- Z-	1422. 1607. 300.0						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1						
EQ. PCK # : 9.2SH1	C588 CATEG.: A APPENDIX E							

REPLACEMENT:
P.079-D81 OF
REF(1)
MAINTAIN.:
P.079-D81 OF
REF(1)
SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1)NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/78.

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.2SH1

CES#-1514

REVISION # :00
DATE :09/18/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AC-D18SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D19SB-1	OPERABIL- ITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS					SRS03.10SH1				
COMPONENT:	ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM 2 DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2 SRST3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	19" H2O	PAB41 FSAR SEC 3.11B	REF(1)P-2 SRSP3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 18 DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6 SRSH3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A SRSC3.10SH1	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	5.3E6 NORM & DBA	RAB4117 FSAR SEC 3.11B	REF(1)P-6 SRSR3.10SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	1U CFR50 PARA.50.51	REF(1)P-6 SRSA3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS3.10SH1	N/A	/	NONE	
P.O #:	435205	COORDINATES X- Y- Z-	1565. 1632. 294.0							
PLANT LOC.:	AB41	INSTALLED (Y/N):	LTR							
COORDINATES X- Y- Z-	1565. 1632. 294.0	INSTAL. REF:	BY-FLD							
EQ. PCK # :	3.10SH1	QUALIF EXEMPTN:	NOT APPLIC							
		*QUALIF:	QUALIFIED							
		*STATUS								
		*PARAMETER	SUPPL. REVIEW							
		*OPERABILITY	O 3.17SH1							
		*TEMPERATURE	T 3.17SH1							
		*PRESSURE	P 3.17SH1							
		*REL. HUMIDTY	H 3.17SH1							
		*CHEM. SPRAY	C 3.10SH1							
		*RADIATION	R 3.10SH1							
		*AGING	A 3.10SH1							
		*SUBMERGENCE	S 3.17SH1							
		U588 CATEG.:	A							
		APPENDIX	E							
		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:	3.10SH1							
		REFERENCES:	(1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAIN- TENANCE SCHEDULE #721.81.132.							
		QUALIFICATION SIGN-OFF	FOUND IN DOCUMENTATION PACKAGE: 3.10SH1							
		CES#-1515								
		REVISION # :	00							
		DATE	:09/14/84							
		SYSTEM :	REAC.AUX.BLDG HVAC							
		TAG	:AC-D19SB-1							





A/E: EBASCO SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEPSON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

07
 CES# 1527

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D5SB-1	OPERABIL- ITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS				SRS03.10SH1					
COMPONENT:	ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM % DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)	
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB41 FSAR SEC 3.11B	REF(1)P-2 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)	
MAJOR : SUPPLIER	RUSKIN				SRS03.10SH1				SUBCOMPONENTS:	
MODEL AND: SERIAL #	NH-96	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM % DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A N/A N/A	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE				SRSC3.10SH1					
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 7.2E4 100% 2.6E4	5.7E6 NORM & DBA	RAB4117 FSAR SEC 3.11B	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	BE-25				SRSR3.10SH1					
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.:	AB41				SRSA3.10SH1					
COORDINATES X- Y- Z-	1574. 1688. 297.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A N/A N/A	/	NONE		
INSTALLED (Y/H):	LTR				SRSS3.10SH1					
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O 3.10SH1					CES#-1527		
*****		TEMPERATURE	T 3.10SH1							
*QUALIF:	QUALIFIED	PRESSURE	P 3.10SH1							
*STATUS		REL. HUMDTY	H 3.10SH1							
*		CHEM. SPRAY	C 3.10SH1							
*		RADIATION	R 3.10SH1							
*****		AGING	A 3.10SH1							
		SUBMERGENCE	S 3.10SH1							
EQ. PCK # :	3.10SH1			REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAIN- TENANCE SCHEDULE #721.81.132.				REVISION # :00 DATE :09/14/86		
		0588 CATEG.:	A					SYSTEM :REAC.AUX.BLDG HVAC		
		APPENDIX E						TAG :AC-D5SB-1		

A/E: EBA. SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARON HA
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

HW- 0
 -1531

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D7SA-1	OPERABILITY	40YRS NORM 1YR DBA	14YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPERS					SRS03.10SH1					
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM R DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF(2)	
MANUFACTURER: ITT					SRS3.10SH1					
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	0.470	PAB41 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF(2)	
MODEL AND SERIAL #: NH-96					SRS3.10SH1					
FUNCT. DES. & SERVICE: DAMPER OPERATOR	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM % DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
					SRS3.10SH1					
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE		
					SRS3.10SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	5.7E6	RAB4117	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA	7.2E4	NORM & DBA	FSAR SEC 3.11B						
	D B SHIELD	100%			SRS3.10SH1					
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4								
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB41					SRS3.10SH1					
COORDINATES X- 1442. Y- 1618. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE		
					SRS3.10SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC ***** *QUALIF: QUALIFIED *STATUS * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
	OPERABILITY	O 3.10SH1		REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.				CES#-1531		
	TEMPERATURE	T 3.10SH1						REVISION # : 00		
	PRESSURE	P 3.10SH1						DATE : 09/14/84		
	REL. HUMDTY	H 3.10SH1						SYSTEM : REAC.AUX.BLDG HVAC		
	CHEM. SPRAY	C 3.10SH1						TAG : AC-D7SA-1		
	RADIATION	R 3.10SH1								
	AGING	A 3.10SH1								
	SUBMERGENCE	S 3.10SH1								
EQ. PCK # : 3.10SH1	OS8P CATEG.: A APPENDIX E									



A/E: EBAS SERVICES INC.
 UTILITY: ATLANTA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 906 MW(E)

0
 -1533

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AC-DRSA-1	OPERABIL- ITY	40YRS NORM 1YR DBA	40YPS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA				SRS03.10SH1			
COMPONENT: ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM 2 DBA	TAB41A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER:ITT					SRST3.10SH1			REPLACEMENT: REF(2)
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB41 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
					SRSP3.10SH1			MAINTAIN.: REF(2)
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90X NORM 100X DBA	100X NORM 2 DBA	HAB41 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSH3.10SH1			NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE
					SRSC3.10SH1			
ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	5.0E6 NORM & DBA	RAB4117 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE
					SRSR3.10SH1			
SPECIFICATIONS:BE-25								
P.O #:435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSA3.10SH1			SAFETY FUNCTION: SS
PLANT LOC.: AB41								
COORDINATES X- 1456. Y- 1618. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE
					SRSS3.10SH1			
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW						
*****	OPERABILITY O	3.10SH1						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:3.10SH1
*QUALIF: QUALIFIED	*TEMPERATURE T	3.10SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:3.10SH1
*STATUS	*PRESSURE P	3.10SH1						CES#-1533
*	*REL. HUMIDTY H	3.10SH1						
*	*CHEM. SPRAY C	3.10SH1						
*****	*RADIATION R	3.10SH1						REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
	AGING A	3.10SH1						(2)NH91 & NH95 ACTUATOR MAIN- TENANCE SCHEDULE #721.81.132.
	SUBMERGENCE S	3.10SH1						REVISION # :00 DATE :09/14/84
EQ. PCK # : 3.10SH1								SYSTEM : REAC.AUX.BLDG HVAC
	0588 CATEG.: A APPENDIX E							TAG : AC-D8SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D9SB-1	OPERABIL- ITY	40YRS NORM 560 CYC	40YRS NORM 10730 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS	NORM/TEST DBA	1YR DBA		SRSD 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	RUSKIN				SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.34E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: RE-25					SRSR 9.1SH1	REVIEW				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	47 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB41					SRSA 9.1SH1	REVIEW				
COORDINATES X- 1545. Y- 1616. Z- 295.0		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC										
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
		OPERABILITY O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-1536		
		TEMPERATURE T	9.1SH1					REVISION # : 00 DATE : 09/18/84		
		PRESSURE P	9.1SH1					SYSTEM : REAC.AUX.BLDG HVAC		
		REL. HUMDTY H	9.1SH1					TAG : AC-D9SB-1		
		CHEM. SPRAY C	9.1SH1							
		RADIATION R	9.1SH1							
		AGING A	9.1SH1							
		SUBMERGENCE S	9.1SH1							
EQ. PCK # : 9.1SH1		OS88 CATEG.: A APPENDIX E								

A/E: EBASCO SERVICES INC.
 UTILITY: MAINE POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 538

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : AH-10(1A-SA)	OPERABILITY	4YRS NORM 1YR DBA	>4YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1				
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: RH INSULATION									
FUNCT. DES. & SERVICE: DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-08					SRSR 4.2SH1				
P.O #: 435105.	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 4.2SH1				
COORDINATES X- 1450. Y- 1614. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
					SRSS 4.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
	OPERABILITY	O 4.2SH1		REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.			CES#-1538 REVISION # : 00 DATE : 07/06/84		
	TEMPERATURE	T 4.2SH1							
	PRESSURE	P 4.2SH1							
	REL. HUMIDTY	H 4.2SH1							
	CHEM. SPRAY	C 4.2SH1							
	RADIATION	R 4.2SH1							
	AGING	A 4.2SH1							
	SUBMERGENCE	S 4.2SH1		SYSTEM : REAC.AUX.BLDG HVAC					
EQ. PCK # : 4.2SH1	0588 CATEG.: A APPENDIX E						TAG : AH-10(1A-SA)		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-10(1B-SB)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNIT								
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAR21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE								
MAJOR SUPPLIER: BAHNSON	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MODEL AND SERIAL #: RH INSULATION	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.94E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-08								
P.O #: 435105	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21								
COORDINATES X- 1510. Y- 1614. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD								
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
*****	OPERABILITY O	4.2SH1						CES4-1540
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE P	4.2SH1						
*	REL. HUMDTY H	4.2SH1						
*	CHEM. SFRAY C	4.2SH1						
*****	RADIATION R	4.2SH1						REVISION # :00
	AGING A	4.2SH1						DATE :07/06/84
	SUBMERGENCE S	4.2SH1						SYSTEM : REAC.AUX.BLDG HVAC
EQ. PCK # : 4.2SH1								TAG : AH-10(1B-SB)
	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 SEE INSTR
 MANUAL
 MAINTAIN.:
 SEE INSTR
 MANUAL
 SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

REFERENCES:
 1. RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT NUC-9,
 DATED JULY 1, 1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-11(1A-SA)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: AIR HANDLING UNIT	NORM/TEST DBA							
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RM INSULATION DRIVE FAN & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4						
SPECIFICATIONS: BE-08	D B SHIELD	100%						
P.O #: 435105	S T.I.D.	3.0E4	2.04E8					
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1479. Y- 1613. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW						
INSTALL. REF: BY-FLD	OPERABILITY	O 4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 4.2SH1						
*****	PRESSURE	P 4.2SH1						
*QUALIF: QUALIFIED-AWAITING	REL. HUMPTY	H 4.2SH1						
*STATUS CONFIRMATORY DATA	CHEM. SPRAY	C 4.2SH1						
*	RADIATION	R 4.2SH1						
*	AGING	A 4.2SH1						
*****	SUBMERGENCE	S 4.2SH1						
EQ. PCK # : 4.2SH1	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 SEE INSTR MANUAL
 MAINTAIN.:
 SEE INSTR MANUAL
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 4.2SH1

CES#-1542

REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT NUC-9,
 DATED JULY 1, 1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.

REVISION # : 00
 DATE : 07/06/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AH-11(1A-SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-11(1B-SB)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 176F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA A BETA D P SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
SPECIFICATIONS: BE-08	PARAMETER	SUPPL. REVIEW						
P.O #: 435105	OPERABILITY	O 4.2SH1						
PLANT LOC.: AB21	TEMPERATURE	T 4.2SH1						
COORDINATES X- 1496. Y- 1613. Z- 236.0	PRESSURE	P 4.2SH1						
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 4.2SH1						
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 4.2SH1						
*****	AGING	A 4.2SH1						
QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S 4.2SH1						
STATUS CONFIRMATORY DATA	OS88 CATEG.: A							
*****	APPENDIX E							

REPLACEMENT:
SEE INSTR
MANUAL
MAINTAIN.:
SEE INSTR
MANUAL
SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH E0 PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 4.2SH1

CES#-1544

REFERENCES:
1. RELIANCE ELECTRIC CO. MOTOR
QUALIFICATION REPORT NUC-9,
DATED JULY 1, 1978, TOGETHER
WITH SUPPLEMENTAL REPORT, REV
2, DATED 7/15/81.

REVISION #: 00
DATE: 07/06/84

SYSTEM: REAC. AUX. BLDG
HVAC
TAG: AH-11(1B-SB)

EQ. PCK #: 4.2SH1

A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 C 1546

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-12(1A-SA)	OPERABILITY	40YRS NORM 1YR DBA	>4YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT					SRSO 4.2SH1				
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER: RELIANCE					SRST 4.2SH1				MAINTAIN.: SEE INSTR MANUAL
MAJOR SUPPLIER : RANSON	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB41 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : RH INSULATION	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.04E8	RAB4117 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: BE-08					SRSR 4.2SH1				
P.O #: 435105	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>4YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB41					SRSA 4.2SH1				
COORDINATES X- 1438. Y- 1616. Z- 286.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
					SRSS 4.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: PY-FLD QUALIF EXEMPTH: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1
	OPERABILITY	O 4.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
	TEMPERATURE	T 4.2SH1							CES#-1546
	PRESSURE	P 4.2SH1							REVISION # :30 DATE :07/06/84
	REL. HUMDTY	H 4.2SH1							SYSTEM : REAC.AUX.BLDG HVAC
	CHEM. SPRAY	C 4.2SH1							TAG : AH-12(1A-SA)
	RADIATION	R 4.2SH1							
	AGING	A 4.2SH1							
	SUPMERGENCE	S 4.2SH1							
EQ. PCK # : 4.2SH1	OS88 CATEG.: A APPENDIX E								REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-12(1B-SA)	OPERABIL-ITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNIT TYPE: IT	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB41 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB41 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA	2.6E4	2.34E8	RAB4117 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-08	S T.I.D.	2.6E4	2.34E8		SRSR 4.2SH1			
P.O #: 435105	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB41	SURMERGED LEVEL	NOT APPLICABLE	NA	SAB41 FSAR SEC 3.11B	NA	N/A	/	NONE
COORDINATES X- 1458. Y- 1616. Z- 286.0					SRSS 4.2SH1			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1	
*****	OPERABILITY	O 4.2SH1		REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.			CESN-1548	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 4.2SH1					REVISION # : 00	
*STATUS CONFIRMATORY DATA	PRESSURE	P 4.2SH1					DATE : 07/06/84	
*	REL. HUMIDTY	H 4.2SH1					SYSTEM : REAC.AUX.BLDG HVAC	
*	CHEM. SPRAY	C 4.2SH1					TAG : AH-12(1B-SA)	
*****	RADIATION	R 4.2SH1						
	AGING	A 4.2SH1						
	SURMERGENCE	S 4.2SH1						
EQ. PCK # : 4.2SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
SEE INSTR
MANUAL
MAINTAIN.:
SEE INSTR
MANUAL
SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS



A/E: EBASC
UTILITY: IVICES INC.
INA POWER & LIGHT

FACILITY: SHEARON HARR
COMPONENT EVALUATION PP - 1

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

U
1550

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-13(1A-SB)	OPERABILITY	40YRS NORM 1YR DBA	>4YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB41 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA	2.6E4	2.04E8	RAB4117 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	M	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	D B SHIELD	100%							
ACCUR. SPEC: NOT APPLICABLE	S T.I.D.	2.6E4	2.04E8						
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>4YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: BE-D8	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
P.O #: 435105									
PLANT LOC.: AB41									
COORDINATES X- 1542. Y- 1615. Z- 286.0									
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
*****	OPERABILITY O	4.2SH1		REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.			CES#-1550		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	4.2SH1							
*	REL. HUMPTY H	4.2SH1							
*	CHEM. SPRAY C	4.2SH1							
*****	RADIATION R	4.2SH1							
	AGING A	4.2SH1		REVISION # : 00			DATE : 07/06/84		
	SUBMERGENCE S	4.2SH1		SYSTEM : REAC.AUX.BLDG HVAC			TAG : AH-13(1A-SB)		
EQ. PCK # : 4.2SH1	OS88 CATEG.: A APPENDIX E								



A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARRIS - PP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1552

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-13(1B-SB)	OPERABILITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 Pg 21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB41 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.04E8	RAB4117 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	M	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB41 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: BE-08	OPERABILITY	O	4.2SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
P.O #: 435105	TEMPERATURE	T	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.					CES#-1552
PLANT LOC.: AB41	PRESSURE	P	4.2SH1						REVISION #: 00
COORDINATES X- 1561.	REL. HUMIDTY	H	4.2SH1						DATE : 07/06/84
Y- 1615.	CHEM. SPRAY	C	4.2SH1						SYSTEM : REAC.AUX.BLDG HVAC
Z- 286.0	RADIATION	R	4.2SH1						TAG : AH-13(1B-SB)
INSTALLED (Y/N): LTR	AGING	A	4.2SH1						
INSTAL. REF: BY-FLD	SUBMERGENCE	S	4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	OS88 CATEG.: A								
*****	APPENDIX E								

A/E: EBAS SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PHR
 CAPACITY: 900 MW(E)

0
 CC-1554

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : AH-15(1A-SA)	OPERABILITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: AIR HANDLING UNIT TYPE	NORM/TEST DBA				SRSO 4.2SH1	REVIEW			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL.	F	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL.	F	NONE	MAINTAIN.: SEE INSTR MANUAL
MAJOR SUPPLIER : BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: RH INSULATION	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: DRIVE FAN & SERVICE					SRSW 4.2SH1	REVIEW			
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.7E4 100X 3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-08					SRSR 4.2SH1	REVIEW			
P.O #: 435105	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51					SRSA 4.2SH1	REVIEW			
COORDINATES X- 1614. Y- 168C. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
*****	OPERABILITY	O 4.2SH1							CES#-1554
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 4.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 4.2SH1							
*	REL. HUMPTY	H 4.2SH1							
*	CHEM. SPRAY	C 4.2SH1							
*****	RADIATION	R 4.2SH1							
	AGING	A 4.2SH1							
	SUBMERGENCE	S 4.2SH1							
EQ. PCK # : 4.2SH1									REVISION # : 00 DATE : 07/06/84
	CS88 CATEG.: A APPENDIX E								SYSTEM : CONTROL ROOM HVAC TAG : AH-15(1A-SA)

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT NUC-9,
 DATED JULY 1, 1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-15(1B-SE)	OPERABILITY	40YRS NORM 1YR DBA	>40YPS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1				
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	FAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA	3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D & B SHIELD	100%							
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	3.7E4	2.34E8		SRSR 4.2SH1				
SPECIFICATIONS: BE-02	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YPS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435105	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
PLANT LOC.: AB51					SRSA 4.2SH1				
COORDINATES X- 1610. Y- 1663. Z- 305.0					SRSS 4.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1	
*****	OPERABILITY O	4.2SH1		REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT MUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1556	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.2SH1						REVISION # : 00	
*STATUS CONFIRMATORY DATA	PRESSURE P	4.2SH1						DATE : 07/06/84	
*	REL. HUMDTY H	4.2SH1						SYSTEM : CONTROL ROOM	
*	CHEM. SPRAY C	4.2SH1						HVAC	
*****	RADIATION R	4.2SH1						TAG : AH-15(1B-SB)	
	AGING A	4.2SH1							
	SUBMERGENCE S	4.2SH1							
EQ. PCK # : 4.2SH1	OS88 CATEG.: A								
	APPENDIX E								

REPLACEMENT:
 SEE INSTR
 MANUAL
 MAINTAIN.:
 SEE INSTR
 MANUAL
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-16(1A-SA)	OPERABIL-ITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UN TYPE IT	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER : BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	2.04E8 2.04E8	RAB5125 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES: DRIVE FAN & SERVICE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: BE-08	OPERABILITY	O	4.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1	
P.O #: 435105	TEMPERATURE	T	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT MUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CESN-1558	
PLANT LOC.: AB51	PRESSURE	P	4.2SH1					REVISION # : 00	
COORDINATES X- 1637. Y- 168C. Z- 305.0	REL. HUMDTY	H	4.2SH1					DATE : 07/06/84	
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	4.2SH1					SYSTEM : REAC.AUX.BLDG HVAC	
INSTAL. REF: BY-FLD	RADIATION	R	4.2SH1					TAG : AH-16(1A-SA)	
QUALIF EXEMPTN: NOT APPLIC	AGING	A	4.2SH1						
*****	SUBMERGENCE	S	4.2SH1						
*****	0588 CATEG.: A								
*****	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AH-16(1B-SP)	OPERABIL-ITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1					
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE INSTR MANUAL	
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL	
MAJOR SUPPLIER : BARNSON	RELATIVE HUMIDITY	20-90X NORM 100X DBA	100X	HAB51 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND SERIAL # : RH INSULATION										
FUNCT. DES. & SERVICE : DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-08					SRSR 4.2SH1					
P.O #: 435105	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA 4.2SH1					
COORDINATES X- 1637. Y- 1663. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE		
INSTALLED (Y/N): LTR					SRSS 4.2SH1					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
QUALIF EXEMPT: NOT APPLIC	OPERABILITY	O 4.2SH1		REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1560		
*****	TEMPERATURE	T 4.2SH1						REVISION # : 00		
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 4.2SH1						DATE : 07/06/84		
*STATUS CONFIRMATORY DATA	REL. HUMIDTY	H 4.2SH1						SYSTEM : REAC.AUX.BLDG HVAC		
*	CHEM. SPRAY	C 4.2SH1						TAG : AH-16(1B-SB)		
*	RADIATION	R 4.2SH1								
*****	AGING	A 4.2SH1								
	SUBMERGENCE	S 4.2SH1								
EQ. PCK # : 4.2SH1	US28 CATEG.: A									
	APPENDIX E									

A/E: EBASCO SERVICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

0
 1574

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-23(1X-SA)	OPERABIL- ITY	4YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	AIR HANDLING UN ITS							
COMPONENT:	MOTOR	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER:	RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB21 FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : SUPPLIER	BAHNSON	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SERIAL #	RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA N/A	/	NONE
FUNCT. DES: & SERVICE	DRIVE FAN	R GAMMA	3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21 COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC:	NOT APPLICABLE	D B SHIELD	100%		SRSR 4.2SH1			
ACCUR. DEM.:	NOT APPLICABLE	S T.I.D.	3.0E4	2.74E8	SRSR 4.2SH1			
SPECIFICATIONS:	BE-08	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #:	435105	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA N/A	/	NONE
PLANT LOC.:	AB21	OPERABILITY O						
COORDINATES X- Y- Z-	1545. 176C. 236.0	TEMPERATURE T						
INSTALLED (Y/N):	LTR	PRESSURE P						
INSTAL. REF:	BY-FLD	REL. HUMDTY H						
QUALIF EXEMPTN:	NOT APPLIC	CHEM. SPRAY C						
*****		RADIATION R						
*QUALIF:	QUALIFIED-AWAITING	AGING A						
*STATUS	CONFIRMATORY DATA	SUBMERGENCE S						
*								
*								

EQ. PCK # :	4.2SH1							

REPLACEMENT:
 SEE INSTR
 MANUAL
 MAINTAIN. :
 SEE INSTR
 MANUAL
 SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCLIST ITEMS SEE SH E9 PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 4.2SH1

CES#-1574

REFERENCES: 1.RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT MUC-9,
 DATED JULY 1,1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.

REVISION # :00
 DATE :07/06/84

SYSTEM :REAC.AUX.BLDG
 HVAC
 TAG :AH-23(1X-SA)

0588 CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-24(1X-SA)	OPERABILITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNITS	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB31 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB31 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB31 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES: DRIVE FAN & SERVICE	R GAMMA	2.6E4	2.04E8	RAB3111	REF 1	COMB.	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5		FSAR SEC 3.11B	PG.14 & 21	TEST & SUPPL.		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-08	S T.I.D.	2.6E4	2.04E8		SRSR 4.2SH1	REVIEW		
P.O #: 435105	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB31 FSAR SEC 3.11B	NA	N/A	/	NONE
COORDINATES X- 1451. Y- 1623. Z- 261.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR	OPERABILITY O	4.2SH1						
INSTAL. REF: BY-FLD	TEMPERATURE T	4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	PRESSURE P	4.2SH1						
*****	REL. HUMDTY H	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	CHEM. SPRAY C	4.2SH1						
*STATUS CONFIRMATORY DATA	RADIATION R	4.2SH1						
*	AGING A	4.2SH1						
*	SUBMERGENCE S	4.2SH1						

EQ. PCK #: 4.2SH1	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT: SEE INSTR MANUAL MAINTAIN.: SEE INSTR MANUAL SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1

REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.

CES#-1576
REVISION #: 00
DATE: 07/06/84
SYSTEM: REAC.AUX.BLDG HVAC
TAG: AH-24(1X-SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-25(1X-SB)	OPERABIL-ITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNITS	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERAT-URE	104F 409F 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB31 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR : BAHNSON SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB31 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: RH INSULATION SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB31 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES: DRIVE FAN & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSR 4.2SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB3111	REF 1	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-08	A BETA	4.4E5		FSAR SEC	PG.14 & 21			
P.O #: 435105	D B SHIELD	100%		3.11B				
PLANT LOC.: AB31	S T.I.D.	2.6E4	2.74E8		SRSR 4.2SH1			
COORDINATES X- 1553. Y- 1623. Z- 263.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB31 FSAR SEC 3.11B	NA	N/A	/	NONE
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE P	4.2SH1						
*	REL. HUMIDTY H	4.2SH1						
*	CHEM. SPRAY C	4.2SH1						
*****	RADIATION A	4.2SH1						
	AGING A	4.2SH1						
	SUBMERGENCE S	4.2SH1						
EQ. PCK # : 4.2SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
SEE INSTR
MANUAL
MAINTAIN.:
SEE INSTR
MANUAL
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 4.2SH1

CES#-1578

REFERENCES:
1. RELIANCE ELECTRIC CO. MOTOR
QUALIFICATION REPORT NUC-9,
DATED JULY 1, 1978, TOGETHER
WITH SUPPLEMENTAL REPORT, REV
2, DATED 7/15/81.

REVISION # : 00
DATE : 07/06/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AH-25(1X-SB)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.				
TAG NO : AH-26(1B-SB)	OPERABILITY	40YRS NORM 1YR DRA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DRA	104F NORM 104F DRA	TAB31A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DRA	ATMOS NORM ATMOS NORM	PAB31 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DRA	100%	HAB31 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB31 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.04E8	RAB3111 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES: DRIVE FAN & SERVICE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB31 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
SPECIFICATIONS: BE-08	OPERABILITY	O	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1582	
P.O #: 435105	TEMPERATURE	T	4.2SH1					REVISION # :00	
PLANT LOC.: AB31	PRESSURE	P	4.2SH1					DATE :07/06/84	
COORDINATES X- 1552. Y- 1758. Z- 261.0	REL. HUMDTY	H	4.2SH1					SYSTEM : REAC.AUX.BLDG HVAC	
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	4.2SH1					TAG : AH-26(1B-SB)	
INSTAL. REF: BY-FLD	RADIATION	R	4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	AGING	A	4.2SH1						
*****	SUBMERGENCE	S	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	OS88 CATEG.: A	APPENDIX E							
*STATUS CONFIRMATORY DATA									

REPLACEMENT:
SEE INSTR
MANUAL
MAINTAIN.:
SEE INSTR.
MANUAL
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : AH-28(1A-SA)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT TYPE: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL			
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB11 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL			
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB11 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB11 FSAR SEC 3.11B	NA	N/A	/	NONE				
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BFTA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	2.24E8	RAB11R3 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE				
FUNCT. DES. & SERVICE: DRIVE FAN	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB11 FSAR SEC 3.11B	NA	N/A	/	NONE				
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
SPECIFICATIONS: BE-08	OPERABILITY	O	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.						CES#-1584		
P.O #: 435105	TEMPERATURE	T	4.2SH1									REVISION # : 00
PLANT LOC.: AB11	PRESSURE	P	4.2SH1									DATE : 07/06/84
COORDINATES X- 1424. Y- 1650. Z- 216.0	REL. HUMDTY	H	4.2SH1									SYSTEM : REAC.AUX.BLDG HVAC
INSTALLED (Y/M): LTR	CHEM. SPRAY	C	4.2SH1									TAG : AH-28(1A-SA)
INSTAL. REF: BY-FLD	RADIATION	R	4.2SH1									
QUALIF EXEMPTH: NOT APPLIC	AGING	A	4.2SH1									
*****	SUBMERGENCE	S	4.2SH1									
*****	OS88 CATEG.: A											
*****	APPENDIX E											

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AH-28(1B-SB)	OPEPABIL- ITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	AIR HANDLING UN IT				SRSO 4.2SH1					
COMPONENT:	MOTOR	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE INSTR MANUAL	
MANUFACTURER:	RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB11 FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL	
MAJOR : SUPPLIER	BAHNSON	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HAB11 FSAR SEC 3.11B	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB11 FSAR SEC 3.11B	NA N/A	/	NONE		
FUNCT. DES: & SERVICE	DRIVE FAN	ACCUR. SPEC:	NOT APPLICABLE		SRSH 4.2SH1					
		ACCUR. DEM.:	NOT APPLICABLE		SRSC 4.2SH1					
SPECIFICATIONS:	BE-08	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.74F8 2.74E8	RAB11R3 FSAR SEC 3.11B	REF 1 PG.14 & 21 COMB. TEST & SUPPL. REVIEW	M	NONE		
P.O #:	435105	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.:	AB11	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB11 FSAR SEC 3.11B	NA N/A	/	NONE		
COORDINATES X- Y- Z-	1575. 1636. 216.C				SRSS 4.2SH1					
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
INSTAL. REF:	BY-FLD	OPERABILITY	O 4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1586		
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T 4.2SH1							
*QUALIF:	QUALIFIED-AWAITING	PRESSURE	P 4.2SH1							
*STATUS	CONFIRMATORY DATA	REL. HUMDTY	H 4.2SH1							
*		CHEM. SPRAY	C 4.2SH1							
*		RADIATION	R 4.2SH1							
		AGING	A 4.2SH1	REVISION # :00			DATE :07/06/84			
		SUBMERGENCE	S 4.2SH1	SYSTEM : REAC.AUX.BLDG HVAC			TAG : AH-28(1B-SB)			
EQ. PCK # :	4.2SH1	OS88 CATEG.:	A	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AH-5 (1A-SA)	OPERABIL- ITY	40YRS NORM 1YR DBA	>47YPS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	AIR HANDLING UN IT									
COMPONENT:	MOTOR	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB01A FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE INSTR MANUAL	
MANUFACTURER:	RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB01 FSAR SEC 3.11B	REF 1 P.21 COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE INSTR MANUAL	
MAJOR : SUPPLIER	BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB01 FSAR SEC 3.11B	NA COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RH INSULATION	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HAB01 FSAR SEC 3.11B	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	DRIVE FAN									
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100X 2.9E4	2.34E8	RAB01R1 FSAR SEC 3.11B	REF 1 PG.14 & 21 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	8E-08									
P.O #:	435105	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.:	AB01									
COORDINATES X- Y- Z-	1428. 1614. 191.2	SUBMERGED LEVEL	191.0 FEET	NA	SAB01 FSAR SEC 3.11B	NA COMB. TEST & SUPPL. REVIEW	P	NONE		
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTH:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1		
*****		OPERABILITY	O 4.2SH1					CES#-1590		
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T 4.2SH1							
*STATUS	CONFIRMATORY DATA	PRESSURE	P 4.2SH1							
*		REL. HUMPTY	H 4.2SH1							
*		CHEM. SPRAY	C 4.2SH1							
*****		RADIATION	R 4.2SH1							
		AGING	A 4.2SH1							
		SUBMERGENCE	S 4.2SH1							
EQ. PCK # :	4.2SH1	US88 CATEG.:	A	REFERENCES:				1.RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1,1978,TOGETHER WITH SUPPLEMENTAL REPORT, REV 2,DATED 7/15/81.		
		APPENDIX	E					REVISION # :00 DATE :07/06/84		
								SYSTEM :REAC.AUX.BLDG HVAC TAG :AH-5 (1A-SA)		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AH-5 (1B-SB)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TABD1A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB01 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	PABD1 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB01 FSAR SEC 3.11B	NA	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100% 2.9E4	2.74E8	PABD1R1 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	191.0 FEET	NA	SABG1 FSAR SEC 3.11B	NA	COMB. TEST & SUPPL. REVIEW	P	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER SUPPL. REVIEW								
SPECIFICATIONS: BE-08	FOR PUNCLIST ITEMS SEE 'SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1				
P.O #: 435105	OPERABILITY	O	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1592	
PLANT LOC.: ABC1	TEMPERATURE	T	4.2SH1					REVISION # : 00	
COORDINATES X- 1573.	PRESSURE	P	4.2SH1					DATE : 07/06/84	
Y- 1614.	REL. HUMIDTY	H	4.2SH1					SYSTEM : REAC. AUX. BLDG.	
Z- 191.2	CHEM. SPRAY	C	4.2SH1					HVAC	
INSTALLED (Y/N): LTR	RADIATION	R	4.2SH1					TAG : AH-5 (1B-SB)	
INSTAL. REF: BY-FLD	AGING	A	4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	SUBMERGENCE	S	4.2SH1						
*****	OS88 CATEG.: A								
*QUALIF: QUALIFIED-AWAITING	APPENDIX E								
*STATUS CONFIRMATORY DATA									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-6 (1A-SA)	OPERABILITY	40YRS NORM 1YR DBA	>47YRS NORM	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.04E8 NORM	RAB21R7 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>47YRS	1C CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
SPECIFICATIONS: BE-08	PARAMETER	SUPPL. REVIEW						
P.O #: 435105	OPERABILITY	O 4.2SH1						
PLANT LOC.: AB21	TEMPERATURE	T 4.2SH1						
COORDINATES X- 1423. Y- 1549. Z- 236.0	PRESSURE	P 4.2SH1						
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 4.2SH1						
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 4.2SH1						
*****	AGING	A 4.2SH1						
*****	SUBMERGENCE	S 4.2SH1						
*****	OSR CATEG.: A							
*****	APPENDIX E							

REPLACEMENT:
 SEE INSTR MANUAL
 MAINTAIN.:
 SEE INSTR MANUAL
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 4.2SH1

CES#-1594

REFERENCES:
 1. RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT NUC-9,
 DATED JULY 1, 1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.

REVISION # : 00
 DATE : 07/06/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AH-6 (1A-SA)

EQ. PCK # : 4.2SH1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : AH-6 (1B-SB)	OPERABILITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	REPLACEMENT: SEE INSTR MANUAL MAINTAIN.: SEE INSTR MANUAL SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT SAFETY FUNCTION: SS
EQUIPMENT TYPE: AIR HANDLING UNIT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE	
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>47YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: BE-08	OPERABILITY	O	4.2SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1	
P.O #: 435105	TEMPERATURE	T	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.				CES#-1596	
PLANT LOC.: AB21	PRESSURE	P	4.2SH1					REVISION #: 00	
COORDINATES X= 1446. Y= 1549. Z= 236.0	REL. HUMDTY	H	4.2SH1					DATE: 07/06/84	
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	4.2SH1					SYSTEM: REAC.AUX.BLDG HVAC	
INSTAL. REF: BY-FLD	RADIATION	R	4.2SH1					TAG: AH-6 (1B-SB)	
QUALIF EXEPTN: NOT APPLIC	AGING	A	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S	4.2SH1						
*STATUS CONFIRMATORY DATA									
* * * * *									
EQ. PCK #: 4.2SH1	0588 CATEG.: A								
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-8 (1X-SB)	OPERABILITY	40YRS NORM 1YR DBA	>47YPS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR HANDLING UNIT	NORM/TEST DBA				SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: RELIANCE	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BAHNSON	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100X 1.8E4	2.04E8 12.04F8	RAB211C FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
SPECIFICATIONS: BE-08								
P.O #: 435105								
PLANT LOC.: AB21								
COORDINATES X- 1601. Y- 1575. Z- 251.0								
INSTALLED (Y/N): LTR								
INSTAL. REF: BY-FLD								
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE P	4.2SH1						
*	REL. HUMDTY H	4.2SH1						
*	CHEM. SPRAY C	4.2SH1						
*****	RADIATION R	4.2SH1						
	AGING A	4.2SH1						
	SUBMERGENCE S	4.2SH1						
EQ. PCK # : 4.2SH1								
	D588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 SEE INSTR
 MANUAL
 MAINTAIN.:
 SEE INSTR
 MANUAL
 SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 4.2SH1

CES#-1602

REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR
 QUALIFICATION REPORT NUC-9,
 DATED JULY 1, 1978, TOGETHER
 WITH SUPPLEMENTAL REPORT, REV
 2, DATED 7/15/81.

REVISION # : 00
 DATE : 07/06/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AH-8 (1X-SB)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AH-9(1A- SA)	OPERABIL- ITY	40YRS NORM 1YR DBA	>40YRS NORM	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA		>1YR DBA		SRSO 4.2SH1			
COMPONENT: MOTOR	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: RELIANCE					SIRST 4.2SH1			
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 100%	2.94E8	RAB21R7 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-08					SRSR 4.2SH1			
P.O #: 435105	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40YRS	10 CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSA 4.2SH1			
COORDINATES X- 1500. Y- 1585. Z- 247.C	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE
					SRSS 4.2SH1			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING * *STATUS CONFIRMATORY DATA * * * *****	PARA- METER	SUPPL. REVIEW						
	OPERABILITY O	4.2SH1						
	TEMPERATURE T	4.2SH1						
	PRESSURE P	4.2SH1						
	REL. HUMDITY H	4.2SH1						
	CHEM. SPRAY C	4.2SH1						
	RADIATION R	4.2SH1						
	AGING A	4.2SH1						
	SUBMERGENCE S	4.2SH1						
EQ. PCK # : 4.2SH1	Q588 CATEG.: A APPENDIX E							

REPLACEMENT:
SEE INSTR
MANUAL
MAINTAIN.:
SEE INSTR
MANUAL
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 4.2SH1

CES#-1616

REFERENCES:
1. RELIANCE ELECTRIC CO. MOTOR
QUALIFICATION REPORT NUC-9,
DATED JULY 1, 1978, TOGETHER
WITH SUPPLEMENTAL REPORT, REV
2, DATED 7/15/81.

REVISION # : 00
DATE : 07/06/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AH-9(1A- SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	QUALIF. METHOD			
TAG NO : AH-9(1B- SB)	OPERABILITY	40YRS NORM 1YR DBA	>40YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR HANDLING UNIT TYPE: IT	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	P	NONE	
COMPONENT: MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS NORM	PAB21 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL MAINTAIN.: SEE INSTR MANUAL SUBCOMPONENTS:
MANUFACTURER: RELIANCE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB21 FSAR SEC 3.11B	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: BAHNSON	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
MODEL AND SERIAL #: RH INSULATION	R GAMMA A BETA D B SHIELD S T.I.D.	13.0E4 17.2E4 1100X 13.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF 1 PG.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>40YRS	1U CFR50 PARA.50.51	REF 1 PG.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB21 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: BE-0A	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1								
P.O #: 435105	OPERABILITY	O	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT, REV 2, DATED 7/15/81.					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
PLANT LOC.: AB21	TEMPERATURE	T	4.2SH1						CESN-1618
COORDINATES X- 1530. Y- 1614. Z- 236.0	PRESSURE	P	4.2SH1						REVISION #: 00 DATE: 07/06/84
INSTALLED (Y/N): LTR	REL. HUMIDTY	H	4.2SH1						SYSTEM: REAC.AUX.BLDG HVAC
INSTAL. REF: BY-FLD	CHEM. SPRAY	C	4.2SH1						TAG: AH-9(1B- SB)
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R	4.2SH1						
*****	AGING	A	4.2SH1						
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S	4.2SH1						
*STATUS CONFIRMATORY DATA	0588 CATEG.: A	APPENDIX E							
*									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D10SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS-NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) P.D42 TO D47 SRST 9.2SH1	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) P.D42 TO D47 DRSP 9.2SH1	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB31 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-21302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION									
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	2.04E8	RAB3111 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79 TO D81 SRSA 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31									
COORDINATES X- 1414. Y- 1694. Z- 271.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 9.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							
*	REL. HUMIDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK #: 9.2SH1	OS88 CATEG.: A APPENDIX E								
FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES4-1706			
						REVISION #: 00			
						DATE: 09/18/84			
						SYSTEM: REAC.AUX.BLDG HVAC			
						TAG: AV-D10SB-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D10SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPER DBA				SRS042.2SH1				
COMPONENT:	PNEUMATIC OPERA TOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER:	BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RUSKIN				SRS42.2SH1				SUBCOMPONENTS:
MODEL AND: SERIAL #	CB-415	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1:QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE				SRSC42.2SH1				
ACCUR. DEM.:	NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25				SRSR42.2SH1				
P.O N:435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB31				SRSA42.2SH1				
COORDINATES X- Y- Z-	1414. 1694. 271.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR				SRSS42.2SH1				
INSTAL. REF:BY-FLO		PARAMETER	SUPPL. REVIEW						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:42.2SH1
QUALIF EXEMPTN: NOT APPLIC		OPERABILITY	O 42.2SH1						
*****		TEMPERATURE	T 42.2SH1						
*QUALIF: LATER		PRESSURE	P 42.2SH1						CES#-1707
*STATUS		REL. HUMPTY	H 42.2SH1						
*		CHEM. SPRAY	C 42.2SH1						
*		RADIATION	R 42.2SH1						
*****		AGING	A 42.2SH1						REVISION # :00
		SUBMERGENCE	S 42.2SH1						DATE :
EQ. PCK # :	42.2SH1								SYSTEM :REAC.AUX.BLDG HVAC
		0588 CATEG.:	A						TAG :AV-D10SB-1
		APPENDIX E							

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D10SB-1	OPERABIL- ITY	NORM:40YRS DBA:1Y ⁰	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC						
COMPONENT:	SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG F1A- 3.2SH1	TAB31A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG F2A- 3.2SH1	PAB31 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90X40RM 100X DBA	NORM:40X DBA:100X	HAB31 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CONTROL AIR-PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM RORON PH ⁰ .5-10.5	CAB31 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE					SRSC 3.2SH1	REVIEW			
ACCUR. DEP.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	2.0FR	RAB3111 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA-50.51	REF 1 P.A-3,C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	435205					SRSA 3.2SH1	REVIEW			
PLANT LOC.:	AB31									
COORDINATES X- Y- Z-	1414. 1694. 271.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW							
QUALIF EXEMPTH:	NOT APPLIC	OPERABILITY	O	3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T	3.2SH1						CESN-1708
*STATUS	CONFIRMATORY DATA	PRESSURE	P	3.2SH1						
*		REL. HUMPTY	H	3.2SH1						
*		CHEM. SPRAY	C	3.2SH1						
*****		RADIATION	R	3.2SH1						REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982
		AGING	A	3.2SH1						REVISION # :00 DATE :08/13/84
		SUBMERGENCE	S	3.2SH1						SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D10SB-1
EQ. PCK # :	3.2SH1									
		0588 CATEG.:	A							
		APPENDIX	E							



A/E: EB SERVICES INC.
UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

14-0
1709

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D11SA-1	OPERABILITY	40YRS NORM 500 CYC	140YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42 TO D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42 TO D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSR 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.6E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW			
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79 TO D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- 1497. Y- 1597. Z- 247.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY	G 9.2SH1							CES#-1709
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							
*	REL. HUMIDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK #: 9.2SH1									REVISION #: 00 DATE: 09/18/54
	OS88 CATEG.: A APPENDIX E								SYSTEM: REAC.AUX.BLDG HVAC TAG: AV-D11SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1) NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/79.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D11SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : PUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAPMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4			SRSR42.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1497. Y- 1597. Z- 247.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							CES#-1710
*STATUS	PRESSURE	P 42.2SH1							
*	REL. HUMDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*****	RADIATION	R 42.2SH1							
	AGING	A 42.2SH1							REVISION # : 00 DATE :
	SUBMERGENCE	S 42.2SH1							SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D11SA-1
EQ. PCK # : 42.2SH1	OS88 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D11SA-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC		REF 1,P.26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW		NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW		NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	3070 PPM RORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.3E3 2.3E3	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW		NONE	
MODEL AND: SERIAL #	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
FUNCT. DES: & SERVICE	SUBPERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH E9 PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
SPECIFICATIONS: RE-25	OPERABILITY	O	3.2SH1						
P.O #: 435205	TEMPERATURE	T	3.2SH1						
PLANT LOC.: AB21	PRESSURE	P	3.2SH1						
COORDINATES X- 1497. Y- 1597. Z- 247.0	REL. HUMDTY	H	3.2SH1						
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	3.2SH1						
INSTAL. REF: BY-FLD	RADIATION	R	3.2SH1						
QUALIF EXEMPTH: NOT APPLIC	AGING	A	3.2SH1						
*****	SUBMERGENCE	S	3.2SH1						
*QUALIF: QUALIFIED-AWAITING	REFERENCES: 1.ASCO TEST REPORT # AGR-67368 REV.0, MARCH 1992								
*STATUS CONFIRMATORY DATA	REVISION # :00 DATE :08/13/84								
*	SYSTEM : REAC.AUX.BLDG HVAC								
*	TAG : AV-D11SA-1								
*****	EQ. PCK # : 3.2SH1								
*****	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D12SB-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36 SRSO 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPERS								
COMPONENT:	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B REF(1) P.D42-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAR21 FSAR SEC 3.11B REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.04E3	RAB21R6 FSAR SEC 3.11B REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
MODEL AND: SERIAL #	EA-180-21302	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	1U CFR50 PARA.50.51 REF(1) P.D79-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.:	NOT APPLICABLE	INSTALLED (Y/N):	LTR						
SPECIFICATIONS:	BE-25	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1	
P.O #:	435205	OPERABILITY	O 9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CESN-1712	
PLANT LOC.:	AB21	TEMPERATURE	T 9.2SH1					REVISION # :00	
COORDINATES X-:	1493.	PRESSURE	P 9.2SH1					DATE :09/18/84	
Y-:	1603.	REL. HUMDTY	H 9.2SH1					SYSTEM :REAC.AUX.BLDG	
Z-:	246.0	CHEM. SPRAY	C 9.2SH1					HVAC	
		RADIATION	R 9.2SH1					TAG :AV-D12SB-1	
EQ. PCK # :	9.2SH1	AGING	A 9.2SH1						
		SUBMERGENCE	S 9.2SH1						
		OS88 CATEG.:	A						
		APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D12SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO42.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T.I.D.	3.0E4							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1493. Y- 1603. Z- 246.0									
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLO	PARAMETER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							CES#-1713
*STATUS	PRESSURE	P 42.2SH1							
*	REL. HUMIDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*****	RADIATION	R 42.2SH1							REFERENCES:
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM : REAC. AUX. BLOC HVAC
									TAG : AV-D12SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : AV-D12SB-1	OPERABILITY	NORM:40YRS DBA:1YR	NORM:40YRS 120,100 CYC DBA:30DAYS 121 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: DAMPER TYPE	TEMPERATURE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5		
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM DBA	NORM:1 ATM DBA:SEE FIG E2A-3.2SH1	FAB21 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF 1,APP.C		
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: ALL SRS ARE IN TAB E1.		
MODEL AND SERIAL #: NP8320A173E	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.0EB 2.0ER	RAB21R6 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE			
FUNCT. DES & SERVICE: CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR CYLINDER	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
SPECIFICATIONS: BE-25	OPERABILITY	O 3.2SH1		REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982					CES#-1714		
P.O #: 435205	TEMPERATURE	T 3.2SH1									
PLANT LOC.: AB21	PRESSURE	P 3.2SH1									
COORDINATES X= 1493. Y= 1603. Z= 246.0	REL. HUMIDTY	H 3.2SH1									
INSTALLED (Y/M): LTR	CHEM. SPRAY	C 3.2SH1									
INSTAL. REF: BY-FLD	RADIATION	R 3.2SH1									
QUALIF EXEMPTN: NOT APPLIC	AGING	A 3.2SH1									
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S 3.2SH1									
*STATUS CONFIRMATORY DATA	OS88 CATEG.: A								REVISION # :00		
*APPENDIX E	APPENDIX E								DATE :08/13/84		
EQ. PCK # : 3.2SH1									SYSTEM : REAC.AUX.BLDG HVAC		
									TAG : AV-D12SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D13SA-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE					SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO					SRST 9.2SH1				MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1					
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1					
COORDINATES X- 1417. Y- 1597. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1715		
EQ. PCK #: 9.2SH1								REVISION #: 00 DATE: 09/18/84		
	D588 CATEG.: A APPENDIX E							SYSTEM: REAC.AUX.BLOG HVAC TAG: AV-D13SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D13SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X		SRSR42.2SH1					
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1417. Y- 1597. Z- 236.0	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTALLED (Y/N): LTR	TEMPERATURE	T 42.2SH1							CES#-1716
INSTAL. REF: BY-FLO	PRESSURE	P 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMDTY	H 42.2SH1							
*QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							
*STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE:
									SYSTEM: REAC. AUX. BLDG HVAC
									TAG: AV-D13SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D13SA-1	OPERABIL-ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC DBA:30DAYS 21 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER										
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DPA	NORM:120F DBA:SEE FIG F1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5	
MANUFACTURER: ASCO									MAINTAIN.: REF 1,APP.C	
MAJOR : RUSKIN SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM 90% PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: ALL SRS ARE IN TAB E1.	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.3E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25										
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YPS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1417. Y- 1597. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR										
INSTAL. REF: BY-FLD										
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1						CES#-1717		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1								
*	REL. HUMDTY	H 3.2SH1								
*	CHEM. SPRAY	C 3.2SH1								
*****	RADIATION	R 3.2SH1		REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.O, MARCH 1982				REVISION # :00		
	AGING	A 3.2SH1						DATE :08/13/84		
	SUBMERGENCE	S 3.2SH1						SYSTEM : REAC.AUX.BLDG HVAC		
EQ. PCK # : 3.2SH1								TAG : AV-D13SA-1		
	OS88 CATEG.: A									
	APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D14SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPERS				SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RUSKIN				SRSP 9.2SH1				
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- Y- Z-	1420. 1605. 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1	
*OPERABILITY O		OPERABILITY O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1718	
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE T	9.2SH1						
*STATUS CONFIRMATORY DATA		PRESSURE P	9.2SH1						
*		REL. HUMDTY H	9.2SH1						
*		CHEM. SPRAY C	9.2SH1						
*****		RADIATION R	9.2SH1						
		AGING A	9.2SH1						
		SUBMERGENCE S	9.2SH1						
EQ. PCK # : 9.2SH1		US88 CATEG.: A APPENDIX E							REVISION # : JO DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D14SB-1

REPLACEMENT:
P.D79-D81 OF
REF(1)
MAINTAIN.:
P.D79-D81 OF
REF(1)
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-D14SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO42.2SH1			
COMPONENT: PNEUMATIC OPERA TOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: BETTIS					SRST42.2SH1			REPLACEMENT:
MAJOR : RUSKIN SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
					SRSP42.2SH1			MAINTAIN.:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90X NORM 100X DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE					SRSH42.2SH1			SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-25					SRSR42.2SH1			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSA42.2SH1			SAFETY FUNCTION: SS
COORDINATES X- 1420. Y- 1605. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC					SRSS42.2SH1			
*****	PARAMETER	SUPPL.		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	OPERABILITY	REVIEW						CES4-1719
*STATUS	TEMPERATURE	42.2SH1						
*	PRESSURE	42.2SH1						
*	REL. HUMDTY	42.2SH1						
*	CHEM. SPRAY	42.2SH1						
*****	RADIATION	42.2SH1						
	AGING	42.2SH1						REVISION # : 00
	SUBMERGENCE	42.2SH1						DATE :
EQ. PCK # : 42.2SH1								SYSTEM : REAC.AUX.BLOG HVAC
	0588 CATEG.: A APPENDIX E							TAG : AV-D14SB-1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-014SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC DBA: 30DAYS	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1, P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE		
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE		
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: NP8320A173E	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.7E8 2.0E8	RAB21R6 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES & SERVICE: CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR CYLINDER	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1				
SPECIFICATIONS: BE-25	OPERABILITY	O	3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AOR-67368 REV.0, MARCH 1982			CES#-1720			
P.O #: 435205	TEMPERATURE	T	3.2SH1							
PLANT LOC.: AB21	PRESSURE	P	3.2SH1							
COORDINATES X- 1420. Y- 1605. Z- 245.0	REL. HUMIDTY	H	3.2SH1							
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	3.2SH1							
INSTAL. REF: BY-FLD	RADIATION	R	3.2SH1							
QUALIF EXEMPTN: NOT APPLIC	AGING	A	3.2SH1	REVISION # :00			DATE :08/13/84			
*****	SUBMERGENCE	S	3.2SH1	SYSTEM : REAC.AUX.BLDG HVAC			TAG : AV-014SB-1			
*****	OS88 CATEG.: A	APPENDIX E								

EQ. PCK # : 3.2SH1

OS88 CATEG.: A
 APPENDIX E

REVISION # :00
 DATE :08/13/84
 SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-014SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D155A-1	OPERABILITY	LATER	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	95F 400M 95F 09A	LATEP	TYD31R FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: RETTIS	PRESSURE	ATMOS NORM ATMOS 09A	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	10-100% 100% 09A	LATEP	HYD31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	1.8E4	LATER	RAB211U FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	1.8E4								
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	1U CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATEP	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21					SRSS42.2SH1					
COORDINATES X- 1595. Y- 1695. Z- 244.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1722		
*****	TEMPERATURE	T 42.2SH1								
*QUALIF: LATER	PRESSURE	P 42.2SH1								
*STATUS	REL. HUMDTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*	RADIATION	R 42.2SH1								
*****	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00	
	APPENDIX E								DATE :	
									SYSTEM : REAC.AUX.BLDG HVAC	
									TAG : AV-D155A-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D155A-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC							
COMPONENT: SOLENOID VALVE	TEMPERATURE	95F NORM 95F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TYD31R FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1, P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF 1, APP.C	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	10-100% NORM 100% DBA	NORM: 40% DBA: 100%	HYD31 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.	
MODEL AND SERIAL #: NP8320A173E	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES. & SERVICE: CONTROL AIR-PRESSURE IN PNEUMATIC OPERATOR CYLINDER	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	2.7E4 2.9E4	RAB211G FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF 1 P.A-3, C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAP SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
SPECIFICATIONS: BE-25	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
P.O #: 435205	OPERABILITY	O 3.2SH1					CESR-1723			
PLANT LOC.: AB21	TEMPERATURE	T 3.2SH1								
COORDINATES X- 1595.	PRESSURE	P 3.2SH1								
Y- 1695.	REL. HUMIDTY	H 3.2SH1								
Z- 244.0	CHEM. SPRAY	C 3.2SH1								
INSTALLED (Y/N): LTR	RADIATION	R 3.2SH1								
INSTAL. REF: BY-FLD	AGING	A 3.2SH1								
QUALIF EXEMPTN: NOT APPLIC	SUBMERGENCE	S 3.2SH1								
*****	REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. U, MARCH 1982									
*QUALIF: QUALIFIED-AWAITING	REVISION # : 00									
*STATUS CONFIRMATORY DATA	DATE : 09/13/84									
* *****	SYSTEM : REAC. AUX. BLDG HVAC									
	TAG : AV-D155A-1									
EQ. PCK # : 3.2SH1	US88 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : AV-D16SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPEP. REVIEW	REF(1) PG. 4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1						
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	NOT AVAILABLE	104F NORM 104F DBA		REF(1) PG. 10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	H	NONE			
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG. 10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE			
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.D-1	100% NORM 100% DBA		REF(1) PG. 4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE			
MODEL AND SERIAL #: EA-180-21302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG. 10-7	COMB. TEST & SUPPL. REVIEW	H	NONE			
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD				SRSR 9.1SH1						
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.0E4									
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF(1) PG. 4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE			
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
PLANT LOC.: AB21					SRSS 9.1SH1						
COORDINATES X- 1582. Y- 1706. Z- 236.0											
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.					CES#-1724		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1									
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1									
*	REL. HUMDTY H	9.1SH1									
*	CHEM. SPRAY C	9.1SH1									
*****	RADIATION R	9.1SH1									
	AGING A	9.1SH1						REVISION # : 00 DATE : 09/18/84			
	SUPERGENCE S	9.1SH1						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D16SB-1			
EQ. PCK # : 9.1SH1	0588 CATEG.: A APPENDIX E										

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	W/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-016SB-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERAT-URE	NOT AVAILARLF	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS					SRST42.2SH1				MAINTAIN.:	
MAJOR : RUSKIN	PRESSURE	ATMOS NORM	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:	
SUPPLIER	ATMOS DBA				SRSP42.2SH1					
MODEL AND: CB-315	RELATIVE HUMIDITY	20-100% (DBA)	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
SERIAL #	TABLE				SRSH42.2SH1				NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA	7.2E4								
	D B SHIELD									
	S T.I.D.	3.0E4			SRSR42.2SH1					
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205					SRSA42.2SH1					
PLANT LOC.: AB21										
COORDINATES X- 1582.	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
Y- 1706.										
Z- 236.0					SRSS42.2SH1					
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1725		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1								
*****	PRESSURE	P 42.2SH1								
*QUALIF: LATER	REL. HUMPTY	H 42.2SH1								
*STATUS	CHEM. SFRAY	C 42.2SH1								
*	RADIATION	R 42.2SH1								
*	AGING	A 42.2SH1								
*****	SUBMERGENCE	S 42.2SH1		REVISION # : 00						
EQ. PCK # : 42.2SH1	OSP8 CATEG.: A			DATE :						
	APPENDIX E			SYSTEM : REAC.AUX.BLDG HVAC						
				TAG : AV-016SB-1						



A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS NPP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 CES-1726

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEV. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D16SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P. 26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	NORM: 120F DBA: SEE FIG E1A-3.2SH1		NORM: REF 1 P. 9 DBA:	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL.	P	NONE	MAINTAIN.: REF 1, APP. C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	NORM: 40% DBA: 100%		NORM: REF 1 P. A7 DBA:	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL.	/	NONE	NOTE: ALL SRS ARE IN TAB E1.
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 3.0E4	2.0ER	RAB21R6 FSAR SEC 3.11B	REF 1 P. 15 & 22	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	SPECIFICATIONS: BE-25	AGF- 40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF 1 P. A-3, C-5, C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	PLANT LOC.: AB21	INST LIFE (PER 323-1974 DEF.)			SRSA 3.2SH1	REVIEW			
COORDINATES X- 1582. Y- 1706. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*****	OPERABILITY	O 3.2SH1				CES-1726			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1				REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982			
	AGING	A 3.2SH1				REVISION #: 00 DATE: 09/13/84			
	SURMERGENCE	S 3.2SH1				SYSTEM: REAC. AUX. BLDG HVAC			
EQ. PCK #: 3.2SH1	OSRP CATEG.: A				TAG: AV-D16SB-1				
	APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D17SA-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 70,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST &	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC		REF 1,P.26 SRSO 3.2SH1	SUPPL. REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH2.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE								
	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.3E4 2.0E8	RAB21R6 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
MODEL AND: SERIAL #	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
FUNCT. DES: & SERVICE	PLANT LOC.: AB21								
COORDINATES X- Y- Z-	1429. 1678. 236.0								
COORDINATES X- Y- Z-	1429. 1678. 236.0								
INSTALLED (Y/N): LTP	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTAL. REF:BY-FLD	PARAMETER	SUPPL. REVIEW							
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.2SH1							
*****	TEMPERATURE T	3.2SH1							
QUALIF: QUALIFIED-AWAITING	PRESSURE P	3.2SH1							
*STATUS CONFIRMATORY DATA	REL. HUMDITY H	3.2SH1							
*	CHEM. SPRAY C	3.2SH1							
*	RADIATION R	3.2SH1							
*****	AGING A	3.2SH1							
	SURMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E			FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
				REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982			CES4-1727		
							REVISION # :00 DATE :09/13/84		
							SYSTEM :REAC.AUX.BLDG HVAC		
							TAG :AV-D17SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D17SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100% CO CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
MODEL AND: EA-180-21302 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	ACCUR. SPEC: NOT APPLICABLE				SRSC 9.1SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.94F8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	COORDINATES X- 1429. Y- 1678. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQ. PCK # : 9.1SH1	INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
	*****	OPERABILITY O	9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.			CES#-1728		
	*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1						
	*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1						
	*	REL. HUMDTY H	9.1SH1						
	*	CHEM. SPRAY C	9.1SH1						
	*****	RADIATION R	9.1SH1						
		AGING A	9.1SH1				REVISION # :00 DATE :09/18/84		
		SUBMERGENCE S	9.1SH1				SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D17SA-1		
		OSBR CATEG.: A APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-017SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4						
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-25	S T.I.D.	3.0E4						
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1429. Y- 1678. Z- 236.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1						
*QUALIF: LATER	TEMPERATURE	T 42.2SH1						
*STATUS	PRESSURE	P 42.2SH1						
*	REL. HUMDITY	H 42.2SH1						
*	CHEM. SPRAY	C 42.2SH1						
*****	RADIATION	R 42.2SH1						
	AGING	A 42.2SH1						
	SUBMERGENCE	S 42.2SH1						
EQ. PCK #: 42.2SH1	FSAR CATEG.: A APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
 NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.

SAFETY FUNCTION: SS

FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1

CES#-1729

REVISION #: 00
 DATE:

SYSTEM: REAC. AUX. BLDG HVAC
 TAG: AV-D17SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D17SA-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO42.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1					
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	3.0E4			SRSS42.2SH1					
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21										
COORDINATES X- 1429. Y- 1678. Z- 236.0										
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
INSTAL. REF: BY-FLD	OPERABILITY O	42.2SH1		REFERENCES:				CES#-1729		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	42.2SH1								
*QUALIF: LATER	PRESSURE P	42.2SH1								
*STATUS	REL. HUMDTY H	42.2SH1								
*	CHEM. SPRAY C	42.2SH1								
*	RADIATION R	42.2SH1								
*****	AGING A	42.2SH1								
	SUBMERGENCE S	42.2SH1								
EQ. PCK #: 42.2SH1	OS88 CATEG.: A								REVISION #: 00	
	APPENDIX E								DATE :	
									SYSTEM : REAC.AUX.BLDG HVAC	
									TAG : AV-D17SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D18SR-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE					SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER: NAMCO					SRSST 9.2SH1				MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REF(1) SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1					
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1					
COORDINATES X- 1429. Y- 1474. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1730		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMPTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	F 9.2SH1								
	AGING	A 9.2SH1								
	SUPMERGENCE	S 9.2SH1								
EQ. PCK. #: 9.2SH1	0588 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: REAC.AUX.8LOG HVAC TAG: AV-D18SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D18SB-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER	NORM/TEST DBA				SRSO42.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T. I. D.	3.0E4							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1429. Y- 1674. Z- 236.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							
*****	REL. HUMDTY	H 42.2SH1							CES#-1731
*QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							
*STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							

EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE:
									SYSTEM: REAC. AUX. BLDG HVAC
									TAG: AV-D18SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D18SB-1	OPERABILITY	NORM: 40YRS DBA: 1Y ⁰	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE					
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P. 26 SR50 3.2SH1	REVIEW							
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1, P. C-5				
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C				
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: 1. ALL SRS ARE IN TAB E1.				
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	3.0E4 7.2E4 100% 3.0E4	2.0ER	PAB21R6 FSAR SEC 3.11B	REF 1 P. 15 & 22	COMB. TEST & SUPPL. REVIEW	M	NONE					
SPECIFICATIONS: BE-25	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR 50 PARA. 50.51	REF 1 P. A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
COORDINATES X- 1429. Y- 1674. Z- 236.0	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.2SH1		REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982						CES#-1732			
*****	TEMPERATURE T	3.2SH1											
*QUALIF: QUALIFIED-AWAITING	PRESSURE P	3.2SH1											
*STATUS CONFIRMATORY DATA	REL. HUMIDTY H	3.2SH1											
*	CHEM. SPRAY C	3.2SH1											
*	RADIATION R	3.2SH1											
*****	AGING A	3.2SH1											
*****	SUBMERGENCE S	3.2SH1											
EQ. PCK #: 3.2SH1	Q588 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 08/13/84				
									SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D18SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D19SA-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100% QUOCYC 1YR DBA	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE									
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO									MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 1GDX 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YPS	10 CFR50 PARA. 56.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1476. Y- 1569. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1							
EQ. PCK #: 9.2SH1									
	OS88 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1) NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.2SH1

CES#-1733

REVISION #: 00
 DATE: 09/18/84

SYSTEM: REAC. AUX. BLDG
 HVAC
 TAG: AV-D19SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D19SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE : DAMPER	NORM/TEST DBA				SRS042.2SH1				
COMPONENT : PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CR-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21									
COORDINATES X- 1476. Y- 1569. Z- 236.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1							
*****	PRESSURE	P 42.2SH1							CES#-1734
*QUALIF: LATER	REL. HUMDITY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							REVISION # : 00
*****	SUBMERGENCE	S 42.2SH1							DATE :
EQ. PCK # : 42.2SH1									SYSTEM : REAC.AUX.BLDG HVAC
	US88 CATEG.: A								TAG : AV-D19SA-1
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON PARK NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

UN- U
 -1735

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-019SA-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 4UYRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA:	COMB. TEST &	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P.26 SRSO 3.2SH1	SUPPL. REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.2E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205									
PLANT LOC.: AB21									
COORDINATES X- 1476. Y- 1569. Z- 236.0									
INSTALLED (Y/N): LTR INSTAL. REF: PY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O	3.2SH1				CES#-1735			
	TEMPERATURE T	3.2SH1							
	PRESSURE P	3.2SH1							
	REL. HUMDTY H	3.2SH1							
	CHEM. SFRAY C	3.2SH1							
	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E					REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982			
						REVISION # :00 DATE :08/13/84			
						SYSTEM : REAC.AUX.BLDG HVAC			
						TAG : AV-019SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D20SB-1	OPEPABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	1ATM NORM 1ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN				SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 2.04E8 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YPS	40 YPS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW				
COORDINATES X- 1476. Y- 1567. Z- 236.0		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O	9.2SH1					CES#-1736		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T	9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P	9.2SH1							
*	REL. HUMPTY	H	9.2SH1							
*	CHEM. SPRAY	C	9.2SH1							
*****	RADIATION	R	9.2SH1							
	AGING	A	9.2SH1							
	SUBMERGENCE	S	9.2SH1							
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E			REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION # :00 DATE :09/18/84		
								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D20SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D20SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CR-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE HOLD DAMPER IN REQUIRED POSITION	ACCUR. SPEC: NOT APPLICABLE				SRSH42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PEP 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	PLANT LOC.: AB21				SRSA42.2SH1				
COORDINATES X- 1476. Y- 1567. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
*QUALIF: LATER	OPERABILITY O	42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*STATUS	TEMPERATURE T	42.2SH1							CES#-1737
*	PRESSURE P	42.2SH1							
*	REL. HUMDTY H	42.2SH1							
*	CHEM. SPRAY C	42.2SH1							
	RADIATION R	42.2SH1							
	AGING A	42.2SH1							
	SUBMERGENCE S	42.2SH1							
EQ. PCK # : 42.2SH1	APPENDIX E								REFERENCES:
	0588 CATEG.: A								REVISION # : 00
									DATE :
									SYSTEM : REAC.AUX.BLDG
									HVAC
									TAG : AV-D20SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-020SB-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPER								
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	Y	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	Y	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER	RUSKIN								SUBCOMPONENTS:
MODEL AND: SERIAL #	NP8320A173E	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM ROBON PH7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE		R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.2E8 2.2E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB21									
COORDINATES X- 1476. Y- 1567. Z- 236.0		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		PARA- METER	SUPPL. REVTFW						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1
		OPERABILITY	O	3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
		TEMPERATURE	T	3.2SH1					CES#-1738
		PRESSURE	P	3.2SH1					REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982
		REL. HUMDTY	H	3.2SH1					REVISION # :00 DATE :08/13/84
		CHEM. SPRAY	C	3.2SH1					SYSTEM : REAC.AUX.BLOG HVAC
		RADIATION	R	3.2SH1					TAG : AV-020SB-1
		AGING	A	3.2SH1					
		SUBMERGENCE	S	3.2SH1					
EQ. PCK # : 3.2SH1									
		OS88 CATEG.: A APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D21SA-1	OPERABILITY	40YRS NORM 500 CYC 1YR D9A	40YRS NORM 100% 700CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPERS					SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO					SIRST 9.2SH1				MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1					
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1					
COORDINATES X- 1522. Y- 1568. Z- 242.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS 9.2SH1					
INSTALL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
QUALIF EXEMPT: NOT APPLIC	OPERABILITY O	9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1739		
*****	TEMPERATURE T	9.2SH1								
QUALIF: QUALIFIED-AWAITING	PRESSURE P	9.2SH1								
STATUS CONFIRMATORY DATA	REL. HUMDITY H	9.2SH1								
*	CHEM. SPRAY C	9.2SH1								
*	RADIATION R	9.2SH1								
*****	AGING A	9.2SH1						REVISION # : 00		
	SUBMERGENCE S	9.2SH1						DATE : 09/18/84		
EQ. PCK # : 9.2SH1	0588 CATEG.: A							SYSTEM : REAC.AUX.BLDG HVAC		
	APPENDIX E							TAG : AV-D21SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D21SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 32-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21					SRSS42.2SH1				
COORDINATES X- 1522. Y- 1568. Z- 242.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
QUALIF EXEMPTH: NOT APPLIC	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	PRESSURE	P 42.2SH1							CESN-1740
*STATUS	REL. HUMDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*****	AGING	A 42.2SH1							REFERENCES:
	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	OS88 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM: REAC.AUX.BLOG HVAC
									TAG : AV-D21SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/P	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : AV-D21SA-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 70DAYS 121 CYC		REF 1, P. 26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SFE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	/	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	/	NONE	MAINTAIN.: REF 1, APP. C
MAJOR SUPPLIER: RUSKIN									SUBCOMPONENTS:
MODEL AND SERIAL #: NP8320A173E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES & SERVICE: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100% 2.6E4	2.7E8 2.3E8	RAB21R7 FSAR SEC 3.11B	REF 1 P. 15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	1G CFR50 PARA. 50.51	REF 1 P. A-3, C-5, C-8	COMP. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1522. Y- 1568. Z- 242.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1	REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982			CESM-1741		
EQ. PCK #: 3.2SH1	OS88 CATEG.: A APPENDIX E						REVISION #: 00 DATE: 08/13/84 SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D21SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D23SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)
MANUFACTURER: NAMCO					SRST 9.2SH1				MAINTAIN.: P.079-D81 OF REF(1)
MAJOR : RUSKIN SUPPLIER.	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	PAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION				SRSH 9.2SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 10UX 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1499. Y- 1566. Z- 242.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW							
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1							
EQ. PCK # : 9.2SH1									
	0588 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1)NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/78.

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.2SH1

CES#-1745

REVISION # :00
DATE :09/18/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AV-D23SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D23SA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERAT- URE	104F 104F	NORM 03A	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS ATMOS	NORM 09A	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RUSKIN				SRS42.2SH1				SUBCOMPONENTS:
MODEL AND: SERIAL #	CB-315	RELATIVE HUMIDITY	20-90% 100%	NORM 09A	LATER	HAB21 FSAR SEC 3.11B	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR42.2SH1				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA42.2SH1				
COORDINATES X- Y- Z-	1499. 1568. 242.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/M): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PAPA- METER	SUPPL. REVIEW						
*QUALIF: LATER *STATUS *****		OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	42.2SH1 42.2SH1 42.2SH1 42.2SH1 42.2SH1 42.2SH1 42.2SH1						
EQ. PCK # : 42.2SH1		OS88 CATEG.: A APPENDIX E							
FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1			
REFERENCES:						CES#-1746			
						REVISION # : 00 DATE :			
						SYSTEM : REAC.AUX.BLDG HVAC			
						TAG : AV-D23SA-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D23SA-1	OPERABILITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	FAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : RUSKIN SUPPLIER	RELATIVE HUMIDITY	20-90XNORM 100X DBA	NORM:40X DBA:100X	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PR & SERVICE ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM RORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.0E8 2.0E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:435205	COORDINATES X- Y- Z-	1499. 1568. 242.0							
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1499. Y- 1568. Z- 242.0	OPERABILITY	O 3.2SH1							
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.2SH1							
*****	PRESSURE	P 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	REL. HUMDTY	H 3.2SH1							
*STATUS CONFIRMATORY DATA	CHEM. SPRAY	C 3.2SH1							
*	RADIATION	R 3.2SH1							
*	AGING	A 3.2SH1							
*****	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.2SH1

CESN-1747

REFERENCES: 1.ASCO TEST REPORT # AQR-67368
REV.0, MARCH 1982

REVISION # :00
DATE :08/13/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AV-D23SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D24SB-1	OPERABIL-ITY	40YRS NORM 50C CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPERS TYPE	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
MODEL AND SERIAL #: EA-180-21302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT.DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	AGE- INST LIFE (FER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES#-1748			
P.O #: 435205	TEMPERATURE	T	9.2SH1										
PLANT LOC.: AB21	PRESSURE	P	9.2SH1										
COORDINATES X- 1499. Y- 1567. Z- 236.0	REL. HUMDTY	H	9.2SH1										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC *****	CHEM. SPRAY	C	9.2SH1										
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	RADIATION	R	9.2SH1										
EQ. PCK #: 9.2SH1	AGING	A	9.2SH1										
	SUBMERGENCE	S	9.2SH1										
	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84				
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D24SB-1				



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-024SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	FAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T. I. D.	2.6E4							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1499. Y- 1567. Z- 236.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1							CES#-1749
*QUALIF: LATER	PRESSURE	P 42.2SH1							
*STATUS	REL. HUMPTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*****	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	D588 CATEG.: A								REVISION # : 00 DATE : SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-024SB-1
	APPENDIX E								

REFERENCES:

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D24SB-1	OPERABIL- ITY	NORM:47YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 5UD	DBA:30DAYS 21 CYC		REF 1,P.26 SRSD 3.2SH1				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIS E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	F	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIS E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM 90R0M PM7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A2G SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D R SHIELD S T.I.D.	2.6E4 100%	2.7E8 12.7E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205	PARAMETER	SUPPL. REVIEW							
PLANT LOC.: AB21	OPERABILITY	O	3.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
COORDINATES X- 1499. Y- 1567. Z- 236.0	TEMPERATURE	T	3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982					CES#-1750
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P	3.2SH1						
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	REL. HUMIDTY	H	3.2SH1						
* * *****	CHEM. SPRAY	C	3.2SH1						
	RADIATION	R	3.2SH1						
	AGING	A	3.2SH1						
	SUBMERGENCE	S	3.2SH1						
EQ. PCK # : 3.2SH1	G588 CATEG.: A APPENDIX E								REVISION # : J0 DATE : 08/13/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D24SB-1



A/E: EBAS SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -1751

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D255A-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN: P.079-081 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSO 9.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1452. Y- 1568. Z- 242.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY	O 9.2SH1							CES#-1751
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							
*	REL. HUMDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1									REVISION # : 00 DATE : 09/18/84
	0588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D255A-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1) NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.




EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D25SA-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER	NORM/TEST DBA				SRSO42.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D R SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O # : 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
COORDINATES X= 1452. Y= 1568. Z= 242.0	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTALLED (Y/N): LTR	TEMPERATURE	T 42.2SH1							CES#-1752
INSTAL. REF: BY-FLD	PRESSURE	P 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H 42.2SH1							
*QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							
*STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : AV-D25SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D25SA-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC DBA: 30DAYS	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	121 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NPR320A173E	FUNCT. DES & SERVICE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER							NOTE: ALL SRS ARE IN TAB E1.
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100% 2.6E4	2.7E4	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR 50 PARA. 50.51	REF 1 P.A-3, C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	PLANT LOC.: AP21								
COORDINATES X- 1452. Y- 1560. Z- 242.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH 09 PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SFRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1		REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.U, MARCH 1982			CES#-1753	
EQ. PCK #: 3.2SH1	US88 CATEG.: A APPENDIX E							REVISION #: 00 DATE: 08/13/84 SYSTEM: REAC.AUX.BLOG HVAC TAG: AV-D25SA-1	





EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D26SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPER								
COMPONENT: MANUFACTURER:	PNEUMATIC OPER ATOR	TEMPERAT- URE	104F NORM 104F DRA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MAJOR : SUPPLIER	RUSKIN	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MODEL AND: SERIAL #	CB-315	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE								
ACCUR. DEP.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25								
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB21								
COORDINATES X- Y- Z-	1452. 1567. 236.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR								
INSTAL. REF:	BY-FLD								
QUALIF EXEPTN:	NOT APPLIC	PARA- METER	SUPPL. REVIEW						FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:42.2SH1
*****		OPERABILITY	O 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:42.2SH1
*QUALIF:	LATER	TEMPERATURE	T 42.2SH1						
*STATUS		PRESSURE	P 42.2SH1						CES#-1755
*		REL. HUMPTY	H 42.2SH1						
*		CHEM. SPRAY	C 42.2SH1						
*****		RADIATION	R 42.2SH1						REFERENCES:
		AGING	A 42.2SH1						
		SUBMERGENCE	S 42.2SH1						
EQ. PCK # :	42.2SH1								
		OS8R CATEG.:	A						REVISION # :00
		APPENDIX	E						DATE :
									SYSTEM : REAC.AUX.BLDG
									HVAC
									TAG : AV-D26SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D26SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 4CYRS 120,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 121 CYC		SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40X DBA: 100X	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	300 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.7E8 2.7E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
PLANT LOC.: AB21	OPERABILITY	O 3.2SH1				CES#-1756			
COORDINATES X- 1452. Y- 1567. Z- 236.0	TEMPERATURE	T 3.2SH1				REVISION # : 00 DATE : 08/13/84			
INSTALLED (Y/N): LTR	PRESSURE	P 3.2SH1				SYSTEM : REAC.AUX.BLDG HVAC			
INSTAL. REF: BY-FLO	REL. HUMDTY	H 3.2SH1				TAG : AV-D26SB-1			
QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	AGING	A 3.2SH1							
*STATUS CONFIRMATORY DATA	SUBMERGENCE	S 3.2SH1							
* *****	US28 CATEG.: A								
* * * * *	APPENDIX E								
*****	REFERENCES:	1. ASCO TEST REPORT # AGR-67368 REV.0, MARCH 1982							



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D27SA-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36 SRSO 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPERS								
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)
MAJOR : SUPPLIER	RUSKIN								SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90X NORM 100X DBA	100X NORM 100Y DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 2.04F8 100X 2.6E4	2.04F8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81 SRSA 9.2SH1	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- Y- Z-	1543. 1565. 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD									
QUALIF EXEMPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1
*****		OPERABILITY O	9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE T	9.2SH1						CES#-1757
*STATUS CONFIRMATORY DATA		PRESSURE P	9.2SH1						
*		REL. HUMDTY H	9.2SH1						REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.
*		CHEM. SPRAY C	9.2SH1						
*****		RADIATION R	9.2SH1						
		AGING A	9.2SH1						REVISION # :00 DATE :09/18/84
		SUBMERGENCE S	9.2SH1						SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D27SA-1
EQ. PCK # : 9.2SH1									
		OSRR CATEG.: A							
		APPENDIX E							



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D27SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X= 1543.0, Y= 1565.0, Z= 236.0	OPERABILITY	O 42.2SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTALLED (Y/M): LTR	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	PRESSURE	P 42.2SH1							CES#-1758
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H 42.2SH1							
*QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							
*STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	US88 CATEG.: A								REFERENCES:
	APPENDIX E								

REVISION # : 00
 DATE :
 SYSTEM : REAC.AUX.BLDG HVAC
 TAG : AV-D27SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D27SA-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DRA:30DAYS 21 CYC	TAB21A FSAR SEC 3.11B	NORM:REF 1 COMB. TEST & SUPPL. REVIEW			REPLACEMENT: REF 1,P.C-5
COMPONENT:	SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90XNORM 100X DBA	NORM:40X DBA:100X	HAB21 FSAR SEC 3.11B	NORM:REF 1 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
MODEL AND: SERIAL #	NP8320A173E	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT.DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	ACCUR. SPEC:	NOT APPLICABLE						
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.7ER 2.7ER	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-6 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	435205	COORDINATES X- Y- Z-	1543. 1565. 236.0						
PLANT LOC.:	AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF:	BY-FLD	OPERABILITY	O	3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T	3.2SH1					CES#-1759
*QUALIF:	QUALIFIED-AWAITING	PRESSURE	P	3.2SH1					
*STATUS	CONFIRMATORY DATA	REL. HUMDITY	H	3.2SH1					
*		CHEM. SPRAY	C	3.2SH1					
*		RADIATION	R	3.2SH1					
*****		AGING	A	3.2SH1					
		SUBMERGENCE	S	3.2SH1					
EQ. PCK # :	3.2SH1	OS88 CATEG.:	A						REVISION # :00 DATE :08/13/84
		APPENDIX E							SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D27SA-1

REFERENCES: 1.ASCO TEST REPORT # AQR-67368
 REV.0, MARCH 1982

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D28SB-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPERS	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: EA-180-21302	R. GAMMA A BETA D B SHIELD S.T.I.D.	2.6E4 100% 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
SPECIFICATIONS: BE-25	OPERABILITY	O	9.2SH1						CES 7-1760	
P.O #: 435205	TEMPERATURE	T	9.2SH1							
PLANT LOC.: AB21	PRESSURE	P	9.2SH1							
COORDINATES X- 1543. Y- 1572. Z- 236.0	REL. HUMIDTY	H	9.2SH1							
	CHEM. SPRAY	C	9.2SH1							
	RADIATION	R	9.2SH1							
	AGING	A	9.2SH1							
	SUBMERGENCE	S	9.2SH1							
INSTALLED (Y/N): LTR										
INSTAL. REF: BY-FLD										
QUALIF EXEMPTN: NOT APPLIC										
*QUALIF: QUALIFIED-AWAITING										
*STATUS CONFIRMATORY DATA										
* * * * *										
* * * * *										
EQ. PCK #: 9.2SH1	0588 CATEG.: A									
	APPENDIX E									
					REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION #: 00 DATE: 09/18/84	
									SYSTEM: REAC.AUX.BLDG HVAC TAG: AV-D28SB-1	



A/E: EBAS SERVICES INC.
 UTILITY: POLINA POWER & LIGHT

FACILITY: SHEARON HARBOR NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -1761

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D28SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4			SRSR42.2SH1				
SPECIFICATIONS: BE-25	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1543. Y- 1572. Z- 236.0	OPERABILITY O	42.2SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTALLED (Y/N): LTR	TEMPERATURE T	42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	PRESSURE P	42.2SH1							CES#-1761
QUALIF EXEMPTN: NOT APPLIC	REL. HUMDTY H	42.2SH1							
*****	CHEM. SPRAY C	42.2SH1							
*****	RADIATION R	42.2SH1							
*****	AGING A	42.2SH1							
*****	SUPMERGENCE S	42.2SH1							
EQ. PCK # : 42.2SH1	0588 CATEG.: A								REFERENCES:
	APPENDIX E								
									REVISION # : 00
									DATE :
									SYSTEM : REAC. AUX. BLDG
									HVAC
									TAG : AV-D28SB-1



A/E: EBAS SERVICES INC.
 UTILITY: ATLANTA POWER & LIGHT

FACILITY: SHEARON HALL APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9CC MW(E)

0
 1764

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D29SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS					SRS142.2SH1				MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CB-315	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.3-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
FUNCT. DES: HOLD DAMPER IN & SERVICE POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRS42.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR42.2SH1					
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB11					SRSA42.2SH1					
COORDINATES X- 1410. Y- 1691. Z- 221.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
*****	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1764		
*QUALIF: LATER	TEMPERATURE	T 42.2SH1								
*STATUS	PRESSURE	P 42.2SH1								
*	REL. HUMIDTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*****	RADIATION	R 42.2SH1								
	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	0588 CATEG.: A APPENDIX E								REVISION #: 00 DATE : SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D29SA-1	


EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-D29SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 3.2SH1			
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : RUSKIN SUPPLIER	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.D-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: NP8320A173E SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPER OR CYLINDER & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSP 3.2SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB11	COORDINATES X- 1410. Y- 1691. Z- 221.0				SRSA 3.2SH1			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 3.2SH1						
*QUALIF: LATER	*TEMPERATURE	T 3.2SH1						
*STATUS	*PRESSURE	P 3.2SH1						
*	*REL. HUMIDTY	H 3.2SH1						
*	*CHEM. SPRAY	C 3.2SH1						
*****	*RADIATION	R 3.2SH1						
	*AGING	A 3.2SH1						
	*SUBMERGENCE	S 3.2SH1						
EQ. PCK # : 3.2SH1	OSBP CATEG.: A APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.2SH1
 CES#-1765
 REVISION # :00
 DATE :
 SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-D29SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D30SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPER				SRS042.2SH1				
COMPONENT: PNEUMATIC OPER ATOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RUSKIN				SRS42.2SH1				SUBCOMPONENTS:
MODEL AND: SERIAL #	CB-315	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR42.2SH1				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11					SRSA42.2SH1				
COORDINATES X- Y- Z-	1414. 1691. 221.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
*****		OPERABILITY	O 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER		TEMPERATURE	T 42.2SH1						
*STATUS		PRESSURE	P 42.2SH1						
*		REL. HUMPTY	H 42.2SH1						
*		CHEM. SPRAY	C 42.2SH1						
*****		RADIATION	R 42.2SH1						
		AGING	A 42.2SH1						
		SUBMERGENCE	S 42.2SH1						
EQ. PCK # : 42.2SH1									REFERENCES:
		OS88 CATEG.: A APPENDIX E							
									CES#-1770
									REVISION # : 00 DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : AV-D30SB-1



A/E: EBAS SERVICES INC.
 UTILITY: LINA POWER & LIGHT

FACILITY: SHEAPON HAI
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1771

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D30SB-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 121 CYC		REF 1,P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:12UF DBA:SEE FIG E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG F2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF 1,APP.C	
MAJOR : SUPPLIER	RUSKIN								SUBCOMPONENTS:	
MODEL AND: SERIAL #	NP8320A173E	RELATIVE HUMIDITY	20-90XNORM 100X DBA	NORM:40X DBA:100X	HAB11 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.	
FUNCT.DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH9.5-10.5	CAB11 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE					SRSC 3.2SH1				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	2.DER 2.DER	RAB11R3 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:BE-25		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
P.O #:435205										
PLANT LOC.:	AB11									
COORDINATES X- Y- Z-	1414. 1691. 221.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
INSTAL. REF:BY-FLD		OPERABILITY O	3.2SH1							
QUALIF EXEMPTN: NOT APPLIC		TEMPERATURE T	3.2SH1							
*****		PRESSURE P	3.2SH1					CES#-1771		
*QUALIF: QUALIFIED-AWAITING		REL. HUMIDTY H	3.2SH1							
*STATUS CONFIRMATORY DATA		CHEM. SPRAY C	3.2SH1							
*		RADIATION R	3.2SH1							
*		AGING A	3.2SH1							
*****		SUBMERGENCE S	3.2SH1							
EQ. PCK # :	3.2SH1	0588 CATEG.:	A	REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982				REVISION # :00 DATE :08/13/84		
		APPENDIX E						SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D30SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			RADIATION		QUALIF. METHOD	R/T	ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	DC ACTU	DEM. QUALIF.			
G NO : AV-D31SA-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPERS TYPE	TEMPERAT- URE	NOT AVAILABLE	104F NORM 104F DBA		REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	100% NORM 107% DBA		REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MAJOR : RUSKIN SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: EA-180-21302 SERIAL #	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.04E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
FUNCT.DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
SPECIFICATIONS: BE-25	OPERABILITY O	9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.			CESN-1772		
P.O #: 435205	TEMPERATURE T	9.1SH1						
PLANT LOC.: AB11	PRESSURE P	9.1SH1						
COORDINATES X- 1587. Y- 171C. Z- 216.0	REL. HUMDTY H	9.1SH1						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO	CHEM. SPRAY C	9.1SH1						
QUALIF EXEPTN: NOT APPLIC	RADIATION R	9.1SH1						
*****	AGING A	9.1SH1						
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE S	9.1SH1						
*STATUS CONFIRMATORY DATA								
* *****								
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E							REVISION # : 00 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D31SA-1

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

NOTE:
(1) PG 4-3,4-3.1 &
4-3.2 OF REPORT
QTR-105 REV 3
DATED 8/20/81

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : AV-D31SA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO42.2SH1							
COMPONENT: PNEUMATIC OPERATOR	TEMPERAT- URE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:			
MANUFACTURER: BETTIS	PRESSURE	ATMCS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:			
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-1007 (DBA) TABLE 3.11.0-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.			
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
FUNCT. DES: & SERVICE	FUNCTION											
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.4E4	LATER	RAB11R3	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE				
ACCUR. DEP.: NOT APPLICABLE	A BETA	7.2E4		FSAR SEC 3.11B								
SPECIFICATIONS: RE-25	D B SHIELD	100%										
P.O #: 435205	S T.I.D.	3.4E4										
PLANT LOC.: AB11	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
COORDINATES X- 1587. Y- 1710. Z- 216.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY	O 42.2SH1		REFERENCES:						CES#-1773		
	TEMPERATURE	T 42.2SH1										
	PRESSURE	P 42.2SH1										
	REL. HUMDTY	H 42.2SH1										
	CHEM. SPRAY	C 42.2SH1										
	RADIATION	R 42.2SH1										
	AGING	A 42.2SH1										
	SUBMERGENCE	S 42.2SH1										
EQ. PCK # : 42.2SH1	OS&P CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D31SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D31SA-1	OPERABILITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC DBA:30DAYS 21 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26 SRSD 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER	TEMPERATURE	NOT AVAILABLE	NORM:12GF DBA:SEE FIG F1A-3.2SH1		NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: REF 1,P.C-5
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG F2A-3.2SH1	PAB11 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-107% (DBA) TABLE 3.11.0-1	NORM:40% DBA:100%		NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAG E1.
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH. 9.5-10.5	CAB11 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: NP832DA173E	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.0ER 2.0ER	RAB11R3 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT.DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: BE-25	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1								
P.O #: 435205	OPERABILITY	O	3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
PLANT LOC.: AB11	TEMPERATURE	T	3.2SH1						CES#-1774
COORDINATES X- 1587. Y- 1710. Z- 216.0	PRESSURE	P	3.2SH1						REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982
INSTALLED (Y/N): LTR	REL. HUMDTY	H	3.2SH1						REVISION # :00 DATE :08/13/84
INSTAL. REF: BY-FLD	CHEM. SPRAY	C	3.2SH1						SYSTEM : REAC.AUX.BLDG HVAC
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R	3.2SH1						TAG : AV-D31SA-1
***** QUALIFIED-AWAITING *****	AGING	A	3.2SH1						
***** STATUS CONFIRMATORY DATA *****	SURMERGENCE	S	3.2SH1						

EQ. PCK # : 3.2SH1	0588 CATEG.: A	APPENDIX E							



A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1775

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D32SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN				SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	7.04E8	RAB11R3 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	1U CFR50 PARA. 50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11					SRSA 9.2SH1	REVIEW				
COORDINATES X- Y- Z-	1580. 1692. 216.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1
*****		OPERABILITY	O	9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE	T	9.2SH1						
*STATUS CONFIRMATORY DATA		PRESSURE	P	9.2SH1						CESN-1775
*		REL. HUMDTY	H	9.2SH1						
*		CHEM. SPRAY	C	9.2SH1						
*****		RADIATION	R	9.2SH1						
		AGING	A	9.2SH1						
		SURMERGENCE	S	9.2SH1						
EQ. PCK # :	9.2SH1									REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.
		OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84
										SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D32SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D32SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-415-SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T.I.D.	3.4E4							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1580. Y- 1692. Z- 216.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTAL. REF: BY-FLO	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							CES#-1776
*QUALIF: LATER	REL. HUMIDTY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*****	SUPMERGENCE	S 42.2SH1							
EQ. PKG # : 42.2SH1	OS88 CATEG.: A								REFERENCES:
	APPENDIX E								
									REVISION # : 00
									DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : AV-D32SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D32SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC							
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG 1A-3.2SH1	TAB11A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG 1A-3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB11 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB11 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: ALL SRS ARE IN TAB E1.	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.4E4 7.2E4 100% 3.4E4	2.7E8	RAB11R3 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.5U.51	REF 1 P.A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS: 9E-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
P.O #: 435205										
PLANT LOC.: AB11										
COORDINATES X- 1580. Y- 1692. Z- 216.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY	O 3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982				CES#-1777			
	TEMPERATURE	T 3.2SH1								
	PRESSURE	P 3.2SH1								
	REL. HUMDTY	H 3.2SH1								
	CHEM. SPRAY	C 3.2SH1								
	RADIATION	R 3.2SH1								
	AGING	A 3.2SH1					REVISION # : 00			
	SUBMERGENCE	S 3.2SH1					DATE : 08/13/84			
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D32SB-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D34SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE : DAMPER	NORM/TEST DBA				SRS042.2SH1					
COMPONENT : PNEUMATIC OPERATOR	TEMPERATURE	104F NORM DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.0E4								
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21					SRSS42.2SH1					
COORDINATES X- 1553. Y- 1603. Z- 236.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
*****	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1782		
*QUALIF: LATER	TEMPERATURE	T 42.2SH1								
*STATUS	PRESSURE	P 42.2SH1								
*	REL. HUMPTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*****	RADIATION	R 42.2SH1								
	AGING	A 42.2SH1								
	SURMERGENCE	S 42.2SH1								
EQ. PCK # : 42.2SH1	0588 CATEG.: A								REVISION # : 00	
	APPENDIX E								DATE :	
									SYSTEM : REAC.AUX.BLDG	
									HVAC	
									TAG : AV-D34SB-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D355A-1	OPERABIL- ITY	40YRS NORM 50C CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS DBA				SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB01A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB01 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN				SRSP 9.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB01 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION				SRSH 9.2SH1	REVIEW				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB01 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.04E4	RAB01R2 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	PLANT LOC.: ABD1				SRSA 9.2SH1	REVIEW				
COORDINATES X- Y- Z-	1584. 1643. 206.0	SUBMERGED LEVEL	191.0 FEET	N/A	SAB01 FSAR SEC 3.11B	COMB. TEST & SUPPL.	M	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTH: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMPTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	SUPPL. REVIEW 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1								
EQ. PCK # : 9.2SH1	OS88 CATEG.: A APPENDIX E									

FOR PUNCHLIST ITEMS SEE SH E9 PACKAGE: 9.2SH1

REFERENCES: (1) NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/78.

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.2SH1

CES#-1734

REVISION # : 00
DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AV-D355A-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D355A-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB01A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB01R2 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4			SRSR42.2SH1	REVIEW				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: A801	SUBMERGED LEVEL	191.0 FEET	LATER	SAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
COORDINATES X- 1584. Y- 1643. Z- 206.0					SRSS42.2SH1	REVIEW				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
*****	OPERABILITY	O 42.2SH1		REFERENCES:				CESN-1785		
*QUALIF: LATER	TEMPERATURE	T 42.2SH1								
*STATUS	PRESSURE	P 42.2SH1								
*	REL. HUMIDTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*****	RADIATION	R 42.2SH1								
	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	0588 CATEG.: A	APPENDIX E							REVISION #: 00 DATE: SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D355A-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D36SR-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB01A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.9E4	LATER	RAB01R1 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.9E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	191.0 FEET	LATER	SAB01 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	
PLANT LOC.: AB01					SRSS42.2SH1				
COORDINATES X- 1581. Y- 1638. Z- 190.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1							
*****	PRESSURE	P 42.2SH1							CES#-1758
*QUALIF: LATER	REL. HUMIDTY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*****	SUBMERGENCE	S 42.2SH1							REVISION # : 00
									DATE :
EQ. PCK # : 42.2SH1	D588 CATEG.: A								SYSTEM : REAC. AUX. BLDG
	APPENDIX E								HYAC
									TAG : AV-D36SR-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D36SB-1	OPERABIL-ITY	NORM:40YRS DBA:1YR	NORM:40YRS 120,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 121 CYC		REF 1,P.26 SRSO 3.2SH1				
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB01A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB01 FSAR SEC 3.11B	REF 1,P.26 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : RUSKIN SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB01 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PR & SERVICE ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH7.5-10.5	CAB01 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100% 2.9E4	2.7ER 2.7ER	RAB01R1 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	1U CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: ABD1	SUBMERGED LEVEL	191.0 FEET	N/A	SABD1 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	
COORDINATES X- 1581. Y- 1632. Z- 190.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T	3.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE	P	3.2SH1						CES#-1789
*	REL. HUMDTY	H	3.2SH1						
*	CHEM. SPRAY	C	3.2SH1						
*****	RADIATION	R	3.2SH1						
	AGING	A	3.2SH1						
	SUBMERGENCE	S	3.2SH1						
EQ. PCK # : 3.2SH1	U588 CATEG.: A APPENDIX E								REVISION # :00 DATE :08/13/84 SYSTEM :REAC.AUX.BLDG. HVAC TAG :AV-D36SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

REFERENCES: 1.ASCO TEST REPORT # AQR-67368
REV.0, MARCH 1982

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : AV-D37SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 107,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS DBA				SRSO 9.2SH1	REVIEW				
COMPONENT:	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047 SUPPL. REVIEW	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047 SUPPL. REVIEW	COMB. TEST & SUPPL.	M	NONE	MAINTAIN: P.079-081 OF REF(1)
MAJOR : SUPPLIER	RUSKIN				SRSO 9.2SH1	REVIEW				SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077 SUPPL. REVIEW	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SUPPL. REVIEW	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE				SRSO 9.2SH1	REVIEW				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016 SUPPL. REVIEW	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	BE-25									
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA-50.51	REF(1) P.079-081 SUPPL. REVIEW	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1458. 1594. 249.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SUPPL. REVIEW	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARA- METER		SUPPL. REVIEW						FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O	9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****		TEMPERATURE	T	9.2SH1						CES#-1790
*QUALIF:	QUALIFIED-AWAITING	PRESSURE	P	9.2SH1						
*STATUS	CONFIRMATORY DATA	REL. HUMDITY	H	9.2SH1						
*		CHEM. SPRAY	C	9.2SH1						REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.
*		RADIATION	R	9.2SH1						
*****		AGING	A	9.2SH1						
		SURMERGENCE	S	9.2SH1						REVISION # :00 DATE :09/18/84
EQ. PCK # :	9.2SH1									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D37SA-1
		0588 CATEG.:	A							
		APPENDIX	E							



A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARTMAN NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -1791

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D37SA-1	OPERABILITY NORM/TEST DBA	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE					SRSO42.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS					SRST42.2SH1				MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CB-315	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR42.2SH1					
P.O #: 4352G5	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA42.2SH1					
COORDINATES X- 1458. Y- 1594. Z- 249.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS42.2SH1					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1		REFERENCES:				CES-1791		
*****	TEMPERATURE	T 42.2SH1								
*QUALIF: LATER	PRESSURE	P 42.2SH1								
*STATUS	REL. HUMIDTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*	RADIATION	R 42.2SH1								
*****	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	CS88 CATEG.: A								REVISION #: 00	
	APPENDIX E								DATE:	
									SYSTEM: REAC. AUX. BLDG HVAC	
									TAG: AV-D37SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : AV-D37SA-1	OPERABILITY	NORM: 40 YRS DBA: 1 YR	NORM: 40 YRS 20,100 CYC DBA: 300 DAYS	OPER. REVIEW	NORM: REF 1 P. 8 DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	6	7	NONE
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A-3.2SH1	TA921A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M		NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M		NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8	COMB. TEST & SUPPL. REVIEW	/		NONE
MODEL AND SERIAL #: NP8320A173E	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH2.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL. REVIEW	/		NONE
FUNCT. DES. & SERVICE: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.0E4 100% 2.0E4	RAB21R7 FSAR SEC 3.11B	REF 1 P. 15 & 22	COMB. TEST & SUPPL. REVIEW	H		NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF 1 P. A-3, C-5, C-8	COMB. TEST & SUPPL. REVIEW	/		NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/		NONE
SPECIFICATIONS: RE-25	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
P.O #: 435205	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT # AOR-67368 REV. 0, MARCH 1982			CES#-1792		
PLANT LOC.: AB21	TEMPERATURE	T 3.2SH1							
COORDINATES X- 1458.	PRESSURE	P 3.2SH1							
Y- 1594.	REL. HUMIDTY	H 3.2SH1							
Z- 249.0	CHEM. SPRAY	C 3.2SH1							
INSTALLED (Y/N): LTR	RADIATION	R 3.2SH1							
INSTAL. REF: BY-FLO	AGING	A 3.2SH1		REVISION # : 00			DATE : 08/13/84		
QUALIF EXEMPTN; NOT APPLIC	SUBMERGENCE	S 3.2SH1		SYSTEM : REAC. AUX. BLDG HVAC			TAG : AV-D37SA-1		
*****	APPENDIX E								

REPLACEMENT: REF 1, P. C-5

MAINTAIN.: REF 1, APP. C

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:

1. ALL SRS ARE IN TAB E1.

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D38SB-1	OPERABILITY	40YRS NORM 500 CYF	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER : RUSKIN					SRSO 9.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: EA180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	7.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR53 PARA.50.51	REF(1) P.D79-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1464. Y- 1603. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
EQ. PCK # : 9.2SH1	OPERABILITY	O 9.2SH1							CES#-1793
	TEMPERATURE	T 9.2SH1							REVISION # :00 DATE :09/18/84
	PRESSURE	P 9.2SH1							SYSTEM : REAC.AUX.BLDG HVAC
	REL. HUMIDTY	H 9.2SH1							TAG : AV-D38SB-1
	CHEM. SPRAY	C 9.2SH1							
	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
	OS88 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1)NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D38SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T.I.D.	3.0E4			SRSR42.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1464. Y- 1603. Z- 236.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	OPERABILITY O	42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	42.2SH1							CES#-1794
*QUALIF: LATER	PRESSURE P	42.2SH1							
*STATUS	REL. HUMDTY H	42.2SH1							
*	CHEM. SPRAY C	42.2SH1							
*	RADIATION R	42.2SH1							
*****	AGING A	42.2SH1							
	SUBMERGENCE S	42.2SH1							
EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : AV-D38SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D4SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.2SH1			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) P.D42 TO D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-DR1 OF REF(1)
MANUFACTURER: HAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAR31 FSAR SEC 3.11B	REF(1) P.D42 TO D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-DB1 OF REF(1)
MAJOR SUPPLIER : RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION						SRSO 9.2SH1			
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79 TO D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31									
COORDINATES X- 1586. Y- 1603. Z- 268.0	SURPERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY	O 9.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							CES#-1796
*	REL. HUMDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1				REFERENCES: (1) HAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					REVISION # : 00 DATE : 09/18/84
	0588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D4SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/R	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D4SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN					SRS042.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR42.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31					SRSA42.2SH1				
COORDINATES X- 1580. Y- 1603. Z- 268.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*****	OPERABILITY	O 42.2SH1							CS-1797
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							
*STATUS	PRESSURE	P 42.2SH1							
*	REL. HUMDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*****	RADIATION	R 42.2SH1							
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	USBB CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-D4SB-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D4SB-1	OPERABIL- ITY NORM/TEST DBA	NORM:40YRS DBA:1YR TOTAL CYC: 500	NORM:40YRS 20,100 CYC DBA:30DAYS 121 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26 SR50 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	TEMPERAT- URE	104F NORM 104F DBA	NORM:12GF DBA:SEE FIG E1A- 3.2SH1	TAB31A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB31 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MANUFACTURER:ASCO	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40X DBA:100X	HAB31 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
MAJOR : RUSKIN SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB31 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: SERIAL #	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	2.7E8	RAB3111 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT.DES: & SERVICE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
SPECIFICATIONS:BE-25	OPERABILITY	O 3.2SH1				CES#-1798			
P.O #:435205	TEMPERATURE	T 3.2SH1							
PLANT LOC.: AB31	PRESSURE	P 3.2SH1							
COORDINATES X- 1580. Y- 16C3. Z- 268.0	REL. HUMDTY	H 3.2SH1							
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 3.2SH1							
INSTAL. REF:BY-FLD	RADIATION	R 3.2SH1							
QUALIF EXEMPTN: NOT APPLIC	AGING	A 3.2SH1							
*****	SUBMERGENCE	S 3.2SH1							
*****	0588 CATEG.: A APPENDIX E								
*****	REFERENCES:		1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982						
*****	REVISION # :00 DATE :08/13/84								
*****	SYSTEM :REAC.AUX.BLDG HVAC								
*****	TAG :AV-D4SB-1								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D52SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	14YRS NORM 100300 CYC	OPER. REVIEW	[REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPERS DBA				[SR50 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	95F NORM 95F DBA	104F NORM 106F DBA	TYD31R FSAR SEC 3.11B	[REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO					[SRST 9.1SH1	REVIEW			
MAJOR : SUPPLIER	RUSKIN								MAINTAIN.: SEE NOTE (1)
MODEL AND: SERIAL #	EA-180								SUBCOMPONENTS:
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE									
SPECIFICATIONS: BE-25									
P.O #: 435205									
PLANT LOC.: AB21									
COORDINATES X- 1595. Y- 1685. Z- 245.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC									
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW							
	OPERABILITY O	9.1SH1							
	TEMPERATURE T	9.1SH1							
	PRESSURE P	9.1SH1							
	REL. HUMDTY H	9.1SH1							
	CHEM. SPRAY C	9.1SH1							
	RADIATION R	9.1SH1							
	AGING A	9.1SH1							
	SUBMERGENCE S	9.1SH1							
EQ. PCK # : 9.1SH1									
	0588 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1SH1

CES#-1802

REVISION # : 00
 DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-052SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D52SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR OPERDAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	95F NORM 95F DBA	LATER	TYD31R FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	10-100% NORM 100% DBA	LATER	HYD31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	R GAMMA	1.8E4	LATER	PAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
SPECIFICATIONS: BE-25	S T. I. D.	1.8E4							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1595. Y- 1685. Z- 245.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							CES#-1803
*****	REL. HUMDTY	H 42.2SH1							
*QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							
*STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							

EQ. PCK # : 42.2SH1	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : REAC. AUX. BLDG HVAC
									TAG : AV-052SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D53SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CR-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-25	S T.I.D.	3.0E4			SRSR42.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1585. Y- 1685. Z- 247.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/H): LTR	OPERABILITY	O 42.2SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							CES#-1806
*QUALIF: LATER	REL. HUMIDTY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							REFERENCES:
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
	SUPKERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	OS88 CATEG.: A								REVISION #: JD
	APPENDIX E								DATE :
									SYSTEM : REAC.AUX.BLDG HVAC
									TAG : AV-D53SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : AV-053SB-1	OPERABILITY	NORM:40YRS DBA:1YP	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC		REF 1,P.26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN: REF 1,APP.C
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3070 PPM BORON PH:9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.2EF 2.2EF	RAB21R6 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
PLANT LOC.: AB21	OPERABILITY	O	3.2SH1						CES#-1807
COORDINATES X- 1585. Y- 1685. Z- 247.0	TEMPERATURE	T	3.2SH1						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PRESSURE	P	3.2SH1						
*QUALIF: QUALIFIED-AWAITING	REL. HUMIDITY	H	3.2SH1						
*STATUS CONFIRMATORY DATA	CHEM. SPRAY	C	3.2SH1						
* *****	RADIATION	R	3.2SH1						
	AGING	A	3.2SH1						
	SUBMERGENCE	S	3.2SH1						
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E				REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982				REVISION # :00 DATE :08/13/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-053SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D56SA-1	OPERABIL-ITY	40YRS. NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPE RATOR	TEMPERAT-URE	104F NORM 104F DBA	122F NORM & DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR : RUSKIN SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM & DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: DAMPER & SERVICE OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	5.7E6	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA		NORM & DBA						
SPECIFICATIONS: BE-25	D B SHIELD	100%							
P.O #: 435205	S T.I.D.	2.6E4			SRSR3.10SH1				
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA. 50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1465. Y- 1595. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	3.10SH1						CES#-1808
*QUALIF: QUALIFIED	TEMPERATURE	T	3.10SH1						
*STATUS	PRESSURE	P	3.10SH1						
*	REL. HUMDTY	H	3.10SH1						
*	CHEM. SPRAY	C	3.10SH1						
*****	RADIATION	R	3.10SH1						
	AGING	A	3.10SH1						
	SUBMERGENCE	S	3.10SH1						
EQ. PCK # : 3.10SH1	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/16/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D56SA-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
(2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D56SA-1	OPERABILITY	40YRS NORM	40YRS NORM	OPER.	REF(1)	COMB.	/	NONE		
	ITY	500 CYC	100,000CYC	REVIEW	P.D36	TEST & SUPPL.				
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM	104F NORM	TAB21A	REF(1)	COMB.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)	
		104F DBA	104F DBA	FSAR SEC 3.11B	P.D42-D47	TEST & SUPPL.			MAINTAIN.: P.079-081 OF REF(1)	
MANUFACTURER: NAMCO					SRST 9.2SH1	REVIEW			SUBCOMPONENTS:	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM	ATM NORM	PAB21	REF(1)	COMB.	M	NONE		
		ATMOS DBA	ATM DBA	FSAR SEC 3.11B	P.D42-D47	TEST & SUPPL.				
					SRSP 9.2SH1	REVIEW				
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM	100% NORM	HAB21	REF(1)	COMB.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
		100% DBA	100% DBA	FSAR SEC 3.11B	P.D77	TEST & SUPPL.				
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION					SRSH 9.2SH1	REVIEW				
	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21	N/A	COMB.	/	NONE		
				FSAR SEC 3.11B		TEST & SUPPL.				
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	2.04E8	RAB21R7	REF(1)	COMB.	M	NONE		
	A BETA			FSAR SEC 3.11B	P.D16	TEST & SUPPL.				
	D B SHIELD	100%			SRSR 9.2SH1	REVIEW				
	S T.I.D.	2.6E4								
SPECIFICATIONS: BE-25	AGE-	40 YEARS	40 YRS	10 CFR50	REF(1)	COMB.	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	INST LIFE (PER 323-1974 DEF.)			PARA.50.51	P.D79-081	TEST & SUPPL.				
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW				
COORDINATES X- 1465.	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21	N/A	COMB.	/	NONE		
Y- 1595.				FSAR SEC 3.11B		TEST & SUPPL.				
Z- 248.0					SRSS 9.2SH1	REVIEW				
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
INSTAL. REF: BY-FLD	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CESN-1809		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 9.2SH1								
*****	PRESSURE	P 9.2SH1								
* QUALIF: QUALIFIED-AWAITING	REL. HUMDTY	H 9.2SH1								
* STATUS CONFIRMATORY DATA	CHEM. SPRAY	C 9.2SH1								
*	RADIATION	R 9.2SH1								
*****	AGING	A 9.2SH1								
	SUBMERGENCE	S 9.2SH1						REVISION #: 00 DATE: 09/18/84		
EQ. PCK #: 9.2SH1	OS88 CATEG.: A							SYSTEM: REAC.AUX.BLDG. HVAC		
	APPENDIX E							TAG: AV-D56SA-1		

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HARBOR NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9JU MW(E)

0
 -1811

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-057SR-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 107,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.036 [RSO 9.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPER TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047 [SRST 9.2SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047 [SRSP 9.2SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077 [SRSH 9.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MAJOR : RUSKIN SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A [SRSC 9.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MODEL AND: EA-180 SERIAL #	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016 [RSR 9.2SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081 [RSRA 9.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A [SRSS 9.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES#-1811			
P.O #: 435205	TEMPERATURE	T	9.2SH1										
PLANT LOC.: AB21	PRESSURE	P	9.2SH1										
COORDINATES X- 1465. Y- 1574. Z- 248.0	REL. HUMDTY	H	9.2SH1										
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD	CHEM. SPRAY	C	9.2SH1										
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R	9.2SH1										
*****	AGING	A	9.2SH1										
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S	9.2SH1										
*STATUS CONFIRMATORY DATA	OS88 CATEG.: A												
*	APPENDIX E												
* *****													
EQ. PCK # : 9.2SH1									REVISION # :00 DATE :39/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-057SR-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-058SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1) MAINTAIN.: P.079-081 OF REF(1) SUBCOMPONENTS:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: RUSKIN					SRSR 9.2SH1				
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1				
ACCUR. DEF.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74E8	RAB21R7- FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1467. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION. PACKAGE: 9.2SH1
	OPERABILITY	O 9.2SH1							CES#-1812
	TEMPERATURE	T 9.2SH1							
	PRESSURE	P 9.2SH1							
	REL. HUMIDITY	H 9.2SH1							
	CHEM. SPRAY	C 9.2SH1							
	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK #: 9.2SH1	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84
					REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-058SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : AV-0585A-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA					SRS042.2SH1			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN:
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION									
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1467. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 42.2SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*STATUS	PRESSURE	P 42.2SH1							CES#-1813
*	REL. HUMDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*****	RADIATION	P 42.2SH1							REFERENCES:
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1									REVISION #: 00 DATE:
	0588 CATEG.: A APPENDIX E								SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-0585A-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-058SA-1	OPERABIL- ITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 121 CYC		REF 1, P.26 SRSO 3.2SH1					
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATP DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C	
MAJOR : SUPPLIER	RUSKIN				SRSP 3.2SH1				SUBCOMPONENTS:	
MODEL AND: SERIAL #	NP8320A173E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8 SRSH 3.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.	
FUNCT. DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3070 PPM 90% ON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.2SH1					
ACCUR. DEM.: NOT APPLICABLE		R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.0ER 2.0ER	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	M	NONE		
SPECIFICATIONS: BE-25		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	10 CFR50 PARA. 50.51	REF 1 P. A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205										
PLANT LOC.: AB21										
COORDINATES X- Y- Z-	1467. 1586. 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****		PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
		OPERABILITY	O 3.2SH1						CES#-1814	
		TEMPERATURE	T 3.2SH1							
		PRESSURE	P 3.2SH1							
		REL. HUMIDTY	H 3.2SH1							
		CHEM. SPRAY	C 3.2SH1							
		RADIATION	R 3.2SH1							
		AGING	A 3.2SH1							
		SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1		0588 CATEG.: A APPENDIX E			REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982				REVISION # : 00 DATE : 08/13/84	
									SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-058SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-059SB-1	OPERABILITY	4CYRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.2SH1			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: EA-180-21302	FUNCT. DES. & SERVICE POSITION	REMOTE INDICATION OF DAMPER POSITION				SRSR 9.2SH1			
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	M	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR53 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	PLANT LOC.: AB21					SRSA 9.2SH1			
COORDINATES X- 1468. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C P A S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
EQ. PCK # : 9.2SH1	OSRP CATEG.: A APPENDIX E				REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1815 REVISION # : 00 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-059SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D59SR-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERER	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 1J4F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	INST LIFE (PER 323-1974 DEF.)				SRSA42.2SH1				
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1462. Y- 1586. Z- 247.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							CES#-1816
*STATUS	PRESSURE	P 42.2SH1							
*	REL. HUMDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*****	RADIATION	R 42.2SH1							
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	OS88 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM : REAC. AUX. BLDG HVAC
									TAG : AV-D59SB-1

FOR PUNCHLIST ITEMS SEE SH ER PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-059SB-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA:30DAYS 21 CYC		SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER:ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : SUPPLIER					SRSP 3.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	3070 PPM RORON PH? 5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.3E4 2.2E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	1D CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:435205									
PLANT LOC.: AB21									
COORDINATES X- Y- Z-	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1					CES#-1817		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E			REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982			REVISION # :00 DATE :08/13/84 SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-059SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D60SA-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE					SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 2 DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT					SRS73.10SH1				
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	9MM20	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
					SRS3.10SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: NH96	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 2 DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: DAMPER OPERATOR					SRS3.10SH1				
	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC3.10SH1				
ACCUR. DEP.: NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	5.0E6 NORM & DBA	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR3.10SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB21					SRSA3.10SH1				
COORDINATES X- 1516. Y- 1595. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRSS3.10SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SHEET PACKAGE: 3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1			
***** *QUALIF: QUALIFIED *STATUS * *****	OPERABILITY O	3.10SH1				CES#-1821			
	TEMPERATURE T	3.10SH1				REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.			
	PRESSURE P	3.10SH1				(2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.			
	REL. HUMIDTY H	3.10SH1				REVISION # : 00			
	CHEM. SPRAY C	3.10SH1				DATE : 09/16/84			
	RADIATION R	3.10SH1				SYSTEM : REAC. AUX. BLDG HVAC			
	AGING A	3.10SH1				TAG : AV-D60SA-1			
	SUBMERGENCE S	3.10SH1							
EQ. PCK # : 3.10SH1	D588 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D60SA-1	OPERABILITY	40YRS NORM 50G CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER : RUSKIN					SRSP 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- 1516. Y- 1595. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF. FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
	OPERABILITY	O 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CES#-1822		
	TEMPERATURE	T 9.2SH1							
	PRESSURE	P 9.2SH1							
	REL. HUMDTY	H 9.2SH1							
	CHEM. SPRAY	C 9.2SH1							
	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1		REVISION # :00 DATE :09/18/84					
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D60SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-061S9-1	OPEPABIL-ITY	40YPS NORM 1YR DBA	40YPS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPE RATOR	TEMPERAT-URE	104F NORM 104F DBA	122F NORM 2 DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	9MM20	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR : RUSKIN SUPPLIER					SRS03.10SH1				SUBCOMPONENTS:
MODEL AND: NH96 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM % DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: DAMPER & SERVICE OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC3.10SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	5.0E6 NORM & DBA	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR3.10SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	1D CFR50 PARA. 50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA3.10SH1				
COORDINATES X- 1516. Y- 1574. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRSS3.10SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
*QUALIF: QUALIFIED	OPERABILITY	O 3.10SH1		REFERENCES: (1) NH90 QUALIFICATION REPORT #721.77.095. (2) NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.			CES#-1823		
*STATUS	TEMPERATURE	T 3.10SH1							
*	PRESSURE	P 3.10SH1							
*	REL. HUMDTY	H 3.10SH1							
*	CHEM. SPRAY	C 3.10SH1							
*	RADIATION	R 3.10SH1							
	AGING	A 3.10SH1					REVISION # : 00 DATE : 09/14/84		
EQ. PCK # : 3.10SH1	SURMERGENCE	S 3.10SH1					SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-061S8-1		
	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-061SB-1	OPERABIL-ITY	4CYRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.2SH1			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR : RUSKIN SUPPLIER						SRSO 9.2SH1			SUBCOMPONENTS:
MODEL AND: EA-180 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE						SRSO 9.2SH1			
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34F8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25						SRSR 9.2SH1			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21						SRSA 9.2SH1			
COORDINATES X- 1516. Y- 1574. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY	O 9.2SH1							CES#-1824
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							
*	REL. HUMDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1	U588 CATEG.: A APPENDIX E								REVISION # :00 DATE :09/18/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-061SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1.

REFERENCES: (1) NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/78.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D62SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPER									
COMPONENT:	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-D47 SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER:	NAMCO									MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR : SUPPLIER	RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-D47 TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-21302	RELATIVE HUMIDITY	2G-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25									
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81 TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1515. 1586. 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****		OPERABILITY	O	9.2SH1						
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE	T	9.2SH1						
*STATUS CONFIRMATORY DATA		PRESSURE	P	9.2SH1						
*		REL. HUMDTY	H	9.2SH1						
*		CHEM. SPRAY	C	9.2SH1						
*****		RADIATION	R	9.2SH1						
		AGING	A	9.2SH1						
		SUBMERGENCE	S	9.2SH1						
EQ. PCK # :	9.2SH1									
		U586 CATEG.:	A							
		APPENDIX	E							

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.2SH1

CES#-1825

REFERENCES: (1)NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

REVISION # :00
 DATE :09/18/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-D62SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D62SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	DBA				SRSO42.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATEP	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	PAINTAIN.:
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATEP	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	R GAMMA	2.6E4	LATEP	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1515. Y- 1586. Z- 247.0	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTALLED (Y/N): LTR	TEMPERATURE	T 42.2SH1							CES#-1826
INSTAL. REF: BY-FLD	PRESSURE	P 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMDITY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*****	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	OS88 CATEG.: A								REVISION # : 00 DATE :
	APPENDIX E								SYSTEM : REAC.AUX. BLOC HVAC TAG : AV-D62SA-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D62SA-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	TOTAL CYC: 50G	DBA:30DAYS 21 CYC		SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1,P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: REF 1,APP.C	
MAJOR : SUPPLIER	RUSKIN				SRSP 3.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	NPR320A173E	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40X DBA:100X	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT.DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	300G PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A2G	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE				SRSC 3.2SH1	REVIEW				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 - 100% 2.6E4	2.0E8 - - 2.0E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS - -	40 YRS - -	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB21				SRSA 3.2SH1	REVIEW				
COORDINATES X- Y- Z-	1515. 1586. 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR					SRSS 3.2SH1	REVIEW				
INSTAL. REF: BY-FLD		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE-SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
QUALIF EXEMPTN: NOT APPLIC		OPERABILITY O	3.2SH1							
*****		TEMPERATURE T	3.2SH1							
*QUALIF: QUALIFIED-AWAITING		PRESSURE P	3.2SH1				CES#-1827			
*STATUS CONFIRMATORY DATA		REL. HUMDTY H	3.2SH1							
*		CHEM. SPRAY C	3.2SH1							
*		RADIATION R	3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982						
*****		AGING A	3.2SH1				REVISION # :00			
		SUBMERGENCE S	3.2SH1				DATE :08/13/84			
EQ. PCK # :	3.2SH1						SYSTEM : REAC.AUX.BLOG HVAC			
		D588 CATEG.:	A				TAG : AV-D62SA-1			
		APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D63SB-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPER TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MODEL AND SERIAL #: EA-180-213G2	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES#-1828			
P.O #: 435205	TEMPERATURE	T 9.2SH1											
PLANT LOC.: AB21	PRESSURE	P 9.2SH1											
COORDINATES X- 1512. Y- 1586. Z- 247.0	REL. HUMIDTY	H 9.2SH1											
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 9.2SH1											
INSTAL. REF: BY-FLO	RADIATION	R 9.2SH1											
QUALIF EXEMPTN: NOT APPLIC	AGING	A 9.2SH1											
*****	SUBMERGENCE	S 9.2SH1											
*****	CSRB CATEG.: A												
*****	APPENDIX E												
EQ. PCK #: 9.2SH1									REVISION #: 00 DATE: 09/18/84				
									SYSTEM: REAC.AUX.BLDG HVAC				
									TAG: AV-D63SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D63SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA				SRS042.2SH1					
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATEP	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: . . .	
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA									
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1					
SPECIFICATIONS: BE-25	S T. I. D.	2.6E4								
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1512. Y- 1586. Z- 247.0					SRSS42.2SH1					
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
INSTAL. REF: BY-FLD	OPERABILITY	O 42.2SH1		REFERENCES:				CESN-1829		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1								
*QUALIF: LATER	PRESSURE	P 42.2SH1								
*STATUS	REL. HUMIDTY	H 42.2SH1								
*	CHEM. SPRAY	C 42.2SH1								
*	RADIATION	R 42.2SH1								
*****	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	D588 CATEG.: A							REVISION #: 00		
	APPENDIX E							DATE:		
								SYSTEM: REAC. AUX. BLDG HVAC		
								TAG: AV-D63SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D64SA-1	OPERABIL-ITY	40YRS NORM 1YR DBA	40YPS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPE RATOR	TEMPERAT-URE	104F NORM 104F DBA	122F NORM R DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM R DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: DAMPER & SERVICE OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	5.0E6	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. DEP.: NOT APPLICABLE	A BETA		NORM & DBA						
SPECIFICATIONS: BE-25	D B SHIELD	100%							
P.O #: 435205	S T.I.D.	2.6E4							
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA. 50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
COORDINATES X- 1482. Y- 1595. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EO PACKAGE: 3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
*****	OPERABILITY O	3.10SH1		REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.			CES#-1831		
*QUALIF: QUALIFIED	TEMPERATURE T	3.10SH1							
*STATUS	PRESSURE P	3.10SH1							
*	REL. HUMDTY H	3.10SH1							
*	CHEM. SPRAY C	3.10SH1							
*****	RADIATION R	3.10SH1							
	AGING A	3.10SH1					REVISION # : 00 DATE : 09/14/84		
	SUBMERGENCE S	3.10SH1					SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-D64SA-1		
EQ. PCK # : 3.10SH1	0588 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D64SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.94E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA								
SPECIFICATIONS: BE-25	D B SHIELD	100X							
P.O #: 435205	S T.I.D.	2.6E4							
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1482. Y- 1595. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 9.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							
*	REL. HUMIDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1	OS88 CATEG.: A APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.2SH1

CESR-1832

REFERENCES: (1) NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/78.

REVISION # : 00
DATE : 09/18/84

SYSTEM : REAC.AUX.8LDG
HVAC
TAG : AV-D64SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : AV-065SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS-NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE			
EQUIPMENT TYPE : DAMPER	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW					
COMPONENT : LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	176F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-DB1 OF REF(1)		
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-DB1 OF REF(1)		
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:		
MODEL AND SERIAL # : EA-180									NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
FUNCT. DES. & SERVICE : REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE			
ACCUR. SPEC: NOT APPLICABLE											
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.76E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE			
SPECIFICATIONS: BE-25											
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	1C CFR5D PARA.50.51	REF(1) P.D79-D91	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS		
PLANT LOC.: AB21											
COORDINATES X- 1479. Y- 1590. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					CES#-1834		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1									
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1									
*	REL. HUMIDTY	H 9.2SH1									
*	CHEM. SPRAY	C 9.2SH1									
*****	RADIATION	R 9.2SH1									
	AGING	A 9.2SH1						REVISION # : 00			
	SUBMERGENCE	S 9.2SH1						DATE : 09/19/84			
EQ. PCK # : 9.2SH1	U588 CATEG.: A APPENDIX E							SYSTEM : REAC. AUX. BLDG HVAC			
								TAG : AV-065SB-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D66SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA				SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO									MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-213G2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.34E8 100%	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1486. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CESN-1835		
	TEMPERATURE	T 9.2SH1					REVISION # : 00		
	PRESSURE	P 9.2SH1					DATE : 09/18/84		
	REL. HUMIDTY	H 9.2SH1					SYSTEM : REAC.AUX.BLOG HVAC		
	CHEM. SPRAY	C 9.2SH1					TAG : AV-D66SA-1		
	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SURFERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1	OSRB CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D66SA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPER DBA				SRS042.2SH1	REVIEW			
COMPONENT:	PNEUMATIC OPER ATOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER:	BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	USKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS, SS
ACCUR. DEM.:	NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS:	BE-25	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
P.O #:	435205	OPERABILITY	O 42.2SH1	REFERENCES:					CES#-1836
PLANT LOC.:	AB21	TEMPERATURE	T 42.2SH1						
COORDINATES X-:	1486.	PRESSURE	P 42.2SH1						
Y-:	1586.	REL. HUMDTY	H 42.2SH1						
Z-:	247.0	CHEM. SPRAY	C 42.2SH1						
INSTALLED (Y/N):	LTR	RADIATION	R 42.2SH1						
INSTAL. REF:	BY-FLO	AGING	A 42.2SH1		REVISION #	300			
QUALIF EXEMPTN:	NOT APPLIC	SUBMERGENCE	S 42.2SH1		DATE				
*QUALIF:	LATER	U588 CATEG.:	A		SYSTEM :	REAC.AUX.ULDB			
*STATUS		APPENDIX E			HVAC				
* * * * *					TAG	AV-D66SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D66SA-1	OPERABIL-ITY	NORM:40YRS DBA:1YR	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 50G	DBA:30DAYS 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DBA	NORM:120F DBA:SEE FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM:REF 1 P.9 DBA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1,P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40X DBA:100X	HAB21 FSAR SEC 3.11B	NORM:REF 1 P.A7 DBA: REF 1,P.A8	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND: NP8320A173E SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM NORM PH?5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: ALL SRS ARE IN TAB E1.
FUNCT.DES: CONTROL AIR PR & SERVICE ESSURE IN PNEU MATIC OPERATOR CYLINDER	ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.3E8 2.3E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:435205	PLANT LOC.: AB21								
COORDINATES X- 1486. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF, FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*QUALIF: QUALIFIED-AWAITING	OPERABILITY	O 3.2SH1		REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982			CES#-1837		
*STATUS CONFIRMATORY DATA	TEMPERATURE	T 3.2SH1							
*	PRESSURE	P 3.2SH1							
*	REL. HUMDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*	RADIATION	R 3.2SH1							
*	AGING	A 3.2SH1							
EQ. PCK # : 3.2SH1	SUBMERGENCE	S 3.2SH1		REVISION # :00 DATE :08/13/84			SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D66SA-1		
	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D67SB-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)
MAJOR : RUSKIN SUPPLIER					SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: EA-180-21302 SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YPS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- 1488. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CES#-1838		
EQ. PCK # : 9.2SH1	DSRB CATEG.: A APPENDIX E						REVISION # :00 DATE :09/18/84 SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-067SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D67SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW		NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW		NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW		NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	INST LIFE (PER 323-1974 DEF.)				SRSA42.2SH1				
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1488. Y- 1586. Z- 247.0	PARAMETER	SUPPL. REVISED							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							CES#-1839
*QUALIF: LATER	REL. HUMIDTY	H 42.2SH1							
*STATUS	CHEM. SPRAY	C 42.2SH1							REFERENCES:
*	RADIATION	P 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE:
									SYSTEM: REAC. AUX. BLDG HVAC
									TAG: AV-D67SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					DEM. QUALIF.
TAG NO : AV-D69SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: DAMPER	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	MAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	M	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- 1538. Y- 1574. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW							
*****	OPERABILITY	O 9.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							CESN-1844
*	REL. HUMIDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
EQ. PCK #: 9.2SH1									REVISION #: 00 DATE: 09/18/84
	OSR CATEG.: A APPENDIX E								SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D69SB-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1) NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-D7SA-1	OPERABILITY	LATER.	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPER	NORM/TEST DBA				SRS042.2SH1			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90XNORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: HOLD DAMPER IN & SERVICE POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4						
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1427. Y- 1595. Z- 236.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1						
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1						
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1						
*QUALIF: LATER	REL. HUMDTY	H 42.2SH1						
*STATUS	CHEM. SPRAY	C 42.2SH1						
*	RADIATION	R 42.2SH1						
*	AGING	A 42.2SH1						
*****	SUBMERGENCE	S 42.2SH1						
EQ. PCK #: 42.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1 REFERENCES:							
	O588 CATEG.: A	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1 CES#-1246 REVISION #: 00 DATE : SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-D7SA-1						
	APPENDIX E							

REPLACEMENT:
 MAINTAIN:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT
 NOTE 1: QUAL REPORT
 NOT AVAILABLE AT
 THIS TIME.

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-07SA-1	OPERABILITY	NORM: 40YRS DBA: 1YP	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.	
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.3E4 2.3E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
MODEL AND SERIAL #: NP8320A173E	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1427. Y- 1595. Z- 236.0	PARAMETER	SUPPL. REVIEW								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLICABLE	OPERABILITY	O	3.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T	3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982				CESN-1847		
*STATUS CONFIRMATORY DATA	PRESSURE	P	3.2SH1							
*	REL. HUMDTY	H	3.2SH1							
*	CHEM. SPRAY	C	3.2SH1							
*****	RADIATION	R	3.2SH1							
*****	AGING	A	3.2SH1							
	SUBMERGENCE	S	3.2SH1					REVISION # :00 DATE :08/13/84		
EQ. PCK # : 3.2SH1	G58R CATEG.: A APPENDIX E							SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-07SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D70SA-1	OPERABIL-ITY	40YRS NORM 500 CYC 1YR DBA	47YRS NORM 107,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 176F DBA	TAB21A FSAR SEC 3.118	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.118	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.118	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MAJOR : RUSKIN SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 103% DBA	HAB21 FSAR SEC 3.118	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND: SERIAL #	AGE	40 YEARS	49 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
FUNCT.DES: & SERVICE	INST LIFE (PER 323- 1974 DEF.)								
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.118	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIFW							
SPECIFICATIONS: BE-25	OPERABILITY	O	9.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
P.O #: 435205	TEMPERATURE	T	9.2SH1	REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					CES#-1848
PLANT LOC.: AB21	PRESSURE	P	9.2SH1						
COORDINATES X- 1537. Y- 1586. Z- 247.0	REL. HUMDITY	H	9.2SH1						
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	9.2SH1						
INSTAL. REF: BY-FLO	RADIATION	R	9.2SH1						
QUALIF EXEMPTH: NOT APPLIC	AGING	A	9.2SH1				REVISION # : 00		
*****	SUBMERGENCE	S	9.2SH1				DATE : 09/18/84		
*QUALIF: QUALIFIED-AWAITING									
*STATUS CONFIRMATORY DATA									
*									

EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E							SYSTEM : REAC.AUX.BLOG HVAC	
								TAG : AV-D70SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D70SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA					SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: CR-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X								
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4				SRSR42.2SH1				
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21						SRSA42.2SH1				
COORDINATES X- 1537. Y- 1586. Z- 247.0						SRSS42.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
***** *QUALIF: LATER *STATUS * *****	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1849		
	TEMPERATURE	T 42.2SH1								
	PRESSURE	P 42.2SH1								
	REL. HUMIDTY	H 42.2SH1								
	CHEM. SPRAY	C 42.2SH1								
	RADIATION	R 42.2SH1								
	AGING	A 42.2SH1								
	SUBMERGENCE	S 42.2SH1								
EQ. PCK #: 42.2SH1	US88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: SYSTEM: REAC.AUX.BLDG HVAC TAG: AV-D70SA-1	



A/E: EBASCO SERVICES INC.
 UTILITY: MAINE POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 1850

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-070SA-1	OPERABILITY	NORM: 40YRS DBA: 1YP	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG F1A-3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN: REF 1, APP.C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM ROZON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.3E8 2.3E8	RAB21R7 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205	COORDINATES X- 1537. Y- 1586. Z- 247.0								
PLANT LOC.: AB21	INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY O	3.2SH1		REFERENCES: 1.ASCO TEST REPORT # AQR-67368 REV.0, MARCH 1982			CES 4-1850		
*****	TEMPERATURE T	3.2SH1							
*****	PRESSURE P	3.2SH1							
*****	REL. HUMDTY H	3.2SH1							
*****	CHEM. SPRAY C	3.2SH1							
*****	RADIATION R	3.2SH1							
*****	AGING A	3.2SH1							
*****	SUBMERGENCE S	3.2SH1		REVISION # : 00 DATE : 08/13/84					
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-070SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-071SB-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	/	NONE	
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: EA-180-21302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					
SPECIFICATIONS: BE-25	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1	
P.O #: 435205	TEMPERATURE	T	9.2SH1					CES#-1851	
PLANT LOC.: AB21	PRESSURE	P	9.2SH1					REVISION # :00	
COORDINATES X- 1537. Y- 1585. Z- 247.0	REL. HUMDTY	H	9.2SH1					DATE :09/18/84	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C	9.2SH1					SYSTEM :REAC.AUX.BLDG HVAC	
*****	RADIATION	R	9.2SH1					TAG :AV-071SB-1	
*****	AGING	A	9.2SH1						
*****	SUBMERGENCE	S	9.2SH1						
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E								

REPLACEMENT:
P.D79-D81 OF
REF(1)
MAINTAIN.:
P.D79-D81 OF
REF(1)
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : AV-D71SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1	REVIEW			
COMPONENT: PNEUMATIC OPER ATOR	TEMPERAT- URE	104F NORM 104F DRA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS					SRST42.2SH1	REVIEW			MAINTAIN.:
MAJOR : RUSKIN SUPPLIER	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	M	NONE	SUBCOMPONENTS:
					SRSP42.2SH1	REVIEW			
MODEL AND: CB-315 SERIAL #	RELATIVE HUMIDITY	20-90X NORM 100X DRA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSI TION					SRSH42.2SH1	REVIEW			
	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.2SH1	REVIEW			
ACCUR. DEV.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR42.2SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	1G CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA42.2SH1	REVIEW			
COORDINATES X- 1537. Y- 1585. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL.	/	NONE	
					SRSS42.2SH1	REVIEW			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW		FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1	
*****	OPERABILITY	O 42.2SH1		REFERENCES:				CES#-1852	
*QUALIF: LATER	TEMPERATURE	T 42.2SH1						REVISION # : 00	
*STATUS	PRESSURE	P 42.2SH1						DATE :	
*	REL. HUMDTY	H 42.2SH1						SYSTEM : REAC.AUX.BLDG	
*	CHEM. SPRAY	C 42.2SH1						HVAC	
*****	RADIATION	R 42.2SH1						TAG : AV-D71SB-1	
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PK # : 42.2SH1	0588 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D72SA-1	OPERABIL- ITY	4CYRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR : SUPPLIER	RUSKIN				SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION								
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8 107 DBA	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O # : 435205									
PLANT LOC.: AB21									
COORDINATES X- 1546. Y- 1595. Z- 248.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIFW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUEMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
EQ. PCK # : 9.2SH1					REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1855
	OS88 CATEG.: A APPENDIX E								REVISION # : UD DATE : 09/18/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D72SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-073SB-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE					SRS03.10SH1					
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 9 DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)	
MANUFACTURER: ITT					SRS3.10SH1				MAINTAIN: REF(2)	
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: NH-96	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 2 DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRS3.10SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	5.0E6 NORM & DBA	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: BE-25					SRSR3.10SH1					
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSAS.10SH1					
COORDINATES X- 1543. Y- 1578. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
					SRS53.10SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
*****	OPERABILITY	O 3.10SH1						CES#-1856		
*QUALIF: QUALIFIED	TEMPERATURE	T 3.10SH1								
*STATUS	PRESSURE	P 3.10SH1								
*	REL. HUMDTY	H 3.10SH1								
*	CHEM. SPRAY	C 3.10SH1								
*****	RADIATION	R 3.10SH1								
	AGING	A 3.10SH1								
	SUBMERGENCE	S 3.10SH1								
EQ. PCK # : 3.10SH1	OS88 CATEG.: A APPENDIX E			REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.				REVISION # : 00 DATE : 09/14/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-073SB-1		

A/E: EB SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HA
 COMPONENT EVALUATION

NPP - 1
 NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

VN- 0
 7-1857

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D73SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-081 OF REF(1)	
MAJOR : RUSKIN SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90XNORM 100X DBA	100X NORM 100X DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION				SRSH 9.2SH1	REVIEW				
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW				
COORDINATES X- 1543. Y- 1578. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY C	9.2SH1								CES#-1857
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	9.2SH1								
*	REL. HUMDTY H	9.2SH1								
*	CHEM. SPRAY C	9.2SH1								
*****	RADIATION R	9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						
	AGING A	9.2SH1								REVISION # : JD DATE : 09/18/84
	SUBMERGENCE S	9.2SH1								SYSTEM : REAC.AUX.BLOG HVAC TAG : AV-D73SB-1
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-074SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-21302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION					SRSR 9.2SH1	REVIEW			
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 2.6E4	2.6E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- 1548. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1							CES#-1858
EQ. PCK # : 9.2SH1	OS88 CATEG.: A APPENDIX E				REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION # : 00 DATE : 09/18/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-074SA-1





EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-074SA-1	OPERABIL- ITY	NORM: 40YRS DBA: 1YD NORM/TEST DBA	NORM: 40YRS 20, 100 CYC DBA: 30DAYS 21 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA: REF 1, P. 26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPER									
COMPONENT:	SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG F1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C	
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40X DBA: 100X 3.2SH1	HAB21 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES: & SERVICE	CONTROL AIR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P. A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A RETA D B SHIELD S T. I. D.	2.6E4 100X 2.6E4	2.0E3 2.0E3	RAB21R7 FSAR SEC 3.11B	REF 1 P. 15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	10 CFR 50 PARA. 50.51	REF 1 P. A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:	435205	COORDINATES X- Y- Z-	1548. 1586. 247.0							
PLANT LOC.:	AB21	INSTALLED (Y/N):	LTR							
COORDINATES		INSTAL. REF:	BY-FLD							
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O	3.2SH1					CES#-1860		
*QUALIF:	QUALIFIED-AWAITING	T	3.2SH1							
*STATUS	CONFIRMATORY DATA	P	3.2SH1							
*	REL. HUMDTY	H	3.2SH1							
*	CHEM. SPRAY	C	3.2SH1							
*****	RADIATION	R	3.2SH1	REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982				REVISION # : 00 DATE : 08/13/84		
	AGING	A	3.2SH1							
	SUBMERGENCE	S	3.2SH1					SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-D74SA-1		
EQ. PCK # :	3.2SH1	OS88 CATEG.:	A							
		APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D75SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS					SRSO 9.2SH1				
COMPONENT:	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1) MAINTAIN.: P.D79-D81 OF REF(1) SUBCOMPONENTS:
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:	435205	COORDINATES X- Y- Z-	1543. 1585. 247.0							
PLANT LOC.:	AB21	INSTALLED (Y/N):	LTR							
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*QUALIF:	QUALIFIED-AWAITING	OPERABILITY O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-1861		
*STATUS	CONFIRMATORY DATA	TEMPERATURE T	9.2SH1							
*		PRESSURE P	9.2SH1							
*		REL. HUMDTY H	9.2SH1							
*		CHEM. SPRAY C	9.2SH1							
*		RADIATION R	9.2SH1							
*		AGING A	9.2SH1							
		SUBMERGENCE S	9.2SH1							
EQ. PCK # :	9.2SH1	0588 CATEG.:	A					REVISION # :00 DATE :09/18/84		
		APPENDIX E						SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D75SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D758B-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1								
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:				
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	MAINTAIN.:				
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT. NOT AVAILABLE AT THIS TIME.				
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEP.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
SPECIFICATIONS: BE-25	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1			
P.O #: 435205	OPERABILITY	O 42.2SH1		REFERENCES:						CES#-1862			
PLANT LOC.: AB21	TEMPERATURE	T 42.2SH1											
COORDINATES X- 1543. Y- 1585. Z- 247.0	PRESSURE	P 42.2SH1											
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 42.2SH1											
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 42.2SH1											
QUALIF EXEMPTH: NOT APPLIC	RADIATION	R 42.2SH1											
*****	AGING	A 42.2SH1											
*QUALIF: LATER	SUBMERGENCE	S 42.2SH1											
*STATUS	US88 CATEG.: A												
*	APPENDIX E												
*													

EQ. PCK #: 42.2SH1									REVISION #: 00 DATE: SYSTEM: REAC.AUX.BLOG HVAC TAG: AV-D758B-1				

A/E: EB SERVICES INC.
UTILITY CAROLINA POWER & LIGHT

FACILITY: SHEARON HANCOCK NPP - 1
COMPONENT EVALUATION REPORT

NSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

W-0
W-1863

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D75SB-1	OPERABIL- ITY NORM/TEST DBA	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE									
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F 104F	NORM DBA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: ASCO									MAINTAIN.:
MAJOR : RUSKIN SUPPLIER	PRESSURE	ATMOS ATMOS	NORM DBA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90X 100X	NORM DBA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4		LATER	RAB21R7 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1543. Y- 1585. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF: FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
***** *QUALIF: LATER *STATUS * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1							CES#-1863
EQ. PCK # : 3.2SH1									REVISION # : 00 DATE :
	0588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG. HVAC TAG : AV-D75SB-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-078SA-1	OPERABILITY	40YRS NORM 500 CYC 1YF DBA	40YRS NORM 107300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSD 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE									
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	95F NORM 95F DBA	104F NORM 104F DBA	TYD31R FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SEE NOTE (1)
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	10-100% NORM 100% DBA	100% NORM 100% DBA	HY631 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	(1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	9.1E4 100X 9.1E4	2.04E8	RAB21R8 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB21									
COORDINATES X- 1602. Y- 163C. Z- 250.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	9.1SH1							CES#-1864
*STATUS CONFIRMATORY DATA	TEMPERATURE T	9.1SH1							
*****	PRESSURE P	9.1SH1							
	REL. HUMIDTY H	9.1SH1							
	CHEM. SPRAY C	9.1SH1							
	RADIATION R	9.1SH1							
	AGING A	9.1SH1							
	SUBMERGENCE S	9.1SH1							
EQ. PCK #: 9.1SH1									REVISION # : 00 DATE : 09/18/84
	0588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-078SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
QUALIFICATION REPORT QTR-105
REVISION 3 DATED 8/20/81.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D78SA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPER DBA				SRS042.2SH1				
COMPONENT:	PNEUMATIC OPER ATOR	TEMPERAT- URE	95F NORM 95F DBA	LATER	TYD31R FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER:	BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	10-100% 100% DBA	LATER	HYD31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
MODEL AND: SERIAL #	CB-415-SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	R GAMMA	9.1E4	LATER	RAB21R FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC:	NOT APPLICABLE	D B SHIELD	100%		SRSR42.2SH1				
ACCUR. DEM.:	NOT APPLICABLE	S T.I.D.	9.1E4						
SPECIFICATIONS:	BE-25	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	435205	INST LIFE (PER 323- 1974 DEF.)							
PLANT LOC.:	AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- Y- Z-	1602. 163C. 250.0								
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF:	BY-FLD	OPERABILITY	O 42.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T 42.2SH1						CES#-1865
*QUALIF:	LATER	PRESSURE	P 42.2SH1						
*STATUS		REL. HUMDTY	H 42.2SH1						
*		CHEM. SPRAY	C 42.2SH1						
*		RADIATION	R 42.2SH1						
		AGING	A 42.2SH1						REVISION # : 00
		SUBMERGENCE	S 42.2SH1						DATE :
EQ. PCK # :	42.2SH1								SYSTEM : REAC.AUX.BLDG HVAC
		OSRR CATEG.:	A						TAG : AV-D78SA-1
		APPENDIX	E						

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

A/E: EBASCO SERVICES INC.
 UTILITY: MAINE POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION SHEET - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

7-0
 1966

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D78SA-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30DAYS 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	95F NORM 95F DBA	NORM: 120F DBA: SEE FIG E1A-3.2SH1	TYD31R FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1, P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	10-100% NORM 100% DBA	NORM: 40% DBA: 100%	HYD31 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1, P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	9.1E4 100X 9.1E4	2.0E8 2.0E8	RAB21R8 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
SPECIFICATIONS: BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435205									
PLANT LOC.: AB21									
COORDINATES X- 1602. Y- 1630. Z- 250.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
QUALIF EXEMPTN: NOT APPLICABLE	OPERABILITY	O 3.2SH1							CES#-1866
QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
	REL. HUMIDTY	H 3.2SH1							
	CHEM. SPRAY	C 3.2SH1							
	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E				REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV.J, MARCH 1982				REVISION # : 00 DATE : 08/13/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D78SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D79SB- 1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO					SRST 9.1SH1	REVIEW			
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)
MODEL AND: SERIAL #					SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:
FUNCT. DES: & SERVICE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	(1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.1SH1	REVIEW			
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.1SH1	REVIEW			
COORDINATES X- 1585. Y- 1630. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							CES4-1867
EQ. PCK # : 9.1SH1					REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION # : 00 DATE : 09/18/84
	0588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX. BLDG HVAC TAG : AV-D79SB- 1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-079SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATKOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-415-SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: HOLD DAMPER IN & SERVICE REQUIRED POSITION	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100X							
SPECIFICATIONS: BE-25	S T.I.D.	3.0E4			SRSR42.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1585. Y- 1630. Z- 247.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							CSN-1868
*****	REL. HUMDTY	H 42.2SH1							
* QUALIF: LATER	CHEM. SPRAY	C 42.2SH1							REFERENCES:
* STATUS	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*	SUBMERGENCE	S 42.2SH1							

EQ. PCK #: 42.2SH1	US88 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE:
									SYSTEM: REAC. AUX. BLDG. HVAC
									TAG: AV-079SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : AV-D79SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC DBA: 30DAYS 121 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: DAMPER	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: REF 1,P.26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.C-5	
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C	
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90X NORM 100X DBA	NORM: 40X DBA: 100X	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: REF 1,P.A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: NP8320A173E	R GAPMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.0E8 2.0E8	RAB21R6 FSAR SEC 3.11B	REF 1 P.15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
FUNCT. DES. & SERVICE: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3,C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O 3.2SH1	REFERENCES: 1.ASCO TEST REPORT # AGR-6736E REV.0, MARCH 1982				CES#-1869			
P.O #: 435205	TEMPERATURE	T 3.2SH1								
PLANT LOC.: AB21	PRESSURE	P 3.2SH1								
COORDINATES X- 1585. Y- 1630. Z- 247.0	REL. HUMDTY	H 3.2SH1								
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 3.2SH1								
INSTAL. REF: BY-FLD	RADIATION	R 3.2SH1								
QUALIF EXEMPTN: NOT APPLIC	AGING	A 3.2SH1					REVISION # : 00 DATE : 08/13/84			
*****	SUBMERGENCE	S 3.2SH1					SYSTEM : REAC.AUX.BLOG HVAC TAG : AV-D79SB-1			
*****	0588 CATEG.: A	APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D86SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE	MAINTAIN:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D & B SHIELD	100%			SRSR42.2SH1				
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
P.O #: 435205	INST LIFE (PER 323-1974 DEF.)				SRSA42.2SH1				
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1580. Y- 1705. Z- 270.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
*QUALIF: LATER	TEMPERATURE	T 42.2SH1							CESN-1877
*STATUS	PRESSURE	P 42.2SH1							REVISION # : 00 DATE :
*	REL. HUMIDTY	H 42.2SH1							SYSTEM : REAC. AUX. BLDG HVAC
*	CHEM. SPRAY	C 42.2SH1							TAG : AV-D86SA-1
*****	RADIATION	R 42.2SH1							
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	0588 CATEG.: A APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-DR6SA-1	OPERABIL- ITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPER	NORM/TEST DBA	TOTAL CYC: 500	21 CYC	REF 1, P. 26 SRSO 3.2SH1	REVIEW				
COMPONENT:	SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG F1A- 3.2SH1	TAB31A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG F2A- 3.2SH1	FAB31 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB31 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAG E1.
FUNCT. DES: & SERVICE	CONTROL ATR PR ESSURE IN PNEU MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM ROROM PH 7.5-10.5	CAB31 FSAR SEC 3.11B	REF 1 P. A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA	2.6E4	2.3E4	RAB3111 FSAR SEC 3.11B	REF 1 P. 15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	BE-25	S T.I.D.	2.6E4	2.3E4						
P.O N: 435205		AGE-	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF 1 P. A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB31	INST LIFE (PER 323- 1974 DEF.)								
COORDINATES X- Y- Z-	1580. 1705. 270.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF:	BY-FLD	OPERABILITY	O	3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
QUALIF EXEMPTN:	NOT APPLIC	TEMPERATURE	T	3.2SH1						CESV-1878
*****		PRESSURE	P	3.2SH1						
*QUALIF: QUALIFIED-AWAITING		REL. HUMDTY	H	3.2SH1						
*STATUS CONFIRMATORY DATA		CHEM. SPRAY	C	3.2SH1						
*		RADIATION	R	3.2SH1						
*		AGING	A	3.2SH1						
*****		SUBMERGENCE	S	3.2SH1						
EQ. PCK # :	3.2SH1									
		Q588 CATEG.:	A							
		APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

REFERENCES: 1. ASCO TEST REPORT # AGR-67368
REV. D, MARCH 1982

REVISION # : 00
DATE : 08/13/86
SYSTEM : REAC. AUX. BLDG
HVAC
TAG : AV-D86SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-087SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE					
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW							
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER: RUSKIN					SRSR 9.1SH1	REVIEW			SUBCOMPONENTS:				
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3.4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81				
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW							
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 4.4E5 100% 2.6E4	2.34E8	PAB3111 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE					
SPECIFICATIONS: RE-25					SRSR 9.1SH1	REVIEW							
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	1G CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTIONS: SS				
PLANT LOC.: AB31					SRSA 9.1SH1	REVIEW							
COORDINATES X- 1580. Y- 169C. Z- 272.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EG PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CESN-1879			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1											
*STATUS CONFIRMATORY DATA	PRESSURE	F 9.1SH1											
*	REL. HUMIDTY	H 9.1SH1											
*	CHEM. SPRAY	C 9.1SH1											
*****	RADIATION	R 9.1SH1											
	AGING	A 9.1SH1											
	SUBMERGENCE	S 9.1SH1											
EQ. PCK #: 9.1SH1	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: REAC.AUX.BLDG HVAC TAG: AV-087SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D87SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-315	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: RE-25	S T.I.D.	2.6E4							
P.O. #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1580. Y- 1690. Z- 272.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 42.2SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 42.2SH1							
*QUALIF: LATER	REL. HUMIDTY	H 42.2SH1							CES#-1880
*STATUS	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
*	AGING	A 42.2SH1							
*****	SUBMERGENCE	S 42.2SH1							
EQ. PCK # : 42.2SH1	0588 CATEG.: A								REVISION # : 03
	APPENDIX E								DATE :
									SYSTEM : REAC. AUX. BLDG HVAC
									TAG : AV-D87SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:

REVISION # : 03
 DATE :

SYSTEM : REAC. AUX. BLDG HVAC
 TAG : AV-D87SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D9SA-1	OPERABILITY	LATER	LATFP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRS042.2SH1				
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	95F NORM 95F DBA	LATER	TYD31R FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	LATFP	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	10-100% NORM 100% DBA	LATEP	HYD31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: CB-415	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: HOLD DAMPER IN REQUIRED POSITION	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X			SRSR42.2SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATFP	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB31	PARAMETER	SUPPL. REVIEW							
COORDINATES X= 1410. Y= 1694. Z= 271.0	OPERABILITY	O 42.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1
INSTALLED (Y/N): LTR INSTAL. REF: 9Y-FLD QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 42.2SH1							CES#-1886
*QUALIF: LATER	PRESSURE	P 42.2SH1							
*STATUS	REL. HUMIDTY	H 42.2SH1							
*	CHEM. SPRAY	C 42.2SH1							
*	RADIATION	R 42.2SH1							
	AGING	A 42.2SH1							
	SUBMERGENCE	S 42.2SH1							
EQ. PCK #: 42.2SH1	OS8R CATEG.: A								REVISION # : 00 DATE :
	APPENDIX E								SYSTEM : REAC. AUX. BLDG HVAC TAG : AV-D9SA-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1

REFERENCES:



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D9SA-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8 DBA: 26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 50G	DBA: 30DAYS 21 CYC		REF 1, P.26	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	95F NORM 95F DBA	NORM: 120F DBA: SEE FIG E1A-3.2SH1	TYD31R FSAR SEC 3.11B	NORM: REF 1 P.9 DBA: 26	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-3.2SH1	PAB31 FSAR SEC 3.11B	REF 1, P.26	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	10-100% NORM 100% DBA	NORM: 40% DBA: 100%	HYD31 FSAR SEC 3.11B	NORM: REF 1 P.A7 DBA: 26	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NP832DA173E	FUNCT. DES. & SERVICE	CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER			REF 1, P.A8	REVIEW			NOTE: ALL SRS ARE IN TAB E1.
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM PH 7.5-10.5	CAB31 FSAR SEC 3.11B	REF 1 P.A20	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.0E8 2.0E8	RAB3111 FSAR SEC 3.11B	REF 1 P.15 & 22	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF 1 P.A-3, C-5, C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTIONS: SS
P.O #: 435205	PLANT LOC.: AB31				SRSA 3.2SH1	REVIEW			
COORDINATES X- 1410. Y- 1694. Z- 271.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*OPERABILITY O 3.2SH1	TEMPERATURE T 3.2SH1			REFERENCES: 1.ASCO TEST REPORT # AOR-67368 REV.0, MARCH 1982			CESN-1887		
*STATUS CONFIRMATORY DATA	PRESSURE P 3.2SH1								
*REL. HUMIDTY H 3.2SH1	CHEM. SPRAY C 3.2SH1								
*RADIATION R 3.2SH1	AGING A 3.2SH1								
*SUBMERGENCE S 3.2SH1									
EQ. PCK #: 3.2SH1	U588 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 08/13/84 SYSTEM: REAC.AUX.BLOG HVAC TAG: AV-D9SA-1



A/E: EBA SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON H NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EV#- 0
 1-1900

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CR-DISA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F 104F	NORM DBA	LATER	TAB41A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS ATMOS	NORM DBA	LATER	PAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER					SRSR 9.1/9.				SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% 100%	NORM DBA	LATER	HAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER P OSITION				SRSR 9.1/9.				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4		LATER	RAB4117 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA. 50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #: 435205					SRSA 9.1/9.				
PLANT LOC.: AB41	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1396. Y- 1641. Z- 295.0					SRSS 9.1/9.				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW			FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
*QUALIF: LATER	*OPERABILITY	O 9.1/9.2							CES#-1900
*STATUS	*TEMPERATURE	T 9.1/9.2							
*	*PRESSURE	P 9.1/9.2							
*	*REL. HUMIDTY	H 9.1/9.2							
*	*CHEM. SPRAY	C 9.1/9.2							
*****	*RADIATION	R 9.1/9.2							
	*AGING	A 9.1/9.2							
	*SUBMERGENCE	S 9.1/9.2							
EQ. PCK # : 9.1/9.2					REFERENCES:				REVISION # : 00 DATE :
	058B CATEG.: A APPENDIX E								SYSTEM : CONT. VACUUM RELIEF TAG : CB-DISA-1





EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CR-D1SA-1	OPERABILITY	NORM: 60YRS DBA: 1YR	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: DAMPER	NORM/TEST DBA	TOTAL CYC: 500	DBA: 300DAYS 21 CYC		REF 1, P. 26 SRSD 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG F1A- 3.2SH1	TAB41A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG F2A- 3.2SH1	PAB41 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB41 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: 1. ALL SRS ARE IN TAB E1.
FUNCT. DES. & SERVICE: CONTROL AIR PRESSURE IN PH MATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM RORON PH: 9.5-10.5	CAB41 FSAR SEC 3.11B	REF 1 P. A20 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 7.2E4 100X 2.6E4	2.0E8	RAB4117 FSAR SEC 3.11B	REF 1 P. 15 & 22 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: RE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR5J PARA. 50.51	REF 1 P. A-3, C-5, C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #: 435205									
PLANT LOC.: AB41									
COORDINATES X- 1396. Y- 1641. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982			CES#-1902		
	TEMPERATURE	T 3.2SH1							
	PRESSURE	P 3.2SH1							
	REL. HUMDTY	H 3.2SH1							
	CHEM. SPRAY	C 3.2SH1							
	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1		REVISION # : 00			DATE : 05/13/84		
	SUBMERGENCE	S 3.2SH1		SYSTEM : CONT. VACUUM RELIEF			TAG : CR-D1SA-1		
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : CR-D2SB-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.								
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	#	NONE	MAINTAIN.:				
MAJOR : RUSKIN SUPPLIER					SRSO 9.1/9.				SUBCOMPONENTS:				
MODEL AND: EA-180 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER P OSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1/9.								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB4117	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: BE-25	A BETA	7.2E4		FSAR SEC									
P.O #: 435205	D B SHIELD	100%		3.11B									
PLANT LOC.: AB41	S T.I.D.	2.6E4			SRSR 9.1/9.								
COORDINATES X- 1573. Y- 1686. Z- 295.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM				
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLO QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
*****	PARA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2			
*QUALIF: LATER	OPERABILITY	O 9.1/9.2		REFERENCES:						CESM-1903			
*STATUS	TEMPERATURE	T 9.1/9.2											
*	PRESSURE	P 9.1/9.2											
*	REL. HUMDTY	H 9.1/9.2											
*****	CHEM. SPRAY	C 9.1/9.2											
	RADIATION	R 9.1/9.2											
	AGING	A 9.1/9.2											
	SUBMERGENCE	S 9.1/9.2											
EQ. PCK # : 9.1/9.2	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : CONT. VACUUM RELIEF TAG : CB-D2SB-1				

A/E: EBASCO VICES INC.
 UTILITY: CHINA POWER & LIGHT

FACILITY: SHEARON HARRIS P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 906 MW(E)

0
 CE 1904

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CB-D2SB-1	OPERABIL- ITY NORM/TEST DBA	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPER									
COMPONENT: MANUFACTURER: BETTIS	PNEUMATIC OPERA TOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MAJOR : SUPPLIER	RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN:	
MODEL AND: SERIAL #	CB-415SR	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
FUNCT. DES: & SERVICE	HOLD DAMPER IN REQUIRED POSI TION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: QUAL REPORT NOT AVAILABLE AT THIS TIME.	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEP.: NOT APPLICABLE										
SPECIFICATIONS: BE-25										
P.O #: 435205		R GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 7.2E4 100% 2.6E4	LATER	RAB4117 FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	H	NONE		
PLANT LOC.: AB41		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
COORDINATES X- 1573. Y- 1686. Z- 295.0		SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.118	LATER COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.2SH1		
***** *QUALIF: LATER *STATUS * * *****		OPERABILITY O	42.2SH1	REFERENCES:				CESN-1904		
	TEMPERATURE T	42.2SH1								
	PRESSURE P	42.2SH1								
	REL. HUMIDTY H	42.2SH1								
	CHEM. SPRAY C	42.2SH1								
	RADIATION R	42.2SH1								
	AGING A	42.2SH1								
	SUBMERGENCE S	42.2SH1								
EQ. PCK # : 42.2SH1		OS88 CATEG.: A APPENDIX E							REVISION # : JD DATE : SYSTEM : CONT. VACUUM RELIEF TAG : CB-D2SB-1	

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPSON HALL
 COMPONENT EVALUATION

NPP - 1
 NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

VI- 0
 -1905

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CB-D2SB-1	OPERABILITY	NORM: 40 YRS DBA: 1YR	NORM: 40 YRS 120, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8 DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA	TOTAL CYC: 500	DBA: 30 DAYS 121 CYC		REF 1, P. 26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: SEE FIG E1A-13.2SH1	TAB41A FSAR SEC 3.11B	NORM: REF 1 P. 9 DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P. C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2A-13.2SH1	PAB41 FSAR SEC 3.11B	REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB41 FSAR SEC 3.11B	NORM: REF 1 P. A7 DBA: REF 1, P. A8	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: ALL SRS ARE IN TAB E1.
FUNCT. DES: CONTROL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB41 FSAR SEC 3.11B	REF 1 P. A20	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.0E8	RAB4117 FSAR SEC 3.11B	REF 1 P. 15 & 22	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.2SH1				
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR 50 PARA. 50.51	REF 1 P. A-3, C-5, C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: PRM
P.O #: 435205					SRSA 3.2SH1				
PLANT LOC.: AB41									
COORDINATES X- 1573. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXE: PTN; NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT # AQR-67368 REV. 0, MARCH 1982			CES#-1905		
	TEMPERATURE	T 3.2SH1					REVISION # : 00 DATE : 08/13/84		
	PRESSURE	P 3.2SH1					SYSTEM : CONT. VACUUM RELIEF		
	REL. HUMIDTY	H 3.2SH1					TAG : CB-D2SB-1		
	CHEM. SPRAY	C 3.2SH1							
	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E								

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SPEARON WA
 COMPONENT EVALUATION

NPP - 1
 NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

ENV - 0
 EST-1930

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D1SA-1	OPERABIL-ITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1					
COMPONENT: ELECTRO-HYDOPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM R DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF(2)	
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	19" H2O	PAB51 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: REF(2)	
MAJOR SUPPLIER : RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: NH-95	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM S DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: DAMPER & SERVICE OPERATOR					SRS3.10SH1					
ACCUR. SPEC: NOT APPLICABLE					SRSC3.10SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	5.0E6 NORM & DBA	RAB5125 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR3.10SH1					
P.O #: 435205	AGE- (INST LIFE (PER 323- 1974 DEF.))	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA3.10SH1					
COORDINATES X- 1606. Y- 1674. Z- 314.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
					SRSS3.10SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED *STATUS * * *****	PARA-METER OPERABILITY O *TEMPERATURE T *PRESSURE P *REL. HUMIDTY H *CHEM. SPRAY C ***** RADIATION R AGING A SUBMERGENCE S	SUPPL. REVIEW 3.10SH1 3.10SH1 3.10SH1 3.10SH1 3.10SH1 3.10SH1 3.10SH1							FOR PUNCHLIST ITEMS SEE SH EO PACKAGE: 3.10SH1 REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.	QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1 CES#-1930 REVISION # : 00 DATE : 09/14/84
EQ. PCK # : 3.10SH1	OS8E CATEG.: A APPENDIX E								SYSTEM : CONTROL ROOM HVAC TAG : CZ-D1SA-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/P	OUTS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITFMS
TAG NO : CZ-D1SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.1/9.			
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4						
SPECIFICATIONS: BE-25	AGE - INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O # : 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51					SRSS 9.1/9.			
COORDINATES X- 1606. Y- 1674. Z- 314.0								
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW						
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1/9.2						
*QUALIF: LATER	TEMPERATURE	T 9.1/9.2						
*STATUS	PRESSURE	P 9.1/9.2						
*	REL. HUMIDTY	H 9.1/9.2						
*	CHEM. SPRAY	C 9.1/9.2						
*****	RADIATION	R 9.1/9.2						
	AGING	A 9.1/9.2						
	SUBMERGENCE	S 9.1/9.2						
EQ. PCK # : 9.1/9.2	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2

REFERENCES:

QUALIFICATION SIGN-OFF- FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2

CES#-1931

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : CZ-D1SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-010SB-1	OPERABILITY	40YRS NQPM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE					SRS03.10SH1				
COMPONENT: ELECTRO-HYDOPERATOR	TEMPERATURE	104F NQPM 104F DBA	122F NORM 2 DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT					SRS3.10SH1				
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	9" H2O	PAB51 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MODEL AND SERIAL #: NH-91					SRS3.10SH1				
FUNCT. DES: DAMPER & SERVICE OPERATOR	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 2 DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
					SRS3.10SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRS3.10SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4	5.0E6	RAB5125	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	M	NONE	
	A BETA		NORM & DBA	FSAR SEC 3.11B					
SPECIFICATIONS: RE-25	D B SHIELD	100X			SRS3.10SH1				
P.O #: 435205	S T.I.D.	3.7E4							
PLANT LOC.: AB51	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
					SRS3.10SH1				
COORDINATES X- 1641. Y- 1667. Z- 315.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRS3.10SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
*****	OPERABILITY	O 3.10SH1							
*QUALIF: QUALIFIED	TEMPERATURE	T 3.10SH1							
*STATUS	PRESSURE	P 3.10SH1							
*	REL. HUMDTY	H 3.10SH1							
*	CHEM. SPRAY	C 3.10SH1							
*****	RADIATION	R 3.10SH1							
	AGING	A 3.10SH1							
	SUBMERGENCE	S 3.10SH1							
EQ. PCK # : 3.10SH1				REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.			REVISION # : 00 DATE : 09/14/84		
	US88 CATEG.: A APPENDIX E						SYSTEM : CONTROL ROOM HVAC TAG : CZ-010SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-D10SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90X NORM 100X DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.1/9.				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4							
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51					SRSS 9.1/9.				
COORDINATES X- 1641. Y- 1667. Z- 315.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
*QUALIF: LATER	OPERABILITY O	9.1/9.2		REFERENCES:			CESN-1933		
*STATUS	TEMPERATURE T	9.1/9.2							
*	PRESSURE P	9.1/9.2							
*	REL. HUMDTY H	9.1/9.2							
*	CHEM. SPRAY C	9.1/9.2							
*	RADIATION R	9.1/9.2							
*****	AGING A	9.1/9.2							
*****	SUBMERGENCE S	9.1/9.2							
EQ. PCK #: 9.1/9.2	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: SYSTEM: CONTROL ROOM HVAC TAG: CZ-D10SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D19SA-1	OPERABIL- ITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS					SRS03.10SH1				
COMPONENT:	ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM & DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2 SRST3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	9"420	PAB51 FSAR SEC 3.11B	REF(1)P-2 SRSP3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM & DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6 SRSH3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC3.10SH1	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	3.7E4 100X 3.7E4	5.7E4 NORM & DBA	PAB5125 FSAR SEC 3.11B	REF(1)P-6 SRSR3.10SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	SPECIFICATIONS:	8E-25							
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6 SRSA3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.:	AB51	COORDINATES X- Y- Z-	1626. 1657. 305.0							
COORDINATES	X- 1626. Y- 1657. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS3.10SH1	N/A	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:3.10SH1			
INSTAL. REF:	RY-FLD	OPERABILITY	O 3.10SH1	REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAIN- TENANCE SCHEDULE #721.81.132.			CES#-1941 REVISION # :00 DATE :09/14/84 SYSTEM :CONTROL ROOM HVAC TAG :CZ-D19SA-1			
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T 3.10SH1							
*QUALIF:	QUALIFIED	PRESSURE	P 3.10SH1							
*STATUS		REL. HUMPTY	H 3.10SH1							
*		CHEM. SPRAY	C 3.10SH1							
*		RADIATION	R 3.10SH1							
*		AGING	A 3.10SH1							
		SUBMERGENCE	S 3.10SH1							
EQ. PCK # :	3.10SH1	0588 CATEG.:	A							
		APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-019SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: HAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA									
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: BE-25	S T. I. D.	3.7E4								
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1626. Y- 1657. Z- 305.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
*OPERABILITY O	9.1/9.2			REFERENCES:				CES#-1942		
*TEMPERATURE T	9.1/9.2									
*PRESSURE P	9.1/9.2									
*REL. HUMDTY H	9.1/9.2									
*CHEM. SPRAY C	9.1/9.2									
*RADIATION R	9.1/9.2									
*AGING A	9.1/9.2									
*SUBMERGENCE S	9.1/9.2							REVISION # : 00 DATE :		
EQ. PCK # : 9.1/9.2	OS88 CATEG.: A APPENDIX E							SYSTEM : CONTROL ROOM HVAC TAG : CZ-019SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : C7-02SB-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYDOPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM R DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	N	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	9" H ₂ O	PAB51 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	N	NONE	MAINTAIN.: REF(2)
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: NH-96	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM R DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: DAMPER & SERVICE OPERATOR					SRS3.10SH1				
ACCUR. SPEC: NOT APPLICABLE					SRS3.10SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	5.0E6 NORM & DBA	RAB5125 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRS3.10SH1				
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA. 50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51					SRS3.10SH1				
COORDINATES X- 1606. Y- 1667. Z- 314.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*QUALIF: QUALIFIED *STATUS	OPERABILITY O	3.10SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1
	TEMPERATURE T	3.10SH1							CESN-1943
	PRESSURE P	3.10SH1							
	REL. HUMIDITY H	3.10SH1							
	CHEM. SPRAY C	3.10SH1							
	RADIATION R	3.10SH1							
	AGING A	3.10SH1							
	SURMERGENCE S	3.10SH1							
EQ. PCK #: 3.10SH1	OS8R CATEG.: A APPENDIX E								REFERENCES: (1) NH90 QUALIFICATION REPORT #721.77.095. (2) NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.
									REVISION #: 00 DATE: 09/16/84
									SYSTEM: CONTROL ROOM HVAC TAG: CZ-02SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-D2SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATEP	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X							
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4			SRSR 9.1/9.				
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51					SRSS 9.1/9.				
COORDINATES X- 1606. Y- 1667. Z- 314.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
***** *QUALIF: LATER *STATUS * *****	OPERABILITY	O 9.1/9.2		REFERENCES:			CESN-1944		
	TEMPERATURE	T 9.1/9.2							
	PRESSURE	P 9.1/9.2							
	REL. HUMIDTY	H 9.1/9.2							
	CHEM. SPRAY	C 9.1/9.2							
	RADIATION	R 9.1/9.2							
	AGING	A 9.1/9.2							
	SURMERGENCE	S 9.1/9.2							
EQ. PCK #: 9.1/9.2	US88 CATEG.: A APPENDIX E								REVISION #: 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D2SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D20SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE : DAMPER	NORM/TEST DBA				SRSO 9.1/9.					
COMPONENT : LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : REMOTE INDICATION OF DAMPER POSITION	R GAPMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA									
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: BE-25	S T.I.D.	3.7E4			SRSR 9.1/9.					
P.O # : 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1626. Y- 1655. Z- 305.0					SRSS 9.1/9.					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY	O 9.1/9.2		REFERENCES:				CES#-1946		
	TEMPERATURE	T 9.1/9.2								
	PRESSURE	P 9.1/9.2								
	REL. HUMDTY	H 9.1/9.2								
	CHEM. SPRAY	C 9.1/9.2								
	RADIATION	R 9.1/9.2								
	AGING	A 9.1/9.2								
	SUBMERGENCE	S 9.1/9.2								
EQ. PCK # : 9.1/9.2	US88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D20SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D23SA-1	OPERABIL- ITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS				{SRS03.10SH1}	REVIEW				
COMPONENT:	ELECTRO-HYD OPE RATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM 9 DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2 SRST3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	9"420	PAB51 FSAR SEC 3.11B	REF(1)P-2 SRSP3.10SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90XNORM 100X DBA	10X NORM 9 DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6 SRSH3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DAMPER OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC3.10SH1	N/A REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A PETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	5.7E6 NORM & DBA	PAB5125 FSAR SEC 3.11B	REF(1)P-6 SRSR3.10SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	1D CFR50 PARA.50.51	REF(1)P-6 SRSA3.10SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS3.10SH1	N/A REVIEW	/	NONE	
P.O #:	435205	COORDINATES X- Y- Z-	1645. 1655. 305.0							
PLANT LOC.:	AB51	INSTALLED (Y/N):	LTR							
COORDINATES X- Y- Z-	1645. 1655. 305.0	INSTAL. REF:	BY-FLD							
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:3.10SH1
*****		OPERABILITY	O 3.10SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:3.10SH1
*QUALIF:	QUALIFIED	TEMPERATURE	T 3.10SH1							
*STATUS		PRESSURE	P 3.10SH1							CES#-1947
*		REL. HUMDTY	H 3.10SH1							
*		CHEM. SPRAY	C 3.10SH1							REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
*****		RADIATION	R 3.10SH1							(2)NH91 & NH95 ACTUATOR MAIN- TENANCE SCHEDULE #721.81.132.
		AGING	A 3.10SH1							REVISION # :00 DATE :09/14/84
		SUBMERGENCE	S 3.10SH1							SYSTEM :CONTROL ROOM HVAC
EQ. PCK # :	3.10SH1	OS88 CATEG.:	A							TAG :CZ-D23SA-1
		APPENDIX	E							

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.							
TAG NO : CZ-D23SA-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.							
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:			
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:			
MAJOR SUPPLIER : RUSKIN									SUBCOMPONENTS:			
MODEL AND SERIAL # : EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES & SERVICE : REMOTE INDICATION OF POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
ACCUR. SPEC: NOT APPLICABLE												
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE				
SPECIFICATIONS: BE-25	A BETA											
P.O #: 435205	D B SHIELD	100%										
PLANT LOC.: AB51	S T.I.D.	3.7E4										
COORDINATES X- 1645. Y- 1655. Z- 305.0	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH ED PACKAGE: 9.1/9.2					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2			
*QUALIF: LATER	OPERABILITY	O 9.1/9.2		REFERENCES:					CES#-1948			
*STATUS	TEMPERATURE	T 9.1/9.2										
*	PRESSURE	P 9.1/9.2										
*	REL. HUMIDTY	H 9.1/9.2										
*	CHEM. SPRAY	C 9.1/9.2										
*	RADIATION	P 9.1/9.2										
*	AGING	A 9.1/9.2										
*****	SUBMERGENCE	S 9.1/9.2										
EQ. PCK # : 9.1/9.2	Q588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D23SA-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-D24SA-1	OPERABILITY	40YRS NORM 1YR DRA	40YRS NORM 1YR DRA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERS					SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DRA	122F NORM 9 DRA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT					SRST3.10SH1				MAINTAIN.: REF(2)
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DRA	0MMH20	PAB51 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: NH-95	RELATIVE HUMIDITY	20-90% NORM 100% DRA	100% NORM 9 DRA	HAB51 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: DAMPER OPERATOR					SRS3.10SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRSC3.10SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.7E4 100X 3.7E4	5.3E4 NORM & DRA	RAB5125 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR3.10SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51					SRSA3.10SH1				
COORDINATES X- 1645. Y- 1653. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
					SRSS3.10SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED *STATUS * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
	OPERABILITY	O 3.10SH1		REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.			CESR-1949		
	TEMPERATURE	T 3.10SH1					REVISION # : 00 DATE : 09/14/84		
	PRESSURE	P 3.10SH1					SYSTEM : CONTROL ROOM HVAC		
	REL. HUMIDTY	H 3.10SH1					TAG : CZ-D24SA-1		
	CHEM. SPRAY	C 3.10SH1							
	RADIATION	R 3.10SH1							
	AGING	A 3.10SH1							
	SUBMERGENCE	S 3.10SH1							
EQ. PCK # : 3.10SH1									
	OS88 CATEG.: A APPENDIX E								

EQUIP DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : CZ-D24SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAP SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION	ACCUR. SPEC: NOT APPLICABLE				SRSC 9.1/9.			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4	LATFP	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-25	A BETA							
P.O #: 435205	D B SHIELD	100%						
PLANT LOC.: AB51	S T.I.D.	3.7E4			SRSR 9.1/9.			
COORDINATES X- 1645. Y- 1653. Z- 305.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 FARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW						
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1/9.2						
*****	TEMPERATURE	T 9.1/9.2						
*QUALIF: LATER	PRESSURE	P 9.1/9.2						
*STATUS	REL. HUMIDTY	H 9.1/9.2						
*	CHEM. SPRAY	C 9.1/9.2						
*	RADIATION	R 9.1/9.2						
*****	AGING	A 9.1/9.2						
	SUBMERGENCE	S 9.1/9.2						
EQ. PCK # : 9.1/9.2	D588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2

CES#-1950

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM HVAC
 TAG : CZ-D24SB-1

A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL
 COMPONENT EVALUATION

NSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

V4- 0
 08-1955

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : CZ-D9SA-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA				SRS03.10SH1			
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM P DBA	TAP51A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	0.720	PAB51 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 8 DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: NH-91	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES. & SERVICE: DAMPER OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRS3.10SH1			
ACCUR. DEP.: NOT APPLICABLE	R GAMMA	3.7E4	5.0E6	RAB5125 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: RE-25	A BETA	100%	NORM & DBA					
P.O #: 435205	D B SHIELD	100%			SRSR3.10SH1			
PLANT LOC.: ABS1	S T.I.D.	3.7E4						
COORDINATES X- 1638. Y- 1672. Z- 314.C	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE
INSTAL. REF: BY-FLD					SRSS3.10SH1			

REPLACEMENT: REF(2)

MAINTAIN.: REF(2)

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1

CES-1955

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
 (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.

REVISION #: 00
 DATE: 09/14/84

EQ. PCK #: 3.10SH1

SYSTEM: CONTROL ROOM HVAC
 TAG: CZ-D9SA-1

D58B CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D9SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPER TYPE	NORM/TEST DBA				SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F 40RM 104F 0RA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS 0RA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100X 0RA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : EA-180	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X			SRSR 9.1/9.					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4								
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O # : 435205	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB51					SRSS 9.1/9.					
COORDINATES X- 1638. Y- 1672. Z- 314.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW	FOR PUNCHLIST ITEMS SEE SH ED PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2			
*****	OPERABILITY	O 9.1/9.2	REFERENCES:				CES#-1956			
*QUALIF; LATER	TEMPERATURE	T 9.1/9.2								
*STATUS	PRESSURE	P 9.1/9.2								
*	REL. HUMIDTY	H 9.1/9.2								
*	CHEM. SPRAY	C 9.1/9.2								
*****	RADIATION	R 9.1/9.2								
	AGING	A 9.1/9.2								
	SUBMERGENCE	S 9.1/9.2								
EQ. PCK # : 9.1/9.2	OS88 CATEG.: A APPENDIX E						REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D9SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : F-6 (1B-SB)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: AIR CLEANING UNITS	NORM/TEST DBA				SRSO					
COMPONENT: DOOR SWITCH (1 OF 2)	TEMPERATURE	104F	NORM 104F	LATER	TAB31A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS	NORM ATMOS	LATER	PAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: CTI-NUCLEAR	RELATIVE HUMIDITY	20-90%	NORM 100%	LATER	HAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-11302	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: REMOTE INDICATION OF DOOR POSITION	R GAMMA	2.6E4		LATER	RAB3111 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A RETA	4.4E5								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: RE-31	S T.I.D.	2.6E4								
P.O #: 435162	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1584. Y- 1766. Z- 261.0	PARAMETER		SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTALLED (Y/N): LTR	OPERABILITY	O		REFERENCES:				CES#-1981		
INSTAL. REF: BY-FLD	TEMPERATURE	T								
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P								
*QUALIF: LATER	REL. HUMDTY	H								
*STATUS	CHEM. SPRAY	C								
*	RADIATION	R								
*	AGING	A						REVISION # :00		
	SUBMERGENCE	S						DATE :		
EQ. PCK # :	0588 CATEG.: A							SYSTEM : REAC.AUX.BLDG HVAC		
	APPENDIX E							TAG : E-6 (1B-SB)		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : E-6 (18-SB)	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR CLEANING UNITS					SRS03.10SH1				
COMPONENT: ELECTRO-HYDR OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 2 DBA	TAB31A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT					SAST3.10SH1				
MAJOR SUPPLIER: CTI-NUCLEAR	PRESSURE	ATMOS NORM ATMOS DBA	9"±20	PAB31 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MODEL AND SERIAL #: NH-94	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 2 DBA	HAB31 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: OPERATE INLET VANES-REGULATE FAN VOLUME					SRS3.10SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. DEP.: NOT APPLICABLE					SRSC3.10SH1				
SPECIFICATIONS: BE-31	R GAMMA	2.6E4	5.7E6	RAB3111	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	M	NONE	
P.O #: 435162	A BETA	4.4E5	NORM & DBA	FSAR SEC 3.11B					
PLANT LOC.: AB31	D B SHIELD	100%			SRSR3.10SH1				
COORDINATES X- 1584. Y- 1766. Z- 261.0	S T.I.D.	2.6E4							
INSTALLED (Y/N): LTR	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTAL. REF: BY-FLD					SRSA3.10SH1				
QUALIF EXEMPTN: NOT APPLIC									
*QUALIF: QUALIFIED									
*STATUS									
*RADIATION AGING SUBMERGENCE									
EQ. PCK # : 3.10SH1									
	OS88 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.10SH1

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
 (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.91.132.

CESW-1983

REVISION # : 00
 DATE : 09/14/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : E-6 (18-SB)



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E-6 (1B-SB)	OPERABIL- ITY	40YRS NORM 1YR DBA	>4YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	AIR CLEANING UNITS									
COMPONENT:	MOTOR	TEMPERAT- URE	104F NORM 104F DBA	105F NORM 105F DBA	TAB31A FSAR SEC 3.11B	REF 1 P.21 SRST 4.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER:	RELIANCE ELECT CO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB31 FSAR SEC 3.11B	REF 1 P.21 SRSP 4.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MAJOR : SUPPLIER	CTI-NUCLEAR									SUBCOMPONENTS:
MODEL AND: SERIAL #	RH INSULATION	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HAB31 FSAR SEC 3.11B	REF 1 P.21 SRSH 4.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB31 FSAR SEC 3.11B	NA SRSC 4.2SH1	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF 1 P.14 & 21 SRSR 4.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-31									
P.O #:	435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	>47YPS	10 CFR50 PARA.50.51	REF 1 P.21 SRSA 4.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT. LOC.:	AB31									
COORDINATES X- Y- Z-	1584. 1766. 261.0	SURMERGED LEVEL	NOT APPLICABLE	NA	SAB31 FSAR SEC 3.11B	NA SRSS 4.2SH1	N/A	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EO PACKAGE: 4.2SH1
*****		OPERABILITY	O 4.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T 4.2SH1							
*STATUS	CONFIRMATORY DATA	PRESSURE	P 4.2SH1							
*		REL. HUMDTY	H 4.2SH1							CES#-1984
*		CHEM. SPRAY	C 4.2SH1							
*****		RADIATION	R 4.2SH1							REFERENCES: 1.RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1,1978,TOGETHER WITH SUPPLEMENTAL REPORT REV 2 DATED 7/15/81.
		AGING	A 4.2SH1							REVISION # :00 DATE :07/09/84
		SUBMERGENCE	S 4.2SH1							SYSTEM : REAC.AUX.BLDG HVAC TAG : E-6 (1B-SB)
EQ. PCK # :	4.2SH1									
		OS88 CATEG.:	A							
		APPENDIX	E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : EHC-24(1X-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: ELECTRIC HEATING COIL	NORM/TEST DBA				SRS010.1SH1			
COMPONENT: ELECTRIC HEATING COIL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BRASCH	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: MAINTAIN REL. HUMIDITY & TEM P.OF AIR	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	100%		SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-22	S T.I.D.	3.7E4						
P.O #: 435152	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATEP	10 CFR50 PAPA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1614. Y- 1680. Z- 305.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 10.1SH1						
*QUALIF: LATER	TEMPERATURE	T 10.1SH1						
*STATUS	PRESSURE	P 10.1SH1						
*	REL. HUMIDTY	H 10.1SH1						
*	CHEM. SPRAY	C 10.1SH1						
*****	RADIATION	R 10.1SH1						
	AGING	A 10.1SH1						
	SUBMERGENCE	S 10.1SH1						
EQ. PCK #: 10.1SH1	0588 CATEG.: A APPENDIX E							

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH E0 PACKAGE: 10.1SH1

REFERENCES:

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 10.1SH1

CES#-1997

REVISION #: 00
DATE :

SYSTEM : CONTROL ROOM
HVAC
TAG : EHC-24(1X-SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : EHC-26(1X-SB)	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: ELECTRIC HEATIN G COIL	NORM/TEST DBA				SRS010.1SH1				
COMPONENT: ELECTRIC HEATIN G COIL	TEMPERAT-URE	104F 104F	NORM DBA	LATER	TAB51A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER:BRASCH	PRESSURE	ATMOS ATMOS	NORM DBA	LATER	PAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR : BRASCH SUPPLIER	RELATIVE HUMIDITY	20-90% 100%	NORM DBA	LATER	HAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: MAINTAIN REL. HUMIDITY & TEM P.OF AIR	R GAMMA	3.7E4		LATER	RAB5125 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:BE-22,	S T.I.D.	3.7E4							
P.O #:435152	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1611. Y- 1662. Z- 305.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	10.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:10.1SH1
*QUALIF: LATER	TEMPERATURE	T	10.1SH1						CESN-1999
*STATUS	PRESSURE	P	10.1SH1						
*	REL. HUMDTY	H	10.1SH1						
*	CHEM. SPRAY	C	10.1SH1						
*****	RADIATION	R	10.1SH1						
	AGING	A	10.1SH1						
	SUBMERGENCE	S	10.1SH1						
EQ. PCK # : 10.1SH1	DS88 CATEG.:	A							REVISION # :00 DATE :
	APPENDIX E								SYSTEM :CONTROL ROOM. HVAC TAG :EHC-26(1X-SB)

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:10.1SH1

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : EHC-30(1B-SB)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: ELECTRIC HEATING COIL	NORM/TEST DBA				SRS010.1SH1			
COMPONENT: ELECTRIC HEATING COIL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BRASCH	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE : MAINTAIN-REL. HUMIDITY & TEM P.OF AIR	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5						
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100X						
SPECIFICATIONS: BE-22	S T.I.D.	2.6E4						
P.O N: 435152	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1582. Y- 1730. Z- 261.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR	OPERABILITY	O 10.1SH1						
INSTAL. REF: BY-FLO	TEMPERATURE	T 10.1SH1						
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 10.1SH1						
*****	REL. HUMPTY	H 10.1SH1						
*QUALIF: LATER	CHEM. SPRAY	C 10.1SH1						
*STATUS	RADIATION	R 10.1SH1						
*	AGING	A 10.1SH1						
*	SUBMERGENCE	S 10.1SH1						

EQ. PCK # : 10.1SH1	US88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTIONS: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1

CES#-2003

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : REAC. AUX. BLDG HVAC
 TAG : EHC-30(1B-SB)

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HART
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 2005

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : EHC-72(1A-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE : ELECTRIC HEATING COIL	NORM/TEST DBA				SRS01G.1SH1				
COMPONENT : ELECTRIC HEATING COIL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER : BRASCH	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : XS-78-C9579	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : MAINTAIN REL. HUMIDITY & TEM P.OF AIR	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X							
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4							
SPECIFICATIONS: BE-22	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O # : 435152	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1627. Y- 1692. Z- 305.0	OPERABILITY	O 10.1SH1							
INSTALLED (Y/N): LTR	TEMPERATURE	T 10.1SH1							
INSTAL. REF: BY-FLD	PRESSURE	P 10.1SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H 10.1SH1							
*****	CHEM. SPRAY	C 10.1SH1							
* QUALIF: LATER	RADIATION	R 10.1SH1							
* STATUS	AGING	A 10.1SH1							
*	SURMERGENCE	S 10.1SH1							
*									

EQ. PCK # : 10.1SH1	OSBR CATEG.: A								
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1

CES#-2005

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : EHC-72(1A-SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CP-EHC-72(1A-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: ELECTRIC HEATING COIL	NORM/TEST DBA				SRS01C.1SH1				
COMPONENT: HEATER CONTROL PANEL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: BRASCH	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: XS-78-09579	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: MAINTAIN REL. HUMIDITY & TEMP. OF ATR	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: BE-22	S T.I.D.	3.7E4							
P.O #: 435152	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1627. Y- 1692. Z- 305.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 10.1SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 10.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 10.1SH1							CESN-2006
*****	REL. HUMIDTY	H 10.1SH1							
*QUALIF: LATER	CHEM. SPRAY	C 10.1SH1							
*STATUS	RADIATION	R 10.1SH1							REFERENCES:
*	AGING	A 10.1SH1							
*	SUBMERGENCE	S 10.1SH1							

EQ. PCK #: 10.1SH1	OS8P CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM: CONTROL ROOM
									HVAC
									TAG : CP-EHC-72(1A-SA)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : EHC-72(1B-SB)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: ELECTRIC HEATING COIL	NORM/TEST DBA				SRS010.1SH1			
COMPONENT: ELECTRIC HEATING COIL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BRASCH	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : XS-78-09579	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE : MAINTAIN REL HUMIDITY & TEMP OF AIR	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X						
ACCUR. DEM.: NOT APPLICABLE	S T.I.O.	3.7E4						
SPECIFICATIONS: BE-22	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O # : 435152	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	PARAMETER	SUPPL. REVIEW						
COORDINATES X- 1631. Y- 1692. Z- 305.0	OPERABILITY	O 10.1SH1						
INSTALLED (Y/N): LTR	TEMPERATURE	T 10.1SH1						
INSTAL. REF: BY-FLD	PRESSURE	P 10.1SH1						
QUALIF EXEMPTN: NOT APPLIC	REL. HUMDTY	H 10.1SH1						
*****	CHEM. SPRAY	C 10.1SH1						
*QUALIF: LATER	RADIATION	R 10.1SH1						
*STATUS	AGING	A 10.1SH1						
*	SUBMERGENCE	S 10.1SH1						
*								

EQ. PCK # : 10.1SH1	Q588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1

CES#-2007

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : EHC-72(1B-SB)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : CP-EHC-72(1B-SB)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: ELECTRIC HEATING COIL	NORM/TEST DBA				SRS01G.1SH1			
COMPONENT: HEATER CONTROL PANEL	TEMPERATURE	104F NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BRASCH	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: XS-78-09579	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: MAINTAIN REL. HUMIDITY & TEMP. OF AIR	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: BE-22	S T.I.D.	3.7E4			SRSR1G.1SH1			
P.O #: 435152	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1631. Y- 1692. Z- 305.0					SRSS10.1SH1			
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF: BY-FLD	OPERABILITY	O 10.1SH1						
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 10.1SH1						
*****	PRESSURE	P 10.1SH1						
*QUALIF: LATER	REL. HUMIDTY	H 10.1SH1						
*STATUS	CHEM. SPRAY	C 10.1SH1						
*	RADIATION	R 10.1SH1						
*	AGING	A 10.1SH1						
*****	SUBMERGENCE	S 10.1SH1						
EQ. PCK # : 10.1SH1	0528 CATEG.: A	APPENDIX E						

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1

CES#-2008

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : CP-EHC-72(1B-SB)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : R-2 (1A-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: AIR CLEANING UNITS	NORM/TEST DBA				SRSO			
COMPONENT: DOOR SWITCH (1 OF 4)	TEMPERATURE	104F 409W 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO					SRST			
MAJOR SUPPLIER: CTI-NUCLEAR	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
					SRSP			
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: REMOTE INDICATION OF DOOR POSITION					SRSH			
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-31					SRSR			
P.O #: 435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51					SRSA			
COORDINATES X- 162G. Y- 1693. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSS			

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

INSTALLED (Y/N): LTR
 INSTAL. REF: BY-FLD
 QUALIF EXEMPTN: NOT APPLIC

 *OPERABILITY O
 *QUALIF: LATER
 *STATUS
 *
 *

PARAMETER SUPPL. REVIEW
 OPERABILITY O
 *TEMPERATURE T
 *PRESSURE P
 *REL. HUMIDTY H
 *CHEM. SPRAY C

 *RADIATION R
 *AGING A
 *SUBMERGENCE S

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

CES#-2060

REVISION # :00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : R-2 (1A-SA)

EQ. PCK # :

U588 CATEG.: A
 APPENDIX E



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEP. QUALIF.	ACTUAL	DEP. QUALIF.	METHOD		ITEMS		
TAG NO : R-2 (1A-SA)	OPERABIL- ITY	40YRS NORM 1YR DBA	>47YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	AIR CLEANING UN ITS				SRSO 4.2SH1					
COMPONENT:	MOTOR	TEMPERAT- URE	104F NORM 104F DBA	105F NORM 105F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21 SRST 4.2SH1	COMB. TEST & SUPPL. REVIEW	#	NONE	REPLACEMENT: SEE INSTR MANUAL MAINTAIN.:
MANUFACTURER:	RELIANCE ELEC. CO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB51 FSAR SEC 3.11B	REF 1 P.21 SRSP 4.2SH1	COMB. TEST & SUPPL. REVIEW	#	NONE	SEE INSTR MANUAL SUBCOMPONENTS:
MAJOR : SUPPLIER	CTI-NUCLEAR									
MODEL AND: SERIAL #	RH INSULATION	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 P.21 SRSH 4.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	DRIVE FAN	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA SRSC 4.2SH1	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A RETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	2.04E8 100X 2.04E8	RAB5125 FSAR SEC 3.11B	REF 1 P.14 & 21 SRSR 4.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-31									
P.O #:	435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 3.7E4	>47YPS 2.04E8	10 CFR50 PARA.50.51	REF 1 P.21 SRSA 4.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB51									
COORDINATES X- Y- Z-	1620. 1693. 305.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA SRSS 4.2SH1	N/A	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	RY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARA- METER	SUPL. REVIFW			FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
*****		OPERABILITY	O	4.2SH1						CES#-2061
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T	4.2SH1						
*STATUS	CONFIRMATORY DATA	PRESSURE	P	4.2SH1						
*		REL. HUMDTY	H	4.2SH1						
*		CHEM. SPRAY	C	4.2SH1						
*****		RADIATION	R	4.2SH1						
		AGING	A	4.2SH1						
		SUBMERGENCE	S	4.2SH1						
EQ. PCK # :	4.2SH1					REFERENCES:				1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT REV 2 DATED 7/15/81.
		OS88 CATEG.:	A							REVISION # :00 DATE :07/09/84
		APPENDIX E								SYSTEM : CONTROL ROOM HVAC TAG : R-2 (1A-SA)


A/E: EBAS SERVICES INC.
 UTILITY: CALINA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)


0
 2062

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : R-2 (1A-SA)	OPEPABIL- ITY NORM/TEST DBA	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	AIR CLEANING UN ITS				SRSO 3.10SH					
COMPONENT:	ELECTRO-HYDR OP ERATOR	TEMPERAT- URE	104F NORM 104F DBA	122F NORM 2 DBA	TAB51A FSAR SEC 3.11B	REF(1) ADD#2,P-2 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)	
MANUFACTURER:	ITT	PRESSURE	ATMOS NORM ATMOS DBA	9MM20	PAB51 FSAR SEC 3.11B	REF(1)P-2 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN: REF(2)	
MAJOR : SUPPLIER	CTI-NUCLEAR				SRSP 3.10SH				SUBCOMPONENTS:	
MODEL AND: SERIAL #	NH-94	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 2 DBA	HAB51 FSAR SEC 3.11B	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	OPERATE INLET VANES REGULATE FAN VOLUME	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A N/A	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE				SRSC 3.10SH					
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.7E4 100%	5.7E6 NORM NORM & DBA	RAB5125 FSAR SEC 3.11B	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	BE-31				SRSR 3.10SH					
P.O #:	435162	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)P-6 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.:	AB51				SRSA 3.10SH					
COORDINATES X- Y- Z-	1620. 1693. 305.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A N/A	/	NONE		
INSTALLED (Y/N):	LTR				SRSS 3.10SH					
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O 3.10SH1	REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095. (2)NH91 & NH95 ACTUATOR MAINT- ENANCE SCHEDULE #721.81.132				CES#-2062		
*QUALIF:	QUALIFIED	TEMPERATURE	T 3.10SH1							
*STATUS		PRESSURE	P 3.10SH1							
*		REL. HUMDTY	H 3.10SH1							
*		CHEM. SPRAY	C 3.10SH1							
*****		RADIATION	R 3.10SH1							
		AGING	A 3.10SH1							
		SURMERGENCE	S 3.10SH1	REVISION # :00 DATE :09/26/84						
EQ. PCK # :	3.10SH1	0588 CATEG.:	A					SYSTEM :CONTROL ROOM HVAC		
		APPENDIX E						TAG :R-2 (1A-SA)		




EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : R-2 (1B-SB)	OPERABIL- ITY	LATER.	LATER	OPER. REVIEW	LATER	COMB.	/	NONE		
EQUIPMENT: TYPE	AIR CLEANING UN ITS				SRSO	TEST & SUPPL. REVIEW				
COMPONENT:	DOOR SWITCH (1 OF 4)	TEMPERAT- URE	104F NORM 104F DRA	LATER	TAB51A FSAR SEC 3.11B	LATER		M	NONE	REPLACEMENT:
MANUFACTURER:	NANCO				SIRST	COMB. TEST & SUPPL. REVIEW				MAINTAIN.:
MAJOR : SUPPLIER	CTI-NUCLEAR	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB51 FSAR SEC 3.11B	LATER		P	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90%NORM 100% DRA	LATER	HAB51 FSAR SEC 3.11B	LATER		/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DOOR PO SITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER		/	NONE	
ACCUR. SPEC:	NOT APPLICABLE				SRSC	COMB. TEST & SUPPL. REVIEW				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER		H	NONE	
SPECIFICATIONS:	BE-31	D B SHIELD	100X			SRSR				
P.O #:	435162	S T.I.D.	3.7E4							
PLANT LOC.:	AB51	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER		/	NONE	SAFETY FUNCTIONS: SS
COORDINATES X- Y- Z-	1634. 1693. 305.0	INST LIFE (PER 323- 1974 DEF.)				SRSA				
COORDINATES X- Y- Z-	1634. 1693. 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER		/	NONE	
INSTALLED (Y/M):	LTR					SRSS				
INSTAL. REF:BY-FLD		PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O					CES#-2063		
*****		TEMPERATURE	T							
*QUALIF:	LATER	PRESSURE	P							
*STATUS		REL. HUMIDTY	H							
*		CHEM. SPRAY	C							
*		RADIATION	R							
*****		AGING	A							
		SUBMERGENCE	S							
EQ. PCK # :				REFERENCES:				REVISION # :00 DATE :		
								SYSTEM : CONTROL ROOM HVAC		
								TAG : R-2 (1B-SB)		

0588 CATEG.: A
 APPENDIX E



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : R-2 (1B-SP)	OPERABIL-ITY	4CYRS NORM 1YR DBA	>4YRS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: AIR CLEANING UNITS	NORM/TEST DBA				SRSO 4.2SH1				
COMPONENT: MOTOR	TEMPERAT-URE	104F NORM 104F DBA	105F NORM 105F DBA	TAB51A FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER: RELIANCE ELECTRIC CO.	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE INSTR MANUAL
MAJOR SUPPLIER: CTI-NUCLEAR	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: RH INSULATION	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
FUNCT. DES. & SERVICE: DRIVE FAN	R GAMMA	3.7E4	2.34E8	RAB5125 FSAR SEC 3.11B	REF 1 P.14 & 21	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%							
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4	2.74E8		SRSR 4.2SH1				
SPECIFICATIONS: BE-31	AGF-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>4YRS	10 CFR50 PARA. 50.51	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435162	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
PLANT LOC.: AB51	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1634. Y- 1693. Z- 305.0	OPERABILITY	O	4.2SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1	
INSTALLED (Y/N): LTR	TEMPERATURE	T	4.2SH1	REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT REV 2 DATED 7/15/81.				CES#-2064	
INSTAL. REF: BY-FLD	PRESSURE	P	4.2SH1						
QUALIF EXEMPTN: NOT APPLIC	REL. HUMPTY	H	4.2SH1						
*****	CHEM. SPRAY	C	4.2SH1						
*****	RADIATION	R	4.2SH1						
*****	AGING	A	4.2SH1					REVISION # : 00	
*****	SUBMERGENCE	S	4.2SH1					DATE : 07/09/84	
EQ. PCK # : 4.2SH1	D588 CATEG.: A							SYSTEM : CONTROL ROOM HVAC	
	APPENDIX E							TAG : R-2 (1B-SP)	



CLASS IE COMPONENT EVALUATION SHEETS

ADDENDUM 1

Volume 2



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS					
TAG NO : P1X-SAB AUX FW TD	OPERABIL-ITY	4GYRS NORM PLUS 1YR DBA	40YRS NORM PLUS 1YR DBA	OPER. REVIEW	REF(1)&(2)	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: TURBINES TYPE	TEMPERAT-URE	104F NORM DBA	104F NORM DBA	TAB21A FSAR SEC 3.11B	REF(1) PG. D11	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)				
COMPONENT: AUX. FEED PUMP TURBIN	PRESSURE	ATMOS NORM DBA	ATMOS NORM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG. D11	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)				
MANUFACTURER:TERRY CORP	RELATIVE HUMIDITY	20-90% NORM DBA	10% DBA	HAB21 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MAJOR : INGERSOLL-RAND SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE					
MODEL AND: GS-2H SERIAL #	R GAMMA	2.6E4	1.1E5	RAB21R7 FSAR SEC 3.11B	REF(2)	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT.DES: DRIVER OF TURBINE OPER AUX FEED PUMP	D B SHIELD	100%		SRSR74.1SH1									
ACCUR. SPEC: NA	S T.I.D.	2.6E4		SRSA74.1SH1									
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(2)	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: CRHR				
SPECIFICATIONS:M-05	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE					
P.O #:435043	PARA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:74.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:74.1SH1			
PLANT LOC.: AB21	OPERABILITY	O 74.1SH1		REFERENCES: (1)TERRY EQUIP QUAL DOC MANUAL E/L NO.20713 DATED 6/1/84. (2)LETTER SH-MNE-10U12 DATED 8/2/84.						CESN-2114			
COORDINATES X- 1520. Y- 1529. Z- 236.0	TEMPERATURE	T 74.1SH1											REVISION # :00 DATE :07/27/84
INSTALLED (Y/N): LTR	PRESSURE	P 74.1SH1											SYSTEM :AUXILIARY FEEDWTR TAG :P1X-SAB AUX FW
INSTAL. REF:BY-FLD	REL. HUMIDTY	H 74.1SH1											
QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C 74.1SH1											
*****	RADIATION	R 74.1SH1											
*QUALIF: QUALIFIED-AWAITING	AGING	A 74.1SH1											
*STATUS CONFIRMATORY DATA	SUBMERGENCE	S 74.1SH1											
*****	OS88 CATEG.:	A											
EQ. PCK # : 74.1SH1	APPENDIX	E											



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : 2CB-B1SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 9.1/9.							
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:			
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:			
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:			
MODEL AND SERIAL #: EA-180-31302	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES. & SERVICE: REMOTE INDICATION OF VALVE POSITION	ACCUR. SPEC: NOT APPLICABLE				SRSP 9.1/9.							
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB4117	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE				
SPECIFICATIONS: BE-35	A BETA	7.2E4		FSAR SEC 3.11B								
P.O #: 435211	D B SHIELD	100%			SRSR 9.1/9.							
PLANT LOC.: AB41	S T.I.D.	2.6E4							SAFETY FUNCTION: PRRM			
COORDINATES X- 1462. Y- 1634. Z- 295.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
***** *QUALIF: LATER *STATUS * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
	OPERABILITY O	9.1/9.2		REFERENCES:						CES#-2115		
	TEMPERATURE T	9.1/9.2										
	PRESSURE P	9.1/9.2										
	REL. HUMDTY H	9.1/9.2										
	CHEM. SPRAY C	9.1/9.2										
	RADIATION R	9.1/9.2										
	AGING A	9.1/9.2							REVISION # : 00			
	SUBMERGENCE S	9.1/9.2							DATE :			
EQ. PCK # : 9.1/9.2	0588 CATEG.: A APPENDIX E								SYSTEM : CONT.VACUUM RELIEF TAG : 2CB-B1SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CB-B1SA-1	OPERABILITY	40YRS NORM 1YR DBA	NORM:40YRS 1570 CYC	OPER. REVIEW	REF(1) P.3 & 4	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	500 CYC TOTAL	1YR 122 CYC		SRS042.1SH1	REVIEW			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	123F NORM FOR DBA	TAB41A FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEAL & LUB EVERY 5YRS MAINTAIN.: SEE INSTR MANUAL
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM FOR DBA	PAB41 FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1	COMB. TEST & SUPPL.	M	NONE	SEE INSTR MANUAL SUBCOMPONENTS:
MAJOR SUPPLIER: BIF			REFER FIG E2-42.1SH1		SRSP42.1SH1	REVIEW			
MODEL AND SERIAL #: NT-316B-SR2-12	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1)P.3 NORM&DBA VOLV, PII-1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	CHEMICAL SPRAY	NOT APPLICABLE	4270 PPM BORON	CAB41 FSAR SEC 3.11B	REF(1)VOL V, P. II-1	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.1SH1				
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	1.4E8	RAB4117 FSAR SEC 3.11B	REF(1)VOL V, P. IV-4	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-35					SRSR42.1SH1	REVIEW			
P.O #: 435211	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR53 PARA.50.51	REF(1) VOL 1, P.3	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: PRPM
PLANT LOC.: AB41					SRSA42.1SH1	REVIEW			
COORDINATES X- 1462. Y- 1634. Z- 295.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPT: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.1SH1
EQ. PCK #: 42.1SH1	OS88 CATEG.: A APPENDIX E				REFERENCES: G H BETTIS NUCLEAR QUALIFICATION TEST REPORT #37274, REV 8, DATED 08/17/84.				CESN-2116 REVISION #: 00 DATE: 10/02/84 SYSTEM: CONT. VACUUM RELIEF TAG: 2CB-B1SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	NORM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CB-815A-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 40000CYC	OPER. REVIEW	NORM: REF 1 P.4-1, DBA: P.4-21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	TOTAL 500 CYC	DBA: 30DAYS 120CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: FIG EIR-3.2SH1	TAB41A FSAR SEC 3.11B	NORM: REF 1 P.4-1, DBA: P.4-21 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P.I-2, I-8 MAINTAIN.: REF 1, P.I-8
MANUFACTURER: ASCO	PRESSURE	ATMOS. NORM ATMOS. DBA	NORM: 1 ATM DBA: SEE FIS EIR- 3.2SH1	PAB41 FSAR SEC 3.11B	REF 1 P.4-21 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40X DBA: 100X	HAB41 FSAR SEC 3.11B	NORM: REF 1 P.8-1, DBA: REF1, P.8-2 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES: 1. ALL SRS ARE IN TAB E2
MODEL AND SERIAL #: NP831665E	FUNCT. DES. & SERVICE	CONTROL AIR PRESSURE FOR PNEUMATIC OPERATOR CYLINDER							
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB41 FSAR SEC 3.11B	REF 1 P.4-4 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 7.2E4 100X 2.6E4	2.7E3 2.7E3	RAB4117 FSAR SEC 3.11B	REF 1 P.4-3 & 4-4 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: 8E-35	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1 P.9-4 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #: 435211	PLANT LOC.: AB41								
COORDINATES X- 1462. Y- 1634. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOP PUNCHLIST ITEMS SEE SHEET PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	3.2SH1	REFERENCES: 1. ASCO TEST REPORT# AOS-21678/ TR, REV A, JULY 1979			CES#-2117			
*STATUS CONFIRMATORY DATA	TEMPERATURE T	3.2SH1							
*	PRESSURE P	3.2SH1							
*	REL. HUMDTY H	3.2SH1							
*	CHEM. SPRAY C	3.2SH1							
*	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	OSBR CATEG.: A APPENDIX E					REVISION # : 00 DATE : 09/04/84 SYSTEM : CONT. VACUUM RELIEF TAG : 2CB-815A-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : PS 1CB 7682A SA	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE BUTTERFLY VALVE	NORM/TEST DBA				SRSO				
COMPONENT: PRESS. ELECT. S WITCH	TEMPERAT- URE	104F 104F	NORM DRA	LATER	TAB41A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LATER					SRST				
MAJOR : BIF SUPPLIER	PRESSURE	ATMOS ATMOS	NORM DRA	LATER	PAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MODEL AND: SERIAL # LATER	RELATIVE HUMIDITY	20-90% 100%	NORM DRA	LATER	HAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE LOW PRESSURE S IGNAL FOR ACCU MULATR TANK TK	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4		LATER	RAB4117 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35					SRSR				
P.O #: 435211	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.: AB41					SRSA				
COORDINATES X- 1462. Y- 1634. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB41 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTH: NOT APPLIC	PARA- METER								
*QUALIF: LATER *STATUS * * *****	SUPPL. REVIEW								
EQ. PCK # :	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CES#-2118	
	REFERENCES:							REVISION # : 00 DATE :	
	0588 CATEG.: A APPENDIX E							SYSTEM : CONT. VACUUM RELIEF TAG : PS 1CB 7682A SA	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CB-82SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA180-31302	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF VALVE POSITION IO N					SRSR 9.1/9.				
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB4117 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4							
SPECIFICATIONS: BE-35	D B SHIELD	100%							
P.O #: 435211	S T.I.D.	2.6E4			SRSR 9.1/9.				
PLANT LOC.: AB41	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRM
COORDINATES X- 1575. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1/9.2							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
*****	TEMPERATURE	T 9.1/9.2							
*QUALIF: LATER	PRESSURE	P 9.1/9.2							
*STATUS	REL. HUMPTY	H 9.1/9.2							CES#-2119
*	CHEM. SPRAY	C 9.1/9.2							
*	RADIATION	R 9.1/9.2							
*****	AGING	A 9.1/9.2							REFERENCES:
	SUBMERGENCE	S 9.1/9.2							
EQ. PCK #: 9.1/9.2									
	0588 CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM : CONT. VACUUM RELIEF
									TAG : 2CB-82SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CB-B2SB-1	OPERABIL-ITY	40YRS NORM 1YR DBA	NORM:40YRS 5000 CYC	OPER. REVIEW	REF(1) P.3 & 4	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	500 CYC TOTAL	DBA: 1YR 22 CYC		SRSO42.1SH1	REVIEW			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA REFER FIG E1-42.1SH1	TAB41A FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1 SRST42.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEAL & LUB EVERY SYRS MAINTAIN.:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM FOR DBA REFER FIG E2-42.1SH1	PAB41 FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1 SRSP42.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SEE INSTR MANUAL SUBCOMPONENTS:
MAJOR : BIF SUPPLIER									
MODEL AND: NT-316B-SR2-12 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1)P.3 NORM DBA VOLV,PII-1 SRSH42.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: ACTUATE VALVE & SERVICE AND CONTROL POSITION	CHEMICAL SPRAY	NOT APPLICABLE	6200 PPM BORON PH11	CAB41 FSAR SEC 3.11B	REF(1)VOL V,P.II-1 SRSC42.1SH1	N/A REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	1.4ER 1.4ER	PAB4117 FSAR SEC 3.11B	REF(1)VOL V,P.IV-4 SRSR42.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35									
P.O #: 435211	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)VOL 1,P.3 SRSA42.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.: AB41									
COORDINATES X- 1575. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS42.1SH1	N/A REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1 42.1SH1		REFERENCES:	G H BETTIS NUCLEAR QUALIFI- CATION TEST REPORT #37274, REV 8, DATED 8/17/84.		CES#-2120	
EQ. PCK # : 42.1SH1								REVISION # : 00 DATE : 10/02/84	
	0588 CATEG.: A APPENDIX E							SYSTEM : CONT. VACUUM RELIEF TAG : 2CB-B2SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEP. QUALIF.				
TAG NO : ZCB-B2SB-1	OPERABIL- ITY	NORM:40YRS DBA:1YR	NORM:40YRS 4000CYC	OPER. REVIEW	NORM:REF 1 P.4-1,DBA: P.4-21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	TOTAL 500 CYC	DBA:30DAYS 12CYC						
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	NORM:120F DBA:FIG F19-3.2SH1	TAB41A FSAR SEC 3.11B	NORM:REF 1 P.4-1,DBA: P.4-21	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,P.1-2, I-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM:1 ATM DBA:SEE FIG F2B- 3.2SH1	PAB41 FSAR SEC 3.11B	REF 1 P.4-21	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,P.I-8
MAJOR : BIF SUPPLIER									SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	NORM:40% DBA:100%	HAB41 FSAR SEC 3.11B	NORM:REF 1 P.8-1,DBA: REF1,P.8-2	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES: 1. ALL SRS ARE IN TAB E2
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	CONTROL AIR PR ESSURE PNEUMAT IC OPER	NOT APPLICABLE	3070 PPM ROXON PH9.5-10.5	CAB41 FSAR SEC 3.11B	REF 1 P.4-4	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.7E8	RAB4117 FSAR SEC 3.11B	REF 1 P.4-3 & 4-4	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YFARS	1D CFR50 PARA.50.51	REF 1 P.9-4	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #: 435211									
PLANT LOC.: AB41									
COORDINATES X- 1575. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*****	OPERABILITY O	3.2SH1				CES4-2121			
*QUALIF: QUALIFIED-AWAITING	*TEMPERATURE T	3.2SH1							
*STATUS CONFIRMATORY DATA	*PRESSURE P	3.2SH1							
*	*REL. HUMDTY H	3.2SH1							
*	*CHEM. SPRAY C	3.2SH1							
*****	*RADIATION R	3.2SH1				REFERENCES: 1.ASCO TEST REPORT# AQS-21678/ TR,REV A, JULY 1979			
	*AGING A	3.2SH1							
	*SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	DSBR CATEG.: A APPENDIX E					REVISION # : 00 DATE : 09/04/84 SYSTEM : CONT.VACUUM RELIEF TAG : ZCB-B2SB-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : PS 2CB 7682B SB	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO					
COMPONENT: PRESS. ELEC. SW ITCH	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LATER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSR					
LOW PRESSURE S IGNAL FOR ACCU MULATR TANK	ACCUR. DEM.: NOT APPLICABLE									
	R GAMMA	2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA	7.2E4								
	D B SHIELD	100%								
	S T.I.D.	2.6E4			SRSR					
SPECIFICATIONS: BE-35	AGE-	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
P.O N: 435211	INST LIFE (PER 323- 1974 DEF.)				SRSA					
PLANT LOC.: AB41	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1575. Y- 1626. Z- 295.C					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O		REFERENCES:				CESN-2122		
*QUALIF: LATER	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :	OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : CONT. VACUUM RELIEF TAG : PS 2C9 7682B SB	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CP-B2SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F 104F	NORM DBA	LATER	TAB21A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS	NORM DBA	LATER	PAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% 100%	NORM DBA	LATER	HAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: EA-180-31302	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF VALVE POSITION IO N	R GAMMA	3.0E4		LATER	RAB21R6 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEF.: NOT APPLICABLE	D-B SHIELD	100%							
SPECIFICATIONS: BE-35	S T.I.P.	3.0E4							
P.O #: 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 FARA-50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1430. Y- 1665. Z- 255.0	PARA-METER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O	9.1/9.2						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2
INSTAL. REF: BY-FLD	TEMPERATURE	T	9.1/9.2						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P	9.1/9.2						CES#-2133
*****	REL. HUMIDTY	H	9.1/9.2						
*QUALIF: LATER	CHEM. SPRAY	C	9.1/9.2						
*STATUS	RADIATION	R	9.1/9.2						
*	AGING	A	9.1/9.2						
*	SUBMERGENCE	S	9.1/9.2						

EQ. PCK #: 9.1/9.2	OS98 CATEG.: A								REFERENCES:
	APPENDIX E								
									REVISION #: 00
									DATE:
									SYSTEM: CONT. ATMOSPHERE
									PRG/MKUP
									TAG: 2CP-B2SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2CP-R2SB-1	OPERABILITY	40YRS NORM 1YR DBA	NORM: 40YRS 5000 CYC DBA: 1YR	OPER. REVIEW	REF(1) P.3 & 4	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	500 CYC TOTAL	22 CYC		SRSO42.1SH1	REVIEW		
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM FOR DBA REFER FIG E1-42.1SH1	TAB21A FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1 SRST42.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM FOR DBA REFER FIG E2-42.1SH1	PAR21 FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1 SRSP42.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1)P.3 NORM&DBA VOLV,PII-1 SRSH42.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : N721C-SR60-12	CHEMICAL SPRAY	NOT APPLICABLE	6200 PPM 90RON	CAB21 FSAR SEC 3.11B	REF(1)VOL V, P.II-1 SRSC42.1SH1	N/A	/	NONE
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	ACCUR. SPEC: NOT APPLICABLE							
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	11.4EP 11.4EP	RAB21R6 FSAR SEC 3.11B	REF(1)VOL V,P.IV-4 SRSR42.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40YPS		10 CFR50 PARA.50.51	REF(1) VOL 1,P.3 SRSA42.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435211	PLANT LOC.: AB21							
COORDINATES X- 1430. Y- 1665. Z- 255.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS42.1SH1	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 42.1SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 42.1SH1						
*STATUS CONFIRMATORY DATA	PRESSURE	P 42.1SH1						
*	REL. HUMIDTY	H 42.1SH1						
*	CHEM. SPRAY	C 42.1SH1						
*****	RADIATION	R 42.1SH1						
	AGING	A 42.1SH1						
	SUBMERGENCE	S 42.1SH1						
EQ. PCK # : 42.1SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
SEAL & LUB
EVERY 5YRS
MAINTAIN.:
SEE INSTR
MANUAL
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
CI

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 42.1SH1

REFERENCES: G H BETTIS NUCLEAR QUALIFI-
CATION TEST REPORT #37274,
REV 8, DATED 08/17/84.

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 42.1SH1

CES#-2134

REVISION # : 00
DATE : 10/02/84

SYSTEM : CONT. ATMOSPHERE
PRG/MKUP
TAG : 2CP-92SB-1



A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HARBOR NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 906 MW(E)

0
 -2135

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2CP-82SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 40000CYC DBA: 30DAYS	OPER. REVIEW	NORM: REF 1 P.4-1, DBA: P.4-21	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: BUTTERFLY VALVE	NORM/TEST DBA	TOTAL 500 CYC	120CYC					
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F 40YR 104F DBA	NORM: 120F DBA: FIG E19-3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.4-1, DBA: P.4-21 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: KSCO	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIG E2B- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1 P.4-21 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40X DBA: 100X	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.8-1, DBA: REF1, P.9-2 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: HP8321A6E	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 9.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.4-4 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: CONTRL AIR PRESSURE IN PNEUMATIC OPERATOR CYLINDER	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.0ER 2.0ER	RAB21R6 FSAR SEC 3.11B	REF 1 P.4-3 & 4-4 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1 P.9-4 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: BE-35	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
P.O #: 435211	OPERABILITY	O 3.2SH1				CES#-2135		
PLANT LOC.: AB21	TEMPERATURE	T 3.2SH1						
COORDINATES X- 1430. Y- 1665. Z- 255.0	PRESSURE	P 3.2SH1						
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 3.2SH1						
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 3.2SH1						
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 3.2SH1						
*****	AGING	A 3.2SH1						
*****	SUBMERGENCE	S 3.2SH1						
*****	0588 CATEG.: A							
*****	APPENDIX E							
EQ. PCK # : 3.2SH1				REFERENCES: 1. ASCO TEST REPORT# AOS-21678/ TR, REV A, JULY 1979		REVISION # : 00 DATE : 09/04/84		
						SYSTEM : CONT. ATMOSPHERE PRG/MKUP TAG : 2CP-82SB-1		

REPLACEMENT:
REF 1, P.I-2,
I-8
MAINTAIN.:
REF 1, P.I-8
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTES:
ALL SRS ARE IN
TAB E2
SAFETY FUNCTION:
CI

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CP-945B- 1	OPERABIL- ITY	LATER	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATEP	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : BIF SUPPLIER					SRSP 9.1/9.				
MODEL AND: EA-180-31302 SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT.DES: REMOTE INDICAT & SERVICE ION OF VALVE PO SITION IO M	CHEMICAL SPRAY	NOT APPLICABLE	LATEP	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1/9.				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	LATEP	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35					SRSR 9.1/9.				
P.O #: 435211	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21					SRSA 9.1/9.			SAFETY FUNCTION: CI	
COORDINATES X- 1429. Y- 1664. Z- 255.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2		REFERENCES:					CES#-2139
EQ. PCK # : 9.1/9.2	U588 CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : CONT. ATMOSPHERE PRG/MKUP TAG : 2CP-945B- 1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CP-B4SB-1	OPERABILITY	40YRS NORM 1YR DBA	NORM: 40YRS CND CYC DBA: 1YR	OPER. REVIEW	REF(1) P.3 & 4	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA	500 CYC TOTAL	DBA: 1YR 22 CYC		SRS042.1SH1	REVIEW			
COMPONENT: PNEUMATIC OPERATOR	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA REFERR FIG E1-42.1SH1	TAB21A FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEAL & LUB EVERY 5YRS MAINTAIN.:
MANUFACTURER: BETTIS	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM FOR DBA REFERR FIG E2-47.1SH1	PAB21 FSAR SEC 3.11B	REF(1)VOL V P.V1-2 FIG V1-1	COMB. TEST & SUPPL.	M	NONE	SEE INSTR MANUAL
MAJOR SUPPLIER: BIF					SRSP42.1SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: NT820-SR-4-12-5	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1)P.3 NORM&DBA VOLV,PII-1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	CHEMICAL SPRAY	NOT APPLICABLE	4200 PPM 90RON	CAB21 FSAR SEC 3.11B	REF(1)VOL V, P.II-1	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC42.1SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	1.4E8 1.4E8	RAB21R6 FSAR SEC 3.11B	REF(1)VOL V,P.IV-4	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-35					SRSR42.1SH1	REVIEW			
P.O #: 435211	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) VOL 1,P.3	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA42.1SH1	REVIEW			
COORDINATES X- 1429. Y- 1664. Z- 255.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 42.1SH1
*****	OPERABILITY	O 42.1SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 42.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 42.1SH1							CES#-2140
*	REL. HUMDTY	H 42.1SH1							
*	CHEM. SPRAY	C 42.1SH1							
*****	RADIATION	R 42.1SH1							
	AGING	A 42.1SH1							
	SUBMERGENCE	S 42.1SH1							
EQ. PCK #: 42.1SH1	US88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 10/02/84
									SYSTEM: CONT. ATMOSPHERE PRG/MKUP TAG: 2CP-B4SB-1

REFERENCES: G H BETTIS NUCLEAR QUALIFICATION TEST REPORT #37274, REV 8, DATED 08/17/84.

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 42.1SH1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : 2CP-B4SB-1	OPERABILITY	NORM: 40YRS DBA: 1YR	NORM: 40YRS 4000PCYC DBA: 30DAYS 12CYC	OPER. REVIEW	NORM: REF 1 P.4-1, DBA: P.4-21 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: BUTTERFLY VALVE TYPE	TEMPERATURE	104F NORM 104F DBA	NORM: 120F DBA: FIG EIR-3.2SH1	TAB21A FSAR SEC 3.11B	NORM: REF 1 P.4-1, DBA: P.4-21 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, P. I-2, I-8 MAINTAIN.: REF 1, P. I-8			
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	NORM: 1 ATM DBA: SEE FIS E2B- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1 P.4-21 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:			
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	NORM: 40% DBA: 100%	HAB21 FSAR SEC 3.11B	NORM: REF 1 P.8-1, DBA: REF1, P.8-2 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTES: ALL SRS ARE IN TAB E2			
MAJOR SUPPLIER : BIF	CHEMICAL SPRAY	NOT APPLICABLE	3000 PPM BORON PH 7.5-10.5	CAB21 FSAR SEC 3.11B	REF 1 P.4-4 SRSC 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE				
MODEL AND: NP831665E	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.0E2 2.0E2	RAB21R6 FSAR SEC 3.11B	REF 1 P.4-3 & 4-4 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE				
FUNCT. DES: CONTROL AIR PRESS FOR PNEUMATIC OPERATOR CYLINDER	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1 P.9-4 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI			
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE				
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1						
SPECIFICATIONS: 8E-35	OPERABILITY	O	3.2SH1					CES#-2141				
P.O #: 435211	TEMPERATURE	T	3.2SH1									
PLANT LOC.: AB21	PRESSURE	P	3.2SH1									
COORDINATES X- 1429.0	REL. HUMDTY	H	3.2SH1									
Y- 1664.0	CHEM. SPRAY	C	3.2SH1									
Z- 255.0	RADIATION	R	3.2SH1									
INSTALLED (Y/N): LTR	AGING	A	3.2SH1									
INSTAL. REF: BY-FLD	SUPMERGENCE	S	3.2SH1									
QUALIF EXEPTN: NOT APPLIC	OSRR CATEG.: A				REFERENCES: 1. ASCO TEST REPORT# AQS-21678/ TR, REV A, JULY 1979				REVISION # : 00 DATE : 09/04/84			
*****	APPENDIX E								SYSTEM : CONT. ATMOSPHERE PRG/MKUP TAG : 2CP-B4SB-1			

A/E: EBASCO SERVICES INC.
 UTILITY: IONA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1.
 COMPONENT EVALUATION S

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 2155

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3AC-B1SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NOMP ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	10-100% (DBA) TABLE 3.11.0-1+	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMB-0-25 W/H30C	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	R GAMMA	2.6E4	LATER	RAB5122	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4		FSAR SEC 3.11B				
ACCUR. DEM.: NOT APPLICABLE	D 9 SHIELD	100%			SRSR 3.3SH1			
SPECIFICATIONS: BE-35	S T.I.D.	2.6E4						
P.O #: 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1464. Y- 1581. Z- 307.C	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.3SH1						
*QUALIF: LATER	TEMPERATURE T	3.3SH1						
*STATUS	PRESSURE P	3.3SH1						
*	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
	AGING A	3.3SH1						
	SURMERGENCE S	3.3SH1						
EQ. PCK # : 3.3SH1	US88 CATEG.: A APPENDIX E							

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.3SH1

CES#-2155

REVISION # : 00
 DATE :

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : 3AC-B1SA-1

REPLACEMENT:
 MAINTAIN:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS



A/E: EDWARDS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

#- 0
 24-2159

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3AC-B3SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: LIMITORQUE					SRST 3.3SH1			
MAJOR : BIF SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MODEL AND: SMB-D-25 SERIAL # W/H3BC	RELATIVE HUMIDITY	10-100% (DBA) TABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: ACTUATE VALVE & SERVICE AND CONTROL POSITION		3.11.0-1*			SRSR 3.3SH1			
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB5122 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: BE-35	A BETA	7.2E4						
P.O #: 435211	D B SHIELD	100%						
PLANT LOC.: ABS1	S T.I.D.	2.6E4				SRSR 3.3SH1		
COORDINATES X- 1536. Y- 1581. Z- 307.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTAL. REF: BY-FLD								
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	3.3SH1						
*QUALIF: LATER	TEMPERATURE T	3.3SH1						
*STATUS	PRESSURE P	3.3SH1						
*	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK # : 3.3SH1	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-2159

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : REAC. AUX. BLDG HVAC
 TAG : 3AC-B3SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3AV-B4SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SFC-04-5 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: ACTUATE VALVE & SERVICE AND CONTROL POSITION	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
MODEL AND: BE-35 SERIAL #	S T.I.O.	2.6E4						
FUNCTIONS: BE-35	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB31	COORDINATES X- 1585. Y- 1724. Z- 261.0							
COORDINATES X- 1585. Y- 1724. Z- 261.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	OPERABILITY	O 3.3SH1						
*****	TEMPERATURE	T 3.3SH1						
*QUALIF: LATER	PRESSURE	P 3.3SH1						
*STATUS	REL. HUMIDTY	H 3.3SH1						
*	CHEM. SPRAY	C 3.3SH1						
*	RADIATION	R 3.3SH1						
*****	AGING	A 3.3SH1						
	SUBMERGENCE	S 3.3SH1						
EQ. PCK # : 3.3SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTIONS:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.3SH1

CES#-2168

REFERENCES:

REVISION # : 00
DATE :

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : 3AV-B4SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3AV-85SR-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1					
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:	
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : SMC-04-5	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: BE-35	S T.I.D.	2.6E4								
P.O # : 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1584. Y- 1759. Z- 261.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
*****	OPERABILITY O	3.3SH1		REFERENCES:				CES#-217C		
*QUALIF: LATER	TEMPERATURE T	3.3SH1								
*STATUS	PRESSURE P	3.3SH1								
*	REL. HUMDTY H	3.3SH1								
*	CHEM. SPRAY C	3.3SH1								
*****	RADIATION R	3.3SH1								
	AGING A	3.3SH1								
	SUBMERGENCE S	3.3SH1								
EQ. PCK # : 3.3SH1	OSER CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : REAC.AUX.BLOG HVAC TAG : 3AV-85SR-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-91SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TABS1A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PABS1 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MAJOR SUPPLIER: RIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HABS1 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SPB-00-10	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CABS1 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RABS125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1			
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4						
SPECIFICATIONS: BE-35	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435211	INST LIFE (PER 323-1974 DEF.)				SRSA 3.3SH1			
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SABS1 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1595. Y- 1675. Z- 305.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR	OPERABILITY O	3.3SH1						
INSTAL. REF: BY-FLD	TEMPERATURE T	3.3SH1						
QUALIF EXEMPTN: NOT APPLIC	PRESSURE P	3.3SH1						
*****	REL. HUMDTY H	3.3SH1						
*QUALIF: LATER	CHEM. SPRAY C	3.3SH1						
*STATUS	RADIATION R	3.3SH1						
*	AGING A	3.3SH1						
*	SUBMERGENCE S	3.3SH1						

EQ. PCK # : 3.3SH1	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION. PACKAGE: 3.3SH1

CES#-2177

REVISION # : 00
DATE :

SYSTEM : CONTROL ROOM
HVAC
TAG : 3CZ-B1SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CZ-B17SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4							
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1600.0 Y- 1684.0 Z- 305.0	OPERABILITY	O 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
INSTALLED (Y/N): LTP	TEMPERATURE	T 3.3SH1							CES#-2189
INSTAL. REF: RY-FLD	PRESSURE	P 3.3SH1							
QUALIF EXEMPTH: NOT APPLIC	REL. HUMIDTY	H 3.3SH1							
*QUALIF: LATER	CHEM. SPRAY	C 3.3SH1							
*STATUS	RADIATION	R 3.3SH1							
*	AGING	A 3.3SH1							
*	SUBMERGENCE	S 3.3SH1							
EQ. PCK # : 3.3SH1	OS88 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : CONTROL ROOM
									HVAC
									TAG : 3CZ-B17SA-1

REFERENCES:

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CZ-B18SR-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1					
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104F 104F	NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS ATMOS	NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90% 100%	NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SURCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	FUNCTIONS: & SERVICE	ACTUATE VALVE AND CONTROL PO SITION				SRSR 3.3SH1				
ACCUR., SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%		LATER	RAB5125 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435211	PLANT LOC.: AB51					SRSA 3.3SH1				
COORDINATES X- 1600. Y- 1680. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1			
***** *QUALIF: LATER *STATUS * *****	OPERABILITY O	3.3SH1	REFERENCES:				CESN-2191			
	TEMPERATURE T	3.3SH1								
	PRESSURE P	3.3SH1								
	REL. HUMDTY H	3.3SH1								
	CHEM. SPRAY C	3.3SH1								
	RADIATION R	3.3SH1								
	AGING A	3.3SH1					REVISION # : 00			
	SUBMERGENCE S	3.3SH1					DATE :			
EQ. PCK # : 3.3SH1	0588 CATEG.: A APPENDIX E						SYSTEM : CONTROL ROOM HVAC TAG : 3CZ-B18SR-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-820SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SMC-04-5 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: ACTUATE VALVE & SERVICE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1			
SPECIFICATIONS: BF-35	S T.I.D.	3.7E4						
P.O #: 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1630. Y- 1677. Z- 305.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 3.3SH1						
*****	TEMPERATURE	T 3.3SH1						
*QUALIF: LATER	PRESSURE	P 3.3SH1						
*STATUS	REL. HUMIDTY	H 3.3SH1						
*	CHEM. SPRAY	C 3.3SH1						
*	RADIATION	R 3.3SH1						
*****	AGING	A 3.3SH1						
	SURMERGENCE	S 3.3SH1						
EQ. PCK # : 3.3SH1	APPENDIX E							

FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.3SH1

CES4-2197

REVISION # : 00
DATE :

SYSTEM : CONTROL ROOM
HVAC
TAG : 3CZ-820SB-1

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-B21SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAR51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATEP	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAP SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMC-04-5	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATFP	PAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATFP	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: BE-35								
P.O #: 435211								
PLANT LOC.: 4B51								
COORDINATES X- 1630. Y- 1677. Z- 305.0								
INSTALLED (Y/N): LTR								
INSTAL. REF: BY-FLD								
QUALIF EXEMPTN: NOT APPLIC								
*****	PARAMETER	SUPPL. REVIFW						
*QUALIF: LATER	OPERABILITY O	3.3SH1						
*STATUS	TEMPERATURE T	3.3SH1						
*	PRESSURE P	3.3SH1						
*	REL. HUMDITY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK #: 3.3SH1	0588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CESW-2199

REVISION #: 00
 DATE:

SYSTEM: CONTROL ROOM
 HVAC
 TAG: 3CZ-B21SA-1

A/E: EB SERVICES INC.
UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

4-0
CESA-2201

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CZ-8225B-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BIF					SRSR 3.3SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-5	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: ACTUATE VALVE AND CONTROL POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: RE-35	D B SHIELD	100%			SRSR 3.3SH1				
P.O #: 435211	S T.I.D.	3.7F4							
PLANT LOC.: AB51	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1644. Y- 1690. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*****	TEMPERATURE T	3.3SH1							CESA-2201
*QUALIF: LATER	PRESSURE P	3.3SH1							
*STATUS	REL. HUMIDTY H	3.3SH1							
*	CHEM. SPRAY C	3.3SH1							
*	RADIATION R	3.3SH1							
*****	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK # : 3.3SH1									REVISION # : 00 DATE :
	Q588 CATEG.: A								SYSTEM : CONTROL ROOM HVAC
	APPENDIX E								TAG : 3CZ-8225B-1

FOR PUNCHLIST ITEMS SEE SH E0 PACKAGE: 3.3SH1

REFERENCES:

A/E: EBB SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPSON HALL NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 74-2203

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CZ-823SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DRA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DRA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : SMC-04-5	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	PAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D R SHIELD	100%							
SPECIFICATIONS: BE-35	S T.I.D.	3.7E4							
P.O # : 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1625.0 Y- 1693.0 Z- 305.0	PARA-METER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
INSTAL. REF: RY-FLO	TEMPERATURE	T 3.3SH1							CES#-2203
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 3.3SH1							
*****	REL. HUMIDTY	H 3.3SH1							
*QUALIF: LATER	CHEM. SPRAY	C 3.3SH1							
*STATUS	RADIATION	R 3.3SH1							
*	AGING	A 3.3SH1							
*	SUBMERGENCE	S 3.3SH1							

EQ. PCK # : 3.3SH1	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : CONTROL ROOM
									HVAC
									TAG : 3CZ-823SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : 3CZ-823SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CZ-B24SB-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE BUTTERFLY VALVE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERAT- URE	104F 104F	NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS ATMOS	NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER BIF	RELATIVE HUMIDITY	20-90% 100%	NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND: SERIAL # SMB-04-5	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE ACTUATE VALVE AND CONTROL PO SITION	R GAMMA	3.7E4		LATER	RAB5125 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4							
SPECIFICATIONS: BE-35	AGE-	40 YEARS		LATER	10 CFR50 PARA. 50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435211	INST LIFE (PER 323- 1974 DEF.)					SRSA 3.3SH1			
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB51 FSAR SEC 3.119	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1630. Y- 1693. Z- 305.0	PARA- METER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.3SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1
*QUALIF: LATER	*TEMPERATURE T	3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*STATUS	*PRESSURE P	3.3SH1							CESN-2205
*	*REL. HUMDTY H	3.3SH1							
*	*CHEM. SPRAY C	3.3SH1							REFERENCES:
*****	*RADIATION R	3.3SH1							
	*AGING A	3.3SH1							REVISION # : 00
	*SUBMERGENCE S	3.3SH1							DATE :
EQ. PCK # : 3.3SH1	OSRB CATEG.: A								SYSTEM : CONTROL ROOM
	APPENDIX E								HVAC
									TAG : 3CZ-B24SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CZ-B25SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1					
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: SMP-00-15	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4								
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB51					SRSS 3.3SH1					
COORDINATES X- 1609. Y- 1683. Z- 305.0										
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
INSTAL. REF: BY-FLD	OPERABILITY	O 3.3SH1		REFERENCES:				CES#-2207		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.3SH1								
*****	PRESSURE	P 3.3SH1								
*QUALIF: LATER	REL. HUMIDTY	H 3.3SH1								
*STATUS	CHEM. SPRAY	C 3.3SH1								
*	RADIATION	R 3.3SH1								
*	AGING	A 3.3SH1								
*****	SUBMERGENCE	S 3.3SH1								
EQ. PCK # : 3.3SH1	OS88 CATEG.: A								REVISION # : 00	
	APPENDIX E								DATE :	
									SYSTEM : CONTROL ROOM	
									HVAC	
									TAG : 3CZ-B25SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS
TAG NO : 3C7-B26SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATFR	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				[SRSO 3.3SH1]			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATEP	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SPB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: ACTUATE VALVE AND CONTROL POSITION	R GAPMA	3.7E4	LATFR	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X			[SRSR 3.3SH1]			
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4						
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATEP	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	PARAMETER	SUPPL. REVIEW						
COORDINATES X- 1605. Y- 166C. Z- 305.0	OPERABILITY	O 3.3SH1						
INSTALLED (Y/N): LTR	TEMPERATURE	T 3.3SH1						
INSTAL. REF: BY-FLO	PRESSURE	P 3.3SH1						
QUALIF EXEMPTN: NOT APPLIC	REL. HUMDTY	H 3.3SH1						
*****	CHEM. SPRAY	C 3.3SH1						
*QUALIF: LATER	RADIATION	R 3.3SH1						
*STATUS	AGING	A 3.3SH1						
*	SUBMERGENCE	S 3.3SH1						
*								

EQ. PCK # : 3.3SH1	0588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TARGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTIONS: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION, PACKAGE: 3.3SH1

CES#-2209

REVISION # : 00
 DATE :

SYSTEM : CONTROL ROOM
 HVAC
 TAG : 3C2-B26SB-1

A/E: EB SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -2213

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-B32SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1			
ACCUR. DEM.: NOT APPLICABLE	S T.I.O.	3.7E4						
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51					SRSS 3.3SH1			
COORDINATES X- 1600.0 Y- 1695.0 Z- 305.0								
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1	
INSTAL. REF: BY-FLD	OPERABILITY O	3.3SH1		REFERENCES:			CES#-2213	
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	3.3SH1						
*QUALIF: LATER	PRESSURE P	3.3SH1						
*STATUS	REL. HUMIDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*	RADIATION R	3.3SH1						
*****	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK # : 3.3SH1	OS88 CATEG.: A	APPENDIX E					REVISION # : 00	DATE :
							SYSTEM : CONTROL ROOM HVAC	TAG : 3CZ-B32SA-1

REPLACEMENT:
 MAINTAIN:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-833SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NOPM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: LIPITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : SMB-005-15	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	100X			SRSR 3.3SH1			
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100X						
SPECIFICATIONS: BE-35	S T.I.D.	3.7E4						
P.O # : 435211	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1600.0 Y- 1690.0 Z- 305.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	OPERABILITY O	3.3SH1						
*****	TEMPERATURE T	3.3SH1						
*QUALIF: LATER	PRESSURE P	3.3SH1						
*STATUS	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*	RADIATION R	3.3SH1						
*****	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK # : 3.3SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-2215

REFERENCES:

REVISION # : 00
DATE :

SYSTEM : CONTROL ROOM
HVAC
TAG : 3CZ-833SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CZ-955A--1	OPERABIL-ITY	LATEP	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERAT-URE	104F NORM 104F DRA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSUPE	ATMOS NORM ATMOS DRA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : BIF SUPPLIER					SRSP 3.3SH1				SUBCOMPONENTS:
MODEL AND: SMB-00-5 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: ACTUATE VALVE & SERVICE AND CONTROL POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A PETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35					SRSR 3.3SH1				
P.O #: 435211	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: ABS1					SRSA 3.3SH1				
COORDINATES X- 1604. Y- 1696. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/M): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O	3.3SH1		REFERENCES:			CES#-2222		
	TEMPERATURE T	3.3SH1							
	PRESSURE P	3.3SH1							
	REL. HUMDTY H	3.3SH1							
	CHEM. SPRAY C	3.3SH1							
	RADIATION R	3.3SH1							
	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK # : 3.3SH1	USER CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : 3CZ-955A--1

A/E: **ENERGO SERVICES INC.**
 UTILITY: **CAROLINA POWER & LIGHT**

FACILITY: **SHEARON S NPP - 1**
 COMPONENT EVALUATION SHEET

NSSS: **WESTINGHOUSE - PWR**
 CAPACITY: **900 MW(E)**

WV-0
 CES-2224

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CZ-86SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DBA				SRSO 3.3SH1					
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:	
MAJOR SUPPLIER : BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : SMB-00-5	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : ACTUATE VALVE AND CONTROL POSITION	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B. SHIELD	100%			SRSR 3.3SH1					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4								
SPECIFICATIONS: BE-35	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435211	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB51					SRSS 3.3SH1					
COORDINATES X- 1607.0 Y- 1696.0 Z- 305.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
*QUALIF: LATER	OPERABILITY O	3.3SH1		REFERENCES:				CES-2224		
*STATUS	TEMPERATURE T	3.3SH1								
*	PRESSURE P	3.3SH1								
*	REL. HUMIDTY H	3.3SH1								
*	CHEM. SPRAY C	3.3SH1								
*	RADIATION R	3.3SH1								
*	AGING A	3.3SH1								
	SUBMERGENCE S	3.3SH1								
EQ. PCK # : 3.3SH1	OS88 CATEG.: A								REVISION # : 00	
	APPENDIX E								DATE :	
									SYSTEM : CONTROL ROOM HVAC	
									TAG : 3CZ-86SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CZ-B8SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: BUTTERFLY VALVE TYPE	NORM/TEST DRA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DRA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SPB-00-5 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: VALVE AND CONT & SERVICE ROL POSITION	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: BE-35								
P.O #: 435211								
PLANT LOC.: AB51								
COORDINATES X- 1596.0 Y- 1653.0 Z- 305.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	3.3SH1						
*QUALIF: LATER	TEMPERATURE T	3.3SH1						
*STATUS	PRESSURE P	3.3SH1						
*	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK # : 3.3SH1	0588 CATEG.: A APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.3SH1

CES#-2229

REFERENCES:

REVISION # : 00
DATE :

SYSTEM : CONTROL ROOM
HVAC
TAG : 3CZ-B8SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CX-W34SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 120,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	80F NORM 104F DBA	127F NORM FOR DBA FIG F2A-3.2SH1	TAB51J FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG F2A-3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	40% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NP-83208175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	N/A	N/A	N/A	/	NONE	
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.05E8 2.05E8	RAB5122 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 325-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	N/A FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB51	COORDINATES X- 1571. Y- 1612. Z- 305.0								
COORDINATES	PARAMETER	SUPPL. REVIFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
INSTALLED (Y/N): LTR	OPERABILITY	O 3.2SH1	REFERENCES: 1. ASCO TEST REPORT #AGR-67368/ R O DATED MARCH 1982			CES#-2286			
INSTAL. REF: BY-FLO	TEMPERATURE	T 3.2SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 3.2SH1							
*****	REL. HUMIDTY	H 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	CHEM. SPRAY	C 3.2SH1							
*STATUS CONFIRMATORY DATA	RADIATION	R 3.2SH1							
*	AGING	A 3.2SH1							
*****	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	OS&P CATEG.: A	APPENDIX E				REVISION # : 00 DATE : 09/04/86			
						SYSTEM : ESS. SER. CHILLED WATER TAG : 3CX-W34SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : A1-R11-ESF-B	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: 9800 SERVICE AIR TYPE (STATION AIR)	NORM/TEST DBA											
COMPONENT: TERMINAL BLOCK	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:			
MANUFACTURER: GE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.:			
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:			
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES. & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE				
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.5C.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE				
SPECIFICATIONS:	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:13.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:13.2SH1				
P-0 #:	OPERABILITY	O 13.2SH1		REFERENCES:				CES#-2314				
PLANT LOC.: AB21	TEMPERATURE	T 13.2SH1										
COORDINATES X- 1584. Y- 1529. Z- 236.0	PRESSURE	P 13.2SH1										
INSTALLED (Y/N): LTR	REL. HUMDTY	H 13.2SH1										
INSTAL. REF:BY-FLD	CHEM. SPRAY	C 13.2SH1										
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 13.2SH1										
*QUALIF: LATER	AGING	A 13.2SH1						REVISION # :00				
*STATUS	SUBMERGENCE	S 13.2SH1						DATE :				
*O588 CATEG.: A										SYSTEM : CNTRL BOARDS & PNL (IBC)		
APPENDIX E										TAG : A1-R11-ESF-B		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : A1-R31-ESF-A	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: 9800SERVICE AIR TYPE (STATION AIR)	NORM/TEST DBA					SRS013.2SH1			
COMPONENT: TERMINAL BLOCK	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: GE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: LATER SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	A BETA	7.2E4							
P.O #:	D B SHIELD	100%							
PLANT LOC.: AB11	S T.I.D.	3.4E4				SRSR13.2SH1			
COORDINATES X- 1414. Y- 1609. Z- 216.0	AGE- INST LIFE (PER .323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:13.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:13.2SH1
*QUALIF: LATER	OPERABILITY	O 13.2SH1						CES#-2315	
*STATUS	TEMPERATURE	T 13.2SH1							
*	PRESSURE	P 13.2SH1							
*	REL. HUMDTY	H 13.2SH1							
*	CHEM. SPRAY	C 13.2SH1							
*****	RADIATION	R 13.2SH1							
	AGING	A 13.2SH1							
	SUBMERGENCE	S 13.2SH1							
EQ. PCK # : 13.2SH1	0582 CATEG.: A APPENDIX E							REVISION # :00 DATE :	
								SYSTEM :CNTRL BOARDSS PHL(I&C) TAG :A1-R31-ESF-A	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

REFERENCES:

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : CP AUX FW P 1X-SAB	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: 9600 COMPRESSD AIR IN DG AIR	NORM/TEST DBA				SRS074.1SH1			
COMPONENT: CONTROL PANEL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: TERRY	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #:	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE:	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS:								
P.O #:								
PLANT LOC.: AB21								
COORDINATES X- 1525. Y- 1520. Z- 236.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 74.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 74.1SH1	
*****	OPERABILITY	O 74.1SH1		REFERENCES:			CES#-2318	
*QUALIF: LATER	TEMPERATURE	T 74.1SH1						
*STATUS	PRESSURE	P 74.1SH1						
*	REL. HUMDTY	H 74.1SH1						
*	CHEM. SPRAY	C 74.1SH1						
*****	RADIATION	R 74.1SH1						
	AGING	A 74.1SH1				REVISION # : 00	DATE :	
	SUBMERGENCE	S 74.1SH1				SYSTEM : AUXILIARY FEEDTR	TAG : CP AUX FW P 1X-	
EQ. PCK # : 74.1SH1	0588 CATEG.: A	APPENDIX E						

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: CRHR

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CP EHC24 1X-SA RAB	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: 9600 COMPRESSD A TYPE IR IN DG AIR	NORM/TEST DBA				SRS010.1SH1				
COMPONENT: CONTROL PANEL	TEMPERAT-URE	104F 104F	NORM DPA	LATER	TAB51A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: BRASCH	PRESSURE	ATMOS	NORM DPA	LATER	PAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90%	NORM DPA	LATER	HAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	R GAMMA	3.7E4		LATER	RAB5125 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR10.1SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4							
SPECIFICATIONS:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51					SRSS10.1SH1				
COORDINATES X- 1602. Y- 1669. Z- 305.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:10.1SH1.				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:10.1SH1		
INSTAL. REF:BY-FLD	OPERABILITY O	10.1SH1	REFERENCES:				CES#-2323		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	10.1SH1							
*****	PRESSURE P	10.1SH1							
*QUALIF: LATER	REL. HUMDTY H	10.1SH1							
*STATUS	CHEM. SPRAY C	10.1SH1							
*	RADIATION R	10.1SH1							
*	AGING A	10.1SH1							
*****	SUBMERGENCE S	10.1SH1							
EQ. PCK # : 10.1SH1	U588 CATEG.: A	APPENDIX E					REVISION # :00 DATE : SYSTEM :CONTROL ROOM HVAC TAG :CP EHC24 1X-SA		

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CP EHC26 1X-SB RAB	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: 9600 COMPRESSO A TYPE IR(IN DG AIR	NORM/TEST DBA				SRS010.1SH1				
COMPONENT: CONTROL PANEL	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: PRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATEP	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #									NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATEP	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS:									
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATEP	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51									
COORDINATES X- 1621. Y- 1660. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 10.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1
*****	TEMPERATURE	T 10.1SH1							
*QUALIF: LATER	PRESSURE	P 10.1SH1							
*STATUS	REL. HUMPTY	H 10.1SH1							CES#-2324
*	CHEM. SPRAY	C 10.1SH1							
*	RADIATION	R 10.1SH1							REFERENCES:
*****	AGING	A 10.1SH1							
	SUBMERGENCE	S 10.1SH1							REVISION # : 00
									DATE :
EQ. PCK # : 10.1SH1									SYSTEM : CONTROL ROOM
	G588 CATEG.: A								HVAC
	APPENDIX E								TAG : CP EHC26 1X-SB



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : CP EHC30 1B-SB RAB	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: 9600COMPRESSD A TYPE IRGIN DG AIR	NORM/TEST DBA				SRS01G.1SH1						
COMPONENT: CONTROL PANEL	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:		
MANUFACTURER: BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:		
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:		
MODEL AND: CP-78-00386 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRS10.1SH1						
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE			
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
P.O #: PLANT LOC.: AB31	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE			
COORDINATES X- 1574. Y- 173C. Z- 261.0					SRSS10.1SH1						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 10.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 10.1SH1		
*QUALIF: LATER	*OPERABILITY O	10.1SH1		REFERENCES:					CES#-2326		
*STATUS	*TEMPERATURE T	10.1SH1									
*	*PRESSURE P	10.1SH1									
*	*REL. HUMDTY H	10.1SH1									
*	*CHEM. SPRAY C	10.1SH1									
*	*RADIATION R	10.1SH1									
	AGING A	10.1SH1						REVISION # : 00			
	SUBMERGENCE S	10.1SH1						DATE :			
EQ. PCK # : 10.1SH1	U588 CATEG.: A APPENDIX E							SYSTEM : REAC.AUX.BLOG HVAC			
								TAG : CP EHC30 1B-SB			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CP E6 1B SB F D FT	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO10.1SH1				
COMPONENT: FIRE DET.PANEL	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER:BRASCH	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT.DES: & SERVICE	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	2.6E4							
P.O #:	AGE-	4C YEARS	LATER	1G CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB31	INST LIFE (PER 323- 1974 DEF.)								
COORDINATES X- 1582. Y- 1740. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/M): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:10.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:10.1SH1		
*****	OPERABILITY	O 10.1SH1	REFERENCES:				CES#-2332		
*QUALIF: LATER	TEMPERATURE	T 10.1SH1							
*STATUS	PRESSURE	P 10.1SH1							
*	REL. HUMPTY	H 10.1SH1							
*	CHEM. SPRAY	C 10.1SH1							
*****	RADIATION	R 10.1SH1							
	AGING	A 10.1SH1							
	SUBMERGENCE	S 10.1SH1							
EQ. PCK # : 10.1SH1	US88 CATEG.: A APPENDIX E								
							REVISION # :00 DATE :		
							SYSTEM :CONTROL ROOM HVAC		
							TAG :CP E6 1B SB F D		

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : A1-C7-ESF-A	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: 9600COMPRESSOR AIR (IN DG AIR)	NORM/TEST DBA				SRS013.2SH1				
COMPONENT: TERMINAL BLOCK	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: GE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL # : LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE :	R GAPMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	2.6E4							
P.O # :	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB31	INST LIFE (PER 323-1974 DEF.)								
COORDINATES X- 1435. Y- 1660. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:13.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:13.2SH1	
INSTAL. REF:BY-FLD	OPERABILITY	O 13.2SH1		REFERENCES:				CES#-2477	
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 13.2SH1							
*****	PRESSURE	P 13.2SH1							
*QUALIF: LATER	REL. HUMDTY	H 13.2SH1							
*STATUS	CHEM. SFRAY	C 13.2SH1							
*	RADIATION	R 13.2SH1							
*	AGING	A 13.2SH1							
*****	SUBMERGENCE	S 13.2SH1						REVISION # :00	
EQ. PCK # : 13.2SH1	OS88 CATEG.: A							DATE :	
	APPENDIX E							SYSTEM :CNTRL BOARD& PNL(I&C)	
								TAG :A1-C7-ESF-A	

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 125V DC MCC DP-1A2	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: 9600 COMPRESSOR AIR (IN DG AIR)	NORM/TEST DBA				SRSO 2.0SH1					
COMPONENT: DC DISTRIBUTION PANEL	TEMPERATURE	104F NORM 104F D9A	LATER	TAB41A FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS D9A	LATER	PAB41 FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN:	
MAJOR SUPPLIER :					SRSO 2.0SH1				SUBCOMPONENTS:	
MODEL AND SERIAL # : LATER	RELATIVE HUMIDITY	20-90% NORM 100% D9A	LATER	HAB41 FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : DISTRIBUTES DC POWER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SPSC 2.0SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:					SRSR 2.0SH1					
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB41					SRSA 2.0SH1					
COORDINATES X- 1461. Y- 1628. Z- 286.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS 2.0SH1					
INSTAL. REF: RY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 2.0SH1		REFERENCES:				CESN-2661		
*QUALIF: LATER	TEMPERATURE	T 2.0SH1								
*STATUS	PRESSURE	P 2.0SH1								
*	REL. HUMIDTY	H 2.0SH1								
*	CHEM. SPRAY	C 2.0SH1								
*****	RADIATION	R 2.0SH1								
	AGING	A 2.0SH1								
	SUBMERGENCE	S 2.0SH1								
EQ. PCK # : 2.0SH1	Q588 CATEG.: A							REVISION # : 00		
	APPENDIX E							DATE :		
								SYSTEM : DC POWER DISTR.		
								TAG : 125V DC MCC DP-		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/W	OUTS ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO : 125V DC MCC DP-182	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: 9600 COMPRESSD AIR IN DG AIR	NORM/TEST DBA				SRSO 2.0SH1			
COMPONENT: D.C. DISTRIBUTION PANEL	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE
MAJOR SUPPLIER :					SRSP 2.0SH1			
MODEL AND SERIAL # : LATER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE : DISTRIBUTES DC POWER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSC 2.0SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	N	NONE
	A BETA	7.2E4						
	D B SHIELD	100%						
	S T.I.D.	2.6E4				SRSR 2.0SH1		
SPECIFICATIONS:								
P.O #:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB41						SRSA 2.0SH1		
COORDINATES X- 1537. Y- 1628. Z- 286.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR								
INSTAL. REF: BY-FLO	PARA-METER	SUPPL. REVIEW						
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	2.0SH1					
*****	TEMPERATURE	T	2.0SH1					
*QUALIF: LATER	PRESSURE	P	2.0SH1					
*STATUS	REL. HUMDTY	H	2.0SH1					
*	CHEM. SPRAY	C	2.0SH1					
*	RADIATION	R	2.0SH1					
*****	AGING	A	2.0SH1					
	SUBMERGENCE	S	2.0SH1					
EQ. PCK # : 2.0SH1								
	OS88 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
MAINTAIN.:
SUBCOMPONENTS:
NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTIONS:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1

CES#-2662

REFERENCES:

REVISION # : 00
DATE :

SYSTEM : DC POWER DISTR.
TAG : 125V DC MCC DP

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1A21-SA	OPERABILITY	40YRS + 1YR D9A	40YRS + 1YR D9A	OPER. REVIEW	REF 1 ATTACH 9	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: MOTOR CONTROL C TYPE ENTERS	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F N09M 104F D9A	104F N09M 104F D9A	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS D9A	ATMOSPHER- TC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1 SUBCOMPONENTS:
MAJOR : N/A SUPPLIER	RELATIVE HUMIDITY	20-90%N09M 100% D9A	100%	HAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOM- PONENTS
FUNCT. DES: DISTRIBUTES AC & SERVICE POWER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 7.2E4 100% 2.6E4	1MRAD MINIMUM TTD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: E10B	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435143									
PLANT LOC.: AB41									
COORDINATES X- 1461. Y- 1615. Z- 286.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION. PACKAGE: 2.0SH1		
*****	OPERABILITY O	2.0SH1		REFERENCES: 1. GOULD QUALIFICATION REPORT CC-323.74-54			CES#-2685		
*QUALIF: QUALIFIED	TEMPERATURE T	2.0SH1							
*STATUS	PRESSURE P	2.0SH1							
*	REL. HUMDTY H	2.0SH1							
*	CHEM. SPRAY C	2.0SH1							
*****	RADIATION R	2.0SH1							
	AGING A	2.0SH1							
	SUBMERGENCE S	2.0SH1							
EQ. PCK # : 2.0SH1	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 07/06/84 SYSTEM: AC POWER DISTR. TAG: 480V MCC# 1A21-



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1A31-SA	OPERABILITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH B	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: MOTOR CONTROL CENTERS	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER- TC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1 SUBCOMPONENTS:
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100%	PAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOMPONENTS
MODEL AND SERIAL #: SERIES 560C	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: DISTRIBUTES AC POWER					SRSH 2.0SH1				
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	1MRAD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4	MINIMUM						
SPECIFICATIONS: E10B	D B SHIELD	100%	TID						
P.O #: 435143	S T.I.D.	2.6E4			SPSR 2.0SH1				
PLANT LOC.: AB41	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1473. Y- 1619. Z- 286.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1 QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1
*QUALIF: QUALIFIED	OPERABILITY O	2.0SH1							CES#-2688
*STATUS	*TEMPERATURE T	2.0SH1							
	*PRESSURE P	2.0SH1							
	*REL. HUMDTY H	2.0SH1							
	*CHEM. SPRAY C	2.0SH1							
	*RADIATION R	2.0SH1							
	*AGING A	2.0SH1							
	*SURMERGENCE S	2.0SH1							
EQ. PCK # : 2.0SH1	USER CATEG.: A				REFERENCES: 1.GOULD QUALIFICATION REPORT CC-323.74-54				REVISION # :00 DATE :07/06/84
	APPENDIX E								SYSTEM :AC POWER DISTR. TAG :480V MCC# 1A31-

A/E: EB SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

7-0
 24-2690

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.						
TAG NO : 480V MCC# 1A34-SA	OPERABILITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH 9	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: MOTOR CONTROL CENTER	NORM/TEST DBA				SRSO 2.0SH1						
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1		
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHERIC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31832 REF 1 SUBCOMPONENTS:		
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOMPONENTS		
MODEL AND SERIAL #: SERIES 5600	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
FUNCT. DES. & SERVICE: DISTRIBUTES AC POWER	ACCUR. SPEC: NOT APPLICABLE				SRSC 2.0SH1						
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	1MRAD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	H	NONE			
SPECIFICATIONS: E10B	A BETA	7.2E4	MINIMUM								
P.O #: 435143	D B SHIELD	100%	TID								
PLANT LOC.: AB41	S T.I.D.	2.6E4			SRSR 2.0SH1						
COORDINATES X- 1474, Y- 1633, Z- 286.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1				
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	2.0SH1					CES#-2690			
*QUALIF: QUALIFIED	TEMPERATURE	T	2.0SH1								
*STATUS	PRESSURE	P	2.0SH1								
*	REL. HUMIDTY	H	2.0SH1								
*	CHEM. SPRAY	C	2.0SH1	REFERENCES: 1.GOULD QUALIFICATION REPORT CC-323.74-54				REVISION # :00 DATE :07/06/84			
*****	RADIATION	R	2.0SH1								
	AGING	A	2.0SH1								
	SUBMERGENCE	S	2.0SH1					SYSTEM : AC POWER DISTR. TAG : 480V MCC# 1A34-			
EQ. PCK # : 2.0SH1	O588 CATEG.: A APPENDIX E										



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1A36-SA	OPERABILITY	40YRS + 1YR DBA	40YPS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH 3	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: MOTOR CONTROL C TYPE: ENTERS	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB51A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER- IC	PAB51 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1
MAJOR : N/A SUPPLIER					SRSO 2.0SH1				SUBCOMPONENTS:
MODEL AND: SERIES 560U SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% %	HAB51 FSAR SEC 3.11B	REF 1 PGS.107 TO 11L	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1:
FUNCT.DES: DISTRIBUTES AC & SERVICE POWER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOM- PONENTS
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	1MRAD MINIMUM TTD	RAB5125 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: E10B	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435143					SRSA 2.0SH1				
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1628. Y- 1670. Z- 305.0					SRSS 2.0SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVTFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1			
***** *QUALIF: QUALIFIED *STATUS * *****	OPERABILITY O	2.0SH1				CES#-2692			
	*TEMPERATURE T	2.0SH1							
	*PRESSURE P	2.0SH1							
	*REL. HUMIDTY H	2.0SH1							
	*CHEM. SPRAY C	2.0SH1							
	*RADIATION R	2.0SH1							
	*AGING A	2.0SH1							
	*SUBMERGENCE S	2.0SH1							
EQ. PCK # : 2.0SH1	OS88 CATEG.: A APPENDIX E		REFERENCES: 1.GOULD QUALIFICATION REPORT CC-323.74-54			REVISION # : 00 DATE : 07/06/84 SYSTEM : AC POWER DISTR. TAG : 480V MCC# 1A36-			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1B21-SP	OPERABIL-ITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH B	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: MOTOR CONTROL CENTERS	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CFS	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER-TC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND: SERIES 5600	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOMPONENTS
SERIAL #	R GAMMA	2.6E4	1MRAD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES: DISTRIBUTES AC & SERVICE POWER	D B SHIELD	100%	TIO		SRSR 2.0SH1				
ACCUR. SPEC: NOT APPLICABLE	S T.I.D.	2.6E4							
ACCUR. DEM.: NOT APPLICABLE	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: E10B	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435143	PARAMETER	SUPPL. REVIEW							
PLANT LOC.: AB41	OPERABILITY	O 2.0SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1
COORDINATES X- 1537. Y- 1615. Z- 286.0	TEMPERATURE	T 2.0SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1
INSTALLED (Y/N): LTR	PRESSURE	P 2.0SH1							CES#-2693
INSTAL. REF: BY-FLD	REL. HUMDTY	H 2.0SH1							
QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C 2.0SH1							
*****	RADIATION	R 2.0SH1							REFERENCES: 1. GOULD QUALIFICATION REPORT CC-323.74-54
*QUALIF: QUALIFIED	AGING	A 2.0SH1							REVISION #: 00
*STATUS	SUBMERGENCE	S 2.0SH1							DATE: 07/06/84
*									
*									

EQ. PCK # : 2.0SH1	OS8R CATEG.: A								SYSTEM: AC POWER DISTR.
	APPENDIX E								TAG: 480V MCC# 1B21-

A/E: EB SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SPEARON HA NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

W- 0
 N-2696

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1B31-SB	OPERABILITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH B	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: MOTOR CONTROL CENTER	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER- TC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: PGS.31&32 REF 1 SUBCOMPONENTS:
MAJOR SUPPLIER : N/A	RELATIVE HUMIDITY	20-90%NORM 100% DBA	10% DBA	HAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOMPONENTS
MODEL AND: SERIES 5600	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: DISTRIBUTES AC POWER & SERVICE	R GAMMA	2.6E4	1MRAD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	H	NONF	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4	MINIMUM						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%	TTD						
SPECIFICATIONS: E10B	S T.I.D.	2.6E4							
P.O #: 435143	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR5J PARA.50.51	REF 1 PGS.20,107 TO 11C	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB41	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1527. Y- 1618. Z- 286.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 2.0SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 2.0SH1							CES#-2696
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 2.0SH1							
*****	REL. HUMDTY	H 2.0SH1							
* QUALIF: QUALIFIED	CHEM. SPRAY	C 2.0SH1							
* STATUS	RADIATION	R 2.0SH1							
*	AGING	A 2.0SH1							
*	SUBMERGENCE	S 2.0SH1							

EQ. PCK # : 2.0SH1	OS8R CATEG.: A								
	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EO PACKAGE: 2.0SH1

REFERENCES: 1. GOULD QUALIFICATION REPORT
 CC-323.74-54

REVISION # : 00
 DATE : 07/06/84
 SYSTEM : AC POWER
 DISTR.
 TAG : 480V MCC# 1B31-

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 480V MCC# 1834-SB	OPERABILITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH 9	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: MOTOR CONTROL CENTERS	NORM/TEST DBA				SRSO 2.0SH1				
COMPONENT: SEE NOTE (1) OF CES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER- IC	PAB41 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1 SUBCOMPONENTS:
MAJOR SUPPLIER: N/A	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB41 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1:
FUNCT. DES: DISTRIBUTES AC & SERVICE POWER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOMPONENTS
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	1MRAD MINIMUM TTD	RAB4117 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	M	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: E10B	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435143					SRSA 2.0SH1				
PLANT LOC.: AB41									
COORDINATES X- 1527. Y- 1630. Z- 286.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH E9 PACKAGE: 2.0SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1		
*QUALIF: QUALIFIED	OPERABILITY	O 2.0SH1		REFERENCES: 1. GOULD QUALIFICATION REPORT CC-323.74-54			CES#-2698		
*STATUS	TEMPERATURE	T 2.0SH1							
*	PRESSURE	P 2.0SH1							
*	REL. HUMIDTY	H 2.0SH1							
*	CHEM. SPRAY	C 2.0SH1							
*****	RADIATION	R 2.0SH1							
	AGING	A 2.0SH1							
	SUBMERGENCE	S 2.0SH1							
EQ. PCK # : 2.0SH1	OS98 CATEG.: A APPENDIX E								REVISION #: 00 DATE : 07/06/84 SYSTEM : AC POWER DISTR. TAG : 480V MCC# 1834-

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 480V MCC# 1B36-SB	OPERABIL-ITY	40YRS + 1YR DBA	40YRS + 1YR DBA	OPER. REVIEW	REF 1 ATTACH 9	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: MOTOR CONTROL C TYPE: ENTERS	NORM/TEST DBA				SRSO 2.0SH1					
COMPONENT: SEE NOTE (1) OF CES	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF 1 PG.20	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: PG.35 REF 1	
MANUFACTURER: GOULD	PRESSURE	ATMOS NORM ATMOS DBA	ATMOSPHER-IC	PAB51 FSAR SEC 3.11B	REF 1 PG.9	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: PGS.31&32 REF 1	
MAJOR : N/A SUPPLIER					SRSO 2.0SH1				SUBCOMPONENTS:	
MODEL AND: SERIES 5600 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%	HAB51 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: DISTRIBUTES AC & SERVICE POWER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE 1: REFER TO SRS SC 2.0SH1 FOR IDENTIFICATION OF ALL MCC SUBCOM- PONENTS	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	1MRAD MINIMUM 100%	RAB5125 FSAR SEC 3.11B	REF 1 PGS.107 TO 110	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE					SRSR 2.0SH1					
SPECIFICATIONS: E10B	AGE- INST LIFE (PEP 323-1974 DEF.)	40 YEARS	40YRS	10 CFR5J PARA.50.51	REF 1 PGS.20,107 TO 110	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS	
P.O #: 435143					SRSA 2.0SH1					
PLANT LOC.: AB51										
COORDINATES X- 1595. Y- 166C. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSS 2.0SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 2.0SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 2.0SH1		
*****	OPERABILITY	O 2.0SH1		REFERENCES: 1. GOULD QUALIFICATION REPORT CC-323.74-54				CES#-2700		
*QUALIF: QUALIFIED	TEMPERATURE	T 2.0SH1								
*STATUS	PRESSURE	P 2.0SH1								
*	REL. HUMPTY	H 2.0SH1								
*	CHEM. SPRAY	C 2.0SH1								
*****	RADIATION	R 2.0SH1								
	AGING	A 2.0SH1								
	SUBMERGENCE	S 2.0SH1								
EQ. PCK # : 2.0SH1	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 07/06/84	
									SYSTEM: AC POWER DISTR. TAG: 480V MCC# 1B36-	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : S-65(1X-SB)	OPERABILITY	40YRS NORM 1YR DBA	>40YPS NORM >1YR DBA	OPER. REVIEW	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: FANS TYPE					SRSO 4.2SH1				
COMPONENT: MOTOR	TEMPERATURE	105F NORM 105F DBA	105F NORM 105F DBA	TAB51G FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: SEE INSTR MANUAL
MANUFACTURER: RELIANCE					SRS1 4.2SH1				MAINTAIN.: SEE INSTR MANUAL
MAJOR SUPPLIER : JOY	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB51 FSAR SEC 3.11B	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : RH INSULATION	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100%		REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : PROVIDE VENT FOR ESF EQUIPMENT	CHEMICAL SPRAY	NOT APPLICABLE	NA	CAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.34E8	RAB5122 FSAR SEC 3.11B	REF 1 P.14 & 21	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-17A					SRSR 4.2SH1				
P.O # : 435263	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	>40YPS	10 CFR50 FARA.50.51	REF 1 P.21	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB51					SRSA 4.2SH1				
COORDINATES X- 1544. Y- 1627. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	NA	SAB51 FSAR SEC 3.11B	NA	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.2SH1
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA *	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	4.2SH1 4.2SH1 4.2SH1 4.2SH1 4.2SH1 4.2SH1 4.2SH1							CES#-2762
EQ. PCK # : 4.2SH1	0588 CATEG.: A APPENDIX E								REFERENCES: 1. RELIANCE ELECTRIC CO. MOTOR QUALIFICATION REPORT NUC-9, DATED JULY 1, 1978, TOGETHER WITH SUPPLEMENTAL REPORT REV 2 DATED 7/15/81.
									REVISION # : 00 DATE : 07/09/84 SYSTEM : REAC. AUX. BLDG HVAC TAG : S-65(1X-SB)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.				
TAG NO : P1A-SA SW BOOSTER	OPERABIL-ITY	40YRS NORM PLUS 1YR DBA	40YRS NORM PLUS 1YR DBA	OPER. REVIEW	REF(1) PG.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: MOTORS TYPE									
COMPONENT: SERVICE WATER BOOSTER PUMP	TEMPERAT-URE	104F NORM DBA	311F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.D31	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE 1
MANUFACTURER: GOULD PUMPS, INC (SIEMENS ALLIS)	PRESSURE	ATMOS NORM DBA	ATMOS DBA	PAB21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE 1
MAJOR SUPPLIER : N/A									SUBCOMPONENTS:
MODEL AND: 447TS / EL-8-51 SERIAL # 03-90232-2	RELATIVE HUMIDITY	20-90% NORM DBA	100% RH DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.D32	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: FOLLOW VENDOR'S RECOMM REPLACEMENT & MAIN SCH. SEE ALSO PGS C34, C37. SEE VENDOR INSTR MANUAL.
FUNCT. DES: DRIVES SERVICE WATER BOOSTER PUMP & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2ER RADS	RAB21R7 FSAR SEC 3.11B	REF(1) PG.D31	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-13									
P.O #: 435042	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1) PG.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1419. Y- 1578. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.4SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.4SH1		
*****	OPERABILITY O	4.4SH1					CES#-2763		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	4.4SH1							
*STATUS FIELD VERIFICATION	PRESSURE P	4.4SH1							
*	REL. HUMDTY H	4.4SH1							
*	CHEM. SPRAY C	4.4SH1							
*****	RADIATION R	4.4SH1							
	AGING A	4.4SH1							
	SURMERGENCE S	4.4SH1							
EQ. PCK # : 4.4SH1				REFERENCES: (1)SIEMENS-ALLIS QUALIFICATION REPORT #NOR902322, REV 1			REVISION # :00 DATE :07/03/84		
	O588 CATEG.: A APPENDIX E						SYSTEM :SERVICE WATER TAG :P1A-SA SW		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2BD-V11SA-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	176F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/COM SUPPLIER OFLOW					SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: EA-180-11302 SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-66H					SRSR 9.1SH1	REVIEW			
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTIONS: CI
PLANT LOC.: AB21					SRSA 9.1SH1	REVIEW			
COORDINATES X- 1426. Y- 168E. Z- 255.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PARA-METER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							CES#-2827
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMDITY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1									REVISION # : 00 DATE : 09/18/84
	OS88 CATEG.: A APPENDIX E								SYSTEM : BLOWDOWN TAG : 2BD-V11SA-1

REFERENCES: (1)NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1



A/E: J SERVICES INC.
 UTIL: CAROLINA POWER & LIGHT

FACILITY: SHEARON IS NPP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE
 CAPACITY: 900 MW(E)

ES4-2828

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 28D-V155A-1	OPERABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 70,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	123F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW									
MODEL AND: SERIAL #	NP8320A185E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE						SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.05E8 2.05E8	RAB21R6 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	1D CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
P.O #: 435176										
PLANT LOC.: AB21										
COORDINATES X- Y- Z-	1494. 1623. 253.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1 CFS#-2828
EQ. PCK # : 3.2SH1										REFERENCES: 1. ASCO TEST REPORT #AGR-67368/ R D DATED MARCH 1982
		U588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/06/84 SYSTEM : BLOWDOWN TAG : 28D-V155A-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2CT-V145SB-1	OPERABILITY	41YRS NORM 500 CYC	140YRS: OVER 140YRS WITH 1817 CYC	OPER. REVIEW	REF(1)&(2) P.7,8810	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	106F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: YARWAY	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: RWST DISCH HEADER TO 3CT2-5SAB	R GAMMA	3.4E4	2.04E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP.11	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS: M-34Y	S T.I.D.	3.4E4						
P.O #: 435056	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1522. Y- 1603. Z- 219.0	PARA-METER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	3.3SH1						
*****	TEMPERATURE T	3.3SH1						
*QUALIF: QUALIFIED-AWAITING	PRESSURE P	3.3SH1						
*STATUS CONFIRMATORY DATA	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*	RADIATION R	3.3SH1						
*****	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK #: 3.3SH1	G588 CATEG.: A APPENDIX E							

REPLACEMENT: APP. A REF(1)
 MAINTAIN.: APP. A REF(1)
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTIONS: CI

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CESN-2892

REFERENCES: (1)LIMITORQUE REPORT #B0058
 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT B0003

REVISION #: 00
 DATE: 09/27/84

SYSTEM: CONTAINMENT SPRAY
 TAG: 2CT-V145SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 2CT-V2SA-1	OPERABILITY	41YRS NORM 500 CYC	NORM: OVER 140YRS WITH 1817 CYC	OPER. REVIEW	REF(1)&(2) P.7,8&10	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	X	NONE	REPLACEMENT: APP A REF(1)
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)
MAJOR SUPPLIER: ANCHOR/DARLING VALVE CO	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMB-000	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: INLET TO CONT & SERVICE SPRAY PUMP 1A- SA SUCTION					SRSH 3.3SH1				
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.04E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP. II	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-32A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: CI
P.O #: 435013					SRSA 3.3SH1				
PLANT LOC.: AB11									
COORDINATES X- 1451. Y- 1606. Z- 219.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*****	OPERABILITY	O 3.3SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.3SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.3SH1							
*	REL. HUMIDTY	H 3.3SH1							
*	CHEM. SPRAY	C 3.3SH1							
*****	RADIATION	R 3.3SH1							
	AGING	A 3.3SH1							
	SUBMERGENCE	S 3.3SH1							
EQ. PCK #: 3.3SH1	USRR CATEG.: A APPENDIX E								FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1
									REFERENCES: (1)LIMITORQUE REPORT #80058 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT 80003
									QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
									CES#-2922
									REVISION #: 00 DATE: 09/27/84
									SYSTEM: CONTAINMENT SPRAY
									TAG: 2CT-V2SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CT-V21SA-1	OPERABILITY	41YRS NORM SUD CYC	NORM: OVER 40YRS WITH 1817 CYC	OPER. REVIEW	REF(1)&(2) P.7,8&10	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: APP A REF(1)
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)
MAJOR SUPPLIER : ANCHOR/DARLING VALVE CO	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N.A	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SB-00	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : ISOLATION VALVE					SRSH 3.3SH1				
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E7	RAB21R6 FSAR SEC 3.11B	REF(2) APP.II	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-32A					SRSR 3.3SH1				
P.O #: 435013	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA 3.3SH1				
COORDINATES X- 1466. Y- 1637. Z- 251.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: 8Y-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW							
*****	OPERABILITY	O 3.3SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.3SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.3SH1							
*	REL. HUMDTY	H 3.3SH1							
*	CHEM. SPRAY	C 3.3SH1							
*****	RADIATION	R 3.3SH1							
	AGING	A 3.3SH1							
	SUBMERGENCE	S 3.3SH1							
EQ. PCK # : 3.3SH1									
	0588 CATEG.: A APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.3SH1

CES#-2924

REFERENCES:

- (1) LIMITORQUE REPORT #B0058
- (2) APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT B0003

REVISION # : 00
 DATE : 09/27/84

SYSTEM : CONTAINMENT
 SPRAY
 TAG : 2CT-V21SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.						
TAG NO : 2CT-V3SB-1	OPERABIL- ITY NORM/TEST DBA	41YRS NORM 500 CYC	NORM: OVER 49YRS WITH 1917 CYC	OPER. REVIEW	PEF(1)&(2) P.7,881D RSRO 3.3SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: VALVE OPERATORS TYPE	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.1D SRST 3.3SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: APP A REF(1)		
COMPONENT: MOTOR OPERATOR	PRESSURE	ATPOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10 SRSP 3.3SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)		
MANUFACTURER: LIMITORQUE	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5 SRSH 3.3SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
MAJOR : ANCHOR/DARLING SUPPLIER VALVE CO	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N.A SRSC 3.3SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
MODEL AND: SERIAL #	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.34E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP.II SRSR 3.3SH1	COMB. TEST & SUPPL. REVIEW	H	NONE			
FUNCT.DES: & SERVICE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7 SRSA 3.3SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: CI		
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 3.3SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
SPECIFICATIONS:M-32A	OPERABILITY O	3.3SH1		REFERENCES: (1)LIMITORQUE REPORT #B0058 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT B0003					CES#-2928		
P.O #:435013	TEMPERATURE T	3.3SH1									
PLANT LOC.: AB11	PRESSURE P	3.3SH1									
COORDINATES X- 1530. Y- 1606. Z- 219.0	REL. HUMDTY H	3.3SH1									
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD	CHEM. SPRAY C	3.3SH1									
QUALIF EXEMPTN: NOT APPLIC	RADIATION R	3.3SH1									
*****	AGING A	3.3SH1						REVISION # :00 DATE :09/27/84			
*****	SUBMERGENCE S	3.3SH1						SYSTEM : CONTAINMENT SPRAY TAG : 2CT-V3SB-1			
EQ. PCK # : 3.3SH1	OS88 CATEG.: A APPENDIX E										



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2CT-V8SA-1	OPERABILITY	41YRS NORM 500 CYC	NORM: OVER 140YRS WITH 1817 CYC	OPER. REVIEW	REF(1)&(2) P.7,8&13	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: YARWAY	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N.A.	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: RWST DISCH HEADER TO 3CT2-5SAB	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.34E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP.11	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: M-34Y	PARA-METER	SUPPL. REVIEW						
P.O #: 435056	OPERABILITY O	3.3SH1						
PLANT LOC.: AB11	TEMPERATURE T	3.3SH1						
COORDINATES X- 1526. Y- 1603. Z- 219.0	PRESSURE P	3.3SH1						
INSTALLED (Y/N): LTR	REL. HUMDTY H	3.3SH1						
INSTAL. REF: BY-FLD	CHEM. SPRAY C	3.3SH1						
QUALIF EXEMPTN: NOT APPLIC	RADIATION R	3.3SH1						
*****	AGING A	3.3SH1						
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE S	3.3SH1						
*STATUS CONFIRMATORY DATA								
* *****								
EQ. PCK # : 3.3SH1								

REPLACEMENT:
APP A REF(1)

MAINTAIN.:
APP A REF(1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
CI

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.3SH1

CES#-2938

REFERENCES: (1)LIMITORQUE REPORT #B0058
(2)APP D OUTSIDE CONTAINMENT
QUALIFICATION REPORT B0003

REVISION # : 00
DATE : 09/27/84

SYSTEM : CONTAINMENT
SPRAY
TAG : 2CT-V8SA-1

Q588 CATEG.: A
APPENDIX E



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2FP-V44SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DRA:	COMB. TEST & SUPPL.	/	40VE		
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DRA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DRA	OPSIG NOMP FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DRA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.0E4	2.75E8	RAB21R6 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4								
DB SHIELD	100X									
ST. I.O.	3.0E4	2.75E8								
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435176										
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
COORDINATES X- 1451. Y- 1648. Z- 241.U										
INSTALLED (Y/M): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY O	3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R U DATED MARCH 1982				CES#-2940		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	3.2SH1								
*	REL. HUMDITY H	3.2SH1								
*	CHEM. SPRAY C	3.2SH1								
*****	RADIATION R	3.2SH1								
	AGING A	3.2SH1								
	SUBMERGENCE S	3.2SH1								
EQ. PCK #: 3.2SH1	OS88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/06/84 SYSTEM: FIRE PROTECT. TAG: 2FP-V44SA-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2FP-V45SA-1	OPERABIL-ITY	NORM:40YRS 500 CYC	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8,DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 121 CYC		REF 1,P.26	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL.	#	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.: REF 1,APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL.	#	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90X NORM 100X DBA	107X NORM 107X DBA	HAB21 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 9.2.3	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE								
	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.05E8 2.05E8	RAB21R6 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	1G CFR50 PARA.50.51	REF 1,P.A3 FIG 184, P.C-5&C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB21	COORDINATES X- Y- Z-	1482. 1629. 255.0							
COORDINATES	INSTALLED (Y/N): LTR								
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	3.2SH1							
*STATUS CONFIRMATORY DATA	TEMPERATURE T	3.2SH1							
	PRESSURE P	3.2SH1							
	REL. HUMDTY H	3.2SH1							
	CHEM. SPRAY C	3.2SH1							
	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	OS88 CATEG.: A								
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1

CES#-2942

REFERENCES: 1.ASCO TEST REPORT #AGR-67368/
R O DATED MARCH 1982

REVISION # :00
DATE :09/04/84

SYSTEM : FIRE PROTECT.

TAG : 2FP-V45SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	W/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 21A-V34SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRS03.2SH1					
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
MANUFACTURER: PARKER HANNIFIN	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: H202-NC-50	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES. & SERVICE: ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13 64-51355	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: M-32A	S T.I.D.	3.0E4			SRSR3.2SH1					
P.O #: 435013	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1470. Y- 1636. Z- 236.0					SRSS3.2SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1	
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY	O 3.2SH1		REFERENCES:					CES4-2974	
	TEMPERATURE	T 3.2SH1								
	PRESSURE	P 3.2SH1								
	REL. HUMIDTY	H 3.2SH1								
	CHEM. SPRAY	C 3.2SH1								
	RADIATION	R 3.2SH1								
	AGING	A 3.2SH1						REVISION # : 00		
	SUBMERGENCE	S 3.2SH1						DATE :		
EQ. PCK # : 3.2SH1								SYSTEM : INSTRUMENT AIR		
	0588 CATEG.: A APPENDIX E							TAG : 21A-V34SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 21A-V34SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRS09.1SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: D24J0X-2	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13 64-51355	R GAMMA A BETA S T.I.D.	3.0E4 7.2E4 100X 3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE-INST LIFE (PER 325-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS: M-32A	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
P.O #: 435013	OPERABILITY	O 9.1SH1	REFERENCES:				CES#-2975		
PLANT LOC.: AB21	TEMPERATURE	T 9.1SH1							
COORDINATES X- 1470. Y- 1636. Z- 236.0	PRESSURE	P 9.1SH1							
INSTALLED (Y/N): LTR	REL. HUMIDTY	H 9.1SH1							
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 9.1SH1							
QUALIF EXEMPTM: NOT APPLIC	RADIATION	R 9.1SH1							
*QUALIF: LATER	AGING	A 9.1SH1					REVISION # : 00		
*STATUS	SUBMERGENCE	S 9.1SH1					DATE :		
* * * * *	OS28 CATEG.: A					SYSTEM : INSTRUMENT AIR			
* * * * *	APPENDIX E					TAG : 21A-V34SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2MD-V77SB-1	OPERABILITY	41YRS NORM SUG CYC	NORM: OVER 140YRS WITH 1R17 CYC	OPER. REVIEW	REF(1)&(2) P.7,8&10	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	DBA				SRSO 3.3SH1	REVIEW			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: APP A REF(1)
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: APP A REF(1)
MAJOR SUPPLIER: ANCHOR/DARLING VALVE CO					SRSR 3.3SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: SMB-000	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: CONT SUMP PUMP DISCH THRU PENET M-46	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N.A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100X 3.4E4	2.74E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP.II	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-32A					SRSR 3.3SH1	REVIEW			
P.O #: 435013	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11					SRSA 3.3SH1	REVIEW			
COORDINATES X- 1558. Y- 1656. Z- 230.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	3.3SH1 3.3SH1 3.3SH1 3.3SH1 3.3SH1 3.3SH1 3.3SH1							CESN-2978
				REFERENCES:	(1)LIMITORQUE REPORT #80058 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT 80U03				REVISION # :00 DATE :09/27/84
EQ. PCK # : 3.3SH1	US88 CATEG.: A APPENDIX E								SYSTEM : MISC. DRAINS TAG : 2MD-V77SB-1

A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWK
 CAPACITY: 900 MW(E)

3088

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : SMS-V17SAB-1	OPERABILITY	NORM: 40YRS 50G CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC						
COMPONENT: SOLENOID VALVE (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	123F NORM FOR DBA FIG E1A-3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	0PSIG NORM FOR DBA FIG E2A-3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: HP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRSC 3.2SH1				
	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100X 2.6E4	2.05E8 2.05E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB21	COORDINATES X- Y- Z-	1515. 1520. 238.0			SRSS 3.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982			CES#-3088		
QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	Q58P CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/04/84 SYSTEM : MAIN STEAM TAG : SMS-V17SAB-1

A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEPARD HARBOR
 COMPONENT EVALUATION

ISS: WESTINGHOUSE - PW
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3MS-V18SAB-1	OPERABILITY	NORM: 40YRS 500 CYC DBA: 1YR	NORM: 40YRS 27,100 CYC DBA: 1YR	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: VALVE OPERATORS	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
COMPONENT: SOLENOID VALVE (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.2SH1	N/A	/	NONE
MODEL AND SERIAL #: NP8320A175E	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.05E8 100%	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	N/A	/	NONE
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				
SPECIFICATIONS: M-66H	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1	
P.O #: 435176	TEMPERATURE	T 3.2SH1					CES#-3090	
PLANT LOC.: AB21	PRESSURE	P 3.2SH1					REVISION #: 00	
COORDINATES X- 1515.	REL. HUMDTY	H 3.2SH1					DATE: 09/04/84	
Y- 152P.	CHEM. SPRAY	C 3.2SH1					SYSTEM: MAIN STEAM	
Z- 238.0	RADIATION	R 3.2SH1					TAG: 3MS-V18SAB-1	
INSTALLED (Y/N): LTR	AGING	A 3.2SH1						
INSTAL. REF: BY-FLO	SUBMERGENCE	S 3.2SH1						
QUALIF EXEMPTN: NOT APPLIC	US88 CATEG.: A							
*****	APPENDIX E							

REPLACEMENT:
 REF 1, FIG.1,
 P.C-5
 MAINTAIN.:
 REF 1, APP.C
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 CI

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3MS-V18SAB-1	OPERABILITY	4YRS NORM 500 CYC	4YRS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVES TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 4)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW					SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: EA-180-11302 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:	
FUNCT. DES: POSITION & SERVICE INDICATION					SRSO 9.1SH1	REVIEW			(1) PG.4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	.10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: CI	
P.O #: 435176					SRSA 9.1SH1	REVIEW				
PLANT LOC.: AB21										
COORDINATES X- 1515. Y- 1528. Z- 238.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	OPERABILITY O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3091		
*	TEMPERATURE T	9.1SH1						REVISION # :00		
*	PRESSURE P	9.1SH1						DATE :09/18/84		
*	REL. HUMDTY H	9.1SH1						SYSTEM : MAIN STEAM		
*	CHEM. SPRAY C	9.1SH1						TAG : 3MS-V18SAB-1		
*	RADIATION R	9.1SH1								
EQ. PCK # : 9.1SH1	AGING A	9.1SH1								
	SUBMERGENCE S	9.1SH1								
	Q588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3SW-B14SR-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: PRIMARY ELEMENT TYPE	DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	95F 95F	NORM DBA	LATER	TYD31R FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS	NORM DBA	LATER	PAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	10-100% 100%	NORM DBA	LATER	HY031 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMB-00-10-H2BC	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: SW RETURN HDR B TO NORM SW D ISCH HDR	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4		LATER	RAB2110 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SURMERGED LEVEL	NOT APPLICABLE		LATER	SAB21 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: M-44	PARAMETER	SUPPL. REVIEW						
P.O #: 435082	OPERABILITY	O	3.3SH1					
PLANT LOC.: AB21	TEMPERATURE	T	3.3SH1					
COORDINATES X- 1636. Y- 1575. Z- 240.0	PRESSURE	P	3.3SH1					
INSTALLED (Y/N): LTR	REL. HUMDTY	H	3.3SH1					
INSTAL. REF: BY-FLD	CHEM. SPRAY	C	3.3SH1					
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R	3.3SH1					
*****	AGING	A	3.3SH1					
*QUALIF: LATER	SUBMERGENCE	S	3.3SH1					
*STATUS								
* * * * *								
EQ. PCK #: 3.3SH1	0588 CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-3104

REFERENCES:

REVISION #: 00
 DATE:

SYSTEM: SERVICE WATER

TAG: 3SW-B14SR-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-B64SA-1	OPERABILITY	NORM: 40YRS 500 CYC DBA: 1YR	NORM: 40YRS 20,100 CYC DBA: 1YR	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	DBA	1 CYC	21 CYC		SRSO 3.2SH1					
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM 109 DBA FTS E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FTS E2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW										
MODEL AND SERIAL #: NP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR										
	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A SRSC 3.2SH1	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.4E4	2.75E8	RAB11R3 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H	A BETA	7.2E4								
P.O #: 435176	D B SHIELD	100%								
PLANT LOC.: AB11	S T.I.D.	3.4E4	2.75E8							
	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 1B4, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1447. Y- 1602. Z- 218.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 3.2SH1	N/A	/	NONE		
INSTALLED (Y/N): LTR										
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	3.2SH1					CESW-3124		
STATUS CONFIRMATORY DATA	TEMPERATURE	T	3.2SH1							
	PRESSURE	P	3.2SH1							
	REL. HUMDTY	H	3.2SH1							
	CHEM. SPRAY	C	3.2SH1							
	RADIATION	R	3.2SH1							
	AGING	A	3.2SH1							
	SUBMERGENCE	S	3.2SH1							
EQ. PCK #: 3.2SH1				REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R G DATED MARCH 1982				REVISION #: 00 DATE: 09/04/84		
	0588 CATEG.: A APPENDIX E							SYSTEM: SERVICE WATER		
								TAG: 3SW-B64SA-1		

REPLACEMENT:
 REF 1, FIG. 1,
 P.C-5
 MAINTAIN.:
 REF 1, APP.C
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : JSW-B64SA-1	OPERABILITY	4CYRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: VALVES TYPE													
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:				
MODEL AND SERIAL # : EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
FUNCT. DES. & SERVICE : POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE													
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.74E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: M-66H													
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS				
PLANT LOC.: AB11													
COORDINATES X- 1447. Y- 1608. Z- 218.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC													
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-3125			
*STATUS CONFIRMATORY DATA	TEMPERATURE T	9.1SH1											REVISION # : 00 DATE : 09/18/84
*	PRESSURE P	9.1SH1											
*	REL. HUMDTY H	9.1SH1											
*	CHEM. SPRAY C	9.1SH1											
*****	RADIATION R	9.1SH1											
	AGING A	9.1SH1											
	SUBMERGENCE S	9.1SH1											
EQ. PCK # : 9.1SH1				0588 CATEG.: A APPENDIX E						SYSTEM : SERVICE WATER TAG : JSW-B64SA-1			

A/E: EBAS... VICES INC.
 UTILITY: ... LINA POWER & LIGHT

FACILITY: SHEARON HARR... P - 1
 COMPONENT EVALUATION S...

NSSS: WESTINGHOUSE - P&R
 CAPACITY: 90G MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-B65SB-1	OPERABIL- ITY	NORM: 40YRS SUC CYC	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA; REF 1, P. 26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	SUBCOMPONENTS:
MAJOR : HAMMEL DAHL/ SUPPLIER CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	177% NORM 177% DBA	HAB11 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.05E8 2.05E8	RAB11R3 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEP.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: M-66H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O #: 435176									
PLANT LOC.: AB11									
COORDINATES X- 1558. Y- 1614. Z- 228.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY O	3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982			CES#-3126		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	3.2SH1							
*	REL. HUMDTY H	3.2SH1							
*	CHEM. SPRAY C	3.2SH1							
*****	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E						REVISION # : 00 DATE : 09/04/84 SYSTEM : SERVICE WATER TAG : 3SW-B65SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-8655B-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 100% DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: VALVES TYPE	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MANUFACTURER: NAMCO	MAJOR : SUPPLIER	HAMMEL DAHL/COM OFLOW							SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.34E8	PAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	H	NONE		
ACCUR. DEM.: NOT APPLICABLE		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS: M-66H		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- Y- Z-	1558. 1614. 228.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*OPERABILITY	O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CESN-3127		
*TEMPERATURE	T	9.1SH1								
*PRESSURE	P	9.1SH1								
*REL. HUMDTY	H	9.1SH1								
*CHEM. SPRAY	C	9.1SH1								
*RADIATION	R	9.1SH1								
*AGING	A	9.1SH1								
*SUBMERGENCE	S	9.1SH1						REVISION # : 00 DATE : 09/18/84		
EQ. PCK # :	9.1SH1	G588 CATEG.: A APPENDIX E						SYSTEM : SERVICE WATER TAG : 3SW-8655B-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-B70SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BLAKE EQUIPMENT					SRSR 3.3SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-2-HOBC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: SW FROM SW SUPPLY HDR A TO AUX FW PMP 1X-S AB BACK UP LIM	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAPMA A BETA S T.I.D.	2.6E4 100X 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-44					SRSR 3.3SH1				
P.O #: 435082	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 3.3SH1				
COORDINATES X- 1496. Y- 1548. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEPTN: NOT APPLIC ***** *QUALIF: LATER *STATUS* * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
	OPERABILITY O	3.3SH1		REFERENCES:			CES#-3130		
	TEMPERATURE T	3.3SH1					REVISION # :00		
	PRESSURE P	3.3SH1					DATE :		
	REL. HUMDTY H	3.3SH1					SYSTEM :SERVICE WATER:		
	CHEM. SPRAY C	3.3SH1					TAG :3SW-B70SA-1		
	RADIATION R	3.3SH1							
	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK # : 3.3SH1				0588 CATEG.: 4					
				APPENDIX E					

A/E: EBA ADVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HART
 COMPONENT EVALUATION PP - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

3132

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3SW-871SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMC-04-2-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1			
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4						
SPECIFICATIONS: M-44	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435082	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSS 3.3SH1			
COORDINATES X- 1504. Y- 1548. Z- 240.0								
INSTALLED (Y/N): LTR								
INSTAL. REF: 8Y-FLD								
QUALIF EXEMPTN: NOT APPLIC								
*****	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	3.3SH1						
*****	TEMPERATURE T	3.3SH1						
*****	PRESSURE P	3.3SH1						
*****	REL. HUMIDTY H	3.3SH1						
*****	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
*****	AGING A	3.3SH1						
*****	SUBMERGENCE S	3.3SH1						
EQ. PCK #: 3.3SH1								
	OSPB CATEG.: A							
	APPENDIX E							

REPLACEMENT:
 MAINTAIN:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-3132

REVISION #: 00
 DATE :

SYSTEM : SERVICE WATER

TAG : 3SW-871SA-1



A/E: EBASCO SERVICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON HARRIS P - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9UG MW(E)

6-134

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-B72SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-2-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: SW FROM SW SUPPLY HDR B TO AUX FW PUMP 1X-SAB BACK UP LI & SERVICE	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-44	S T.I.D.	2.6E4							
P.O #: 4350R2	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: CI
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1518. Y- 1548. Z- 240.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
*QUALIF: LATER	OPERABILITY O	3.3SH1		REFERENCES:			CES#-3134		
*STATUS	TEMPERATURE T	3.3SH1							
*	PRESSURE P	3.3SH1							
*	REL. HUMDTY H	3.3SH1							
*	CHEM. SPRAY C	3.3SH1							
*	RADIATION R	3.3SH1							
*	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK #: 3.3SH1	0588 CATEG.: A APPENDIX E						REVISION #: 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-B72SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3SW-B73SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LINITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : BLAKE EQUIPMENT					SRSO 3.3SH1			
MODEL AND SERIAL #: SPC-04-2-HOBC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE					SRSO 3.3SH1			
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: M-44	D B SHIELD	100%			SRSR 3.3SH1			
P.O #: 435082	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSA 3.3SH1			
COORDINATES X- 1510. Y- 1548. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR					SRSS 3.3SH1			
INSTAL. REF: BY-ELD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1	
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 3.3SH1		REFERENCES:			CES#-3136	
*QUALIF: LATER	TEMPERATURE	T 3.3SH1					REVISION #: 00	
*STATUS	PRESSURE	P 3.3SH1					DATE :	
*	REL. HUMIDTY	H 3.3SH1					SYSTEM : SERVICE WATER	
*	CHEM. SPRAY	C 3.3SH1					TAG : 3SW-B73SB-1	
*****	RADIATION	R 3.3SH1						
	AGING	A 3.3SH1						
	SUBMERGENCE	S 3.3SH1						
EQ. PCK # : 3.3SH1	0588 CATEG.: A							
	APPENDIX E							

A/E: EBASCO SERVICES INC.
 UTILITY: CHINA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION SHEET - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9GG MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-874SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN:
MAJOR SUPPLIER : MILLER ENERGY INC	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : SMC-04-2-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: FROM 3SW10-68S A-1 TO AUX FW PUMP 1A-SA SUC T	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1				
ACCUR. DEP.: NOT APPLICABLE	S T.I.O.	2.6E4							
SPECIFICATIONS: M-44	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
P.O #: 435082	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21									
COORDINATES X- 1493, Y- 1521, Z- 238.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.3SH1							CES#-3138
*****	PRESSURE	P 3.3SH1							
*QUALIF: LATER	REL. HUMIDTY	H 3.3SH1							
*STATUS	CHEM. SPRAY	C 3.3SH1							
*	RADIATION	R 3.3SH1							
*	AGING	A 3.3SH1							
*****	SUBMERGENCE	S 3.3SH1							
EQ. PCK # : 3.3SH1	OS88 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : SERVICE WATER
									TAG : 3SW-874SA-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:



A/E: EBASCO VICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-V237SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	HORM/TEST DBA				SRSO					
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: PARKER HANNIFIN					SRS1				MAINTAIN.:	
MAJOR : ANCHOR DARLING SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND: H202 NC-50 SERIAL #	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH ASCO SOLENOIDS.	
FUNCT. DES: LATER & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRS1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100X 1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-32A					SRSR					
P.O #: 435013	AGE- INST LIFE (PER 323- 1974 DFF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA					
COORDINATES X- 1646. Y- 1538. Z- 236.0	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O					CESN-3154			
*QUALIF: LATER	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SURPERGENCE	S								
EQ. PCK # :	US88 CATEG.: A APPENDIX E		REFERENCES:				REVISION # : 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-V237SA-1			





A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					DEM. QUALIF.
TAG NO : 3SW-V238SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER		/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO				
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	LATER		LATER		H	NONE	
MANUFACTURER: PARKER HANNIFIN					SRSST			REPLACEMENT:	
MAJOR SUPPLIER: ANCHOR DARLING	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER		M	NONE	
MODEL AND SERIAL #: H202 NC-50	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.7-1	LATER		LATER		/	NONE	
FUNCT. DES. & SERVICE: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CA821 FSAR SEC 3.11B	LATER		/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSR			NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH ASCO SOLENOIDS.	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER		H	NONE	
SPECIFICATIONS: M-32A	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER		/	NONE	
P.O #: 435013					SRSA			SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER		/	NONE	
COORDINATES X- 1645. Y- 1538. Z- 236.0					SRSS				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
***** *QUALIF: LATER *STATUS * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S		REFERENCES:				CESW-3156		
EQ. PCK # :	Q588 CATEG.: A APPENDIX E						REVISION # : 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-V238SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-V238SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: LIMIT SWITCHES TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	MAINTAIN.:
MAJOR SUPPLIER: ANCHOR DARLING	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.2-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: D240GX-2	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: LATER	R GAPMA	1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	1.8E4							
SPECIFICATIONS: M-32A	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435013	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1645. Y- 1538. Z- 236.0	OPERABILITY O								FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:
INSTALLED (Y/N): LTR	TEMPERATURE T								QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. REF: BY-FLO	PRESSURE P								CES#-3157
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY H								
*QUALIF: LATER	CHEM. SPRAY C								
*STATUS	RADIATION R								
*	AGING A								
*	SUBMERGENCE S								

EQ. PCK # :	0588 CATEG.: A								REFERENCES:
	APPENDIX E								
									REVISION # : 00
									DATE :
									SYSTEM : SERVICE WATER
									TAG : 3SW-V238SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-V266SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO				
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:
MANUFACTURER: PARKER HANNIFIN					SRSST				MAINTAIN.:
MAJOR SUPPLIER: MILLER ENERGY INC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: H202 MC-50	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE 1: TO BE REPLACED WITH ASCO SOLENOIDS.
ACCUR. SPEC: NOT APPLICABLE					SRSR				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	1.8E4	LATER	RAB211G FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-32A	A BETA								
P.O #: 435013	D B SHIELD	100%			SRSR				
PLANT LOC.: AB21	S T.I.D.	1.8E4							
COORDINATES X- 1646. Y- 1549. Z- 237.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
INSTALLED (Y/N): LTR					SRSA				
INSTAL. REF: BY-FLD									
QUALIF EXEMPTN: NOT APPLIC									
*****	OPERABILITY	O							
*QUALIF: LATER	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMIDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A							
	SUBMERGENCE	S							
EQ. PCK # :									
	US88 CATEG.: A								
	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

CESW-3158

REVISION # : 00
 DATE :

SYSTEM : SERVICE WATER

TAG : 3SW-V266SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-V267SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO					
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: PARKER HANNIFIN	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	MAINTAIN.:	
MAJOR SUPPLIER: MILLER ENERGY INC	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: H202 NC-50	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH ASCO SOLENOIDS.	
FUNCT. DES. & SERVICE: LATER	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	LATER	RAB2110 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
SPECIFICATIONS: M-32A										
P.O #: 435013										
PLANT LOC.: AB21										
COORDINATES X- 1646. Y- 1548. Z- 237.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PAPA-METER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION P AGING A SUBMERGENCE S			REFERENCES:				CES#-3160		
EQ. PCK # :	0588 CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-V267SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3SW-V267SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	NOT AVAILABLE	LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: MILLER ENER GY INC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: D2400X-2	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.7-1	LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: LATER					SRSR			
ACCUR. SPEC: NOT APPLICABLE					SRSR			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: M-32A					SRSS			
P.O #: 435013	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21					SRSA			
COORDINATES X- 1646. Y- 1548. Z- 237.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
***** *QUALIF: LATER *STATUS * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S							
EQ. PCK # :	0588 CATEG.: A APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
 NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
 CES#-3161
 REVISION # : 00
 DATE :
 SYSTEM : SERVICE WATER
 TAG : 3SW-V267SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : 3SW-V480SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA								
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	NOT AVAILABLE	106 F NORM 176 F DBA		REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: SEE NOTE (1)		
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN: SEE NOTE (1)		
MAJOR SUPPLIER: HANMEL DAHL/CON OFLOW									SUBCOMPONENTS:		
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11, P-1	100% NORM 100% DBA		REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.		
FUNCT. DES. & SERVICE POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
ACCUR. SPEC: NOT APPLICABLE											
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	3.4E4 7.2E4 100% 3.4E4	2.04E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE			
SPECIFICATIONS: M-66H											
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
PLANT LOC.: AB11											
COORDINATES X- 1393. Y- 1615. Z- 216.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD											
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1;					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.					CES#-3163		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1									
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1									
*	REL. HUMDTY	H 9.1SH1									
*	CHEM. SPRAY	C 9.1SH1									
*****	RADIATION	R 9.1SH1									
	AGING	A 9.1SH1									
	SUBMERGENCE	S 9.1SH1						REVISION # : 00 DATE : 09/18/86			
EQ. PCK # : 9.1SH1								SYSTEM : SERVICE WATER			
	0588 CATEG.: A APPENDIX E							TAG : 3SW-V480SB-1			

A/E: EBASCO /ICES INC.
 UTILITY: CINA POWER & LIGHT

FACILITY: SHEARON HARRI
 COMPONENT EVALUATION SH

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3SW-V481SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1			
COMPONENT: SOLENOID VALVE	TEMPERATURE	NOT AVAILABLE	123F NORM FOR DBA FIG E1A-3.2SH1		REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
MANUFACTURER: ASCO	PRESSURE	ATPOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A-3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: HAMMEL DAHL/ CONO FLOW	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.0-1	100% NORM 100% DBA		REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: NP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRSC 3.2SH1			
	R GAMMA	3.4E4	2.05E8	RAB11R3	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
	A BETA	7.2E4		FSAR SEC 3.11B				
	D B SHIELD	100%						
	S T.I.D.	3.4E4	2.05E8					
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	60 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435176	PLANT LOC.: AB11							
COORDINATES X- 1393. Y- 1609. Z- 216.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW						
	OPERABILITY O	3.2SH1						
	TEMPERATURE T	3.2SH1						
	PRESSURE P	3.2SH1						
	REL. HUMDTY H	3.2SH1						
	CHEM. SPRAY C	3.2SH1						
	RADIATION R	3.2SH1						
	AGING A	3.2SH1						
	SUBMERGENCE S	3.2SH1						
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
REF 1, FIG. 1,
P.C-5
MAINTAIN.:
REF 1, APP.C
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 3.2SH1

CES#-3164

REFERENCES: 1. ASCO TEST REPORT #AQR-67368/
R O DATED MARCH 1982

REVISION # : 00
DATE : 09/04/84

SYSTEM : SERVICE WATER

TAG : 3SW-V481SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : 3SW-V481SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/ NONE
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	NOT AVAILABLE	104F NORM 104F DBA		REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	H NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M NONE
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-100% (DBA) TABLE 3.11.7-1	100% NORM 100% DBA		REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/ NONE
MODEL AND SERIAL #: EA-180-11302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/ NONE
FUNCT. DES. & SERVICE: POSITION INDICATION	R GAMMA	3.4E4	2.04E8	RAB11R3	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4		FSAR SEC 3.11B			
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.1SH1		
SPECIFICATIONS: M-66H	S T.I.D.	3.4E4					
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/ NONE
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/ NONE
COORDINATES X- 1393. Y- 1609. Z- 216.0	PARAMETER	SUPPL. REVIEW					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	9.1SH1					
*****	TEMPERATURE T	9.1SH1					
*QUALIF: QUALIFIED-AWAITING	PRESSURE P	9.1SH1					
*STATUS CONFIRMATORY DATA	REL. HUMDTY H	9.1SH1					
*	CHEM. SPRAY C	9.1SH1					
*	RADIATION R	9.1SH1					
*****	AGING A	9.1SH1					
	SUBMERGENCE S	9.1SH1					
EQ. PCK #: 9.1SH1	OS8R CATEG.: A APPENDIX E						

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTE:

(1) PG.4-3,4-3.1 &
4-3.2 OF REPORT
QTR-105 REV 3
DATED 8/20/81.

SAFETY FUNCTIONS:
SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.1SH1

CES#-3165

REFERENCES: (1) NAMCO CONTROLS DIVISION
QUALIFICATION REPORT QTR-105
REVISION 3 DATED 8/20/81.

REVISION #: 00
DATE: 09/18/84

SYSTEM: SERVICE WATER

TAG: 3SW-V481SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SW-B45SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-5-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: SW SUPPLY TO CONTROL FAN COOLER AH-2	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-44	S T.I.D.	3.4E4							
P.O #: 435092	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	1D CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1545. Y- 1645. Z- 230.0	PARAMETER SUPPL. REVIEW								
INSTALLED (Y/N): LTR	OPERABILITY	O	3.3SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1	
INSTAL. REF: RY-FLD	TEMPERATURE	T	3.3SH1	REFERENCES:				CESN-3172	
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P	3.3SH1						
*****	REL. HUMIDTY	H	3.3SH1						
*QUALIF: LATER	CHEM. SPRAY	C	3.3SH1						
*STATUS	RADIATION	R	3.3SH1						
*	AGING	A	3.3SH1						
*	SUBMERGENCE	S	3.3SH1					REVISION # 100	
*****								DATE :	
EQ. PCK # : 3.3SH1	OS88 CATEG.: A							SYSTEM : SERVICE WATER	
	APPENDIX E							TAG : 2SW-B45SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SW-846SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-5-H08C	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : SW SUPPLY TO CONTROL FAN COOLER AH-3	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-44	S T.I.D.	3.4E4							
P.O #: 435082	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	1D CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1455. Y- 1645. Z- 230.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 3.3SH1							
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 3.3SH1							
*QUALIF: LATER	REL. HUMIDTY	H 3.3SH1							CESW-3174
*STATUS	CHEM. SPRAY	C 3.3SH1							
*	RADIATION	R 3.3SH1							
*	AGING	A 3.3SH1							REVISION # : 00
	SUBMERGENCE	S 3.3SH1							DATE :
EQ. PCK # : 3.3SH1	OS88 CATEG.: A								SYSTEM : SERVICE WATER
	APPENDIX E								TAG : 2SW-846SA-1

FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

A/E: EBAS SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARON HARBOR APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

3176

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SW-B47SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: SMC-04-5-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: SW RETURN FROM CONTMT FAN COOLER AH-3	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.4E4							
SPECIFICATIONS: M-44	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435082	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB11					SRSS 3.3SH1				
COORDINATES X- 1470. Y- 1635. Z- 230.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
*****	OPERABILITY O	3.3SH1	REFERENCES:				CES#-3176		
*QUALIF: LATER	TEMPERATURE T	3.3SH1							
*STATUS	PRESSURE P	3.3SH1							
*	REL. HUMPTY H	3.3SH1							
*	CHEM. SPRAY C	3.3SH1							
*****	RADIATION R	3.3SH1							
	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK #: 3.3SH1	US88 CATEG.: A	APPENDIX E					REVISION #: 00 DATE: : SYSTEM: SERVICE WATER TAG: 2SW-B47SA-1		

REPLACEMENT:
 MAINTAIN:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTIONS:
 SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SW-948SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATEP	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: 4.
MODEL AND SERIAL #: SMC-04-S-MCBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: SW RETURN FROM CONTMT FAN CO OLER AH-1	R GAPMA	3.4E4	LATEP	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-44	S T.I.D.	3.4E4							
P.O #: 435082	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	1G CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1453. Y- 1648. Z- 230.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY	O 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.3SH1							
*QUALIF: LATER	PRESSURE	P 3.3SH1							CES#-3178
*STATUS	REL. HUMDTY	H 3.3SH1							
*	CHEM. SFRAY	C 3.3SH1							
*	RADIATION	R 3.3SH1							
*****	AGING	A 3.3SH1							REVISION # : 00
	SURMERGENCE	S 3.3SH1							DATE :
EQ. PCK # : 3.3SH1	0588 CATEG.: A								SYSTEM : SERVICE WATER
	APPENDIX E								TAG : 2SW-948SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : SERVICE WATER

TAG : 2SW-948SB-1

A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEARON HARBOR PP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

3180

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2SW-849SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BLAKE EQUIPMENT	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMC-04-5-H0BC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: SW RETURN FROM CONTMT FAN CO OLER AH-2	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4						
	D B SHIELD	100%						
	S T.I.D.	3.4E4						
SPECIFICATIONS: M-44	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435082								
PLANT LOC.: AB11								
COORDINATES X- 1529. Y- 1635. Z- 230.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY O	3.3SH1						
*QUALIF: LATER	TEMPERATURE T	3.3SH1						
*STATUS	PRESSURE P	3.3SH1						
*	REL. HUMDTY H	3.3SH1						
*	CHEM. SPRAY C	3.3SH1						
*****	RADIATION R	3.3SH1						
	AGING A	3.3SH1						
	SUBMERGENCE S	3.3SH1						
EQ. PCK #: 3.3SH1	CS88 CATEG.: A APPENDIX E							

REPLACEMENT:

MAINTAIN:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-3150

REVISION #: 00
 DATE:

SYSTEM: SERVICE WATER

TAG: 2SW-849SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 2SW-B51SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORP/TEST DBA				(RSO 3.3SH1)				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER: BLAKE EQUIPPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SPC-04-5-HDBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: SW SUPPLY TO CONTROL FAN COOLER AH-4	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-44	S T.I.D.	3.4E4							
P.O #: 435082	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1552. Y- 1653. Z- 230.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY	O 3.3SH1							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1
INSTAL. REF: BY-FLD	TEMPERATURE	T 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
QUALIF EXEMPTN: NOT APPLIC	PRESSURE	P 3.3SH1							CES#-3184
*****	REL. HUMIDTY	H 3.3SH1							
*QUALIF: LATER	CHEM. SPRAY	C 3.3SH1							
*STATUS	RADIATION	R 3.3SH1							REFERENCES:
*	AGING	A 3.3SH1							
*	SUBMERGENCE	S 3.3SH1							

EQ. PCK #: 3.3SH1	OS8R CATEG.: A								REVISION #: 00
	APPENDIX E								DATE :
									SYSTEM : SERVICE WATER
									TAG : 2SW-B51SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2SW-852SB-1	OPERABILITY	LATER	LATEP	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO 3.3SH1			
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB11A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: SMC-04-5-HUBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: SW SUPPLY TO CONTMNT FAN COOLER AH-1	R GAMMA	3.4E4	LATER	RAB11R3 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1			
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.4E4						
SPECIFICATIONS: M-44	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435082	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB11 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB11					SRSS 3.3SH1			
COORDINATES X- 1448. Y- 1652. Z- 230.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*OPERABILITY O		3.3SH1						
*TEMPERATURE T		3.3SH1						
*PRESSURE P		3.3SH1						
*REL. HUMPTY H		3.3SH1						
*CHEM. SPRAY C		3.3SH1						
*RADIATION R		3.3SH1						
*AGING A		3.3SH1						
*SUBMERGENCE S		3.3SH1						
EQ. PCK #: 3.3SH1	G588 CATEG.: A APPENDIX E							

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1

CES#-3186

REFERENCES:

REVISION #: 00
 DATE:

SYSTEM: SERVICE WATER

TAG: 2SW-852SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 2SW-B88SAB-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8,DEA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1					
COMPONENT: SOLENOID VALVE (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG F1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.: REF 1,APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	100SIG NORM FOR DBA FIG F2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR SUPPLIER: HAMMEL DAHL/COM OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: SW SUPPLY TO & SERVICE NON SAFETY HVAC COOLERS	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A SRSC 3.2SH1	N/A REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.4E4	2.05E3	RAB11R3 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: M-66H	S T.I.D.	3.4E4	2.05E8							
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.A3 FIG 144, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 3.2SH1	N/A REVIEW	/	NONE		
COORDINATES X- 1430. Y- 1693. Z- 233.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		EQ PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*****	OPERABILITY O	3.2SH1								
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	3.2SH1							CES#-3198	
*	REL. HUMDTY H	3.2SH1								
*	CHEM. SPRAY C	3.2SH1								
*****	RADIATION R	3.2SH1								
	AGING A	3.2SH1							REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982	
	SUBMERGENCE S	3.2SH1							REVISION # :00 DATE :09/04/84	
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E								SYSTEM : SERVICE WATER TAG : 2SW-B88SAB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	M/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SW-B90SB-1	OPERABIL-ITY	NORM:40YRS 50G CYC	NORM:40YRS 120,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA:1YD 1 CYC	DBA:1YR 121 CYC		REF 1,P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.:	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REF 1,APP.C	
MAJOR : HAMMEL DAHL/ SUPPLIER CONOFLOW									SUBCOMPONENTS:	
MODEL AND: NP8320A175E SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	7.75E8 12.05E8	RAB11R3 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:M-66H										
P.O #:435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB11										
COORDINATES X- 1435. Y- 166C. Z- 230.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O	3.2SH1		REFERENCES: 1.ASCO TEST REPORT MAQR-67368/ R O DATED MARCH 1982				CES#-3192		
	TEMPERATURE T	3.2SH1						REVISION # :00		
	PRESSURE P	3.2SH1						DATE :J9/04/84		
	REL. HUMDTY H	3.2SH1						SYSTEM :SERVICE WATER		
	CHEM. SFRAY C	3.2SH1						TAG :2SW-B90SB-1		
	RADIATION R	3.2SH1								
	AGING A	3.2SH1								
	SUBMERGENCE S	3.2SH1								
EQ. PCK # : 3.2SH1	C588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 2SW-89QSB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 107*10 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE					
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW							
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER: HAMMEL DAHL/COM OFLOW					SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:				
MODEL AND SERIAL #: EA-180-113C2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1SH1	REVIEW							
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.04ER	RAB11R3 FSAR SEC 3.11B	REF(1) PG.1C-7 4-5	COMB. TEST & SUPPL.	H	NONE					
SPECIFICATIONS: M-66H					SRSR 9.1SH1	REVIEW							
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: AB11					SRSA 9.1SH1	REVIEW							
COORDINATES X- 1435. Y- 166L. Z- 230.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EO PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*****	OPERABILITY O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CESN-3193			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1											
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1											
*	REL. HUMDTY H	9.1SH1											
*	CHEM. SPRAY C	9.1SH1											
*****	RADIATION R	9.1SH1											
	AGING A	9.1SH1											
	SUBMERGENCE S	9.1SH1											
EQ. PCK #: 9.1SH1	OS8R CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: SERVICE WATER TAG: 2SW-89QSB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3AF-P1SA-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVES	NORM/TEST DBA				SRS03.10SH1				
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 2 DBA	TAB21A FSAR SEC 3.11B	REF(1) ADDN2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF(2)
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	0.420	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF(2)
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 2 DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NH90	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES. & SERVICE: VALVE OPERATOR	R GAMMA	2.6E4	5.7E6	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA		NORM & DBA						
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-66M	S T.I.D.	2.6E4							
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CHR
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
COORDINATES X- 1484. Y- 1521. Z- 248.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF: BY-FLD	OPERABILITY O	3.10SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	3.10SH1							
*****	PRESSURE P	3.10SH1							CES#-3214
*QUALIF: QUALIFIED	REL. HUMDTY H	3.10SH1							
*STATUS	CHEM. SPRAY C	3.10SH1							
*	RADIATION R	3.10SH1							
*	AGING A	3.10SH1							
*****	SUBMERGENCE S	3.10SH1							
EQ. PCK #: 3.10SH1									
	Q588 CATEG.: A								
	APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
(2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.

REVISION #: 00
DATE: 09/14/84

SYSTEM: AUXILIARY FEEDWTR
TAG: 3AF-P1SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3AF-P1SA-1	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH#1 (1 OF 2)	TEMPERATURE	104F NORM 104F CRA		TAB21A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:	
MANUFACTURER: ITT HAMMEL DAHL / CONOFL	PRESSURE	ATMOS NORM ATMOS CRA		PAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% CRA		HAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: LATER	R GAMMA	2.6E4		RAB21R7 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4								
SPECIFICATIONS: M-66N	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CRHR	
P.O #: 435176	SURMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21					SRSS					
COORDINATES X- 1484. Y- 1521. Z- 248.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O		REFERENCES:				CES#-3215			
*****	TEMPERATURE T									
*QUALIF:	PRESSURE P									
*STATUS	REL. HUMDTY H									
*	CHEM. SPRAY C									
*	RADIATION R									
*****	AGING A						REVISION # :00			
	SURMERGENCE S						DATE :			
EQ. PCK # :	C585 CATEG.: A						SYSTEM : AUXILIARY FEEDWTR			
	APPENDIX E						TAG : 3AF-P1SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3AF-P2SB-1	OPERABILITY	40YRS NORM 1YR DBA	40YRS NORM 1YR DBA	OPER. REVIEW	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: VALVES TYPE	NORM/TEST DBA				SRS03.10SH1			
COMPONENT: ELECTRO-HYD OPERATOR	TEMPERATURE	104F NORM 104F DBA	122F NORM 5 DBA	TAB21A FSAR SEC 3.11B	REF(1) ADD#2 P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ITT	PRESSURE	ATMOS NORM ATMOS DBA	10" H2O	PAB21 FSAR SEC 3.11B	REF(1)P-2	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 5 DBA	HAB21 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: NH90	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES. & SERVICE: VALVE OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRS03.10SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	5.7E6	RAB21R7 FSAR SEC 3.11B	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	M	NONE
SPECIFICATIONS: M-66M	D B SHIELD	100%			SRSR3.10SH1			
P.O #: 435176	S T.I.D.	2.6E4						
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YPS	10 CFR50 PARA. 50.51	REF(1)P-6	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1499. Y- 1520. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF: BY-FLD	OPERABILITY O	3.10SH1						
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	3.10SH1						
*****	PRESSURE P	3.10SH1						
*QUALIF: QUALIFIED	REL. HUMPTY H	3.10SH1						
*STATUS	CHEM. SPRAY C	3.10SH1						
*	RADIATION R	3.10SH1						
*	AGING A	3.10SH1						
*****	SUBMERGENCE S	3.10SH1						
EQ. PCK #: 3.10SH1	D588 CATEG.: A							
	APPENDIX E							

REPLACEMENT: REF(2)

MAINTAIN.: REF(2)

SUBCOMPONENTS:

NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: CHR

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.10SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.10SH1

CES#-3216

REFERENCES: (1)NH90 QUALIFICATION REPORT #721.77.095.
 (2)NH91 & NH95 ACTUATOR MAINTENANCE SCHEDULE #721.81.132.

REVISION #: 00
 DATE: 09/14/84

SYSTEM: AUXILIARY FEEDWTR.
 TAG: 3AF-P2SB-1

A/E: EBAS /ICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON HARRY
 COMPONENT EVALUATION S - 1

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					DEM. QUALIF.
TAG NO : 3AF-P2SB-1	OPERABILITY			OPER. REVIEW			/	NONE	
EQUIPMENT TYPE : PRIMARY ELEMENT	NORM/TEST DBA				SRSO				
COMPONENT : LIMIT SWITCH#2(2 OF 2)	TEMPERATURE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B			M	NONE	REPLACEMENT:
MANUFACTURER: ITT HAMPPEL DAHL / CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B			M	NONE	MAINTAIN.:
MAJOR SUPPLIER : BLAKE EQUIPMENT					SRSR				SUBCOMPONENTS:
MODEL AND SERIAL # : LATER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B			/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE : LATER	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B			/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4		RAB21R7 FSAR SEC 3.11B			H	NONE	
SPECIFICATIONS: M-66N					SRSR				
P.O # : 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51			/	NONE	SAFETY FUNCTION: CPHR
PLANT LOC.: AB21					SRSA				
COORDINATES X- 1499. Y- 1520. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B			/	NONE	
					SRSS				
INSTALLED (Y/M): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
***** *QUALIF: *STATUS * * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	REFERENCES:				CES#-3217		
EQ. PCK # :	US88 CATEG.: A APPENDIX E						REVISION # : 00 DATE :		
							SYSTEM : AUXILIARY FEEDWTR TAG : 3AF-P2SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3AF-V187SA-1	OPERABIL- ITY	41YRS NORM 500 CYC	NORM: OVER 140YRS WITH 1917 CYC	OPER. REVIEW	REF(1)8(2) P.7,8&10	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	VALVE OPERATORS DBA				SRSO 3.3SH1					
COMPONENT:	MOTOR OPERATOR	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10 COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: APP A REF(1)	
MANUFACTURER:	LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(2)P.10 COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)	
MAJOR : SUPPLIER	YARWAY								SUBCOMPONENTS:	
MODEL AND: SERIAL #	SMB-00-15	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	MAB21 FSAR SEC 3.11B	REF(2)P.5 COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	AUX FEED PUMP 1A-SA RECIRC TO COND STORAGE TANK	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N.A COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04F7	RAB21R7 FSAR SEC 3.11B	REF(2) APP.11 COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	M-34Y									
P.O #:	435056	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)8(2) P.7 COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CRHR	
PLANT LOC.:	AB21									
COORDINATES	X- 1478. Y- 1533. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11P	N/A COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARA- METER								
QUALIF EXEMPTN:	NOT APPLIC	SUPPL. REVIEW								

*QUALIF:	QUALIFIED-AWAITING	OPERABILITY	O	3.3SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*STATUS	CONFIRMATORY DATA	TEMPERATURE	T	3.3SH1	REFERENCES: (1)LIMITORQUE REPORT #B0058 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT BUL03					CES#-3218
*		PRESSURE	P	3.3SH1						
*		REL. HUMDITY	H	3.3SH1						
*		CHEM. SPRAY	C	3.3SH1						
*		RADIATION	R	3.3SH1						

		AGING	A	3.3SH1						REVISION # :00
		SUBMERGENCE	S	3.3SH1						DATE :09/27/84
EQ. PCK # :	3.3SH1									SYSTEM :AUXILIARY FEEDWTR
		0588 CATEG.:	A							TAG :3AF-V187SA-1
		APPENDIX E								

A/E: EBAS VICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS. ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3AF-V188SB-1	OPERABILITY	41YRS NORM SUD CYC	NORM: OVER 40YRS WITH 1R17 CYC	OPER. REVIEW	REF(1)&(2) P.7,8&10	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: APP A REF(1)
COMPONENT: MOTOR OPERATOR	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)
MANUFACTURER: LIMITORQUE	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR : YARWAY SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N.A.	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: AUX FEED PUMP & SERVICE 1B-SB RECIRC TO COND STOR TANK	R GAMMA	2.6E4	2.74E7	RAB21R7 FSAR SEC 3.11B	REF(2) APP.11	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X							
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: M-34Y	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)&(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CRNR
P.O #: 435056	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21									
COORDINATES X- 1493. Y- 1533. Z- 236.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
*****	OPERABILITY O	3.3SH1		REFERENCES: (1)LIMITORQUE REPORT #B0058 (2)APP D OUTSIDE CONTAINMENT QUALIFICATION REPORT B0003			CES#-3220		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.3SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	3.3SH1							
*	REL. HUMIDTY H	3.3SH1							
*	CHEM. SPRAY C	3.3SH1							
*****	RADIATION R	3.3SH1							
	AGING A	3.3SH1							
	SUBMERGENCE S	3.3SH1							
EQ. PCK # : 3.3SH1	US88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/27/84 SYSTEM : AUXILIARY FEEDWTR TAG : 3AF-V188SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : 3CH-P1SB-1	OPERABILITY	40YRS NORM 50G CYC 1YR DBA	40YRS NORM 100% CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT: VALVES TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)		
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)		
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.		
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	4/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
MODEL AND SERIAL #: EA180-11302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE			
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
ACCUR. SPEC: NOT APPLICABLE	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE			
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.					CES#-3243		
P.O #: 435176	TEMPERATURE	T	9.1SH1								
PLANT LOC.: AB21	PRESSURE	P	9.1SH1								
COORDINATES X- 1572. Y- 1519. Z- 245.0	REL. HUMDTY	H	9.1SH1								
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	9.1SH1								
INSTAL. REF:RY-FLD	RADIATION	R	9.1SH1								
QUALIF EXEMPTN: NOT APPLIC	AGING	A	9.1SH1					REVISION # : 00 DATE : 07/18/84			
*****	SUBMERGENCE	S	9.1SH1					SYSTEM : ESS.SER.CHILLO WATER TAG : 3CH-91SB-1			
*****	0588 CATEG.: A										
*****	APPENDIX E										

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-R2SA-1	OPERABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 27,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	VALVE OPERATORS DBA	1 CYC	21 CYC		SRSO 3.2SH1	REVIEW				
COMPONENT:	SOLENOID VALV E	TEMPERAT- URE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSO 3.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A N/A SRSO 3.2SH1	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.75E8 2.75E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	H	NONE		
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.43 FIG 184, P.C-58C-8 SRSA 3.2SH1	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS:	M-66H	PLANT LOC.:	AB21							
P.O #:	435176	COORDINATES X- Y- Z-	1574. 1519. 245.0							
INSTALLED (Y/N):	LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A N/A SRSO 3.2SH1	/	NONE		
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY O	3.2SH1					CES#-3244		
*****		TEMPERATURE T	3.2SH1							
*QUALIF:	QUALIFIED-AWAITING	PRESSURE P	3.2SH1							
*STATUS	CONFIRMATORY DATA	REL. HUMDTY H	3.2SH1							
*		CHEM. SPRAY C	3.2SH1							
*		RADIATION R	3.2SH1							
*****		AGING A	3.2SH1							
		SUBMERGENCE S	3.2SH1							
EQ. PCK # :	3.2SH1	OS88 CATEG.:	A	REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				REVISION # :00 DATE :09/04/84		
		APPENDIX E						SYSTEM :ESS.SER.CHILLO WATER TAG :3CH-92SA-1.		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CH-R2SA-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: VALVES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MAJOR SUPPLIER: HAMMEL DAHL/COM OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
MODEL AND SERIAL #: EA180-11302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE					
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	1C CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-3245			
P.O #: 435176	TEMPERATURE	T	9.1SH1										
PLANT LOC.: AB21	PRESSURE	P	9.1SH1										
COORDINATES X- 1574. Y- 1519. Z- 245.0	REL. HUMDTY	H	9.1SH1										
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	9.1SH1										
INSTAL. REF: BY-FLD	RADIATION	R	9.1SH1										
QUALIF EXEMPTN: NOT APPLIC	AGING	A	9.1SH1										
*****	SUBMERGENCE	S	9.1SH1										
EQ. PCK #: 9.1SH1	OS88 CATEG.: A												
	APPENDIX E												
									REVISION #: 00 DATE: 09/18/84				
									SYSTEM: ESS. SER. CHILLO WATER TAG: 3CH-92SA-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-B3SA-1	OPERABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8,DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 21 CYC		REF 1,P.26 SRSD 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALV E	TEMPERAT- URE	104F NORM 104F DBA	120F NORM FOR DBA FIG F1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.: REF 1,APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMEL DAHL/ CONOFLOW								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	NP8320A175E	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	/	NONE		
FUNCT.DES: & SERVICE	CONTROL AIR TO PNEUM.OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE						SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.35E8 2.35E8	PAB21R7 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	H	NONE		
SPECIFICATIONS:M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	/	NONE	SAFETY FUNCTION: SS	
P.O #:435176										
PLANT LOC.: AB21										
COORDINATES X- Y- Z-	1574. 1519. 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLO QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		OPERABILITY O	3.2SH1					CES#-3246		
		TEMPERATURE T	3.2SH1							
		PRESSURE P	3.2SH1							
		REL. HUMDTY H	3.2SH1							
		CHEM. SFRAY C	3.2SH1							
		RADIATION R	3.2SH1							
		AGING A	3.2SH1							
		SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1		0588 CATEG.: A APPENDIX E		REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				REVISION # :00 DATE :09/04/84		
								SYSTEM :ESS.SER.CHILLO WATER TAG :3CH-B3SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 3CH-B3SA-1	OPERABIL- ITY	40YRS. NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.1SH1				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW					SRSP 9.1SH1			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA180-11302	RELATIVE HUMIDITY	2G-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
FUNCT. DES: & SERVICE	POSITION INDICATION					SRSH 9.1SH1			(1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC:	NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 2.04E8 100% 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-66H		AGE- INST LIFE (PEP 323- 1974 DEF.)	40 YEARS 40YRS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
COORDINATES X- 1574. Y- 1519. Z- 245.0						SRSS 9.1SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*QUALIF: QUALIFIED-AWAITING		OPERABILITY O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3267		
*STATUS CONFIRMATORY DATA		TEMPERATURE T	9.1SH1							
*		PRESSURE P	9.1SH1							
*		REL. HUMDTY H	9.1SH1							
*		CHEM. SPRAY C	9.1SH1							
*		RADIATION R	9.1SH1							
		AGING A	9.1SH1					REVISION # : 00 DATE : 09/19/84		
EQ. PCK # : 9.1SH1		SUBMERGENCE S	9.1SH1					SYSTEM : ESS.SER.CHILLD WATER TAG : 3CH-B3SA-1		
		OS88 CATEG.: A APPENDIX E								



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-B4SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YPS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	VALVES									
COMPONENT:	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.664 100% 2.664	2.74FB 	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 	40YRS 	10 CFR50 PARA.SU.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	M-66H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:	435176	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
PLANT LOC.:	AB21	OPERABILITY	O 9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3249		
COORDINATES X-	1584.	TEMPERATURE	T 9.1SH1							
Y-	1521.	PRESSURE	P 9.1SH1							
Z-	245.0	REL. HUMDTY	H 9.1SH1							
INSTALLED (Y/N):	LTR	CHEM. SPRAY	C 9.1SH1							
INSTAL. REF:	BY-FLD	RADIATION	R 9.1SH1							
QUALIF EXEMPTN:	NOT APPLIC	AGING	A 9.1SH1					REVISION # :00 DATE :09/18/84		
*STATUS CONFIRMATORY DATA	*	SUBMERGENCE	S 9.1SH1					SYSTEM :ESS.SER.CHILLO WATER		
*QUALIF: QUALIFIED-AWAITING	*	US88 CATEG.:	A					TAG :3CH-B4SB-1		
*STATUS CONFIRMATORY DATA	*	APPENDIX E								

A/E: EBASCO SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARON HARRY P - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CH-V128SA-1	OPERABILITY	NORM: 40 YRS 500 CYC DBA: 1 YR 1 CYC	NORM: 4 CYRS 20, 100 CYC DBA: 1 YR 21 CYC	OPER. REVIEW	NORM: REF 1 P. 6, DBA: REF 1, P. 26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5 MAINTAIN.: REF 1, APP.C
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SHSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
MODEL AND SERIAL #: NP8320A175E	R GAMMA	3.7E4	2.05E8	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	D B SHIELD	100%							
ACCUR. SPEC: NOT APPLICABLE	S T.I.D.	3.7E4	2.05E8						
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: M-66H	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O. #: 435176									
PLANT LOC.: AB51									
COORDINATES X- 164E, Y- 1689, Z- 305.0									
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
INSTAL. REF: BY-FLO	METER								
QUALIF EXEMPT: NOT APPLIC	OPERABILITY	O 3.2SH1							CES#-3252
*****	TEMPERATURE	T 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 3.2SH1							
*STATUS CONFIRMATORY DATA	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*	RADIATION	R 3.2SH1							
*****	AGING	A 3.2SH1							
	SURMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	USBP CATEG.: A			REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982					REVISION # : 00 DATE : 09/04/84
	APPENDIX E								SYSTEM : ESS.SER.CHILLD WATER TAG : 3CH-V128SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-V1285A-1	OPERABILITY	40YRS NORM 500 CYC	140YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT; VALVES TYPE									
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/CON SUPPLIER OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: EA-180-11302 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEV.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 . 100% 3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51									
COORDINATES X- 1648. Y- 1689. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOR PUNCHLIST ITEMS SEE SM EQ PACKAGE: 9.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							CES#-3253
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMPTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1				REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.					REVISION # : 00 DATE : 09/18/84
	OS88 CATEG.: A APPENDIX E								SYSTEM : ESS.SER.CHILLD WATER TAG : 3CH-V1285A-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-V129SB-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 120, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 121 CYC		REF 1, P. 26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P. C-5 MAINTAIN.: REF 1, APP. C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER : HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: NP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	2.75E8	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P. C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
PLANT LOC.: AB51	COORDINATES X- 1648. Y- 1687. Z- 305.0				SRSS 3.2SH1				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
	OPERABILITY O	3.2SH1							CES#-3254
	TEMPERATURE T	3.2SH1							
	PRESSURE P	3.2SH1							
	REL. HUMIDTY H	3.2SH1							
	CHEM. SPRAY C	3.2SH1							
	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E								REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982
									REVISION # : 00 DATE : 09/04/84
									SYSTEM : ESS. SER. CHILLO WATER TAG : 3CH-V129SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-V129SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.7E4	2.74E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: M-66H	S T.I.D.	3.7E4								
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51	SURPERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1648. Y- 1687. Z- 305.C										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION '3 DATED 8/20/81.				CES#-3255		
*	TEMPERATURE	T 9.1SH1						REVISION # : JJ		
*	PRESSURE	P 9.1SH1						DATE : 09/18/84		
*	REL. HUMDTY	H 9.1SH1						SYSTEM : ESS.SER.CHILLD WATER		
*	CHEM. SPRAY	C 9.1SH1						TAG : 3CH-V129SB-1		
*	RADIATION	R 9.1SH1								
EQ. PCK # : 9.1SH1	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
	OS8B CATEG.: A									
	APPENDIX E									

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HARR
 COMPONENT EVALUATION - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 920 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CH-V130SA-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER SRST	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: HAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER SRSP	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : BLAKE EQUI SUPPLIER PMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	ESSENTIAL SER CH FOR AH-17 (1-4A-SA)	LATER	RAB5125 FSAR SEC 3.11B	LATER SRSR	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	NOT APPLICABLE	LATER	10 CFR50 PARA. 50.51	LATER SRSA	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	40 YEARS	LATER	SAB51 FSAR SEC 3.11B	LATER SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE
SPECIFICATIONS: M-32P	PARAMETER	NOT APPLICABLE	LATER					
P.O #: 435022	OPERABILITY							
PLANT LOC.: AB51	TEMPERATURE							
COORDINATES X- 1648. Y- 1687. Z- 305.0	PRESSURE							
INSTALLED (Y/N): LTR	REL. HUMDTY							
INSTAL. REF: BY-FLD	CHEM. SPRAY							
QUALIF EXEMPTN: NOT APPLIC	RADIATION							
*****	AGING							
*QUALIF: LATER	SUBMERGENCE							
*STATUS								
*								
*								

EQ. PCK # :								

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE:

CES#-3256

REVISION # :00
 DATE :

SYSTEM : ESS.SER.CHILLO
 WATER

TAG : 3CH-V130SA-1

OS88 CATEG.: A
 APPENDIX E

A/E: EBA (VICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS PP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 960 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-8755A-1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	PRIMARY ELEMENT DBA				SRSO 3.3SH1	REVIEW				
COMPONENT:	MOTOR OPERATOR	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER:	LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	MILLER ENER GY INC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	SMC-04-2-HORC	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE		R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE		
ACCUR. SPEC: NOT APPLICABLE		D B SHIELD	100%		SRSR 3.3SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE		S T.I.D.	2.6E4							
SPECIFICATIONS: M-44		AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435082		INST LIFE (PER 323- 1974 DEF.)								
PLANT LOC.: AR21		SUPERMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1493. Y- 1520. Z- 238.0		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EO PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
INSTALLED (Y/N): LTR		OPERABILITY	O 3.3SH1	REFERENCES:				CES#-3140		
INSTAL. REF: BY-FLO		TEMPERATURE	T 3.3SH1							
QUALIF EXEMPTH: NOT APPLIC		PRESSURE	P 3.3SH1							
*QUALIF: LATER		REL. HUMDTY	H 3.3SH1							
*STATUS		CHEM. SPRAY	C 3.3SH1							
*		RADIATION	R 3.3SH1							
*		AGING	A 3.3SH1							
*****		SUPERMERGENCE	S 3.3SH1							
EQ. PCK # : 3.3SH1		USRR CATEG.: A							REVISION # : 00	
		APPENDIX E							DATE :	
									SYSTEM : SERVICE WATER	
									TAG : 3SW-8755A-1	

A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-B7658-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMCS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : MILLER ENERGY INC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL # : SPC-04-2-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: FROM 3SW10-74S B-1 TO AUX FW PUMP 18-SR SUCT	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS: M-44	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
P.O #: 435082	OPERABILITY	O 3.3SH1		REFERENCES:			CESN-3142		
PLANT LOC.: AB21	TEMPERATURE	T 3.3SH1							
COORDINATES X- 1509.	PRESSURE	P 3.3SH1							
Y- 1526.	REL. HUMIDTY	H 3.3SH1							
Z- 238.0	CHEM. SPRAY	C 3.3SH1							
INSTALLED (Y/M): LTR	RADIATION	R 3.3SH1							
INSTAL. REF: BY-FLD	AGING	A 3.3SH1		REVISION # : 00			DATE :		
QUALIF EXEMPTN: NOT APPLIC	SUBMERGENCE	S 3.3SH1		SYSTEM : SERVICE WATER			TAG : 3SW-B7658-1		
*****	OS88 CATEG.: A			APPENDIX E					

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-877SB-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERAT-URE	104F NORM 104F DBA	LATFP	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LIPITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER : MILLER ENER GY INC	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: SMC-04-2-HOBC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	R GAMMA	2.6E4	LATER	RAB21R7 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X							
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	2.6E4							
SPECIFICATIONS: M-44	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435082	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB21	PARAMETER	SUPPL. REVIEW							
COORDINATES X- 1509. Y- 1521. Z- 238.0	OPERABILITY	O 3.3SH1							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.3SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*****	PRESSURE	P 3.3SH1							CES#-3144
*QUALIF: LATER	REL. HUMDTY	H 3.3SH1							
*STATUS	CHEM. SPRAY	C 3.3SH1							
*	RADIATION	R 3.3SH1							
*	AGING	A 3.3SH1							
*****	SUBMERGENCE	S 3.3SH1							REFERENCES:
EQ. PCK # : 3.3SH1	0588 CATEG.: A								REVISION # :00
	APPENDIX E								DATE :
									SYSTEM :SERVICE WATER
									TAG :3SW-877SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-B85A-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 3.3SH1					
COMPONENT: MOTOR OPERATOR	TEMPERATURE	95F NORM DBA	LATER	TYD31R FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	10-100% NORM DBA	LATER	HYD31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: SMB-00-10/H3BC	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: SW RETURN FROM AUX BLDG HDR. B TO SW RETURN	R GAMMA	1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100X			SRSR 3.3SH1					
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	1.8E4								
SPECIFICATIONS: M-44	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435082	INST LIFE (PER 323-1974 DEF.)				SRSA 3.3SH1					
PLANT LOC.: AR21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1636. Y- 1574. Z- 240.0					SRSS 3.3SH1					
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1		
INSTAL. REF: BY-FLD	OPERABILITY	O 3.3SH1		REFERENCES:				CESN-3146		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T 3.3SH1								
*****	PRESSURE	P 3.3SH1								
*QUALIF: LATER	REL. HUMIDTY	H 3.3SH1								
*STATUS	CHEM. SPRAY	C 3.3SH1								
*	RADIATION	R 3.3SH1								
*	AGING	A 3.3SH1								
*****	SUBMERGENCE	S 3.3SH1								
EQ. PCK # : 3.3SH1	US88 CATEG.: A	APPENDIX E							REVISION # : 00	
									DATE :	
									SYSTEM : SERVICE WATER	
									TAG : 3SW-B85A-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-V85SB-1	OPERABILITY	NORM: 40YRS 500 CYC	40YRS 120,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	121F NORM FOR DBA FIG F1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG F2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	2.35E8 100%	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51									
COORDINATES X- 1648. Y- 1665. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1						CES#-3258
EQ. PCK # : 3.2SH1				REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982					REVISION # : 00 DATE : 09/04/84
	D588 CATEG.: A APPENDIX E								SYSTEM : ESS.SEP.CHILLD WATER TAG : 3CH-V85SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CH-V855B-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100% CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: VALVES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MAJOR SUPPLIER: HANMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
MODEL AND SERIAL #: EA-180-11302	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-3259			
P.O #: 435176	TEMPERATURE	T	9.1SH1										
PLANT LOC.: AB51	PRESSURE	P	9.1SH1										
COORDINATES X- 1648. Y- 1665. Z- 305.0	REL. HUMIDTY	H	9.1SH1										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO	CHEM. SPRAY	C	9.1SH1										
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R	9.1SH1										
*****	AGING	A	9.1SH1										
* QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S	9.1SH1										
* STATUS CONFIRMATORY DATA	OS&E CATEG.: A												
* *****	APPENDIX E												
EQ. PCK # : 9.1SH1													
									REVISION # : 00 DATE : 09/18/84 SYSTEM : ESS.SER.CHILLO WATER TAG : 3CH-V855B-1				



A/E: EBAS SERVICES INC.
 UTILITY: PLINA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

49-0
 -3260

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS			
TAG NO : 3CH-V86SA-1	OPERABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 27,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE			
EQUIPMENT: TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 21 CYC								
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	123F NORM FOR DBA FIG E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5		
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: REF 1, APP.C		
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW								SUBCOMPONENTS:		
MODEL AND: SERIAL #	NP832DA175E	RELATIVE HUMIDITY	20-90%NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	/	NONE			
ACCUR. SPEC: NOT APPLICABLE											
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 2.05E8 100% 3.7E4	2.05E8	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: M-66H											
P.O #: 435176		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 1E4, P.C-58C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: ABS1											
COORDINATES X- 1648. Y- 1667. Z- 305.0		SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	/	NONE			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SURMERGENCE S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				CESW-3260		
EQ. PCK # : 3.2SH1		0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/04/84	
										SYSTEM : ESS. SER. CHILLD WATER TAG : 3CH-V86SA-1	

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HARBOR APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -3261

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 3CH-V86SA-1	OPERABILITY	40YRS NORM 5JL CYC	40YPS NORM 100% CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND SERIAL #: EA180-11302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	R GAMMA A PETA D B SHIELD S T.I.D.	3.7E4 100%	3.74E8	PAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEG: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YPS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176										
PLANT LOC.: AB51										
COORDINATES X- 1648. Y- 1667. Z- 305.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF PACKAGE IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3261		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1								
*	REL. HUMIDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK #: 9.1SH1	OSR8 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: ESS.SER.CHILLO WATER TAG: 3CH-V96SA-1	

A/E: EBAS SERVICES INC.
UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARBOR APP - 1
COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

0
3262

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CT-V855A-1	OPERABILITY	41YRS NORM 50U CYC	NORM: OVER 40YRS WITH 1917 CYC	OPER. REVIEW	REF(1)8(2) P.7,81U	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA				SRSO 3.3SH1				
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1)P.12 REF(2)P.10	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: APP A REF(1)
MANUFACTURER: LIMITORQUE	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(2)P.10	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: APP A REF(1)
MAJOR SUPPLIER: YARWAY	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(2)P.5	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND SERIAL #: SMB-00-15	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N.A	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: CONN BETWEEN 3 CT2-26SAB-1 & 3CT2-33SAB-1	R GAMMA	3.4E4	2.74E7	RAB11R3 FSAR SEC 3.11B	REF(2) APP. II	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 3.3SH1				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.4E4							
SPECIFICATIONS: M-34Y	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF(1)8(2) P.7	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
P.O #: 435056	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB11					SRSS 3.3SH1				
COORDINATES X- 1519. Y- 1603. Z- 219.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.3SH1
*****	OPERABILITY O	3.3SH1							CES#-3262
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.3SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	3.3SH1							
*	REL. HUMDTY H	3.3SH1							
*	CHEM. SPRAY C	3.3SH1							
*****	RADIATION R	3.3SH1							
	AGING A	3.3SH1							REVISION # : 00 DATE : 09/27/84
	SUBMERGENCE S	3.3SH1							SYSTEM : CONTAINMENT SPRAY
EQ. PCK # : 3.3SH1	U588 CATEG.: A APPENDIX E								TAG : 3CT-V855A-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.3SH1

REFERENCES: (1) LIMITORQUE REPORT #80058
(2) APP D OUTSIDE CONTAINMENT
QUALIFICATION REPORT 8003



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS
TAG NO : 3CX-B1SB-1	OPERABIL- ITY	NORM: 40YRS 500 CYC	NORM: 40YRS 27,100 CYC	OPER. REVIEW	NORM: PEF 1 P.8, DBA:	COMB. TEST &	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 121 CYC		REF 1, P.26 SRSO 3.2SH1	SUPPL. REVIEW		
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	129F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OP SIG NORM FOR DBA FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW							
MODEL AND: SERIAL #	NPR320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC P.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/ NONE
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/ NONE
ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D H SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.75E8 100X 2.75E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H NONE
SPECIFICATIONS: P-66H								
P.O #: 435176		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/ NONE
PLANT LOC.: AB21								
COORDINATES X- Y- Z-	1569. 1520. 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/ NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC								
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		PARAMETER	SUPPL. REVIEW					
		OPERABILITY O	3.2SH1					
		TEMPERATURE T	3.2SH1					
		PRESSURE P	3.2SH1					
		REL. HUMIDTY H	3.2SH1					
		CHEM. SPRAY C	3.2SH1					
		RADIATION R	3.2SH1					
		AGING A	3.2SH1					
		SUBMERGENCE S	3.2SH1					
EQ. PCK # : 3.2SH1								
		US88 CATEG.: A APPENDIX E						
					FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
					REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982			CES#-3266
								REVISION # : 00 DATE : 09/04/84
								SYSTEM : ESS. SER. CHILLD WATER TAG : 3CX-91SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CX-B2SA-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100% CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVES TYPE									
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/CON SUPPLIER OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: EA-180-11302 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O N: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1567. Y- 1520. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARA- METER OPERABILITY O TEMPERATURE T PRESSURE F REL. HUMPTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	SUPPL. REVIEW 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1 CES#-3269 REVISION # :00 DATE :09/18/84 SYSTEM :ESS.SER.CHILLO WATER TAG :3CX-B2SA-1
EQ. PCK # : 9.1SH1	OSFR CATEG.: A APPENDIX E				REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-B3SB-1	OPEPABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 27,100 CYC	OPER. REVIEW	NORM:REF 1 P.8,DEA: REF 1,P.26	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	VALVE OPERATORS	DBA 1 CYC	DBA:1YR 21 CYC		SPSO 3.2SH1					
COMPONENT:	SOLENOID VALVE(1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	127F NORM FOR DBA FIT E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.: REF 1,APP.C	
MANUFACTURER:	ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIT E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90%NORM 100% DBA	107% NORM 107% DBA	HAB21 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT.DES: & SERVICE	CONTROL AIR TO PNEUM.OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A N/A SRSC 3.2SH1	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.25E4 2.25E4	RAB21R7 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	H	NONE		
SPECIFICATIONS:	M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.A3 FIG 184, P.C-5&C-8 SRSA 3.2SH1	/	NONE	SAFETY FUNCTION: SS	
P.O #:	435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A N/A SRSS 3.2SH1	/	NONE		
COORDINATES X- Y- Z-	1582. 1535. 245.0	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
INSTALLED (Y/N):	LTR	OPERABILITY O	3.2SH1	REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982				CESN-327C		
INSTAL. REF:	BY-FLD	TEMPERATURE T	3.2SH1							
QUALIF EXEMPTN:	NOT APPLIC	PRESSURE P	3.2SH1							
*****		REL. HUMDTY H	3.2SH1							
*QUALIF: QUALIFIED-AWAITING	*	CHEM. SPRAY C	3.2SH1							
*STATUS CONFIRMATORY DATA	*	RADIATION R	3.2SH1							
*****		AGING A	3.2SH1					REVISION # :JJ		
*****		SUBMERGENCE S	3.2SH1					DATE :09/04/84		
EQ. PCK # :	3.2SH1	U588 CATEG.:	A					SYSTEM :ESS.SER.CHILLD WATER		
		APPENDIX F						TAG :3CX-B3SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CX-B3SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW		
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	176F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE
MODEL AND SERIAL #: FA180-11302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE
FUNCT. DES. & SERVICE: POSITION INDICATION	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE
SPECIFICATIONS: M-66H								
P.O #: 435176								
PLANT LOC.: AB21								
COORDINATES X- 1582. Y- 1535. Z- 245.0								
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW						
	OPERABILITY O	9.1SH1						
	TEMPERATURE T	9.1SH1						
	PRESSURE P	9.1SH1						
	REL. HUMIDTY H	9.1SH1						
	CHEM. SPRAY C	9.1SH1						
	RADIATION R	9.1SH1						
	AGING A	9.1SH1						
	SUBMERGENCE S	9.1SH1						
EQ. PCK #: 9.1SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT:
 SEE NOTE (1)

MAINTAIN.:
 SEE NOTE (1)

SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT
 NOTE:
 (1) PG.4-3,4-3.1 &
 4-3.2 OF REPORT
 QTR-105 REV 3
 DATED 8/20/81.

SAFETY FUNCTION:
 SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1.

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1SH1

CES#-3271

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

REVISION #: 00
 DATE: 09/18/84

SYSTEM: ESS.SER.CHILLO
 WATER
 TAG: 3CX-B3SB-1



A/E: E SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON H NPP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

V#- 0
 N-3272

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CX-B4SA-1	OPERABILITY	NORM: 40YRS 500 CYC	40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 1 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALV E	TEMPERATURE	104F NORM 104F DBA	127F NORM 100 DBA FIS E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW		NONE	REPLACEMENT: REF 1, FIG.1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIS F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW		NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW									SUBCOMPONENTS:
MODEL AND SERIAL #: KP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	17% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.35E8 2.35E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW		NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-5BC-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1582. Y- 1537. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*****	OPERABILITY	O 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							CES#-3272
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK #: 3.2SH1	0588 CATEG.: A APPENDIX F								REVISION # : 00 DATE : 09/04/84
					REFERENCES: 1. ASCO TEST REPORT MAQR-6736R/ R D DATED MARCH 1982				SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-B4SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CX-B4SA-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YPS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1								
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR : HAMMEL DAHL/COM SUPPLIER OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
FUNCT.DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.94E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
ACCUR. DEP.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
SPECIFICATIONS:M-66H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
P.O #:435176	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
PLANT LOC.: AB21	OPERABILITY	9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-3273			
COORDINATES X- 1582. Y- 1537. Z- 245.0	TEMPERATURE	9.1SH1											
INSTALLED (Y/N): LTR INSTAL. REF:RY-FLD QUALIF EXEMPTN: NOT APPLIC	PRESSURE	9.1SH1											
*****	REL. HUMIDTY	9.1SH1											
*QUALIF: QUALIFIED-AWAITING	CHEM. SPRAY	9.1SH1											
*STATUS CONFIRMATORY DATA	RADIATION	9.1SH1											
*****	AGING	9.1SH1											
*****	SUBMERGENCE	9.1SH1											
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX F								REVISION # :00 DATE :09/18/84 SYSTEM :ESS.SER.CHILLD WATER TAG :3CX-B4SA-1				



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-V111SA-1	OPERABIL-ITY	NORM:40YRS 500 CYC	NORM:40YRS 120,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 121 CYC		REF 1,P.26 [SRSO 3.2SH1]	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DBA	127F NORM FOR DBA	TAB51A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA	PAB51 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1,APP.C
MAJOR : HAMMEL DAHL/ SUPPLIER CONOFLOW			FIG F2A- 3.2SH1		SRSP 3.2SH1				SUBCOMPONENTS:
MODEL AND: NP8320A175E SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA	107% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1,SEC 9.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% - 3.7E4	2.75E8	RAB5125 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176					SRSA 3.2SH1				
PLANT LOC.: AB51									
COORDINATES X- 1647. Y- 1654. Z- 307.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1						CES#-3276
EQ. PCK # : 3.2SH1					REFERENCES: 1.ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982				REVISION # :03 DATE :09/04/84
	OS88 CATEG.: A APPENDIX E								SYSTEM : ESS.SEP.CHILLO WATER TAG : 3CX-V111SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO : 3CX-V111SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.		/	NONE	
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.		M	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.		M	NONE	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW					SRSP 9.1SH1	REVIEW				
MODEL AND SERIAL #: EA-120-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.		/	NONE	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.		/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	2.34E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.		H	NONE	
SPECIFICATIONS: M-66H					SRSR 9.1SH1	REVIEW				
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.		/	NONE	
PLANT LOC.: AB51					SRSA 9.1SH1	REVIEW				
COORDINATES X- 1647. Y- 1654. Z- 307.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.		/	NONE	
					SRSS 9.1SH1	REVIEW				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3277		
EQ. PCK #: 9.1SH1	OS&P CATEG.: A APPENDIX E							REVISION #: 00 DATE: 09/18/84		
								SYSTEM: ESS.SER.CHILLO WATER TAG: 3CX-V111SA-1		

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTE:

(1)PG.4-3,4-3.1 &
4-3.2 OF REPORT
QTR-105 REV 3
DATED 8/20/81.

SAFETY FUNCTION:
SS



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V113SA-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: .	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: .	
MAJOR SUPPLIER : PACIFIC					SRSO				SUBCOMPONENTS: .	
MODEL AND: EA-180 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: ESSENTIAL SER & SERVICE CX FOR AH-15 (1A-SA)	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-32P					SRSR					
P.O #: 435022	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1607. Y- 1687. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O						CESN-3278		
*QUALIF: LATER	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :	USBR CATEG.: A			REFERENCES:				REVISION # : 00 DATE :		
	APPENDIX E							SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V113SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CX-V114SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 120, 100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 121 CYC		SRSO 3.2SH1			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	123F NORM FOR DBA FIG E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.7E4	2.05E8	RAB5125	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	M	NONE
ACCUR. DEM.: NOT APPLICABLE	A BETA			FSAR SEC 3.11B				
SPECIFICATIONS: M-66H	D B SHIELD	100X						
P.O #: 435176	S T.I.D.	3.7E4	2.35E8		SRSR 3.2SH1			
PLANT LOC.: AB51	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P.A3 FIG 184, P.C-5RC-8	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1648. Y- 1681. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 3.2SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1						
*	REL. HUMIDTY	H 3.2SH1						
*	CHEM. SPRAY	C 3.2SH1						
*****	RADIATION	R 3.2SH1						
	AGING	A 3.2SH1						
	SURMERGENCE	S 3.2SH1						
EQ. PCK # : 3.2SH1	USRB CATEG.: A APPENDIX E							

REPLACEMENT:
 REF 1, FIG.1,
 P.C-5
 MAINTAIN.:
 REF 1, APP.C
 SUBCOMPONENTS:

NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCHLIST ITEMS SEE SH E9 PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.2SH1

CES#-3280

REFERENCES: 1. ASCO TEST REPORT NAQR-67368/
 R D DATED MARCH 1982

REVISION # : 00
 DATE : 09/04/84

SYSTEM : ESS.SER.CHILLO
 WATER
 TAG : 3CX-V114SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V114SA-1	OPERABIL- ITY	40YRS NORM 50G CYC	40YRS NORM 107300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	HAMEL DAHL/CON OFLOW				SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	107% NORM 107% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
FUNCT. DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	(1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
ACCUR. SPEC: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 2.74E8 100% 3.7E4	2.74E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEM.: NOT APPLICABLE		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: M-66H		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
COORDINATES X- 1648. Y- 1681. Z- 305.0						SRSS 9.1SH1	REVIEW			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O	9.1SH1					CES#-3281		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T	9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P	9.1SH1							
*	REL. HUMIDTY	H	9.1SH1							
*	CHEM. SPRAY	C	9.1SH1							
*****	RADIATION	R	9.1SH1							
	AGING	A	9.1SH1							
	SUBMERGENCE	S	9.1SH1							
EQ. PCK # : 9.1SH1	058R CATEG.: A APPENDIX E			REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION # : 00 DATE : 09/18/84 SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V114SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-V115SB-1	OPERABILITY	NORM: 4YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DRA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	DBA	DBA: 1YR 1 CYC	DBA: 1YR 1 CYC		SRSD 3.2SH1	REVIEW			
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA F7% E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA F7% F2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.7E4	2.75E8	RAB5125	REF 1, SEC	COMB.	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA			FSAR SEC	4.1.4 &	TEST &			
SPECIFICATIONS: M-66H	D B SHIELD	100X		3.11B	4.2.2	SUPPL.			
P.O #: 435176	S T.I.D.	3.7E4	2.75E8		SRSR 3.2SH1	REVIEW			
PLANT LOC.: AB51	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1648. Y- 16R3. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*****	OPERABILITY O	3.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE F	3.2SH1				CES#-3292			
*	REL. HUMDTY H	3.2SH1							
*	CHEM. SPRAY C	3.2SH1				REFERENCES: 1. ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982			
*****	RADIATION R	3.2SH1							
	AGING A	3.2SH1				REVISION # : 00 DATE : 09/04/84			
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	OS8P CATEG.: A				SYSTEM : ESS.SER.CHILLED WATER				
	APPENDIX E				TAG : 3CX-V115SB-1				



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V115SB-1	OPEPABIL- ITY NORM/TEST DBA	40YRS NORM 50G CYC 1YR DBA	40YRS NORM 107300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	VALVES									
COMPONENT: MANUFACTURER: NAMCO	LIMIT SWITCH (1 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TA951A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	F	NONE	REPLACEMENT: SEE NOTE (1)
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 177% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	2.34E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	435176									
PLANT LOC.:	AB51									
COORDINATES	X- 1648. Y- 16R3. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	RY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1
*****		OPERABILITY	O 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							CES4-3283
*STATUS	CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*		REL. HUMIDTY	H 9.1SH1							
*		CHEM. SPRAY	C 9.1SH1							
*****		RADIATION	R 9.1SH1							REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.
		AGING	A 9.1SH1							REVISION # :00 DATE :09/18/84
		SUBMERGENCE	S 9.1SH1							SYSTEM :ESS.SER.CHILLD WATER TAG :3CX-V115SB-1
EQ. PCK # :	9.1SH1									
		USE8 CATEG.:	A							
		APPENDIX	E							

A/E: EBAS SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARSON HARRIS
 COMPONENT EVALUATION SHEET - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 3290

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V243SR-1	OPERABIL- ITY	NORM:40YRS 500 CYC	NORM:40YRS 120,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 121 CYC		SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	127F NORM FOR DBA FIG F1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW									
MODEL AND: SERIAL #	NP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	2.05E8 2.05E8	RAB2110 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.5G.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #:	435176	SUBMERGED LEVEL.	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
COORDINATES X- Y- Z-	1607. 1579. 250.0									
INSTALLED (Y/N):	LTR	PARA- METER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
INSTAL. REF:	RY-FLD	OPERABILITY O	3.2SH1							
QUALIF EXEMPTN:	NOT APPLIC	TEMPERATURE T	3.2SH1							
*****		PRESSURE P	3.2SH1					CES#-3290		
*QUALIF: QUALIFIED-AWAITING	*	REL. HUMDTY H	3.2SH1							
*STATUS CONFIRMATORY DATA	*	CHEM. SPRAY C	3.2SH1							
*	*	RADIATION R	3.2SH1							
*****		AGING A	3.2SH1							
		SUBMERGENCE S	3.2SH1							
EQ. PCK # :	3.2SH1	0588 CATEG.:	A	REFERENCES: 1.ASCO TEST REPORT #AGR-67368/ R O DATED MARCH 1982				REVISION # :00 DATE :09/04/84		
		APPENDIX E						SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V243SR-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO : 3CX-V244SR-1	OPERABIL-ITY	NORM: 40YRS 500 CYC	NORM: 40YRS 120,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT: VALVE OPEATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 121 CYC		SRSO 3.2SH1	REVIEW		
COMPONENT: SOLENOID VALVE	TEMPERAT-URE	104F NORM 104F DBA	120F NORM 107 DBA FIG E1A- 3.2SH1	TAB31A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB31 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : HAMMEL DAHL/ SUPPLIER CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: NP8320A175E SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES: CONTPOL AIR TO & SERVICE PNEUM. OPERATOR	R GAMMA	2.6E4	2.75E8	RAB3111 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D Θ SHIELD	100%						
ACCUR. DEP.: NOT APPLICABLE	S T.I.D.	2.6E4	2.75E8					
SPECIFICATIONS: M-66H	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA-50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE
PLANT LOC.: AB31	PARA-METER	SUPPL. REVIEW						
COORDINATES X- 1546. Y- 1626. Z- 263.0	OPERABILITY O	3.2SH1						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T	3.2SH1						
*****	PRESSURE P	3.2SH1						
*QUALIF: QUALIFIED-AWAITING	REL. HUMDTY H	3.2SH1						
*STATUS CONFIRMATORY DATA	CHEM. SPRAY C	3.2SH1						
*	RADIATION R	3.2SH1						
*	AGING A	3.2SH1						
*****	SUBMERGENCE S	3.2SH1						
EQ. PCK # : 3.2SH1	OSRB CATEG.: A APPENDIX E							

REPLACEMENT:
 REF 1, FIG.1,
 P.C-5
 MAINTAIN.:
 REF 1, APP.C
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.2SH1

CES#-3292

REFERENCES: 1.ASCO TEST REPORT #AGR-67368/
 R O DATED MARCH 1982

REVISION # : 00
 DATE : 09/04/84

SYSTEM : ESS.SER.CHILLD
 WATER
 TAG : 3CX-V244SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL				
TAG NO : 3CX-V244SB-1	OPERABIL-ITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES	TEMPERAT-URE	104F 40YRS 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
COMPONENT: LIMIT SWITCH (1 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP.9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
MAJOR SUPPLIER: HAMMEL DAHL/COM OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: EA-180-11302	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.34E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7 SPSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-3293		
P.O #: 435176	TEMPERATURE	T	9.1SH1							
PLANT LOC.: AB31	PRESSURE	P	9.1SH1							
COORDINATES X- 1546. Y- 1626. Z- 263.0	REL. HUMDTY	H	9.1SH1							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C	9.1SH1							
*****	RADIATION	R	9.1SH1							
*****	AGING	A	9.1SH1					REVISION # :00 DATE :09/18/84		
*****	SUBMERGENCE	S	9.1SH1					SYSTEM :ESS.SER.CHILLO WATER TAG :3CX-V244SB-1		
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E									

A/E: EBAS SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 (CAPACITY: 900 MW(E))

0
 3294

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CX-V245SB-1	OPERABILITY	NORM: 4 YRS SUC CYC	NORM: 40 YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. R, DBA:	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1 YR 1 CYC	DBA: 1 YR 21 CYC		REF 1, P. 26 SRSO 3.2SH1	REVIEW		
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB31A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OP SIG NORM FOR DBA FIG E2A- 3.2SH1	PAB31 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: NP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	ACCUR. SPEC: NOT APPLICABLE				SRSC 3.2SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 10UX 2.6E4	2.05E8	RAB3111 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P. C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435176	PLANT LOC.: AB31							
COORDINATES X- 1550. Y- 1762. Z- 265.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 3.2SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1						
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1						
*	REL. HUMIDTY	H 3.2SH1						
*	CHEM. SPRAY	C 3.2SH1						
*****	RADIATION	R 3.2SH1						
	AGING	A 3.2SH1						
	SUBMERGENCE	S 3.2SH1						
EQ. PCK #: 3.2SH1	CS&R CATEG.: A APPENDIX E							

REPLACEMENT:
 REF 1, FIG. 1,
 P.C-5
 MAINTAIN.:
 REF 1, APP. C
 SUBCOMPONENTS:
 NO UNIQUE TAGGED
 SUBCOMPONENTS ARE
 ENVELOPED BY THIS
 EQUIPMENT

SAFETY FUNCTION:
 SS

FOR PUNCHLIST ITEMS SEE SH EG PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.2SH1

CES#-3294

REFERENCES: 1. ASCO TEST REPORT #AOR-67368/
 R D DATED MARCH 1982

REVISION #: 00
 DATE: 09/06/84

SYSTEM: ESS. SER. CHILLO
 WATER
 TAG: 3CX-V245SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-V245SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES. & SERVICE POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA	4.4E5							
SPECIFICATIONS: M-66H	D B SHIELD	100%							
P.O #: 435176	S T.I.D.	2.6E4							
PLANT LOC.: AB31	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1550. Y- 1762. Z- 265.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY O	9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.			CES#-3295		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1							
*	REL. HUMPTY H	9.1SH1							
*	CHEM. SPRAY C	9.1SH1							
*****	RADIATION R	9.1SH1							
	AGING A	9.1SH1		REVISION # :00 DATE :09/18/84					
	SURFURGENCE S	9.1SH1		SYSTEM : ESS.SER.CHILLD WATER			TAG : 3CX-V245SB-1		
EQ. PCK # : 9.1SH1	G588 CATEG.: A			APPENDIX F					

A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARBOR APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 3305

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V63SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO									MAINTAIN.:	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	SEE NOTE (1)	
MODEL AND SERIAL #: EA-180-113C2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1489. Y- 166. Z- 239.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/M): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							CES#-3305	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1								
*	REL. HUMDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SURMERGENCE	S 9.1SH1								
EQ. PCK # : 9.1SH1										
	OS88 CATEG.: A APPENDIX E								REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.	
									REVISION # : 00 DATE : 09/18/84	
									SYSTEM : ESS.SER.CMILLO WATER TAG : 3CX-V63SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-V83SA-1	OPERABIL- ITY	NORM:4CYRS 500 CYC	NORM:4CYRS 20,100 CYC	OPER. REVIEW	NORM:REF 1 P.8,DRA: REF 1,P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	DBA:1Y9 1 CYC	DBA:1YR 21 CYC						
COMPONENT: SOLENOID VALV E	TEMPERAT- URE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 [SRST 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	REPLACEMENT: REF 1,FIG.1, P.C-5 MAINTAIN.: REF 1,APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	0PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1,P.26 FIG 4.2 [SRSP 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MAJOR : HAMMEL DAHL/ SUPPLIER CONOFLOW	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1,SEC 8.1.3 & 8.2.3 [SRSH 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: CONTROL AIR TO & SERVICE PNEUM.OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A [SRSC 3.2SH1]	N/A REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.75E8 [2.05E8]	RAB21R6 FSAR SEC 3.11B	REF 1,SEC 4.1.4 & 4.2.2 [SRSR 3.2SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	SPECIFICATIONS:M-66H								
P.O #:435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1,P.43 FIG 124, P.C-58C-8 [SRSA 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1471. Y- 1620. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A [SRSS 3.2SH1]	N/A REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*****	OPERABILITY O	3.2SH1		REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982					CES#-3306
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	3.2SH1							
*	REL. HUMDTY H	3.2SH1							
*	CHEM. SPRAY C	3.2SH1							
*****	RADIATION R	3.2SH1							
	AGING A	3.2SH1							
	SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1	0588 CATEG.: A APPENDIX E								REVISION # :00 DATE :09/04/84 SYSTEM :ESS.SER.CHILLD WATER TAG :3CX-V83SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : 3CX-V83SA-1	OPERABILITY	40YRS NORM 50C CYC 1YR DBA	40YRS NORM 100% CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT TYPE: VALVES												
COMPONENT: LIMIT SWITCH(1 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)			
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)			
MAJOR SUPPLIER: HAMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:			
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES. & SERVICE: POSITION, INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.			
ACCUR. SPEC: NOT APPLICABLE												
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.34E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE				
SPECIFICATIONS: M-66H												
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DFF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12. SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
PLANT LOC.: AB21												
COORDINATES X- 1471. Y- 162C. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-3307		
	TEMPERATURE	T 9.1SH1										
	PRESSURE	P 9.1SH1										
	REL. HUMIDTY	H 9.1SH1										
	CHEM. SPRAY	C 9.1SH1										
	RADIATION	R 9.1SH1										
	AGING	A 9.1SH1										
	SUBMERGENCE	S 9.1SH1							REVISION # : 00 DATE : 09/18/84			
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E								SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V83SA-1			

A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEPARD HARBOR WPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 3310

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W10SB-1	OPERABIL- ITY	NORM: 4 YRS 500 CYC	NORM: 4 YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA: 1 YR 1 CYC	DBA: 1 YR 21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERAT- URE	104F NORM 104F DBA	123F NORM FOR DBA FTG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	NP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	1977 NORM 1977 DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	/	NONE		
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BFTA D B SHIELD S T.I.D.	2.6E4 100%	2.75E8 2.75E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	H	NONE		
SPECIFICATIONS: M-66H										
P.O # : 435176		AGF- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-5&C-8 SRSA 3.2SH1	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- Y- Z-	1453. 1546. 240.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A N/A	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****		OPERABILITY	O 3.2SH1					CESN-3310		
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA		PRESSURE	P 3.2SH1							
*		REL. HUMDTY	H 3.2SH1							
*		CHEM. SPRAY	C 3.2SH1							
*****		RADIATION	R 3.2SH1							
		AGING	A 3.2SH1							
		SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1		0588 CATEG.: A APPENDIX E		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				REVISION # : 00 DATE : 09/04/84		
								SYSTEM : ESS. SER. CHILLO WATER TAG : 3CX-W10SB-1		

A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARTMAN NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -3312

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W12SB-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P. C-5 MAINTAIN.: REF 1, APP. C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & R. 2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.75E8	RAB21R6 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P. 43 FIG 1R4, P. C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176					SRSA 3.2SH1				
PLANT LOC.: AB21									
COORDINATES X- 1522. Y- 1609. Z- 260.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMDTY	H 3.2SH1							
*	CHEM. SFRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK #: 3.2SH1	0588 CATEG.: A APPENDIX F								
FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982						CES#-3312			
						REVISION #: 00 DATE: 09/04/84			
						SYSTEM: ESS, SER. CHILLO WATER			
						TAG: 3CX-W12SB-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W13SR-1	OPERABILITY	NORM: 4YRS 5JC CYC	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		REF 1, P.26 SR50 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG F1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.25E8 2.75E8	RAB21R6 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS: M-65H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
P.O #: 435176										
PLANT LOC.: AB21										
COORDINATES X- 1515. Y- 1609. Z- 240.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PAPA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1.				QUALIFICATION SIGN-OFF FOUNO IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGTNG A SUBMERGENCE S	3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1 3.2SH1		REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				CES#-3314 REVISION # : 00 DATE : 09/04/84		
EQ. PCK # : 3.2SH1	OSER CATEG.: A APPENDIX E							SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-W13SR-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION			QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : 3CX-W14SB-1	OPERABILITY	NORM: 47YRS 500 CYC	NORM: 40YRS 120, 100 CYC	OPER. REVIEW	NORM: REF 1 P.R. DBA: REF 1, P.26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	09A: 1YR 1 CYC	08A: 1YR 21 CYC						
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM FOR DBA FIG E2A- 3.2SH1	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAPMA	2.6E4	2.75E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS: M-66H	S T.I.D.	2.6E4	2.75E8						
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
COORDINATES X- 1544. Y- 1547. Z- 240.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTM: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*QUALIF: QUALIFIED-AWAITING *STATUS: CONFIRMATORY DATA	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982			CES#-3316		
*	TEMPERATURE	T 3.2SH1							
*	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	G582 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/04/84 SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-W14SB-1

A/E: EBASCO SERVICES INC.
 UTILITY: MAIN POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

U-0
 3318

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-WISSA-1	OPERABILITY	NORM: 40 YRS 500 CYC	100% 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA:	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	09A: 1 YP 1 CYC	09A: 1 YR 21 CYC		REF 1, P. 26 [RSO 3.2SH1]				
COMPONENT: SOLENOID VALVE	TEMPERATURE	95F NORM 95F 09A	120F NORM FOR DBA FIG E1A- 3.2SH1	TYD31R FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS 09A	OPSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	10-10% NORM 100% 09A	10% NORM 100% DBA	HYD31 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 [RSR 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT.
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	1.8E4	2.05E8	RAB2110 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 [RSR 3.2SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEP.: NOT APPLICABLE	A BETA								
SPECIFICATIONS: M-66H	D B SHIELD	100%							
P.O #: 435176	S T.I.D.	1.8E4	2.05E8						
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 [RSA 3.2SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1636. Y- 1667. Z- 240.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY	0	3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
	TEMPERATURE	T	3.2SH1						CES#-3318
	PRESSURE	P	3.2SH1						
	REL. HUMDTY	H	3.2SH1						
	CHEM. SPRAY	C	3.2SH1						
	RADIATION	R	3.2SH1						
	AGING	A	3.2SH1						
	SURMERGENCE	S	3.2SH1						
EQ. PCK # : 3.2SH1	US88 CATEG.: A APPENDIX E								REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982
									REVISION # : 00 DATE : 09/04/84
									SYSTEM : ESS. SER. CHILLO WATER TAG : 3CX-WISSA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W16SA-1	OPERABILITY	NORM: 40YRS 500 CYC NORM/TEST DBA DBA: 1YR 1 CYC	NORM: 40YRS 170,100 CYC DBA: 1YR 121 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA: REF 1, P. 26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG F1A- 3.2SH1	TAB41A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P. C-5
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG F2A- 3.2SH1	PAB41 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM DBA	HAB41 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
MODEL AND SERIAL #: NP8320A175E	R GAPMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.35E8	RAB4117 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	140 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P. C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: M-66H	OPERABILITY	O	3.2SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
P.O #: 435176	TEMPERATURE	T	3.2SH1						CES#-3320
PLANT LOC.: AB41	PRESSURE	P	3.2SH1						
COORDINATES X- 1561. Y- 1635. Z- 286.0	REL. HUMDITY	H	3.2SH1						
	CHEM. SPRAY	C	3.2SH1						
	RADIATION	R	3.2SH1						
	AGING	A	3.2SH1						
	SUBMERGENCE	S	3.2SH1						
INSTALLED (Y/N): LTR				REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982					REVISION # : 00 DATE : 09/04/84
INSTAL. REF: BY-FLD									SYSTEM : ESS.SER.CHILLO WATER
QUALIF EXEMPTN: NOT APPLIC									TAG : 3CX-W16SA-1

*QUALIF: QUALIFIED-AWAITING									
*STATUS CONFIRMATORY DATA									
* *****									
EQ. PCK # : 3.2SH1	0588 CATEG.: A								
	APPENDIX E								



A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON PARK HPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -3323

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL			
TAG NO : 3CX-W17SA-1	OPERABILITY			OPER. REVIEW			NONE
EQUIPMENT TYPE: PRIMARY ELEMENT	NORM/TEST DBA				SRSO		
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B			NONE
MANUFACTURER: ITT HAMMEL DAHL / CONOFL	PRESSURE	ATMOS NORM ATMOS DBA		PA951 FSAR SEC 3.11B			NONE
MAJOR SUPPLIER: BLAKE EQUIPMENT	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HA951 FSAR SEC 3.11B			NONE
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE		CA951 FSAR SEC 3.11B			NONE
FUNCT. DES. & SERVICE: ESSENTIAL SER CX FOR AH-15 (1A-SA)	R GAMMA	3.7E4		RA95125 FSAR SEC 3.11B			NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA						
ACCUR. DEM.: NOT APPLICABLE	D Θ SHIELD	100X					
SPECIFICATIONS: M-66N	S T.I.D.	3.7E4					
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR53 PARA. 50.51			NONE
PLANT LOC.: AB51	SURMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B			NONE
COORDINATES X- 1607. Y- 1687. Z- 305.0							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*QUALIF:	OPERABILITY	O	REFERENCES:			CES#-3323	
*STATUS	TEMPERATURE	T					
*	PRESSURE	P					
*	REL. HUMDTY	H					
*	CHEM. SPRAY	C					
*	RADIATION	R					
	AGING	A	REVISION # : 00		DATE :		
EQ. PCK # :	SURMERGENCE	S	SYSTEM : ESS.SER.CHILLO WATER		TAG : 3CX-W17SA-1		
	OS&P CATEG.: A						
	APPENDIX E						

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W18SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DRA: 1YR 1 CYC	DRA: 1YR 21 CYC		SRSO 3.2SH1				
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG F2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 177% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA S T.I.D.	3.7E4	2.35E8	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: M-66H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE	
P.O #: 435176	PARAMETER	SUPPL. REVIEW							
PLANT LOC.: AB51	OPERABILITY	O 3.2SH1							
COORDINATES X- 1626. Y- 1683. Z- 305.0	TEMPERATURE	T 3.2SH1							
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLD	PRESSURE	P 3.2SH1							
QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H 3.2SH1							
*****	CHEM. SPRAY	C 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	RADIATION	R 3.2SH1							
*STATUS CONFIRMATORY DATA	AGING	A 3.2SH1							
*	SUBMERGENCE	S 3.2SH1							

EQ. PCK # : 3.2SH1	0588 CATEG.: A								
	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 3.2SH1

CES#-3324

REFERENCES: 1. ASCO TEST REPORT #AGR-67368/
 R O DATED MARCH 1982

REVISION # : 00
 DATE : 09/04/84

SYSTEM : ESS. SER. CHILLO
 WATER
 TAG : 3CX-W18SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W2SA-1	OPERABILITY	NORM: 40YRS 500 CYC DBA: 1YR 1 CYC	NORM: 40YRS 20,100 CYC DBA: 1YR 21 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS									
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM 107 DBA FIG E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO									
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: NPR320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A SRSC 3.2SH1	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.4E4 7.2E4 100% 3.4E4	2.05E8 2.75E8	RAB11R3 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11									
COORDINATES X- 1434. Y- 1634. Z- 218.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A SRSS 3.2SH1	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1				REFERENCES: 1.ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982			REVISION # : 00 DATE : 09/04/84		
	0588 CATEG.: A APPENDIX E						SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-W2SA-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : 3CX-W21SA-1	OPERABILITY	NORM: 40YRS 50G CYC	NORM: 40YRS 120, 100 CYC	OPER. REVIEW	NORM: REF 1 P.R. DBA: REF 1, P. 26	COMB. TEST & SUPPL. REVIEW	/	NONE				
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1							
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB01A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5			
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB01 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP. C			
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW					SRSP 3.2SH1				SUBCOMPONENTS:			
MODEL AND SERIAL #: NP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 103% DBA	HABC1 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB01 FSAR SEC 3.11B	N/A	N/A	/	NONE				
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.2SH1							
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.9E4 7.2E4 100% 2.9E4	2.75E8 2.75E8	RAB01R1 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE				
SPECIFICATIONS: M-66H					SRSR 3.2SH1							
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	47 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 1R4, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS			
PLANT LOC.: AB01					SRSA 3.2SH1							
COORDINATES X- 1565. Y- 1612. Z- 192.0	SUBMERGED LEVEL	191.0 FEET	N/A	SAB01 FSAR SEC 3.11B	N/A	N/A	M	NONE				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOP PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982						CES#-3332		
	TEMPERATURE	T 3.2SH1										
	PRESSURE	P 3.2SH1										
	REL. HUMIDTY	H 3.2SH1										
	CHEM. SPRAY	C 3.2SH1										
	RADIATION	R 3.2SH1										
	AGING	A 3.2SH1										
	SUBMERGENCE	S 3.2SH1										
EQ. PCK #: 3.2SH1	0588 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/04/84 SYSTEM: ESS.SER.CHILLD WATER TAG: 3CX-W21SA-1			

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HALL NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWK
 CAPACITY: 900 MW(E)

REV: 0
 3334

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W22SB-1	OPERABILITY	NORM: 40YRS 500 CYC NORM/TEST DBA 1 CYC	NORM: 40YRS 20,100 CYC NORM/TEST DBA 1 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB41A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB41 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MANUFACTURER: ASCO
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM FOR DBA FIG E2A- 3.2SH1	HAB41 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: NP8320A175E	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	2.75E8 2.75E8	RAB4117 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. DEM.: NOT APPLICABLE	SUPERMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
SPECIFICATIONS: M-66H	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
P.O #: 435176	OPERABILITY	O 3.2SH1				CES#-3334			
PLANT LOC.: AB41	TEMPERATURE	T 3.2SH1							
COORDINATES X- 1456. Y- 1626. Z- 286.0	PRESSURE	P 3.2SH1							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	REL. HUMIDTY	H 3.2SH1							
*****	CHEM. SPRAY	C 3.2SH1							
*QUALIF: QUALIFIED-AWAITING	RADIATION	R 3.2SH1							
*STATUS CONFIRMATORY DATA	AGING	A 3.2SH1							
*	SUBMERGENCE	S 3.2SH1							
*****	OSBP CATEG.: A								
EQ. PCK #: 3.2SH1	APPENDIX E				REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				
					REVISION #: 00 DATE: 09/04/84				
					SYSTEM: ESS.SER.CHILLD WATER TAG: 3CX-W22SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W235B-1	OPERABIL- ITY	NORM: 40YRS 500 CYC	NORM: 40YRS [20, 100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	[DBA: 1YR [21 CYC		REF 1, P.26 SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALV E	TEMPERAT- URE	104F NORM 104F DBA	[123F NORM FOR DBA [FIS F1A- [3.2SH1	TAB41A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	[OPSIG NORM FOR DBA [FIS E2A- [3.2SH1	PAB41 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	HAMMEL DAHL/ CONOFLOW								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	NPR320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	[107% NORM [100% DBA	HAB41 FSAR SEC 3.11B	REF 1, SEC [8.1.3 & [8.2.3 [SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	[2.6E4 [7.2E4 [100% [2.6E4	[2.75E8 [7.05E8	RAB4117 FSAR SEC 3.11B	REF 1, SEC [4.1.4 & [4.2.2 [SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: P-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	1G CFR50 PARA. 50.51	REF 1, P.A3 FIG 184, P.C-58C-8 [SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176										
PLANT LOC.: AB41										
COORDINATES X- Y- Z-	1561. 1627. 286.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVISE	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*****		OPERABILITY O	3.2SH1				CESN-3336			
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE T	3.2SH1							
*STATUS CONFIRMATORY DATA		PRESSURE P	3.2SH1							
*		REL. HUMDTY H	3.2SH1							
*		CHEM. SPRAY C	3.2SH1							
*****		RADIATION R	3.2SH1							
		AGING A	3.2SH1							
		SUBMERGENCE S	3.2SH1							
EQ. PCK # : 3.2SH1		U58R CATEG.: A APPENDIX E		REFERENCES: 1. ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982			REVISION # : 00 DATE : 09/04/84 SYSTEM : ESS, SER. CHILLD WATER TAG : 3CX-W235B-1			

A/E: EBAS SERVICES INC.
 UTILITY: FLORIDA POWER & LIGHT

FACILITY: SHEARON HARRIS - NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)


0
 3338

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W24SB-1	OPERABIL-ITY		2	OPER. REVIEW		5	6	7	NONE	
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA				SRSO					
COMPONENT: MOTOR OPERATOR	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B			M		NONE	
MANUFACTURER: ITT HAMMEL DAHL / CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B			P		NONE	
MAJOR SUPPLIER: BLAKE EQUIPMENT					SRSR					
MODEL AND SERIAL #: NH91K4002F1 -L220	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B			/		NONE	
FUNCT. DES. & SERVICE: ESSENTIAL SER CX FOR AH-15 (1B-SB)	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B			/		NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		RAB5125 FSAR SEC 3.11B			H		NONE	
SPECIFICATIONS: M-66N					SRSR					
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51			/		NONE	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1607. Y- 1652. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B			/		NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O	REFERENCES:				CES#-3338			
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMIDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A					REVISION # : 00			
	SUPMERGENCE	S					DATE :			
EQ. PCK # :	USBR CATEG.: A						SYSTEM : ESS.SER.CHILLO WATER			
	APPENDIX E						TAG : 3CX-W24SB-1			

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W24SP-1	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (1 OF 2)	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.119		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: ITT HAMMEL DAHL / CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER : BLAKE EQUIPMENT					SRSP				SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: ESSENTIAL SER & SERVICE CX FOR AH-15 (1B-SB)	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		RAB5125 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66N					SRSR					
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR 50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1607. Y- 1652. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.118		COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O		REFERENCES:					CES#-3339		
*QUALIF:	*TEMPERATURE T									
*STATUS	*PRESSURE P									
*	*REL. HUMDTY H									
*	*CHEM. SPRAY C									
*****	*RADIATION R									
	AGING A							REVISION # : 00		
	SUBMERGENCE S							DATE :		
EQ. PCK # :	OS8R CATEG.: A							SYSTEM : ESS.SER.CHILLO		
	APPENDIX E							WATER		
								TAG : 3CX-W24SB-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 3CX-W25SB-1	OPERABILITY	NORM: 40YRS 500 CYC DBA: 1YR 1 CYC	NORM: 40YRS 20,100 CYC DBA: 1YR 21 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26 SRSO 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVE OPERATORS	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG F1A- 3.2SH1	TAB51A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
COMPONENT: SOLENOID VALVE	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG F2A- 3.2SH1	PAB51 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MANUFACTURER: ASCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
MODEL AND SERIAL #: NP8320A175E	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	2.35E8 2.35E8	RAB5125 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES. & SERVICE: CONTROL AIR TO PNEUM. OPERATOR	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 14, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. SPEC: NOT APPLICABLE	SURPERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
SPECIFICATIONS: M-66H	OPERABILITY	O 3.2SH1							CES#-3340	
P.O #: 435176	TEMPERATURE	T 3.2SH1								
PLANT LOC.: AB51	PRESSURE	P 3.2SH1								
COORDINATES X- 1624.	REL. HUMPTY	H 3.2SH1								
Y- 1652.	CHEM. SPRAY	C 3.2SH1								
Z- 305.0	RADIATION	R 3.2SH1								
	AGING	A 3.2SH1								
	SUBMERGENCE	S 3.2SH1								
INSTALLED (Y/N): LTR	REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R 0 DATED MARCH 1982									
INSTAL. REF: BY-FLO	REVISION # : 00									
QUALIF EXEMPTH: NOT APPLIC	DATE : 09/04/84									
*****	SYSTEM : ESS.SER.CHILLD WATER									
* QUALIF: QUALIFIED-AWAITING	TAG : 3CX-W25SB-1									
* STATUS CONFIRMATORY DATA										
* APPENDIX E										

EQ. PCK # : 3.2SH1										
OS8R CATEG.: A										
APPENDIX E										



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W3SB-1	OPERABIL-ITY	NORM:40YRS 500 CYC	NORM:40YRS 120,100 CYC	OPER. REVIEW	NORM:REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVE OPERATORS TYPE	NORM/TEST DBA	DBA:1YR 1 CYC	DBA:1YR 121 CYC		SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE	TEMPERATURE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB01A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSTG NORM FOR DBA FIG E2A- 3.2SH1	PAB01 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: REF 1, APP.C	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW					SRSO 3.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND SERIAL #: NPR320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB01 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB01 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSO 3.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D R SHIELD S T.I.D.	2.9E4 7.2E4 100X 2.9E4	2.05E8 2.05E8	RAB01R1 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: M-66H					SRSR 3.2SH1	REVIEW				
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-58C-8	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB01					SRSA 3.2SH1	REVIEW				
COORDINATES X- 1565. Y- 1612. Z- 192.0	SUBMERGED LEVEL	191.0 FEET	N/A	SAB01 FSAR SEC 3.11B	N/A	N/A	M	NONE		
INSTALLED (Y/N): LTP					SRSS 3.2SH1					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982				CES#-3346		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1								
*	REL. HUMDITY	H 3.2SH1								
*	CHEM. SPRAY	C 3.2SH1								
*****	RADIATION	R 3.2SH1								
	AGING	A 3.2SH1								
	SUBMERGENCE	S 3.2SH1						REVISION # : 00 DATE : 09/04/84		
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E							SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-W3SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W32SA-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA: REF 1, P.26	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1	REVIEW			
COMPONENT: SOL. VALVE	TEMPERATURE	104F NORM 104F DBA	123F NORM FOP DBA FIG F1A- 3.2SH1	TAB31A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG F2A- 3.2SH1	PAB31 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL.	M	NONE	SUBCOMPONENTS:
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB31 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.05E8	RAB3111 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL.	M	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA	4.4E5							
SPECIFICATIONS: M-66H	D B SHIELD	100%							
P.O #: 435176	S T.I.D.	2.6E4	2.75E8						
PLANT LOC.: AB31	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA.50.51	REF 1, P.A3 FIG 184, P.C-5&C-8 SRSA 3.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1565. Y- 1660. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1							CES#-3348
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							
	AGING	A 3.2SH1							
	SUBMERGENCE	S 3.2SH1							
EQ. PCK # : 3.2SH1	OS8R CATEG.: A APPENDIX E				REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R D DATED MARCH 1982				REVISION # : 00 DATE : 09/06/84
									SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-W32SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : JB RM 1CR-3561A -SA	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.7SH1					
COMPONENT: SAFETY FUSE	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSC 8.7SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4F5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
P.O #: PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1421. Y- 1678. Z- 265.0	INSTALL (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY O	8.7SH1		REFERENCES:				CES#-4089		
*QUALIF: LATER	*TEMPERATURE T	8.7SH1								
*STATUS	*PRESSURE P	8.7SH1								
*	*REL. HUMDTY H	8.7SH1								
*	*CHEM. SPRAY C	8.7SH1								
*****	RADIATION R	8.7SH1								
	AGING A	8.7SH1								
	SURPERGENCE S	8.7SH1								
EQ. PCK # : 8.7SH1	OSRR CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : JB RM 1CR-3561A		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : JB RM 1CR-3561B -SB	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.7SH1					
COMPONENT: SAFETY FUSE	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSC 8.7SH1					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	PAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	1C CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
P.O #:	PLANT LOC.: AB31				SRSA 8.7SH1					
COORDINATES X- 1567. Y- 1654. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY	O 8.7SH1		REFERENCES:				CES#-4090		
*QUALIF: LATER	TEMPERATURE	T 8.7SH1								
*STATUS	PRESSURE	P 8.7SH1								
*	REL. HUMDTY	H 8.7SH1								
*	CHEM. SPRAY	C 8.7SH1								
*****	RADIATION	R 8.7SH1								
	AGING	A 8.7SH1								
	SUBMERGENCE	S 8.7SH1								
EQ. PCK # : 8.7SH1	OS88 CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : JB RM 1CR-3561B		

A/E: EBA SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEPSON HARBOR APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 960 MW(E)

0
 4091

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : JB RM 1CR-3561C -SA	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE SAS PT	NORM/TEST DBA				SRSO 8.7SH1				
COMPONENT: SAFETY FUSE	TEMPERAT- URE	104F 104F	NORM DRA	LATER	TAB31A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS ATMOS	NORM DRA	LATER	PAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% 100%	NORM DRA	LATER	HAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSR 8.7SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A RETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4		LATER	RAB3111 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA. 50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRM
P.O #: PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB31 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1443. Y- 1625. Z- 265.G	INSTALLED (Y/N): LTR				SRSS 8.7SH1				
INSTAL. REF: BY-FLO	PARAMETER	SUPPL. REVIEW			FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
QUALIF EXEMPT: NOT APPLIC	OPERABILITY O	8.7SH1							
*QUALIF: LATER	*TEMPERATURE T	8.7SH1							
*STATUS	*PRESSURE P	8.7SH1							CES#-4091
*	*REL. HUMPTY H	8.7SH1							
*	*CHEM. SPRAY C	8.7SH1							
*****	*RADIATION R	8.7SH1							
	*AGING A	8.7SH1							
	*SUBMERGENCE S	8.7SH1							
EQ. PCK # : 8.7SH1	US88 CATEG.: A APPENDIX E				REFERENCES:				REVISION # : 00 DATE :
									SYSTEM : RAD. MONITORING TAG : JB RM 1CR-3561C

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : JB RM 1CR-35610 -SB	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.7SH1			
COMPONENT: SAFETY FUSE	TEMPERAT- URE	104F 400W 104F 2RA	LATED	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS 400W ATMOS 2RA	LATER	FAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% 400W 100% 2RA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSR 8.7SH1			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1579. Y- 1674. Z- 261.0	INSTALLLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC				SRSS 8.7SH1			
***** *QUALIF: LATER *STATUS * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1	
	OPERABILITY O	8.7SH1		REFERENCES:			CES#-4092	
	TEMPERATURE T	8.7SH1						
	PRESSURE P	8.7SH1						
	REL. HUMDTY H	8.7SH1						
	CHEM. SPRAY C	8.7SH1						
	RADIATION R	8.7SH1						
	AGING A	8.7SH1					REVISION # :00 DATE :	
	SURMERGENCE S	8.7SH1					SYSTEM : RAD. MONITORING	
EQ. PCK # : 8.7SH1	G588 CATEG.: A APPENDIX E						TAG : JB RM 1CR-35610	



A/E: EBASS SERVICES INC.
 UTILITY: ATLANTA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 4098

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : T ASSY RM 3504A -SA	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: SAS PT TYPE	NORM/TEST DBA				SRSO 8.7SH1			
COMPONENT: LATER	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MANUFACTURER: LATER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	A BETA	100%						
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%						
SPECIFICATIONS:	S T.I.D.	3.7E4						
P.O #:	AGE- INST LIFE	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	(PER 323-1974 DEF.)							
COORDINATES X- 1594. Y- 1663. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/M): LTR	PARA-METER	SUPPL. REVIEW						
INSTAL. REF: BY-FLD	OPERABILITY	O	8.7SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE	T	8.7SH1	REFERENCES:				CES#-4098
*****	PRESSURE	P	8.7SH1					
*QUALIF: LATER	REL. HUMDTY	H	8.7SH1					
*STATUS	CHEM. SPRAY	C	8.7SH1					
*	RADIATION	R	8.7SH1					
*	AGING	A	8.7SH1					
*****	SUBMERGENCE	S	8.7SH1				REVISION # :00 DATE :	
EQ. PCK # : 8.7SH1	US8P CATEG.: A						SYSTEM : RAD. MONITORING	
	APPENDIX E						TAG : T ASSY RM 3504A	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D34SB-1	OPERABILITY	40YRS NORM 500 CYC	47YRS NORM 107,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-50% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA180-22302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	3.0E4	2.74ER	RAB21R6 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%								
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.0E4			SRSR 9.2SH1					
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB21					SRSS 9.2SH1					
COORDINATES X- 1553. Y- 1603. Z- 236.0										
INSTALLED (Y/N): LTR										
INSTAL. REF: BY-FLD										
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY	O 9.2SH1							CES#-4156	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	R 9.2SH1								
	AGING	A 9.2SH1								
	SURMERGENCE	S 9.2SH1								
EQ. PCK #: 9.2SH1					REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION #: 00 DATE: 09/18/84	
	0588 CATEG.: A								SYSTEM: REAC.AUX.BLDG HVAC	
	APPENDIX E								TAG: AV-D34SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-063SR-1	OPERABILITY	40YRS NORM 500 CYC	47YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAP SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-22302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	ACCUR. SPEC: NOT APPLICABLE				SRSR 9.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25	A BETA									
P.O #: 435205	D B SHIELD	100%								
PLANT LOC.: AB21	S T.I.D.	2.6E4			SRSR 9.2SH1					
COORDINATES X- 1512. Y- 1586. Z- 247.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
INSTALLED (Y/N): LTR	SURMERGED LEVEL	NOT APPLICABLE	N/A	SA921 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	9.2SH1	REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-4160		
*****	TEMPERATURE	T	9.2SH1							
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P	9.2SH1							
*STATUS CONFIRMATORY DATA	REL. HUMIDTY	H	9.2SH1							
*	CHEM. SPRAY	C	9.2SH1							
*	RADIATION	R	9.2SH1							
*****	AGING	A	9.2SH1							
	SURMERGENCE	S	9.2SH1					REVISION # : 00 DATE : 09/18/84		
EQ. PCK # : 9.2SH1	OS88 CATEG.: A							SYSTEM : REAC. AUX. BLDG HVAC		
	APPENDIX E							TAG : AV-063SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-066SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11E	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSP 9.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: RE-25					SRSR 9.2SH1				
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: A021					SRSA 9.2SH1				
COORDINATES X- 1486. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*****	OPERABILITY O	9.2SH1							
*QUALIF: QUALIFIED-AWAITING	*TEMPERATURE T	9.2SH1							
*STATUS CONFIRMATORY DATA	*PRESSURE P	9.2SH1							CES#-4161
*	*REL. HUMPTY H	9.2SH1							
*	*CHEM. SPRAY C	9.2SH1							
*****	*RADIATION R	9.2SH1							
	*AGING A	9.2SH1							
	*SUBMERGENCE S	9.2SH1							
EQ. PCK # : 9.2SH1									
	OS88 CATEG.: A APPENDIX E								
									REVISION # : 00 DATE : 09/18/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-066SA-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1)NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D70SA-1	OPEPABIL- ITY NORM/TEST DBA	40YRS NORM 50G CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERS									
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW		NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO									
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW		NONE	MAINTAIN.: P.079-081 OF REF(1)
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.24E3	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1537. Y- 1526. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1							CES#-4163
*	REL. HUMIDTY	H 9.2SH1							
*	CHEM. SPRAY	C 9.2SH1							
*****	RADIATION	R 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					
	AGING	A 9.2SH1							REVISION # :00 DATE :09/18/84
	SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1	US88 CATEG.: A								SYSTEM : REAC.AUX.BLDG HVAC
	APPENDIX E								TAG : AV-D70SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D71SR-1	OPERABIL- ITY NORM/TEST DBA	40YRS. NORM 500 CYC 1YR DBA	47YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.036 SRSO 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS									
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11R REF(1) P.042-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11R REF(1) P.042-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B REF(1) P.077 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE	P GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 1COX 2.6E4	2.34E4	PAB21R7 FSAR SEC 3.11B REF(1) P.016 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51 REF(1) P.079-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
P.O #:	435205	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
PLANT LOC.:	AB21	OPERABILITY O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-4164		
COORDINATES X-	1537.	TEMPERATURE T	9.2SH1							
Y-	1585.	PRESSURE P	9.2SH1							
Z-	247.0	REL. HUMIDTY H	9.2SH1							
INSTALLED (Y/N):	LTR	CHEM. SPRAY C	9.2SH1							
INSTAL. REF:	BY-FLD	RADIATION R	9.2SH1							
QUALIF EXEMPTN:	NOT APPLIC	AGING A	9.2SH1					REVISION # :00		
*QUALIF: QUALIFIED-AWAITING		SUBMERGENCE S	9.2SH1					DATE :09/18/84.		
*STATUS CONFIRMATORY DATA								SYSTEM : REAC.AUX.BLDG HVAC		
******								TAG : AV-D71SR-1		

EQ. PCK # :	9.2SH1	0588 CATEG.:	A							
		APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CP-B2SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: PRIMARY ELEMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	#	NONE	REPLACEMENT:
MANUFACTURER: NAPCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	#	NONE	MAINTAIN.:
MAJOR SUPPLIER: BIF	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-32302	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF VALVE POSITION IO N	ACCUR. SPEC: NOT APPLICABLE				SRSH 9.1/9.				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-35	A BETA	7.2E4							
P.O #: 435211	D B SHIELD	100%			SRSR 9.1/9.				
PLANT LOC.: AB21	S T.I.D.	3.0E4							
COORDINATES X- 1430. Y- 1665. Z- 255.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
INSTALLED (Y/N): LTR	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SHEET PACKAGE: 9.1/9.2
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1/9.2							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
*QUALIF: LATER	TEMPERATURE	T 9.1/9.2							CESN-4168
*STATUS	PRESSURE	P 9.1/9.2							
*	REL. HUMDTY	H 9.1/9.2							
*	CHEM. SPRAY	C 9.1/9.2							REFERENCES:
*	RADIATION	R 9.1/9.2							
	AGING	A 9.1/9.2							REVISION #: 00
	SURMERGENCE	S 9.1/9.2							DATE:
EQ. PCK #: 9.1/9.2	0588 CATEG.: A								SYSTEM: CONT. ATMOSPHERE PRG/MKUP
	APPENDIX E								TAG: 2CP-B2SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2CP-845B- 1	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 9.1/9.1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : BIF SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.118	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSH 9.1/9.1				
REMOTE INDICAT ION OF VALVE PO SITION IO N	ACCUR. DEM.: NOT APPLICABLE								
ION OF VALVE PO SITION IO N	SPECIFICATIONS: BE-35								
ION OF VALVE PO SITION IO N	P.O #: 435211								
ION OF VALVE PO SITION IO N	PLANT LOC.: AB21								SAFETY FUNCTION: CI
ION OF VALVE PO SITION IO N	COORDINATES X- 1429. Y- 1664. Z- 255.0								
ION OF VALVE PO SITION IO N	INSTALLED (Y/N): LTR								
ION OF VALVE PO SITION IO N	INSTAL. REF: BY-FLD								
ION OF VALVE PO SITION IO N	QUALIF EXEMPTN: NOT APPLIC								
ION OF VALVE PO SITION IO N	*****								
ION OF VALVE PO SITION IO N	*QUALIF: LATER								
ION OF VALVE PO SITION IO N	*STATUS								
ION OF VALVE PO SITION IO N	*								
ION OF VALVE PO SITION IO N	*								
ION OF VALVE PO SITION IO N	*****								
ION OF VALVE PO SITION IO N	RADIATION R	9.1/9.2							
ION OF VALVE PO SITION IO N	AGING A	9.1/9.2							
ION OF VALVE PO SITION IO N	SUBMERGENCE S	9.1/9.2							
ION OF VALVE PO SITION IO N	EQ. PCK # : 9.1/9.2								
ION OF VALVE PO SITION IO N	OSRR CATEG.: A								
ION OF VALVE PO SITION IO N	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2

REFERENCES:

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1/9.2

CES#-4170

REVISION # : JD
 DATE :

SYSTEM : CONT. ATMOSPHERE
 PRG/MKUP

TAG : 2CP-845B- 1



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : LIT 1CT716DA SA	OPERABIL- ITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LEVEL TRANSMITT EP	TEMPERAT- URE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: TPNSAMERICA-DEL AVAL	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER					SRSR				SUBCOMPONENTS:	
MODEL AND: RE-36562 SERIAL #	RELATIVE HUMIDITY	20-90%NORM 100% DBA		HAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CS CONT SUMP A & SERVICE LVL	CHEMICAL SPRAY	NOT APPLICABLE		CA931 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSO					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4		RAB3111 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: IN33					SRSR					
P.O #: 435275	AGE- INST LIFE (PER 323- 1974 DEF.)	4J YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB31					SRSA					
COORDINATES X- 1435. Y- 1660. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O					CES 4-483			
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :	US88 CATEG.: A APPENDIX E		REFERENCES:				REVISION # : 00 DATE : SYSTEM : CONTAINMENT SPRAY TAG : LIT 1CT716DA SA			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : LIT 1CT7161A SA	OPERABIL-ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: SENSORS TYPE	NORM/TEST DBA				SRSO			
COMPONENT: LEVEL TRANSMITTER	TEMPERATURE	104F NORM 104F DBA		TAB31A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	#	NONE	
MANUFACTURER: TRNSAMERICA-DELAVAL	PRESSURE	ATMOS NORM ATMOS DBA		PAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	#	NONE	
MAJOR : SUPPLIER					SRST			
MODEL AND: RE-36562 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: CONTAINMENT & SERVICE WTR LEVEL (NARROW RANGE)	CHEMICAL SPRAY	NOT APPLICABLE		CAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSP			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4		RAB3111 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: IN33	A BETA	4.4E5						
P.O #: 435275	D B SHIELD	100%			SRSR			
PLANT LOC.: AB31	S T.I.D.	2.6E4						
COORDINATES X- 1435. Y- 1660. Z- 261.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE		SAB31 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
***** *QUALIF: *STATUS * * *****	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CES#-4484	
EQ. PCK # :	OPERABILITY	O	REFERENCES:				REVISION # : 00 DATE :	
	TEMPERATURE	T					SYSTEM : CONTAINMENT SPRAY	
	PRESSURE	P					TAG : LIT 1CT7161A SA	
	REL. HUMIDTY	H						
	CHEM. SPRAY	C						
	RADIATION	R						
	AGING	A						
	SUBMERGENCE	S						
	0588 CATEG.: A APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E/I 1CR 3561A S A	OPERABILITY	LATER	LATER	OPEP. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SAS PT	NORM/TEST DRA				SRSO 8.7SH1					
COMPONENT: CUPRENT TRANSMITTER J B ASSY	TEMPERATURE	104F NORM 104F DRA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DRA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: LATER	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5								
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS:	S T.I.D.	2.6E4								
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1421. Y- 1675. Z- 261.0										
INSTALLED (Y/N): LTR										
INSTAL. REF: BY-FLD										
QUALIF EXEMPTN: NOT APPLIC										
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*QUALIF: LATER	OPERABILITY O	8.7SH1		REFERENCES:				CESN-4896		
*STATUS	TEMPERATURE T	8.7SH1								
*	PRESSURE P	8.7SH1								
*	REL. HUMDTY H	8.7SH1								
*	CHEM. SPRAY C	8.7SH1								
*****	RADIATION R	8.7SH1								
	AGING A	8.7SH1								
	SUBMERGENCE S	8.7SH1								
EQ. PCK # : 8.7SH1	0588 CATEG.: A	APPENDIX E							REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : E/I 1CR 3561A S	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E/I 1CR 35618 S B	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE SAS PT	NORM/TEST DBA				SRSO 8.7SH1					
COMPONENT: CURRENT TRANSMI TTER J B ASSY	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
SPECIFICATIONS:										
P.O #:										
PLANT LOC.: AB31										
COORDINATES X- 1567. : Y- 1660. Z- 261.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY O	8.7SH1		REFERENCES:				CES#-4897		
*QUALIF: LATER	TEMPERATURE T	8.7SH1								
*STATUS	PRESSURE P	8.7SH1								
*	REL. HUMDTY H	8.7SH1								
*	CHEM. SPRAY C	8.7SH1								
*****	RADIATION R	8.7SH1								
	AGING A	8.7SH1								
	SUBMERGENCE S	8.7SH1								
EQ. PCK # : 8.7SH1	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : E/I 1CR 35618 S	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : F/I 1CR 3561C S A	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.7SH1				
COMPONENT: CURRENT TRANSMI TTER J B ASSY	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSP 8.7SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
P.O #:	PLANT LOC.: AB31				SRSA 8.7SH1				
COORDINATES X- 1439. Y- 1640. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: LATER *STATUS * * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
	OPERABILITY O	8.7SH1		REFERENCES:			CES#-4898		
	TEMPERATURE T	8.7SH1							
	PRESSURE P	8.7SH1							
	REL. HUMIDTY H	8.7SH1							
	CHEM. SPRAY C	8.7SH1							
	RADIATION R	8.7SH1							
	AGING A	8.7SH1							
	SUBMERGENCE S	8.7SH1							
EQ. PCK # : 8.7SH1	OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : E/I 1CR 3561C S

A/E: EBAS SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9LG MW(E)

0
 4899

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : E/I 1CR 3561D S B	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: SAS PT	NORM/TEST DBA				SRSO 8.7SH1				
COMPONENT: CURRENT TRANSMITTER J B ASSY	TEMPERATURE	104F NORM DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11P	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER :	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	2.6E4							
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1579. Y- 1678. Z- 261.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	OPERABILITY O	8.7SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
INSTAL. REF: 9Y-FLD	TEMPERATURE T	8.7SH1							CES#-4899
QUALIF EXEMPTN: NOT APPLIC	PRESSURE P	8.7SH1							
*QUALIF: LATER	REL. HUMDTY H	8.7SH1							
*STATUS	CHEM. SPRAY C	8.7SH1							
*	RADIATION R	8.7SH1							
*	AGING A	8.7SH1							
*****	SURGERGENCE S	8.7SH1							
EQ. PCK # : 8.7SH1	0588 CATEG.: A								REVISION # : 00
	APPENDIX E								DATE :
									SYSTEM : RAD. MONITORING
									TAG : E/I 1CR 3561D S

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1

REFERENCES:

REVISION # : 00
 DATE :

SYSTEM : RAD. MONITORING
 TAG : E/I 1CR 3561D S

A/E: EBAS SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT


FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 4900

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E/I 1CR 3563A S A	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: SAS PT	NORM/TEST DBA				SRSO 8.7SH1					
COMPONENT: CURRENT TRANSMITTER J B ASSY	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	4.4E5								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS:	S T.I.D.	2.6E4								
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1418. Y- 1657. Z- 261.0										
COORDINATES X- 1418. Y- 1657. Z- 261.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*****	OPERABILITY	O 8.7SH1		REFERENCES:				CES#-4900		
*QUALIF: LATER	TEMPERATURE	T 8.7SH1								
*STATUS	PRESSURE	P 8.7SH1								
*	REL. HUMIDITY	H 8.7SH1								
*	CHEM. SPRAY	C 8.7SH1								
*****	RADIATION	R 8.7SH1								
	AGING	A 8.7SH1								
	SUBMERGENCE	S 8.7SH1								
EQ. PCK # : 8.7SH1	US88 CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : RAD. MONITORING TAG : E/I 1CR 3563A S		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.				
TAG NO : E/I 1CR 3563B S B	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: SAS PT	NORM/TEST DBA				SRSO 8.7SH1				
COMPONENT: CURRENT TRANSMITTER J R ASSY	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	ACCUR. SPEC:	NOT APPLICABLE			SRSP 8.7SH1				
ACCUR. DEM.:	ACCUR. DEM.:	NOT APPLICABLE			SRSC 8.7SH1				
SPECIFICATIONS:	R GAMMA	2.6E4	LATER	RAB3111	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
P.O #:	A BETA	4.4E5		FSAR SEC 3.11B					
PLANT LOC.: AB31	D B SHIELD	100%			SRSR 8.7SH1				
COORDINATES X- 1582. Y- 1658. Z- 261.0	S T.I.D.	2.6E4							
INSTALLED (Y/N): LTR	AGE-	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM
INSTAL. REF: 8Y-FLD	INST LIFE (PER 323- 1974 DEF.)				SRSA 8.7SH1				
QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
*****	PARAMETER	SUPPL. REVIEW			SRSS 8.7SH1				
*QUALIF: LATER	OPERABILITY O	8.7SH1		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1.	
*STATUS	TEMPERATURE T	8.7SH1		REFERENCES:				CES#-4901	
*	PRESSURE P	8.7SH1							
*	REL. HUMIDTY H	8.7SH1							
*	CHEM. SPRAY C	8.7SH1							
*****	RADIATION R	8.7SH1							
	AGING A	8.7SH1							
	SUBMERGENCE S	8.7SH1						REVISION # :00 DATE :	
EQ. PCK # : 8.7SH1	OS88 CATEG.: A APPENDIX E							SYSTEM : RAD. MONITORING TAG : E/I 1CR 3563B S	



A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT


FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 4902

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : E/I 1CZ 3504A S A	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 8.7SH1					
COMPONENT: CURRENT TRANSMI TTER	TEMPERAT- URE	104F 104F NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: GENERAL ATOMIC	PRESSURE	ATMOS 104F NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSC 8.7SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1594. Y- 1663. Z- 305.0	INSTALL (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1		
*QUALIF: LATER	OPERABILITY O	8.7SH1		REFERENCES:				CES#-4902		
*STATUS	TEMPERATURE T	8.7SH1								
*	PRESSURE P	8.7SH1								
*	REL. HUMIDTY H	8.7SH1								
*	CHEM. SPRAY C	8.7SH1								
*****	RADIATION R	8.7SH1								
	AGING A	8.7SH1								
	SUBMERGENCE S	8.7SH1						REVISION # : 00 DATE :		
EQ. PCK # : 8.7SH1	OSRE CATEG.: A APPENDIX E					SYSTEM : CONTROL ROOM HVAC TAG : E/I 1CZ 3504A S				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : E/I-1CZ-35C4B-S B	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	SAS PT DBA				SRSO 8.7SH1	REVIEW			
COMPONENT:	CURRENT TRANSMI TTER	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER:	GENERAL ATOMIC	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER		RELATIVE HUMIDITY	20-90%NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	LATER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: B SERVICE		R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATER	PAB5125 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.5D.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. DEM.: NOT APPLICABLE		SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS:									
P.O #:									
PLANT LOC.:	AB51								
COORDINATES X- Y- Z-	1606. 1696. 305.0								
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 8.7SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 8.7SH1
*QUALIF: LATER *STATUS * * *****		OPERABILITY O	8.7SH1		REFERENCES:				CES#-4903
		TEMPERATURE T	8.7SH1						
		PRESSURE P	8.7SH1						
		REL. HUMDTY H	8.7SH1						
		CHEM. SPRAY C	8.7SH1						
		RADIATION R	8.7SH1						
		AGING A	8.7SH1				REVISION # :00		
		SUBMERGENCE S	8.7SH1				DATE :		
EQ. PCK # : 8.7SH1		OS88 CATEG.: A APPENDIX E						SYSTEM : CONTROL ROOM HVAC TAG : E/I-1CZ-35U4B-S	



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : ISOL RACK A1-R4 SA	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LATER	TEMPERAT- URE		LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: LATER					SRST				MAINTAIN.:	
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY		LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: EQUIPMENT TO BE IDENTIFIED BY I&C.	
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.O.	3.0E4 7.2E4 3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:					SRSR					
P.O #:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA					
COORDINATES X- 1571. Y- 1710. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CES#-4925
***** *QUALIF: LATER *STATUS * *****	OPERABILITY C *TEMPERATURE T *PRESSURE P *REL. HUMDTY H *CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S			REFERENCES:						REVISION # :00 DATE :
EQ. PCK # :	Q588 CATEG.: A APPENDIX E								SYSTEM : CNTRL BOARDS & PNL(I&C) TAG : ISOL RACK A1-R4	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : ISOL RACK A1-R4 5P	OPERABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LATER	TEMPERAT- URE	104F 104F	NORM ORA	LATER	TAB21A FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: LATER	PRESSURE	ATMOS ATMOS	NORM ORA	LATER	PAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90X 100X	NORM ORA	LATER	HAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: EQUIPMENT TO BE IDENTIFIED BY I&C.
FUNCT. DES: & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4		LATER	RAB21R6 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB21 FSAR SEC 3.11B	LATER COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS:									
P.O #:									
PLANT LOC.: AB21									
COORDINATES X- 1581. Y- 1687. Z- 236.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
*****	OPERABILITY	O	REFERENCES:				CES#-4926		
*QUALIF: LATER	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMIDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A	REVISION # :00			DATE :			
	SUBMERGENCE	S	SYSTEM : CNTRL BOARDS & PNL(I&C)			TAG : ISOL RACK A1-R4			
EQ. PCK # :	OS88 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : FP CLG P1 & 4A-SA	OPERABILITY	40YRS NORM FLUS 1YR DBA	40YRS NORM PLJS 1YR DBA	OPER. REVIEW	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE			
EQUIPMENT TYPE: MOTORS	TEMPERATURE	104F NORM 104F DBA	111F	TFH21A FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE(1)		
COMPONENT: FUEL POOL COOLING PUMP MOTOR	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS	PFH21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	PAINTAIN.: SEE NOTE(1)		
MANUFACTURER: SIEMENS-ALLIS	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% RH	MFH21 FSAR SEC 3.11B	REF(1) PG.019	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT 1.FOLLOW VENDOR RECOMMENDATION ON REPLACEMENT & MAINTENANCE SCHEDULE SEE VENDOR INSTRUCTION MANUAL		
MAJOR SUPPLIER: N/A	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE			
MODEL AND SERIAL #: EL-8-5103-90232-1	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100% 1.1E4	25R RADS	RFH21F1 FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	H	NONE			
FUNCT. DES. & SERVICE: FUEL POOL COOLING PUMP DRIVE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YFARS	10 CFR50 PARA.50.51	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS		
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE			
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW									
SPECIFICATIONS: M-13	OPERABILITY	O	4.5SH1	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.5SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.5SH1		
P.O #: 435042	TEMPERATURE	T	4.5SH1	REFERENCES: (1)SIEMENS-ALLIS QUALIFICATION REPORT #NO 8902321, REV 5.					CES#-4985		
PLANT LOC.: FH21	PRESSURE	P	4.5SH1								
COORDINATES X- 1621. Y- 1816. Z- 236.0	REL. HUMDTY	H	4.5SH1								
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	4.5SH1								
INSTAL. REF: 9Y-FLD	RADIATION	R	4.5SH1								
QUALIF EXEMPTN: NOT APPLIC	AGING	A	4.5SH1								
*****	SUBMERGENCE	S	4.5SH1					REVISION # :00 DATE :07/18/84			
*****	OS88 CATEG.: A							SYSTEM : SPNT FUEL POOL COOL&CLNUP TAG : FP CLG P1 & 4A-			
*****	APPENDIX E										

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : FP CLG P1 & 4B-SR	OPERABILITY	40YRS NORM PLUS 1YR DBA	40YRS NORM PLUS 1YR DBA	OPER. REVIEW	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: MOTORS TYPE					SRSO 4.5SH1								
COMPONENT: FUEL POOL COOLING PUMP MOTOR	TEMPERATURE	104F NORM 104F DBA	311F	TFH21A FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE(1)				
MANUFACTURER: SIEMENS-ALLIS					SIRST 4.5SH1								
MAJOR SUPPLIER : N/A	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS	PFH21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE(1)				
MODEL AND SERIAL #: EL-8-5103-90232-1	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% RH	HFH21 FSAR SEC 3.11B	REF(1) PG.019	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: FUEL POOL COOLING PUMP DRIVE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE	1. FOLLOW VENDOR RECOMMENDATION ON REPLACEMENT & MAINTENANCE SCHEDULE				
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.5SH1				SEE VENDOR INSTRUCTION MANUAL				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100% 1.1E4	2E9 RADS	RFM21F1 FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: M-13					SRSR 4.5SH1								
P.O #: 435042	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CF950 PARA.50.51	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: FH21					SRSA 4.5SH1								
COORDINATES X- 1633. Y- 1816. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.5SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.5SH1			
*****	OPERABILITY	O 4.5SH1		REFERENCES: (1) SIEMENS-ALLIS QUALIFICATION REPORT #NO 9902321, REV 5.						CES#-4986			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 4.5SH1											
*STATUS FIELD VERIFICATION	PRESSURE	P 4.5SH1											
*	REL. HUMIDTY	H 4.5SH1											
*	CHEM. SPRAY	C 4.5SH1											
*****	RADIATION AGING	R A 4.5SH1											
	SUBMERGENCE	S 4.5SH1											
EQ. PCK # : 4.5SH1	US8E CATEG.: A APPENDIX E								REVISION # : 00 DATE : 07/18/84				
									SYSTEM : SP4T FUEL POOL COOL&CLNUP TAG : FP CLG P1 & 4B-				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : FP CLG P2 & 3A-SA	OPERABILITY	40YRS NORM PLUS 1YR DBA	40YRS NORM PLUS 1YR DBA	OPER. REVIEW	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: MOTORS	TEMPERATURE	104F NORM DBA	111F	TFH21A FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE(1)
COMPONENT: FUEL POOL COOLING PUMP MOTOR	PRESSURE	ATMOS NORM DBA	ATMOS	PFH21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE(1)
MANUFACTURER: SIEMENS-ALLIS	RELATIVE HUMIDITY	20-90% NORM DBA	100% RH	HFH21 FSAR SEC 3.11B	REF(1) PG.019	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: N/A	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE	1.FOLLOW VENDOR RECOMMENDATION ON REPLACEMENT & MAINTENANCE SCHEDULE
MODEL AND SERIAL #: EL-8-5103-90232-1	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100%	2ER PADS	RFH21F1 FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	H	NONE	SEE VENDOR INSTRUCTION MANUAL
FUNCT. DES. & SERVICE: FUEL POOL COOLING PUMP DRIVE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	1G CFR50 PARA.50.51	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS: M-13	OPERABILITY	O 4.5SH1							
P.O #: 435042	TEMPERATURE	T 4.5SH1							
PLANT LOC.: FH21	PRESSURE	P 4.5SH1							
COORDINATES X- 1695. Y- 1816. Z- 236.0	REL. HUMIDTY	H 4.5SH1							
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 4.5SH1							
INSTAL. REF: BY-FLD	RADIATION	R 4.5SH1							
QUALIF EXEMPTN: NOT APPLIC	AGING	A 4.5SH1							
*****	SUBMERGENCE	S 4.5SH1							
*QUALIF: QUALIFIED-AWAITING									
*STATUS FIELD VERIFICATION									
* * * * *									

EQ. PCK #: 4.5SH1	OS88 CATEG.: A								
	APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.5SH1

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.5SH1

CES#-4987

REFERENCES: (1)SIEMENS-ALLIS QUALIFICATION REPORT #NO 3902321, REV 5.

REVISION #: 00
 DATE: 07/18/84

SYSTEM: SPNT FUEL POOL COOL&CLNUP
 TAG: FP CLG P2 & 3A-

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : FP CLG P2 & 3B-SP	OPERABILITY	40YRS NORM PLUS 1YR	40YRS NORM PLUS 1YR	OPER. REVIEW	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: MOTORS	NORM/TEST D9A	D9A	D9A		SRSO 4.5SH1					
COMPONENT: FUEL POOL COOLING PUMP MOTOR	TEMPERATURE	104F NORM 104F D9A	111F	TFH21A FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE(1)	
MANUFACTURER: SIEMENS-ALLIS	PRESSURE	ATMOS NORM ATMOS D9A	ATMOS	PFH21 FSAR SEC 3.11B	REF(1)	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE(1)	
MAJOR SUPPLIER: N/A					SRSP 4.5SH1				SUBCOMPONENTS:	
MODEL AND SERIAL #: EL-8-5103-90232 -1	RELATIVE HUMIDITY	20-90% NORM 100% D9A	177% RH	HFH21 FSAR SEC 3.11B	REF(1) PG.019	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: FUEL POOL COOLING PUMP DRIVE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE	1. FOLLOW VENDOR RECOMMENDATION ON REPLACEMENT & MAINTENANCE SCHEDULE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 4.5SH1				SEE VENDOR INSTRUCTION MANUAL	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.1E4 100%	2E9 RADS	RFH21F1 FSAR SEC 3.11B	REF(1) PG.018	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-13					SRSR 4.5SH1					
P.O #: 435042	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR53 PARA.50.51	REF(1) PG.023	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: FH21					SRSA 4.5SH1					
COORDINATES X- 1665. Y- 1816. Z- 236.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SFH21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
INSTALLED (Y/N): LTR					SRSS 4.5SH1					
INSTAL. REF: 9Y-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 4.5SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 4.5SH1		
QUALIF EXEMPTH: NOT APPLIC	OPERABILITY	O 4.5SH1		REFERENCES: (1) SIEMENS-ALLIS QUALIFICATION REPORT HQ 8902321, REV 5.				CES#-4988		
*****	TEMPERATURE	T 4.5SH1								
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 4.5SH1								
*STATUS FIELD VERIFICATION	REL. HUMDTY	H 4.5SH1								
*	CHEM. SPRAY	C 4.5SH1								
*	RADIATION	R 4.5SH1								
*****	AGING	A 4.5SH1								
	SUBMERGENCE	S 4.5SH1		REVISION # : 00			DATE : 07/18/84			
EQ. PCK # : 4.5SH1	OS8R CATEG.: A			SYSTEM : SPNT FUEL POOL COOL&CLNUP			TAG : FP CLG P2 & 3B-			
	APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-V238SB-1	OPERABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: LIMIT SWITCHES TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT-URE		LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR : ANCHOR DARLING SUPPLIER					SRSR				SUBCOMPONENTS:	
MODEL AND: D2400X-2SR SERIAL #	RELATIVE HUMIDITY		LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: LATER & SERVICE					SRSR				NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH	
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100X 1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435013					SRSA					
PLANT LOC.: AB21										
COORDINATES X- 1645. Y- 1538. Z- 236.U	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH E0 PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
***** *QUALIF: LATER *STATUS * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S			REFERENCES:				CES#-4995		
EQ. PCK # :	0588 CATEG.: A APPENDIX E							REVISION # : 00 DATE :		
								SYSTEM : SERVICE WATER TAG : 3SW-V238SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-V266SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: LIMIT SWITCHES	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE		LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DRA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY		LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: D2400X-2SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH	
FUNCT. DES. & SERVICE: LATER	R GAMMA	1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA									
ACCUR. DEM.: NOT APPLICABLE	D R SHIELD	100X								
SPECIFICATIONS:	S T.I.D.	1.8E4			SRSR					
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1646. Y- 1549. Z- 237.0					SRSS					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
*****	OPERABILITY	O	REFERENCES:				CES#-4996			
*QUALIF: LATER	TEMPERATURE	T					REVISION # :00 DATE :			
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A	SYSTEM : SERVICE WATER							
	SUBMERGENCE	S	TAG : 3SW-V266SA-1							
EQ. PCK # :	G588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-V267SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: LIMIT SWITCHES	NORM/TEST DBA				SRSO				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE		LATER		LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT:
MANUFACTURER: HANCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER:	RELATIVE HUMIDITY		LATER		LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: 02400X-2SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH
FUNCT. DES. & SERVICE: LATER	R GAMMA	1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	1.8E4			SRSR	REVIEW			
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1646. Y- 1548. Z- 237.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CESN-4997
*QUALIF: LATER	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A							
	SURMERGENCE	S							
EQ. PCK # :	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-V267SB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

REFERENCES:



A/E: EBASCO SERVICES INC.
 UTILITY: IONA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 CE 4998

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL					DEM. QUALIF.
TAG NO : 3SW-V237SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER		NONE		
EQUIPMENT: LIMIT SWITCHES TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE		LATER		LATER		NONE	REPLACEMENT:	
MANUFACTURER: NAMCO					SRST			MAINTAIN.:	
MAJOR : ANCHOR DARLING SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER		NONE	SUBCOMPONENTS:	
MODEL AND: D2400X-2SR SERIAL #	RELATIVE HUMIDITY		LATER		LATER		NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH	
FUNCT. DES: LATER & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER		NONE	EA180 LIMIT SWITCH	
ACCUR. SPEC: NOT APPLICABLE					SRSC				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100% 1.8E4	LATER	RAB2110 FSAR SEC 3.11B	LATER		NONE		
SPECIFICATIONS: M-32A					SRSR				
P.O #: 435013	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER		NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA				
COORDINATES X- 1646. Y- 153P. Z- 236.C	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER		NONE		
					SRSS				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S		REFERENCES:				CES#-4998		
EQ. PCK # :	US82 CATEG.: A APPENDIX E						REVISION # : 00 DATE : SYSTEM : SERVICE WATER TAG : 3SW-V237SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V243SR-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 107300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	VALVES				SRSO 9.1SH1	REVIEW				
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER	HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA180-11320	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE					SRSO 9.1SH1	REVIEW			
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	1.8E4 100X 1.8E4	2.24F8	RAB2110 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #:	435176					SRSA 9.1SH1	REVIEW			
PLANT LOC.:	AB21									
COORDINATES X- Y- Z-	1607. 1579. 250.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTH:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O	9.1SH1							
*QUALIF:	QUALIFIED-AWAITING	T	9.1SH1							
*STATUS	CONFIRMATORY DATA	P	9.1SH1					CESV-4999		
*	REL. HUMDTY	H	9.1SH1							
*	CHEM. SPRAY	C	9.1SH1							
*****	RADIATION	R	9.1SH1							
	AGING	A	9.1SH1							
	SUBMERGENCE	S	9.1SH1							
EQ. PCK # :	9.1SH1	OSBR CATEG.:	A	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105, REVISION 3 DATED 8/20/81.				REVISION # :00 DATE :09/18/84		
		APPENDIX E						SYSTEM :ESS.SER.CHILLD WATER TAG :3CX-V243SR-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CX-B4SA-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSD 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: VALVES TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
MODEL AND SERIAL #: EA180-11302	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100% 2.6E4	2.04E8 	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: M-66H	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5000			
P.O #: 435176	TEMPERATURE	T 9.1SH1											
PLANT LOC.: AB21	PRESSURE	P 9.1SH1											
COORDINATES X- 1582. Y- 1537. Z- 245.0	REL. HUMIDTY	H 9.1SH1											
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 9.1SH1											
INSTAL. REF: BY-FLD	RADIATION	R 9.1SH1											
QUALIF EXEMPTN: NOT APPLIC	AGING	A 9.1SH1											
*****	SUBMERGENCE	S 9.1SH1											
*****	OS&B CATEG.: A												
*****	APPENDIX E												
EQ. PCK # : 9.1SH1									REVISION # : UD DATE : 09/19/84 SYSTEM : ESS.SER.CHILLED WATER TAG : 3CX-B4SA-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CH-B2SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 107300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW								SUBCOMPONENTS:
MODEL AND: SERIAL #	EA180-11302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 2.6E4	2.6E4	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40YPS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:435176									
PLANT LOC.: AB21									
COORDINATES X- 1574. Y- 1519. Z- 245.0		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1	
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		OPERABILITY	O 9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5001 REVISION # :00 DATE :09/18/84	
	TEMPERATURE	T 9.1SH1							
	PRESSURE	P 9.1SH1							
	REL. HUMDTY	H 9.1SH1							
	CHEM. SPRAY	C 9.1SH1							
	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1		OS88 CATEG.: A APPENDIX E						SYSTEM :ESS.SER.CHILLD WATER TAG :3CH-B2SA-1	

A/E: EBAS SERVICES INC.
 UTILITY: LINNA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5002

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V122SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1).	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW					SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND SERIAL #: EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: POSITION INDICATION					SRSH 9.1SH1	REVIEW			NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: M-66H					SRSR 9.1SH1	REVIEW				
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31					SRSA 9.1SH1	REVIEW				
COORDINATES X- 1447.0 Y- 1626.0 Z- 264.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5002		
*REL. HUMDTY	T	9.1SH1						REVISION # : 00		
*CHEM. SPRAY	P	9.1SH1						DATE : 09/18/84		
*RADIATION	H	9.1SH1						SYSTEM : ESS.SER.CHILLO WATER		
*AGING	C	9.1SH1						TAG : 3CX-V122SA-1		
*SUBMERGENCE	R	9.1SH1								
EQ. PCK # : 9.1SH1	G528 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CX-V245SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE					
EQUIPMENT: LIMIT SWITCHES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW							
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW					SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:				
MODEL AND SERIAL #: EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW							
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.04E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE					
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS				
P.O #: 435176					SRSA 9.1SH1	REVIEW							
PLANT LOC.: AB31	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
COORDINATES X- 1550. Y- 1762. Z- 265.0					SRSS 9.1SH1	REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5003			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1											
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1											
*	REL. HUMDTY	H 9.1SH1											
*	CHEM. SPRAY	C 9.1SH1											
*****	RADIATION	R 9.1SH1											
	AGING	A 9.1SH1											
	SUBMERGENCE	S 9.1SH1											
EQ. PCK #: 9.1SH1	US88 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84 SYSTEM: ESS-SER.CHILLO WATER TAG: 3CX-V245SB-1				



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-B3SB-1	OPERABIL- ITY	NORM: 6YRS 500 CYC	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		REF 1, P.26 SRSO 3.2SH1					
COMPONENT: SOLENOID VALVE (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRST 3.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OP SIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2 SRSP 3.2SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER										
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 3.2SH1	N/A REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.75E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1582. Y- 1535. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 3.2SH1	N/A REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*****	OPERABILITY O	3.2SH1								CES#-5005
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	3.2SH1								
*	REL. HUMDTY H	3.2SH1								
*	CHEM. SPRAY C	3.2SH1								
*****	RADIATION R	3.2SH1								
	AGING A	3.2SH1								
	SUBMERGENCE S	3.2SH1								
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E			REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982						REVISION # : 00 DATE : 09/04/84
										SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-B3SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-B2SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 [SRSO 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRST 9.1SH1]	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRSP 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 [SRSH 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A [SRSC 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 [SRSR 9.1SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 [SRSA 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1567. Y- 1520. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A [SRSS 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1								
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							CES#-5006	
*	REL. HUMDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK # : 9.1SH1	0588 CATEG.: A APPENDIX E				REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION # : 00 DATE : 09/18/84 . SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-92SA-1	

A/E: EBAS SERVICES INC.
 UTILITY: MAINA POWER & LIGHT

FACILITY: SHEARON HARRIS APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5007

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 3CX-B2SA-1	OPERABIL- ITY	NORM: 40YRS 500 CYC	NORM: 40YRS 20, 100 CYC	OPER. REVIEW	NORM: REF 1 P. 8, DBA: REF 1, P. 26	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		SRSO 3.2SH1	REVIEW				
COMPONENT: SOLENOID VALVE (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	120F NORM FOR DBA FIG E1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: REF 1, FIG. 1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	10PSIG NORM FOR DBA FIG E2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P. 26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
FUNCT. DES: & SERVICE	ACCUR. SPEC: NOT APPLICABLE				SRSO 3.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.75F8 2.75F8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P. A3 FIG 184, P.C-5&C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE		
PLANT LOC.: AB21	COORDINATES X- Y- Z-	1567. 1520. 245.0			SRSO 3.2SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1			
*OPERABILITY	O	3.2SH1					CESM-5007			
*TEMPERATURE	T	3.2SH1								
*PRESSURE	P	3.2SH1								
*REL. HUMDTY	H	3.2SH1								
*CHEM. SPRAY	C	3.2SH1								
*RADIATION	R	3.2SH1								
*AGING	A	3.2SH1								
*SUBMERGENCE	S	3.2SH1								
EO. PCK # : 3.2SH1	OS8R CATEG.: A APPENDIX E		REFERENCES: 1. ASCO TEST REPORT #AOR-67368/ R O DATED MARCH 1982				REVISION # : 00 DATE : 09/04/84 SYSTEM : ESS. SER. CHILLO WATER TAG : 3CX-B2SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-81SR-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 10300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	VALVES								
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M /	NONE
MANUFACTURER:	NAMCO								REPLACEMENT: SEE NOTE (1)
MAJOR : SUPPLIER	HANMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M /	NONE
MODEL AND: SERIAL #	EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC:	NOT APPLICABLE								(1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS:	M-66H								
P.O #:	435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.:	AB21								SAFETY FUNCTION: SS
COORDINATES X- Y- Z-	1549. 1520. 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N):	LTR								
INSTAL. REF:	BY-FLD								
QUALIF EXEMPTN:	NOT APPLIC	PARA- METER	SUPPL. REVIEW						FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1 .
*****		OPERABILITY O	9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1						
*STATUS	CONFIRMATORY DATA	PRESSURE P	9.1SH1						
*		REL. HUMIDTY H	9.1SH1						
*		CHEM. SPRAY C	9.1SH1						
*****		RADIATION R	9.1SH1						
		AGING A	9.1SH1						
		SUBMERGENCE S	9.1SH1						
EQ. PCK # :	9.1SH1								REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.
		US8P CATEG.:	A						REVISION # :00 DATE :09/18/84
		APPENDIX E							SYSTEM :ESS.SER.CHILLO WATER TAG :3CX-81S9-1

A/E: EBAS SERVICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON HARBOR APP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 Mw(E)

0
 5009

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-84SB-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST DBA	40YRS NORM 100% DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
MODEL AND SERIAL #: EA180-11302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5009		
P.O #: 435176	TEMPERATURE	T	9.1SH1							
PLANT LOC.: AB21	PRESSURE	P	9.1SH1							
COORDINATES X- 1584.	REL. HUMDTY	H	9.1SH1							
Y- 1521.	CHEM. SPRAY	C	9.1SH1							
Z- 245.0	RADIATION	R	9.1SH1							
	AGING	A	9.1SH1							
INSTALLED (Y/N): LTR	SUBMERGENCE	S	9.1SH1					REVISION # : 00 DATE : 09/18/84		
INSTAL. REF: BY-FLD	OS8P CATEG.: A							SYSTEM : ESS.SER.CHILLD WATER		
QUALIF EXEMPTH: NOT APPLIC	APPENDIX E							TAG : 3CH-94SB-1		



A/E: EBAS SERVICES INC.
 UTILITY: ALINA POWER & LIGHT

FACILITY: SHEARON HARRISON - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5010

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-B3SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10700 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE : VALVES	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1				
COMPONENT : LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW									SUBCOMPONENTS:
MODEL AND SERIAL # : EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/26/81.
FUNCT. DES. & SERVICE : POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1574. Y- 1519. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	C 9.1SH1					CES#-5010		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMDTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1	0588 CATEG.: A APPENDIX E			REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.			REVISION # :00 DATE :09/18/84		
							SYSTEM :ESS.SER.CHILLO WATER TAG :3CH-B3SA-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 3CH-B1SR-1	OPERABILITY	43YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: VALVES								
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO								
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MODEL AND SERIAL #: EA180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: P-66H								
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	1U CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB21								
COORDINATES X- 1572. Y- 1519. Z- 245.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 9.1SH1						
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1						
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1						
*	REL. HUMDTY	H 9.1SH1						
*	CHEM. SPRAY	C 9.1SH1						
*****	RADIATION	R 9.1SH1						
	AGING	A 9.1SH1						
	SUBMERGENCE	S 9.1SH1						
EQ. PCK #: 9.1SH1								
	0588 CATEG.: A APPENDIX E							

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTE:
(1) PG.4-3,4-3.1 &
4-3.2 OF REPORT
QTR-105 REV 3
DATED 8/20/81.

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
QUALIFICATION REPORT QTR-105
REVISION 3 DATED 8/20/81.

QUALIFICATION SIGN-OFF
FOUN) IN DOCUMENTATION
PACKAGE: 9.1SH1

CES#-5011

REVISION #: JO
DATE: 09/18/84

SYSTEM: ESS. SER. CHILLD
WATER

TAG: 3CH-B1SR-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS				
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.							
TAG NO : AV-D23SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE				
EQUIPMENT: TYPE	DAMPERS											
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)			
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)			
MAJOR : SUPPLIER	RUSKIN								SUBCOMPONENTS:			
MODEL AND: SERIAL #	EA-180-22302								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT			
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION											
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE				
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS			
P.O #: 435205												
PLANT LOC.: AB21												
COORDINATES X- Y- Z-	1499. 1568. 242.0											
INSTALLED (Y/N): LTR INSTAL. REF:RY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.119	N/A	COMB. TEST & SUPPL.	/	NONE				
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
	OPERABILITY O	9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					CESN-5019			
	TEMPERATURE T	9.2SH1										
	PRESSURE P	9.2SH1										
	REL. HUMDTY H	9.2SH1										
	CHEM. SPRAY C	9.2SH1										
	RADIATION R	9.2SH1										
	AGING A	9.2SH1										
	SUBMERGENCE S	9.2SH1										
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E								REVISION # :00 DATE :09/18/84 SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D23SA-1			



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D24SB-1	OPERABILITY	4YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36 SRSO 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: DAMPERS	TEMPERATURE	104F NORM 104F DBA	176F NORM 176F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)				
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
MODEL AND SERIAL #: EA-180-22302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.24E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES#-5020			
P.O #: 435205	TEMPERATURE	T 9.2SH1											
PLANT LOC.: AB21	PRESSURE	P 9.2SH1											
COORDINATES X- 1499. Y- 1567. Z- 236.0	REL. HUMIDTY	H 9.2SH1											
INSTALLED (Y/N): LTR	CHEM. SPRAY	C 9.2SH1											
INSTAL. REF: BY-FLO	RADIATION	R 9.2SH1											
QUALIF EXEMPTH: NOT APPLIC	AGING	A 9.2SH1											
*****	SUBMERGENCE	S 9.2SH1											
*****	OS88 CATEG.: A												
*****	APPENDIX E												
EQ. PCK # : 9.2SH1									REVISION # :00 DATE :09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D24SB-1				

A/E: EBAS SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

U-5021

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D27SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-22302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	2.6E4								
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	47 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SA921 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
PLANT LOC.: AB21					SRSS 9.2SH1	REVIEW				
COORDINATES X- 1543. Y- 1565. Z- 236.C										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5021		
*****	TEMPERATURE	T 9.2SH1								
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 9.2SH1								
*STATUS CONFIRMATORY DATA	REL. HUMDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*	RADIATION	R 9.2SH1								
*****	AGING	A 9.2SH1						REVISION # :00 DATE :09/18/84		
	SUBMERGENCE	S 9.2SH1						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D27SA-1		
EQ. PCK # : 9.2SH1										
	0588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D26SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION					SRSO 9.2SH1	REVIEW				
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.64E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1	REVIEW				
COORDINATES X- 1452. Y- 1567. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
					SRSS 9.2SH1	REVIEW				
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH ED PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1						CES#-5022		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMIDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	R 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION # :00 DATE :09/18/84		
	AGING	A 9.2SH1								
	SUBMERGENCE	S 9.2SH1						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D26SB-1		
EQ. PCK # : 9.2SH1										
	0588 CATEG.: A APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : AV-D35SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	14YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DRA	1YR DRA	1YR DRA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DRA	104F NORM 104F DRA	TAB01A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DRA	ATM NORM ATM DRA	PAB01 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN				SRSR 9.2SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DRA	100% NORM 100% DRA	HAB01 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB01 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1	REVIEW				
ACCUR. DEP.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.74E4	RAB01R2 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1	REVIEW				
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: ABO1					SRSA 9.2SH1	REVIEW				
COORDINATES X- 1584. Y- 1643. Z- 206.0		SUBMERGED LEVEL	191.0 FEET	N/A	SAB01 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	M	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC										
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****		PARA- METER	SUPPL. REVIEW	FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
		OPERABILITY	O 9.2SH1					CES#-5023		
		TEMPERATURE	T 9.2SH1							
		PRESSURE	P 9.2SH1							
		REL. HUMDTY	H 9.2SH1							
		CHEM. SPRAY	C 9.2SH1							
		RADIATION	P 9.2SH1							
		AGING	A 9.2SH1							
		SUBMERGENCE	S 9.2SH1							
EQ. PCK # : 9.2SH1		OS88 CATEG.: A APPENDIX E		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				REVISION # : 00 DATE : 09/18/84		
								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D35SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D25SA-1	OPERABILITY	40YRS NORM 50G CYC	40YRS NORM 100% QUOCYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YP DBA	1YP DBA			SRSO 9.2SH1			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-22302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	ACCUR. SPEC: NOT APPLICABLE								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	A BETA								
P.O #: 435205	D B SHIELD	100%							
PLANT LOC.: AB21	S T.I.D.	2.6E4				SRSR 9.2SH1			
COORDINATES X- 1452. Y- 1568. Z- 242.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	10 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-18U REV 1 DATED 9/5/73.			CES#-5024		
*STATUS CONFIRMATORY DATA	TEMPERATURE T	9.2SH1							
*	PRESSURE P	9.2SH1							
*	REL. HUMDTY H	9.2SH1							
*	CHEM. SPRAY C	9.2SH1							
*****	RADIATION R	9.2SH1							
	AGING A	9.2SH1					REVISION # :00 DATE :09/18/84		
EQ. PCK # : 9.2SH1	SUBMERGENCE S	9.2SH1					SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D25SA-1		
	USRR CATEG.: A APPENDIX E								







A/E: EBAS SERVICES INC.
 UTILITY: MISSOURI POWER & LIGHT

FACILITY: SHEARON HARRIS
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

IN- D
 5027

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-04SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) P.D42 TO 047 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) P.D42 TO 047 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER : RUSKIN									SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 4.4E5 100% 2.6E4	2.34E8	RAB3111 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79 TO 081 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTIONS: SS
PLANT LOC.: AB31									
COORDINATES X- 1580. Y- 1603. Z- 268.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SURMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CES#-5027		
EQ. PCK # : 9.2SH1							REVISION # : 00 DATE : 09/18/84		
	0588 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-04SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D2RSB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO					SRST 9.2SH1				MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER : RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-223G2	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1543. Y- 1572. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					CES#-5028
EQ. PCK # : 9.2SH1								REVISION # :00 DATE :09/18/84	
	0588 CATEG.: A APPENDIX E							SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D28SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D20SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (2 CF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	F	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-047	COMB. TEST & SUPPL. REVIEW	F	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER : RUSKIN					SRSO 9.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER & SERVICE POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR53 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1476. Y- 1567. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CESW-5029	
EQ. PCK #: 9.2SH1								REVISION #: 00 DATE: 09/18/86	
	OS88 CATEG.: A APPENDIX E							SYSTEM: REAC.AUX.BLDG HVAC TAG: AV-D20SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D19SA-1	OPERABILITY	4CYRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: DAMPERS	DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAR21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSO 9.2SH1	REVIEW			SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1	REVIEW			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	7.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: BE-25	D B SHIELD	100%			SRSR 9.2SH1	REVIEW			
P.O #: 435205	S T.I.D.	2.6E4							
PLANT LOC.: AB21	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- 1476. Y- 1569. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
EQ. PCK # : 9.2SH1	OPERABILITY	O 9.2SH1							CES#-5030
	TEMPERATURE	T 9.2SH1							
	PRESSURE	P 9.2SH1							
	REL. HUMIDTY	H 9.2SH1							
	CHEM. SPRAY	C 9.2SH1							
	RADIATION	R 9.2SH1							
	AGING	A 9.2SH1							
	SUBMERGENCE	S 9.2SH1							
	OS88 CATEG.: A APPENDIX 2								REVISION # :00 DATE :09/18/84
					REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D19SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D56SA-1	OPERABIL-ITY	40YRS NORM 500 CYC	47YRS NORM 107,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA	1YR DBA	1YR DBA		SR50 9.2SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1) MAINTAIN.: P.079-D81 OF REF(1) SUBCOMPONENTS:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : RUSKIN SUPPLIER					SR5P 9.2SH1				
MODEL AND: EA-180 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1				
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.2SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.5C.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21					SRSA 9.2SH1				
COORDINATES X- 1465. Y- 1595. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA-METER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CESW-5032		
EQ. PCK # : 9.2SH1							REVISION # :00 DATE :09/18/84		
	0588 CATEG.: A APPENDIX E						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D56SA-1		



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	NOM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-D58SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1								
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)				
MAJOR SUPPLIER: RUSKIN					SRSO 9.2SH1				SUBCOMPONENTS:				
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.2SH1								
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	M	NONE					
SPECIFICATIONS: BE-25					SRSR 9.2SH1								
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: AB21					SRSA 9.2SH1								
COORDINATES X- 1467. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF. EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS, SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CES#-5034			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1											
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1											
*	REL. HUMIDTY	H 9.2SH1											
*	CHEM. SPRAY	C 9.2SH1											
*****	RADIATION	R 9.2SH1											
	AGING	A 9.2SH1											
	SUBMERGENCE	S 9.2SH1											
EQ. PCK #: 9.2SH1	OS82 CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84				
									SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D58SA-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D59SR-1	OPERABILITY	40YRS NORM 500 CYC	40YRS-NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA							
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F 400M 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS 400M ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% 400M 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION										
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: RE-25										
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D31	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1468. Y- 1586. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: PY-FLD										
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1						CESN-5035		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMIDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	R 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						
	AGING	A 9.2SH1						REVISION # :00 DATE :09/18/84		
	SUBMERGENCE	S 9.2SH1						SYSTEM : REAC.AUX.BLDG HVAC		
EQ. PCK # : 9.2SH1								TAG : AV-D59SR-1		
	US88 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D11SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	140YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS				SRSO 9.2SH1	REVIEW				
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47 SUPPL.	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SUPPL.	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER	RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SUPPL.	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-22302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SUPPL.	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION					SRSO 9.2SH1	REVIEW			
ACCUR. SPEC:	NOT APPLICABLE					SRSO 9.2SH1	REVIEW			
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.34F8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SUPPL.	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	BE-25					SRSR 9.2SH1	REVIEW			
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	140 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81 SUPPL.	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB21					SRSA 9.2SH1	REVIEW			
COORDINATES X- Y- Z-	1497. 1597. 247.0	SUBMERGED LEVL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SUPPL.	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N):	LTR					SRSS 9.2SH1	REVIEW			
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL.							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
QUALIF EXEMPTN:	NOT APPLIC	METER	REVIEW							
*****		OPERABILITY	O 9.2SH1							CES#-5C36
*QUALIF: QUALIFIED-AWAITING		TEMPERATURE	T 9.2SH1							
*STATUS CONFIRMATORY DATA		PRESSURE	P 9.2SH1							
*		REL. HUMDTY	H 9.2SH1							
*		CHEM. SPRAY	C 9.2SH1							
*****		RADIATION	P 9.2SH1							
		AGING	A 9.2SH1							
		SUBMERGENCE	S 9.2SH1							
EQ. PCK # :	9.2SH1									REVISION # :00 DATE :09/18/84
		0528 CATEG.:	A							SYSTEM :REAC.AUX.BLDG HVAC
		APPENDIX E								TAG :AV-D11SA-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

REFERENCES: (1)NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : AV-D87SB-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE									
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR : RUSKIN SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITON								
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100% 2.6E4	2.6E4 4.4E5 100% 2.6E4	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB31									
COORDINATES X- 1580. Y- 1690. Z- 272.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPT: NOT APPLIC	PARAMETER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1 QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1 CES#-5037
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY TEMPERATURE PRESSURE REL. HUMIDTY CHEM. SPRAY RADIATION AGING SUBMERGENCE	O T P H C R A S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1						REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81. REVISION # : 00 DATE : 09/19/84
EQ. PCK # : 9.1SH1	OSRP CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D87SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D9SA-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 1000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 [SRSO 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DAMPERS	TEMPERATURE	95F NORM 95F DBA	104F NORM 104F DBA	TYD31R FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRST 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11P	REF(1) PG.10-14 & 4-4 [SRSP 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	10-100% NORM 100% DBA	100% NORM 100% DBA	HYD31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 [SRSH 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A [SRSC 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
MODEL AND SERIAL #: EA-180-22302	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 4.4E5 100X 2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7 [SRSR 9.1SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YOS	10 CFR5J PARA.50.51	REF(1) PG.4-7 & 4-12 [SRSA 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A [SRSS 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW			FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
SPECIFICATIONS: BE-25	OPERABILITY	O	9.1SH1						CES#-5038
P.O #: 435205	TEMPERATURE	T	9.1SH1						
PLANT LOC.: AB31	PRESSURE	P	9.1SH1						
COORDINATES X- 1410. Y- 1694. Z- 271.0	REL. HUMIDTY	H	9.1SH1						
	CHEM. SPRAY	C	9.1SH1						
	RADIATION	R	9.1SH1						
	AGING	A	9.1SH1						
	SUBMERGENCE	S	9.1SH1						
INSTALLED (Y/N): LTR									
INSTALL. REF: BY-FLD									
QUALIF EXEMPTN: NOT APPLIC									

*QUALIF: QUALIFIED-AWAITING									
*STATUS CONFIRMATORY DATA									
*									
*									

EQ. PCK # : 9.1SH1									
	USRR CATEG.: A								
	APPENDIX E								
					REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION # : 00 DATE : 09/18/84
									SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D9SA-1

A/E: EBASC SERVICES INC.
 UTILITY: INA POWER & LIGHT

FACILITY: SHEARON MARK
 COMPONENT EVALUATION S PP - 1

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5039

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D7SA-1	OPERABILITY	40YRS NORM 500 CYC	14YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42 TO D47 SRST 9.2SH1	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42 TO D47 SRSP 9.2SH1	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)	
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: RFMTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL.	/	NONE		
ACCUR. SPEC: NOT -APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB21R7 FSAP SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL.	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4								
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YPS	10 CFR50 PARA.50.51	REF(1) P.079 TO 081. SRSA 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL.	/	NONE		
COORDINATES X- 1427. Y- 1595. Z- 236.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5039 REVISION # : 00 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D7SA-1		
	TEMPERATURE	T 9.2SH1								
	PRESSURE	P 9.2SH1								
	REL. HUMDTY	H 9.2SH1								
	CHEM. SPRAY	C 9.2SH1								
	RADIATION	R 9.2SH1								
	AGING	A 9.2SH1								
	SUBMERGENCE	S 9.2SH1								
EQ. PCK # : 9.2SH1	U588 CATEG.: A APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AV-069SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA			SRSO 9.2SH1							
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)				
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE						SRSP 9.2SH1							
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74ER	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: BE-25						SRSR 9.2SH1							
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: AB21						SRSA 9.2SH1							
COORDINATES X- 1538. Y- 1574. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.						CESW-5040			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1											
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1											
*	REL. HUMDTY	H 9.2SH1											
*	CHEM. SPRAY	C 9.2SH1											
*****	RADIATION	R 9.2SH1											
	AGING	A 9.2SH1											
	SUBMERGENCE	S 9.2SH1											
EQ. PCK # : 9.2SH1	C588 CATEG.: A APPENDIX F								REVISION # : 00 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-069SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D68SA-1	OPERABILITY	40YRS NORM	40YRS NORM	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE : DAMPERS					SRSO 9.2SH1					
COMPONENT : LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER: NAMCO					SRST 9.2SH1				MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR SUPPLIER : RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PA921 FSAR SEC 3.11B	REF(1) P.042-D47	COMB. TEST & SUPPL. REVIEW	P	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL # : EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE : REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.2SH1					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: BE-25					SRSR 9.2SH1					
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.2SH1					
COORDINATES X- 1538. Y- 1595. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTP INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC					SRSS 9.2SH1					
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
	OPERABILITY	O 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5041		
	TEMPERATURE	T 9.2SH1								
	PRESSURE	P 9.2SH1								
	REL. HUMIDTY	H 9.2SH1								
	CHEM. SPRAY	C 9.2SH1								
	RADIATION	R 9.2SH1								
	AGING	A 9.2SH1						REVISION # :00 DATE :09/18/84		
	SUBMERGENCE	S 9.2SH1						SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D68SA-1		
EQ. PCK # : 9.2SH1	OSRR CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D65SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS									
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR SUPPLIER :	RUSKIN	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: R SERVICE	REMOTE INDICAT ION OF DAMPER, POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.74E5	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.:	NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS:	BE-25	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:	435205	INSTALLED (Y/N):	LTR							
PLANT LOC.:	AB21	QUALIF EXEMPTN:	NOT APPLIC							
COORDINATES X- Y- Z-	1479. 1590. 247.0	PARAMETER	SUPPL. REVIEW							
		OPERABILITY	O 9.2SH1							
		TEMPERATURE	T 9.2SH1							
		PRESSURE	P 9.2SH1							
		REL. HUMPTY	H 9.2SH1							
		CHEM. SPRAY	C 9.2SH1							
		RADIATION	R 9.2SH1							
		AGING	A 9.2SH1							
		SUBMERGENCE	S 9.2SH1							
EQ. PCK # :	9.2SH1	US88 CATEG.:	A							
		APPENDIX	E							

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.2SH1.

CES#-5042

REFERENCES: (1)NAMCO QUALIFICATION REPORT
 EA-180 REV 1 DATED 9/5/78.

REVISION # :00
 DATE :09/18/84

SYSTEM :REAC.AUX.BLDG
 HVAC
 TAG :AV-D65SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CB-D1SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE	REMOTE INDICATION OF DAMPER POSITION				SRSH 9.1/9.					
ACCUR. SPEC:	NOT APPLICABLE				SRSC 9.1/9.					
ACCUR. DEM.:	NOT APPLICABLE									
SPECIFICATIONS:										
P.O #:	R GAMMA INST LIFE (PER 323-1974 DEF.)	2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	SAFETY FUNCTION: PRRM	
PLANT LOC.:	AB41				SRSA 9.1/9.					
COORDINATES X- Y- Z-	1396. 1641. 295.0									
INSTALLED (Y/N): LTR										
INSTAL. REF: RY-FLD										
QUALIF EXEMPTN: NOT APPLIC										
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
*QUALIF: LATER	OPERABILITY O	9.1/9.2		REFERENCES:				CES#-5043		
*STATUS	TEMPERATURE T	9.1/9.2								
*	PRESSURE P	9.1/9.2								
*	REL. HUMDTY H	9.1/9.2								
*	CHEM. SPRAY C	9.1/9.2								
*****	RADIATION R	9.1/9.2								
	AGING A	9.1/9.2								
	SUBMERGENCE S	9.1/9.2								
EQ. PCK # :	9.1/9.2							REVISION # : 00 DATE :		
	US82 CATEG.: A							SYSTEM : CONT. VACUUM RELIEF		
	APPENDIX E							TAG : CB-D1SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : CB-D2SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	#	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	#	NONE
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE	ACCUR. SPEC:	NOT APPLICABLE			SRSO 9.1/9.			
REMOTE INDICATION OF DAMPER POSITION	ACCUR. DEM.:	NOT APPLICABLE						
	SPECIFICATIONS:							
	R GAMMA	2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
	A BETA	7.2E4						
	D B SHIELD	100X						
	S T.I.D.	2.6E4			SRSR 9.1/9.			
	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #:	PLANT LOC.:	AR41			SRSA 9.1/9.			
COORDINATES X- 1573. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW						
*****	OPERABILITY	O 9.1/9.2						
*QUALIF: LATER	TEMPERATURE	T 9.1/9.2						
*STATUS	PRESSURE	P 9.1/9.2						
*	REL. HUMIDTY	H 9.1/9.2						
*	CHEM. SPRAY	C 9.1/9.2						
*****	RADIATION	R 9.1/9.2						
	AGING	A 9.1/9.2						
	SUBMERGENCE	S 9.1/9.2						
EQ. PCK # : 9.1/9.2	US88 CATEG.: A APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2

REFERENCES:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2

CESN-5044

REVISION # :00
 DATE :

SYSTEM : CONT. VACUUM RELIEF
 TAG : CB-D2SB-1

A/E: EBASCO SERVICES INC.
UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARPIS NPP - 1
COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
CAPACITY: 900 MW(E)

REV#- 0
CES#-5045

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D64SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47 SRST 9.2SH1	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47 SRSP 9.2SH1	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)
MAJOR : SUPPLIER	RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77 SRSH 9.2SH1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION									
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16 SRSR 9.2SH1	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	BE-25	D B SHIELD	100%							
P.O #:	435205	S T.I.D.	2.6E4							
PLANT LOC.:	AB21	AGE-	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81 SRSA 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
COORDINATES X- Y- Z-	1482. 1595. 247.0	INST LIFE (PER 323- 1974 DEF.)								
COORDINATES X- Y- Z-	1482. 1595. 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.2SH1	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW	FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
INSTAL. REF:BY-FLD		OPERABILITY	O 9.2SH1							
QUALIF EXEMPTN: NOT APPLIC		TEMPERATURE	T 9.2SH1							
*****		PRESSURE	P 9.2SH1							
*QUALIF: QUALIFIED-AWAITING		REL. HUMDTY	H 9.2SH1							
*STATUS CONFIRMATORY DATA		CHEM. SPRAY	C 9.2SH1							
*		RADIATION	R 9.2SH1							
*		AGING	A 9.2SH1							
*****		SUBMERGENCE	S 9.2SH1							
EQ. PKY # :	9.2SH1	G588 CATEG.:	A	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			REVISION # :00 DATE :09/18/84			
		APPENDIX E					SYSTEM : REACTOR BLDG HV			
							TAG : A' SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-D86SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10700 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW		
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%		SRSR 9.1SH1		REVIEW		
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4						
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE
PLANT LOC.: AB31				SRSA 9.1SH1		REVIEW		
COORDINATES X- 1580. Y- 1705. Z- 270.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1	
*****	OPERABILITY O	9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.			CES#-5046	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1					REVISION # :00	
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1					DATE :09/18/84	
*	REL. HUMDTY H	9.1SH1					SYSTEM : REAC.AUX.BLDG	
*	CHEM. SPRAY C	9.1SH1					HVAC	
*****	RADIATION R	9.1SH1					TAG : AV-D86SA-1	
	AGING A	9.1SH1						
	SUBMERGENCE S	9.1SH1						
EQ. PCK # : 9.1SH1	USRR CATEG.: A							
	APPENDIX E							

REPLACEMENT: SEE NOTE (1)
 MAINTAIN.: SEE NOTE (1)
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
 NOTE:
 (1)PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-074SA-1	OPERABILITY	40YRS NORM 500 CYC	14YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAP SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEP.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: BE-25	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
P.O #: 435205									
PLANT LOC.: AB21									
COORDINATES X- 1548. Y- 1586. Z- 247.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY O	9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CES#-5047		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	9.2SH1							
*	REL. HUMDTY H	9.2SH1							
*	CHEM. SPRAY C	9.2SH1							
*****	RADIATION R	9.2SH1							
	AGING A	9.2SH1							
	SURMERGENCE S	9.2SH1							
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E						REVISION # :00 DATE :09/18/84 SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-074SA-1		

A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEARON HARRIS - NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

0
 5048

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : AV-D73SB-1	OPERABILITY	43YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.D79-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.D79-081 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.2SH1					
SPECIFICATIONS: BE-25	S T.I.D.	2.6E4								
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1543. Y- 1578. Z- 248.0					SRSS 9.2SH1					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5048		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMIDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	R 9.2SH1								
	AGING	A 9.2SH1								
	SUBMERGENCE	S 9.2SH1								
EQ. PCK #: 9.2SH1	OS&R CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D73SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.						
TAG NO : AV-D75SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	140YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE			
EQUIPMENT: TYPE	DAMPERS	NORM/TEST D9A	1YR DBA		SRSO 9.2SH1	REVIEW					
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.119	REF(1) P.042-047 SUPPL.	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.079-D81 OF REF(1)	
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.119	REF(1) P.042-047 SUPPL.	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-D81 OF REF(1)	
MAJOR : SUPPLIER	RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.119	N/A SUPPL.	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.119	REF(1) P.077 SUPPL.	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE, TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION					SRSO 9.2SH1	REVIEW				
ACCUR. SPEC:	NOT APPLICABLE					SRSC 9.2SH1	REVIEW				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RA921R7 FSAR SEC 3.119	REF(1) P.016 SUPPL.	COMB. TEST & SUPPL.	M	NONE		
SPECIFICATIONS:	BE-25	A BETA	100X			SRSR 9.2SH1	REVIEW				
P.O #:	435205	S T.I.D.	2.6E4								
PLANT LOC.:	AR21	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	16 CFR50 PARA.50.51	REF(1) P.079-D81 SUPPL.	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
COORDINATES	X- 1543. Y- 1585. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.119	N/A SUPPL.	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N):	LTR										
INSTAL. REF:	BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1			
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O	9.2SH1					CES#-5049		
*****		TEMPERATURE	T	9.2SH1							
*QUALIF:	QUALIFIED-AWAITING	PRESSURE	P	9.2SH1							
*STATUS	CONFIRMATORY DATA	REL. HUMIDTY	H	9.2SH1							
*		CHEM. SPRAY	C	9.2SH1							
*		RADIATION	R	9.2SH1							
*****		AGING	A	9.2SH1							
		SUBMERGENCE	S	9.2SH1							
EQ. PCK # :	9.2SH1	OSRR CATEG.:	A					REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			
		APPENDIX E						REVISION # :00 DATE :09/18/84			
								SYSTEM :REAC.AUX.BLDG HVAC			
								TAG :AV-D75SB-1			



A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPPON HARBOR NPP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -5050

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS			
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS			
TAG NO : AV-D72SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE			
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW					
COMPONENT: LIMIT SWITCH (2 CF 2)	TEMPERATURE	104F NORM 104F DBA	106F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)		
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)		
MAJOR SUPPLIER : RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT		
FUNCT. DES: REMOTE INDICAT & SERVICE ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE			
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE			
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR59 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS		
SPECIFICATIONS: RE-25	SUBMERGED LEVFL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE			
P.O # : 435205											
PLANT LOC.: AB21											
COORDINATES X- 1546. Y- 1595. Z- 249.0											
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1) NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.					CES#-5050		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1									
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1									
*	REL. HUMIDTY	H 9.2SH1									
*	CHEM. SPRAY	C 9.2SH1									
*****	RADIATION	R 9.2SH1									
	AGING	A 9.2SH1									
	SUBMERGENCE	S 9.2SH1									
EQ. PCK # : 9.2SH1	OSRP CATEG.: A APPENDIX E							REVISION # : 00 DATE : 09/15/84			
								SYSTEM : REAC.AUX.BLDG HVAC TAG : AV-D72SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D61SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 1000,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPERS								
COMPONENT: . LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	116F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.042-D47 SRST 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-D81 OF REF(1) MAINTAIN.: P.079-D81 OF REF(1) SUBCOMPONENTS:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAR21 FSAR SEC 3.11B	REF(1) P.042-D47 SRSP 9.2SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	RUSKIN								
MODEL AND: SERIAL #	EA-180								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION								
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T. I. D.	2.6E4 100X 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) P.016 SRSR 9.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81 SRSA 9.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #: 435205									
PLANT LOC.: AB21									
COORDINATES X- Y- Z-	1516. 1574. 248.0								
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY O	9.2SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.2SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	9.2SH1							
*	REL. HUMDTY H	9.2SH1							
*	CHEM. SPRAY C	9.2SH1							
*****	RADIATION R	9.2SH1							
	AGING A	9.2SH1							
	SURMFERENCE S	9.2SH1							
EQ. PCK # : 9.2SH1	0588 CATEG.: A APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.2SH1

CES#-5051

REFERENCES: (1) NAMCO QUALIFICATION REPORT
EA-180 REV 1 DATED 9/5/79.

REVISION # : 00
DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG
HVAC
TAG : AV-D61SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : E-6(19-SB)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: DBA					SRSO				
COMPONENT: DOOR SWITCH(2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB31A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO					SRST				
MAJOR SUPPLIER:	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
					SRSP				
MODEL AND SERIAL #: EA-180-31302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION					SRSH				
	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC				
	R GAMMA	2.6E4	LATER	RAB3111 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
	S T.I.D.	2.6E4			SRSR				
SPECIFICATIONS:									
P.O #:	AGE- INST LIFE (PEP 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB31					SRSA				
COORDINATES X- 1584. Y- 1766. Z- 261.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB31 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
					SRSS				
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
QUALIF. EXEMPTN: NOT APPLIC	OPERABILITY	O		REFERENCES:				CES#-5053	
*QUALIF: LATER	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A						REVISION # : 00	
	SUBMERGENCE	S						DATE :	
EQ. PCK # :	0588 CATEG.: A							SYSTEM : REAC.AUX.BLDG HVAC	
	APPENDIX E							TAG : E-6(19-SB)	

A/E: EBAS SERVICES INC.
 UTILITY: OLINA POWER & LIGHT

FACILITY: SHEARON HART NPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 -5055

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2CB-B2SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DBA					SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB41A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO					SRST 9.1/9.				MAINTAIN.:	
MAJOR SUPPLIER:	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-32302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSP 9.1/9.					
ACCUR. DEP.: NOT APPLICABLE	R GAMMA	2.6E4	LATER	RAB4117 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
	A BETA	7.2E4								
	D B SHIELD	100%								
	S T.I.D.	2.6E4				SRSR 9.1/9.				
SPECIFICATIONS:										
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: PRRM	
PLANT LOC.: AB41					SRSA 9.1/9.					
COORDINATES X- 1575. Y- 1686. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB41 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS 9.1/9.					
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY O	9.1/9.2		REFERENCES:				CESN-5055		
*****	TEMPERATURE T	9.1/9.2								
*QUALIF: LATER	PRESSURE P	9.1/9.2								
*STATUS	REL. HUMDTY H	9.1/9.2								
*	CHEM. SPRAY C	9.1/9.2								
*	RADIATION R	9.1/9.2								
*****	AGING A	9.1/9.2								
	SUBMERGENCE S	9.1/9.2								
EQ. PCK # : 9.1/9.2	OSR8 CATEG.: A							REVISION # : 00		
	APPENDIX E							DATE :		
								SYSTEM : CONT. VACUUM RELIEF		
								TAG : 2C9-92SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D10SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100% CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: RUSKIN					SRSR 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.34E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	M	NONE		
SPECIFICATIONS: BE-25					SRSR 9.1SH1	REVIEW				
P.O #: 435205	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB41					SRSA 9.1SH1	REVIEW				
COORDINATES X- 1557. Y- 1616. Z- 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS: CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SURMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5056 REVISION # : 00 DATE : 09/19/84
EQ. PCK # : 9.1SH1	Q588 CATEG.: A APPENDIX E								SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D10SB-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AC-D9SB-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST 1YR DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: DAMPERS TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81				
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
MODEL AND SERIAL #: EA-180	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	2.74E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: BE-25	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5057			
P.O #: 435205	TEMPERATURE	T 9.1SH1											
PLANT LOC.: AB41	PRESSURE	P 9.1SH1											
COORDINATES X- 1545. Y- 1616. Z- 295.0	REL. HUMDTY	H 9.1SH1											
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD	CHEM. SPRAY	C 9.1SH1											
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 9.1SH1											
*****	AGING	A 9.1SH1											
*****	SUBMERGENCE	S 9.1SH1											
EQ. PCK # : . 9.1SH1	OSBR CATEG.: A APPENDIX E								REVISION # : 30 DATE : 09/18/84 SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D9SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AC-D7SA-1	OPERABILITY	40YRS NORM 500 CYC NORM/TEST DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: DAMPERS	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL #: EA-180	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100X 2.6E4	2.7E4	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	AGE-INST-LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW						
SPECIFICATIONS: BE-25	OPERABILITY	O	9.1SH1	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
P.O #: 435205	TEMPERATURE	T	9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5058
PLANT LOC.: AB41	PRESSURE	P	9.1SH1					
COORDINATES X- 1442. Y- 1618. Z- 295.0.	REL. HUMIDTY	H	9.1SH1	REVISION # :00 DATE :09/18/84				
	CHEM. SPRAY	C	9.1SH1					
INSTALLED (Y/N): LTR	RADIATION	R	9.1SH1	SYSTEM : REAC.AUX.BLDG HVAC				
INSTAL. REF: BY-FLD	AGING	A	9.1SH1					
QUALIF EXEMPTN: NOT APPLIC	SUBMERGENCE	S	9.1SH1	TAG : AC-D7SA-1				

*QUALIF: QUALIFIED-AWAITING								
*STATUS CONFIRMATORY DATA								
*								
*								

EQ. PCK # : 9.1SH1	OS88 CATEG.: A							
	APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-D17SA-1	OPERABILITY	40YRS NORM 500 CYC	147YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	176F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	2.6E4	2.74E8	RAB4117 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	A BETA	7.2E4								
SPECIFICATIONS: BE-25	D B SHIELD	100%								
P.O N: 435205	S T.I.D.	2.6E4								
PLANT LOC.: AB41	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
COORDINATES X- 1427. Y- 1604. Z- 298.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5059		
	TEMPERATURE	T	9.2SH1							
	PRESSURE	P	9.2SH1							
	REL. HUMIDTY	H	9.2SH1							
	CHEM. SPRAY	C	9.2SH1							
	RADIATION	R	9.2SH1							
	AGING	A	9.2SH1					REVISION # :00 DATE :09/18/84		
EQ. PCY N : 9.2SH1	SUBMERGENCE	S	9.2SH1					SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D17SA-1		
	0588 CATEG.: A APPENDIX F									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : AC-055SB-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: DAMPERS													
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO													
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATMOS NORM ATMOS DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81				
ACCUR. SPEC: NOT APPLICABLE													
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 100% 2.6E4	2.24E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: BE-25													
P.O #: 435205	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	47 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: A841													
COORDINATES X- Y- Z-: 1574. 1688. 297.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
INSTALLED (Y/N): LTR													
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5061			
*****	TEMPERATURE	T 9.1SH1											
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 9.1SH1											
*STATUS CONFIRMATORY DATA	REL. HUMDTY	H 9.1SH1											
*	CHEM. SPRAY	C 9.1SH1											
*	RADIATION	R 9.1SH1											
*****	AGING	A 9.1SH1											
	SURMERGENCE	S 9.1SH1											
EQ. PCK #: 9.1SH1	OS9P CATEG.: A								REVISION #: 00				
	APPENDIX E								DATE: 09/18/84				
									SYSTEM: REAC.AUX.BLDG HVAC				
									TAG: AC-055SB-1				



A/E: EBA SERVICES INC.
 UTILITY: CAROLINA POWER & LIGHT

FACILITY: SHEPSON HAF
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

44- 0
 8-5062

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AC-019SR-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	DAMPERS DBA				SRSO 9.2SH1	REVIEW				
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) P.042-047 SRSO 9.2SH1	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) P.042-047 SRSO 9.2SH1	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR : SUPPLIER	RUSKIN'				SRSO 9.2SH1	REVIEW				SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180	RELATIVE HUMIDITY	20-90%NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) P.077 SRSO 9.2SH1	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A SRSO 9.2SH1	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEP.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 10GX 2.6E4	2.74E8	RAB4117 FSAR SEC 3.11B	REF(1) P.016 SRSO 9.2SH1	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS:	BE-25									
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081 SRSO 9.2SH1	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB41									
COORDINATES	X- 1565. Y- 1632. Z- 294.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A SRSO 9.2SH1	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD	PARA- METER	SUPPL. REVIEW							
QUALIF EXEMPTN:	NOT APPLIC	OPERABILITY	O	9.2SH1						FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1.
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T	9.2SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*STATUS	CONFIRMATORY DATA	PRESSURE	P	9.2SH1						CESA-5C62
*		REL. HUMDTY	H	9.2SH1						
*		CHEM. SPRAY	C	9.2SH1						REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.
*****		RADIATION	R	9.2SH1						
		AGING	A	9.2SH1						REVISION # :00 DATE :09/18/84
		SUBMERGENCE	S	9.2SH1						SYSTEM :REAC.AUX.BLOG HVAC TAG :AC-019SR-1
EQ. PCK # :	9.2SH1									
		0588 CATEG.:	A							
		APPENDIX	E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AC-D8SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YPS NORM 177300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	DAMPERS DBA	1YR DBA	1YR DBA			SRSO 9.1SH1 REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB41A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	#	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	#	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	RUSKIN								SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB41 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DOOR POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE						SRSC 9.1SH1			
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 7.2E4 10UX 2.6F4	2.04E8	RAB4117 FSAR SEC 3.11B	REF(1) PG.10-7 SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB41									
COORDINATES X- Y- Z-	1456. 1618. 295.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PARA- METER	SUPPL. REVIEW						FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1
*QUALIF: QUALIFIED-AWAITING		OPERABILITY O	9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*STATUS CONFIRMATORY DATA		TEMPERATURE T	9.1SH1						CES#-5063
*REL. HUMIDITY H		PRESSURE P	9.1SH1						
*CHEM. SPRAY C		REL. HUMIDITY H	9.1SH1						
*RADIATION P		CHEM. SPRAY C	9.1SH1						REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.
*AGING A		RADIATION P	9.1SH1						
*SUBMERGENCE S		AGING A	9.1SH1						REVISION # : 00 DATE : 09/18/84
EO. PCK # : 9.1SH1		SUBMERGENCE S	9.1SH1						SYSTEM : REAC.AUX.BLDG HVAC TAG : AC-D8SA-1
		OSRR CATEG.: A APPENDIX E							

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AC-D20SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	DBA	1YR 09A	1YR 09A		SRSO 9.2SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F 09A	104F NORM 104F 09A	TAB41A FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: P.079-081 OF REF(1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS 09A	ATM NORM ATM DBA	PAB41 FSAR SEC 3.11B	REF(1) P.042-047	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: P.079-081 OF REF(1)
MAJOR SUPPLIER: RUSKIN					SRSO 9.2SH1				SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% 09A	100% NORM 100% 09A	HAB41 FSAR SEC 3.11B	REF(1) P.077	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DOOR POSITION					SRSO 9.2SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	2.6E4	2.34E8	RAB4117 FSAR SEC 3.11B	REF(1) P.016	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25	A BETA	7.2E4							
P.O #: 435205	D B SHIELD	100%							
PLANT LOC.: AB41	S T.I.D.	2.6E4			SRSR 9.2SH1				
COORDINATES X= 1571. Y= 1683. Z= 294.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-081	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB41 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*QUALIF: QUALIFIED-AWAITING	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.			CESN-5064		
*STATUS CONFIRMATORY DATA	TEMPERATURE	T	9.2SH1						
*	PRESSURE	P	9.2SH1						
*	REL. HUMIDTY	H	9.2SH1						
*	CHEM. SPRAY	C	9.2SH1						
*	RADIATION	R	9.2SH1						
	AGING	A	9.2SH1				REVISION # : 00		
	SUBMERGENCE	S	9.2SH1				DATE : 09/18/84		
EQ. PCK # : 9.2SH1	OSBR CATEG.: A						SYSTEM : REAC.AUX.BLDG HVAC		
	APPENDIX F						TAG : AC-D20SB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3MS-V17SAB-1	OPERABILITY	NORM: 40YRS 530 CYC	NORM: 40YRS 23,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVE OPERATORS	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 121 CYC		REF 1, P.26 SRSO 3.2SH1				
COMPONENT: SOLENOID VALVE (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	123F NORM FOR DBA FIG F1A- 3.2SH1	TAB21A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OPSIG NORM FOR DBA FIG F2A- 3.2SH1	PAB21 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: REF 1, APP.C
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: NP8320A175E	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF 1, SEC 8.1.3 & 8.2.3	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: CONTROL AIR TO & SERVICE PNEUM. OPERATOR					SRSH 3.2SH1				
ACCUR. SPEC: NOT APPLICABLE					SRSC 3.2SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 100X 2.6E4	2.35E8 2.35E8	RAB21R7 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2	COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS: M-66H					SRSR 3.2SH1				
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YEARS	10 CFR 50 PARA. 50.51	REF 1, P.A3 FIG 14, P.C-58C-8	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21					SRSA 3.2SH1				
COORDINATES X- 1515. Y- 1520. Z- 238.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	N/A	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY	O 3.2SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1							CES#-5065
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1							
*	REL. HUMIDTY	H 3.2SH1							
*	CHEM. SPRAY	C 3.2SH1							
*****	RADIATION	R 3.2SH1							REFERENCES: 1.ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982
	AGING	A 3.2SH1							REVISION # : 00 DATE : 09/04/84
	SUBMERGENCE	S 3.2SH1							SYSTEM : MAIN STEAM
EQ. PCK # : 3.2SH1	OS88 CATEG.: A APPENDIX E								TAG : 3MS-V17SAB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3MS-V17SAB-1	OPERABIL-ITY	4GYRS NORM 500 CYC	40YPS NORM 100% DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVES TYPE									
COMPONENT: LIMIT SWITCH (2 OF 4)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/COM SUPPLIER OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND: EA-180-113C2 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100%	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YPS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21									
COORDINATES X- 1515. Y- 1520. Z- 238.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	9.1SH1							CES#-5067
*STATUS CONFIRMATORY DATA	TEMPERATURE T	9.1SH1							
	PRESSURE P	9.1SH1							
	REL. HUMIDTY H	9.1SH1							
	CHEM. SPRAY C	9.1SH1							
	RADIATION R	9.1SH1							
	AGING A	9.1SH1							
	SUBMERGENCE S	9.1SH1							
EQ. PCK # : 9.1SH1									REVISION # : 00 DATE : 09/18/84
	OS88 CATEG.: A APPENDIX E								SYSTEM : MAIN STEAM TAG : 3MS-V17SAB-1

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1)NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3FS-V17SAB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (3 OF 4)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4	2.34E3	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB21										
COORDINATES X- 1515. Y- 1520. Z- 238.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC										
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY O	9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CESN-5068		
*QUALIF: QUALIFIED-AWAITING	*TEMPERATURE T	9.1SH1								
*STATUS CONFIRMATORY DATA	*PRESSURE P	9.1SH1								
*	*REL. HUMDTY H	9.1SH1								
*	*CHEM. SPRAY C	9.1SH1								
*****	*RADIATION R	9.1SH1								
	*AGING A	9.1SH1								
	*SUBMERGENCE S	9.1SH1								
EQ. PCK # : 9.1SH1	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84 SYSTEM : MAIN STEAM TAG : 3MS-V17SAB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3MS-V18SAB-1	OPERABILITY	40YRS NORM 500 CYC	40YPS NORM 17300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 4)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/CON SUPPLIER OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.3E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YPS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: CI
SPECIFICATIONS:M-66H	SUPERMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
P.O #:435176									
PLANT LOC.: AB21									
COORDINATES X- 1515. Y- 1528. Z- 238.0									
INSTALLED (Y/N): LTR INSTAL. REF:BY-FLD QUALIF EXEMPTN: NOT APPLIC ***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	PARA- METER OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDITY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	SUPPL. REVIEW 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1 CESN-5070 REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E								REVISION # :00 DATE :09/18/84 SYSTEM :MAIN STEAM TAG :3MS-V18SAB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3MS-V18SAB-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 50G CYC 1YR DBA	40YRS NORM 100300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE: VALVES									
COMPONENT: LIMIT SWITCH (3 OF 4)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: HANDEL DAHL/CON OFLOW	PRESSURE ATMOS ATMOS DBA	ATM NORM ATM DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	10% NORM 10% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.04E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI
PLANT LOC.: AB21									
COORDINATES X- 1515. Y- 1528. Z- 238.C	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SURMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
EQ. PCK #: 9.1SH1					REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5071
	USB# CATEG.: A APPENDIX E								REVISION #: 00 DATE: 09/18/84
									SYSTEM: MAIN STEAM
									TAG: 3MS-V18SAB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3MS-V18SAB-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	140YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: VALVES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (4 OF 4)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	R GAMMA A BETA D B SHIELD S T.I.D.	2.6E4 100X 2.6E4	2.74E8	RAB21R7 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
MODEL AND SERIAL #: EA-180-11302	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI				
FUNCT. DES. & SERVICE: POSITION INDICATION	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. SPEC: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1.						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
ACCUR. DEM.: NOT APPLICABLE	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5072			
SPECIFICATIONS: M-66H	TEMPERATURE	T 9.1SH1											
P.O #: 435176	PRESSURE	P 9.1SH1											
PLANT LOC.: AB21	REL. HUMIDITY	H 9.1SH1											
COORDINATES X- 1515. Y- 1528. Z- 238.0	CHEM. SPRAY	C 9.1SH1											
	RADIATION	R 9.1SH1											
INSTALLED (Y/N): LTR	AGING	A 9.1SH1							REVISION #: 00				
INSTAL. REF: BY-FLD	SUBMERGENCE	S 9.1SH1							DATE: 09/18/84				
QUALIF EXEMPTN: NOT APPLIC	GS88 CATEG.: A								SYSTEM: MAIN STEAM				
*****	APPENDIX F								TAG: 3MS-V18SAB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V83SA-1	OPERABILITY	4YRS NORM 50C CYC	4YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO										
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.74E3	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21										
COORDINATES X- 1471. Y- 1620. Z- 240.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1								CES#-5074
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1								
*	REL. HUMIDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK #: 9.1SH1				REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						REVISION #: 00 DATE: 09/18/84
	OS8B CATEG.: A APPENDIX E									SYSTEM: ESS.SER.CHILLD WATER TAG: 3CX-V83SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : 3CX-V63SB-1	OPERABILITY	40YRS NORM 500 CYC	47YRS NORM 17700 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: VALVES TYPE									
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	106F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO									MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E4	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H									
P.O #: 435176	AGE - INST LIFE (PER 323- 1974 DEF.)	40 YEARS	47YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 14R9. Y- 16Q6. Z- 239.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1					QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMIDTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1	USBR CATEG.: A APPENDIX E				REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION # : 00 DATE : 09/19/84
									SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V63SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	M/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : AV-D14SB-1	OPEPARIL-ITY	40YRS NORM 500 CYC	40YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.2SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: P.D79-D81 OF REF(1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: P.D79-D81 OF REF(1)	
MAJOR SUPPLIER: RUSKIN	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND SERIAL #: EA-180-22302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	R GAMMA	3.0E4	2.34E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL.	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR 9.2SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.0E4								
SPECIFICATIONS: BE-25	AGE- INST LIFE (PEP 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
PLANT LOC.: AB21					SRSS 9.2SH1	REVIEW				
COORDINATES X- 1420. Y- 1605. Z- 245.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1		
*****	OPERABILITY	O 9.2SH1		REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CES#-5076		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.2SH1								
*	REL. HUMDTY	H 9.2SH1								
*	CHEM. SPRAY	C 9.2SH1								
*****	RADIATION	R 9.2SH1								
	AGING	A 9.2SH1								
	SUBMERGENCE	S 9.2SH1								
EQ. PCK #: 9.2SH1	OSBR CATEG.: A APPENDIX E								REVISION # :00 DATE :09/18/84 SYSTEM :REAC.AUX.BLDG HVAC TAG :AV-D14SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	P/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : AV-D12SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	147YRS NORM 100,000CYC	OPER. REVIEW	REF(1) P.036	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT: TYPE	DAMPERS							
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	106F NORM 104F DBA	TAB21A FSAR SEC 3.11R	REF(1) P.042-047 TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER:	NAMCO							
MAJOR : SUPPLIER	RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11R	REF(1) P.042-047 TEST & SUPPL. REVIEW	M	NONE
MODEL AND: SERIAL #	EA-180-22302	RELATIVE HUMIDITY	20-90%NORM 100% DBA	107% NORM. 107% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.077 TEST & SUPPL. REVIEW	/	NONE
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC:	NOT APPLICABLE							
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100X 3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.016 TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS:	BE-25							
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.079-D81 TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.:	AB21							
COORDINATES X- Y- Z-	.1493. 1603. 246.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N):	LTR							
INSTAL. REF:	BY-FLO							
QUALIF EXEMPTN:	NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1
*QUALIF:	QUALIFIED-AWAITING	OPERABILITY O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				CESN-5077
*STATUS	CONFIRMATORY DATA	TEMPERATURE T	9.2SH1					
*		PRESSURE P	9.2SH1					
*		REL. HUMDTY H	9.2SH1					
*		CHEM. SPRAY C	9.2SH1					
*		RADIATION R	9.2SH1					
*		AGING A	9.2SH1					
		SUBMERGENCE S	9.2SH1				REVISION # :00 DATE :09/18/84	
EQ. PCK # :	9.2SH1	OS8R CATEG.:	A					SYSTEM : REAC.AUX.8LDG HVAC
		APPENDIX E						TAG : AV-D12SB-1

A/E: EBAS SERVICES INC.
 UTILITY: ILLINOIS POWER & LIGHT

FACILITY: SHEPPARD HARRIS - 1
 COMPONENT EVALUATION S

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 C 5080

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : AV-D17SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT TYPE: DAMPERS	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: RUSKIN					SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81	
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04ER	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: RE-25					SRSR 9.1SH1	REVIEW				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB21					SRSA 9.1SH1	REVIEW				
COORDINATES X- 1429. Y- 1678. Z- 236.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIFW		FOP PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5C80		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1						REVISION # :00		
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1						DATE :09/18/84		
*	REL. HUMDTY	H 9.1SH1						SYSTEM :REAC.AUX.BLDG		
*	CHEM. SPRAY	C 9.1SH1						HVAC		
*****	RADIATION	R 9.1SH1						TAG :AV-D17SA-1		
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK # : 9.1SH1	U588 CATEG.: A APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-053SB-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100,000CYC 1YR DBA	OPER. REVIEW	REF(1) P.D36	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) P.D42-D47	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) P.D77	COMB. TEST & SUPPL. REVIEW	/	NONE	
MAJOR SUPPLIER: RUSKIN	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #: EA-180-22302	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF(1) P.D16	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) P.D79-D81	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.2SH1					
SPECIFICATIONS: RE-25	OPERABILITY	O	9.2SH1	REFERENCES: (1)NAMCO QUALIFICATION REPORT EA-180 REV 1 DATED 9/5/78.				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.2SH1	
P.O #: 435205	TEMPERATURE	T	9.2SH1					CES#-5052	
PLANT LOC.: AB21	PRESSURE	P	9.2SH1					REVISION # :00	
COORDINATES X- 1585. Y- 1685. Z- 247.0	REL. HUMDTY	H	9.2SH1					DATE :09/18/84	
INSTALLED (Y/N): LTR	CHEM. SPRAY	C	9.2SH1					SYSTEM :REAC.AUX.BLDG HVAC	
INSTAL. REF:RY-FLD	RADIATION	R	9.2SH1					TAG :AV-D53SB-1	
QUALIF EXEMPTN: NOT APPLIC	AGING	A	9.2SH1						
*STATUS CONFIRMATORY DATA	SUBMERGENCE	S	9.2SH1						
*QUALIF: QUALIFIED-AWAITING	OSER CATEG.:	A							
******	APPENDIX E								

REPLACEMENT:
P.D79-D81 OF
REF(1)
MAINTAIN. :
P.D79-D81 OF
REF(1)
SUBCOMPONENTS:
NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:
SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D79SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE									
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAPCO									MAINTAIN.:
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	SEE NOTE (1)
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3.4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
FUNCT. DES & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE									
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E3	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25									
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB21									
COORDINATES X- 1585. Y- 163C. Z- 247.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							
*****	OPERABILITY O	9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1							
*	REL. HUMDTY H	9.1SH1							
*	CHEM. SPRAY C	9.1SH1							
*****	RADIATION R	9.1SH1							
	AGING A	9.1SH1							
	SUBMERGENCE S	9.1SH1							
EQ. PCK # : 9.1SH1									
	U588 CATEG.: A APPENDIX E								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

CES#-5083

REVISION # : 00
 DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-D79SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2IA-V34SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DBA	NORM/TEST				SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB21A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER:	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	MAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: D2400X-2SR	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE 1: TO BE REPLACED WITH EA180 LIMIT SWITCH	
FUNCT. DES. & SERVICE: ISO VALVE W/ LIMIT SWITCHES UNIT 2 DWG #13	R GAPMA	3.0E4	LATER	RAB21R6 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	A BETA	7.2E4								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%			SRSR					
SPECIFICATIONS: M-32A	S T.I.D.	3.0E4								
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI	
PLANT LOC.: AB21	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB21 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
COORDINATES X- 1470. Y- 1636. Z- 236.C					SRSS					
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTAL. REF: BY-FLD	OPERABILITY O			REFERENCES:				CES#-5085		
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE T									
*****	PRESSURE P									
*QUALIF: LATER	REL. HUMDTY H									
*STATUS	CHEM. SPRAY C									
*	RADIATION R									
*	AGING A							REVISION # :00		
*****	SUBMERGENCE S							DATE :		
EQ. PCK # :								SYSTEM : INSTRUMENT AIR		
	USPB CATEG.: A							TAG : 2IA-V34SA-1		
	APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2FP-V44SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YPS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	106F NORM 106F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW				SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	107% NORM 107% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1SH1	REVIEW				
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.04E3	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176						SRSA 9.1SH1				
PLANT LOC.: AB21										
COORDINATES X- 1451. Y- 1648. Z- 241.0		SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC		PAPA- METER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****		OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1 CESV-5C87
EQ. PCK # : 9.1SH1										REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.
		0586 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84 SYSTEM : FIRE PROTECT. TAG : 2FP-V44SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS. ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 280-V11SA-1	OPEPABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 100000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW								SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT.DES: & SERVICE	POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A TEST & SUPPL.	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE				SRSC 9.1SH1	REVIEW				
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0E4 7.2E4 100% 3.0E4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7 SUPPL.	H	NONE		
SPECIFICATIONS: M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: CI
P.O #:	435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A TEST & SUPPL.	/	NONE		
COORDINATES X- Y- Z-	1426. 168E. 255.0					SRSS 9.1SH1	REVIEW			
INSTALLED (Y/N): LTR INSTAL. REF:RY-FLD QUALIF EXEMPTN: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****		OPERABILITY O	9.1SH1	REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5089 REVISION # : JO DATE : 09/18/84 SYSTEM : BLOWDOWN TAG : 280-V11SA-1		
	TEMPERATURE T	9.1SH1								
	PRESSURE P	9.1SH1								
	REL. HUMIDTY H	9.1SH1								
	CHEM. SPRAY C	9.1SH1								
	RADIATION R	9.1SH1								
	AGING A	9.1SH1								
	SUBMERGENCE S	9.1SH1								
EQ. PCK # :	9.1SH1	U588 CATEG.: A APPENDIX E								

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 2BD-V15SA-1	OPFRABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1								
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB21A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TFST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW					SRSO 9.1SH1				SUBCOMPONENTS:				
MODEL AND: EA-180-11302 SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB21 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:				
FUNCT. DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	(1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
ACCUR. SPEC: NOT APPLICABLE					SRSO 9.1SH1								
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.0F4 7.2E4 100% 3.0F4	2.74E8	RAB21R6 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE					
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CI				
P.O #: 435176					SRSO 9.1SH1								
PLANT LOC.: AB21													
COORDINATES X- 1494. Y- 1623. Z- 253.C	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC					SRSO 9.1SH1								
*****	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*QUALIF: QUALIFIED-AWAITING	OPERABILITY O	9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CESN-5090			
*STATUS CONFIRMATORY DATA	TEMPERATURE T	9.1SH1											
*	PRESSURE P	9.1SH1											
*	REL. HUMDTY H	9.1SH1											
*	CHEM. SPRAY C	9.1SH1											
*****	RADIATION R	9.1SH1											
	AGING A	9.1SH1											
	SUBMERGENCE S	9.1SH1							REVISION # : 00 DATE : 09/18/84				
EQ. PCK # : 9.1SH1	OSBR CATEG.: A APPENDIX E								SYSTEM : PLOWDOWN TAG : 29D-V15SA-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3SW-V481SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YPS NORM 10300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: TYPE	VALVES								
COMPONENT:	LIMIT SWITCH (2 OF 2)		104F NORM 104F DBA		REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	H	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	NAMCO								MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER	HAMMEL DAHL/COM OFLOW			PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	H	NONE	SUBCOMPONENTS:
MODEL AND: SERIAL #	EA-180-113C2		100% NORM 100% DBA		REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
FUNCT.DES: & SERVICE	POSITION INDICATION				SRSH 9.1SH1	REVIEW			(1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
ACCUR. SPEC:	NOT APPLICABLE								
ACCUR. DEM.:	NOT APPLICABLE								
SPECIFICATIONS:	M-66H								
P.O #:	435176								
PLANT LOC.:	AB11								
COORDINATES	X- 1393. Y- 1609. Z- 216.0								
INSTALLED (Y/M):	LTR								
INSTAL. REF:	BY-FLD								
QUALIF EXEMPTH:	NOT APPLIC								
*QUALIF:	QUALIFIED-AWAITING								
*STATUS	CONFIRMATORY DATA								
* *****									
EQ. PCK # :	9.1SH1								

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1SH1

CES#-5091

REFERENCES: (1)NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

REVISION # :00
 DATE :09/18/84

SYSTEM :SERVICE WATER

TAG :3SW-V481SA-1

0588 CATEG.: A
 APPENDIX E

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-865SR-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100% DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 [SRSO 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRST 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRSP 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 [SPSH 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
PAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A [SRSC 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #: EA-180-117C2	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.04E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 [RSR 9.1SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE		
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 [RSRA 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A [SRSS 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1									
SPECIFICATIONS: M-66H	PARAMETER	SUPPL. REVIEW	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1	
P.O #: 435176	OPERABILITY	O 9.1SH1							CES#-5093	
PLANT LOC.: AB11	TEMPERATURE	T 9.1SH1							REVISION # : 00	
COORDINATES X- 1558. Y- 1614. Z- 228.0	PRESSURE	P 9.1SH1							DATE : 09/18/84	
INSTALLED (Y/N): LTR	REL. HUMDTY	H 9.1SH1							SYSTEM : SERVICE WATER	
INSTAL. REF: BY-FLD	CHEM. SPRAY	C 9.1SH1							TAG : 3SW-865SB-1	
QUALIF EXEMPTN: NOT APPLIC	RADIATION	R 9.1SH1								
*****	AGING	A 9.1SH1								
*QUALIF: QUALIFIED-AWAITING	SUBMERGENCE	S 9.1SH1								
*STATUS CONFIRMATORY DATA	OSBR CATEG.: A									
* *****	APPENDIX E									

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : 2SW-8905B-1	OPERABILITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 100000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE : COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER : HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
MODEL AND SERIAL # : EA-180-11302	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE : POSITION INDICATION	R GAMMA	3.4E4	2.04E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%						
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.4E4			SRSR 9.1SH1	REVIEW		
SPECIFICATIONS: M-66H	AGE	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE
P.O #: 435176	INST LIFE (PER 323-1974 DEF.)							
PLANT LOC.: AB11	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE
COORDINATES X- 1435. Y- 166C. Z- 230.0	PARAMETER	SUPPL. REVIEW						
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O 9.1SH1						
*****	TEMPERATURE	T 9.1SH1						
*QUALIF: QUALIFIED-AWAITING	PRESSURE	F 9.1SH1						
*STATUS CONFIRMATORY DATA	REL. HUMIDTY	H 9.1SH1						
*	CHEM. SPRAY	C 9.1SH1						
*	RADIATION	R 9.1SH1						
*****	AGING	A 9.1SH1						
	SUBMERGENCE	S 9.1SH1						
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E							

REPLACEMENT: SEE NOTE (1)
 MAINTAIN.: SEE NOTE (1)
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
 NOTE:
 (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.

SAFETY FUNCTION: SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 9/20/81.

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1

CESV-5094

REVISION # : 00
 DATE : 09/18/84

SYSTEM : SERVICE WATER

TAG : 2SW-8905B-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3SW-964SA-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 1000 CYC	OPER.	REF(1)	COMB.	/	NONE		
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA	REVIEW	PG.4-4 & 4-5	TEST & SUPPL.				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	176F NORM 176F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.4E4	2.34E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%								
SPECIFICATIONS: M-66H	S T.I.D.	3.4E4								
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB11	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
COORDINATES X- 1447. Y- 1608. Z- 218.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5095		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1								
*	REL. HUMDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK # : 9.1SH1	OS88 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84 SYSTEM : SERVICE WATER TAG : 3SW-964SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : 2SW-B88SAB-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 10000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	VALVES									
COMPONENT:	LIMIT SWITCH (2 OF 4)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.119	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	P	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	HAMMEL DAHL/COM OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
MODEL AND: SERIAL #	EA-180-113L2	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT.DES: & SERVICE	POSITION INDICATION	ACCUR. SPEC:	NOT APPLICABLE							
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.04E4	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 100%	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	435176	PLANT LOC.:	AB11							
COORDINATES X- Y- Z-	1430. 1693. 233.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW							
INSTAL. REF:	RY-FLD	OPERABILITY	O 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
QUALIF EXEMPTH:	NOT APPLIC	TEMPERATURE	T 9.1SH1							CES#-5096
*****		PRESSURE	P 9.1SH1							
*QUALIF:	QUALIFIED-AWAITING	REL. HUMIDTY	H 9.1SH1							
*STATUS	CONFIRMATORY DATA	CHEM. SPRAY	C 9.1SH1							
*		RADIATION	R 9.1SH1							
*		AGING	A 9.1SH1							
*****		SUBMERGENCE	S 9.1SH1							
EQ. PCK # :	9.1SH1	US88 CATEG.:	A							REVISION # : JO DATE : 09/18/84
		APPENDIX	E							SYSTEM : SERVICE WATER TAG : 2SW-888SAB-1

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1)NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 2SW-BR8SAB-1	OPERABIL-ITY	40YRS 400M 500 CYC	40YRS NORM 10000 CYC	OPER.	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA	REVIEW	SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (3 OF 4)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS 400M ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : HAMMEL DAHL/CON SUPPLIER OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.
FUNCT. DES: POSITION & SERVICE INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. SPEC: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 1CGZ 3.4E4	7.7E4	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
ACCUR. DEP.: NOT APPLICABLE	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
SPECIFICATIONS: M-66H	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
P.O #: 435176	COORDINATES X- Y- Z-	1430. 1693. 233.0							
PLANT LOC.: AB11	INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD								
QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1	
*****	OPERABILITY	O 9.1SH1		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CESW-5097	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMIDTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SURMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1	USBR CATEG.: A APPENDIX E							REVISION # : 00 DATE : 09/18/84	SYSTEM : SERVICE WATER
								TAG : 2SW-BR8SAB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SW-B88SAB-1	OPERABIL-ITY	40YRS NORM 500 CYC	40YRS NORM 100300 CYC	OPER.	REF(1)	COMB.	/	NONE		
EQUIPMENT: VALVES TYPE	NORM/TEST DBA	1YR DBA	1YR DBA	REVIEW	PG.4-4 & 4-5	TEST & SUPPL.				
COMPONENT: LIMIT SWITCH (4 OF 4)	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB11A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11P	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	P	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : HAMMEL DAHL/CON SUPPLIER OFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
MODEL AND: EA-180-11302 SERIAL #	FUNCT.DES: POSITION & SERVICE INDICATION				SRSH 9.1SH1	REVIEW			NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	3.4E4	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE		
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS	
P.O #: 435176	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE		
PLANT LOC.: AB11					SRSS 9.1SH1	REVIEW				
COORDINATES X- 1430. Y- 1693. Z- 233.0										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****	OPERABILITY O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-509R REVISION # :00 DATE :09/18/84 SYSTEM :SERVICE WATER TAG :2SW-B88SAB-1			
	TEMPERATURE T	9.1SH1								
	PRESSURE F	9.1SH1								
	REL. HUMDTY H	9.1SH1								
	CHEM. SPRAY C	9.1SH1								
	RADIATION R	9.1SH1								
	AGING A	9.1SH1								
	SURMERGENCE S	9.1SH1								
EQ. PCK # : 9.1SH1	USP8 CATEG.: A APPENDIX E									



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 2SW-B88SAB-1	OPERABILITY	NORM: 40YRS 500 CYC	NORM: 40YRS 120,100 CYC	OPER. REVIEW	NORM: REF 1 P.8, DBA:	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	DBA: 1YR 1 CYC	DBA: 1YR 21 CYC		REF 1, P.26 SRSO 3.2SH1					
COMPONENT: SOLENOID VALVE (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	127F NORM FOR DBA FIG E1A- 3.2SH1	TAB11A FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: REF 1, FIG.1, P.C-5 MAINTAIN.: REF 1, APP.C	
MANUFACTURER: ASCO	PRESSURE	ATMOS NORM ATMOS DBA	OP SIG NORM FOR DBA FIG F2A- 3.2SH1	PAB11 FSAR SEC 3.11B	REF 1, P.26 FIG 4.2	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MAJOR SUPPLIER: HAMMEL DAHL/ CONOFLOW	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB11 FSAR SEC 3.11B	REF 1, SEC 9.1.3 & 8.2.3 SRSH 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: CONTROL AIR TO PNEUM. OPERATOR	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE		
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	3.4E4	2.05E8	RAB11R3 FSAR SEC 3.11B	REF 1, SEC 4.1.4 & 4.2.2 SRSR 3.2SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. DEM.: NOT APPLICABLE	A RETA	7.2E4								
SPECIFICATIONS: M-66H	D B SHIELD	100%								
P.O #: 435176	S T.I.D.	3.4E4	2.05E8							
PLANT LOC.: AB11	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	60 YEARS	10 CFR 50 PARA. 50.51	REF 1, P.A3 FIG 184, P.C-58C-8 SRSA 3.2SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
COORDINATES X- 1430. Y- 1693. Z- 233.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	N/A	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 3.2SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 3.2SH1		
*****	OPERABILITY	O 3.2SH1		REFERENCES: 1. ASCO TEST REPORT #AQR-67368/ R O DATED MARCH 1982				CES#-5099		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 3.2SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 3.2SH1								
*	REL. HUMDTY	H 3.2SH1								
*	CHEM. SPRAY	C 3.2SH1								
*****	RADIATION	R 3.2SH1								
	AGING	A 3.2SH1								
	SUBMERGENCE	S 3.2SH1								
EQ. PCK #: 3.2SH1	0585 CATEG.: A APPENDIX E							REVISION #: 00 DATE: 09/04/84 SYSTEM: SERVICE WATER TAG: 2SW-B88SAB-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	DUTS ITEMS	
	PARAMETER	ACTUAL	NORM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D29SA-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG. 4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: DAMPERS TYPE					SRSO 9.1SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE		1104F NORM 1104F DBA		REF(1) PG. 10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO					SRST 9.1SH1				
MAJOR SUPPLIER: RUSKIN	PRESSURE	ATMOS NORM ATMOS DBA	4ATM NORM 4ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG. 10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MODEL AND SERIAL #: EA-180-22302	RELATIVE HUMIDITY		1100% NORM 1100% DBA		REF(1) PG. 4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.74E3	RAB11R3 FSAR SEC 3.11B	REF(1) PG. 10-7	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: BE-25					SRSR 9.1SH1				
P.O #: 435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA. 50.51	REF(1) PG. 4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB11					SRSA 9.1SH1				
COORDINATES X- 1410. Y- 1601. Z- 221.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							CES#-5100
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1							
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1							
*	REL. HUMIDTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*****	RADIATION	R 9.1SH1							
	AGING	A 9.1SH1							
	SUBMERGENCE	S 9.1SH1							
EQ. PCK #: 9.1SH1	OSPB CATEG.: A APPENDIX E								REVISION #: JD DATE: 09/18/84
					REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				SYSTEM: REAC. AUX. BLDG HVAC TAG: AV-D29SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : AV-D31SA-1	OPERABIL- ITY NORM/TEST DBA	4CYRS NORM 500 CYC 1YR DBA	40YRS NORM 100300 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 [SRSO 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	DAMPERS									
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA		REF(1) PG.10-14 & 4-4 [SRST 9.1SH1]	COMB. TEST & SUPPL. REVIEW	H	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB11 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 [SRSP 9.1SH1]	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	RUSKIN									
MODEL AND: SERIAL #	EA-180-22302	RELATIVE HUMIDITY	100% NORM 100% DBA		REF(1) PG.4-4 & 4-5 [SRSH 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81	
FUNCT. DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB11 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC:	NOT APPLICABLE									
ACCUR. DEM.:	NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.4E4 7.2E4 100% 3.4E4	2.34E8	RAB11R3 FSAR SEC 3.11B	REF(1) PG.10-7 SUPPL. REVIEW	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:	BE-25									
P.O #:	435205	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 [SRSA 9.1SH1]	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB11									
COORDINATES X- Y- Z-	1587. 1710. 216.0	SURMERGED LEVEL	NOT APPLICABLE	N/A	SAB11 FSAR SEC 3.11B	N/A TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N):	LTR									
INSTAL. REF:	BY-FLD									
QUALIF EXEMPTN:	NOT APPLIC	PARA- METER	SUPPL. REVIFW							
*****		OPERABILITY	O	9.1SH1						
*QUALIF:	QUALIFIED-AWAITING	TEMPERATURE	T	9.1SH1						
*STATUS	CONFIRMATORY DATA	PRESSURE	P	9.1SH1						
*		REL. HUMPTY	H	9.1SH1						
*		CHEM. SPRAY	C	9.1SH1						
*****		RADIATION	R	9.1SH1						
		AGING	A	9.1SH1						
		SUBMERGENCE	S	9.1SH1						
EQ. PCK # :	9.1SH1	US88 CATEG.:	A							
		APPENDIX E								

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1SH1

CES#-5102

REVISION # : 00
 DATE : 09/15/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-D31SA-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CH-V86SA-1	OPERABIL-ITY	40YRS NORM 500 CYC 1YR DBA	40YRS NORM 17000 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE: VALVES	TEMPERAT-URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)				
COMPONENT: LIMIT SWITCH (2 OF 2)	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)				
MANUFACTURER: NAMCO	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
MODEL AND SERIAL #: EA-180-11302	R GAMMA A BETA D B SHIELD S T.I.O.	3.7E4 100% 3.7E4	2.04E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE					
FUNCT. DES. & SERVICE: POSITION INDICATION	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE					
ACCUR. DEP.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
SPECIFICATIONS: M-66H	OPERABILITY	O	9.1SH1	REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CES#-5104			
P.O #: 435176	TEMPERATURE	T	9.1SH1										
PLANT LOC.: AB51	PRESSURE	P	9.1SH1										
COORDINATES X- 1648. Y- 1667. Z- 305.0	REL. HUMIDTY	H	9.1SH1										
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	CHEM. SPRAY	C	9.1SH1										
*****	RADIATION	R	9.1SH1										
*QUALIF: QUALIFIED-AWAITING	AGING	A	9.1SH1						REVISION #: 00 DATE: 09/18/84				
*STATUS CONFIRMATORY DATA	SUBMERGENCE	S	9.1SH1						SYSTEM: ESS.SER.CHILLO WATER				
* *****	OS98 CATEG.: A APPENDIX E								TAG: 3CH-V86SA-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-W17SA-1	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: ITT HAMMEL DAHL /CONOFL.	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
MAJOR SUPPLIER					SRSP				SUBCOMPONENTS:	
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4		RAB5125 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:	A BETA									
P.O #:	D B SHIELD	100X								
PLANT LOC.: AB51	S T.I.D.	3.7E4			SRSR					
COORDINATES X- 1607.	AGE-	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
Y- 1687.	INST LIFE (PER 323-1974 DEF.)				SRSA					
Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR					SRSS					
INSTALL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:			
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O					CES#-5105			
*QUALIF:	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SUBMERGENCE	S								
EQ. PCK # :			REFERENCES:				REVISION # : 00 DATE :			
	D588 CATEG.: A						SYSTEM : ESS.SER.CHILLD WATER			
	APPENDIX E						TAG : 3CX-W17SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : 3CX-W24SR-1	OPERABIL-ITY	1	2	3	4	5	6	7	
EQUIPMENT: TYPE	NORM/TEST DBA			OPER. REVIEW	SRSO	COMB. TEST & SUPPL. REVIEW	/	NONE	
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT-UPE	104F NORM 104F DBA		TAB51A FSAR SEC 3.11B	SRST	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: ITT HAMMEL DAHL / CONOFL	PRESSURE	ATMOS NORM ATMOS DBA		PAB51 FSAR SEC 3.11B	SRSP	COMB. TEST & SUPPL. REVIEW	M.	NONE	
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB51 FSAR SEC 3.11B	SRSH	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND: SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B	SRSC	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE	R GAPMA	3.7E4		RAB5125 FSAR SEC 3.11B	SRSR	COMB. TEST & SUPPL. REVIEW	H	NONE	
ESSENTIAL SER CX FOR AH-15 (1B-SB)	D B SHIELD	100%							
ACCUR. SPEC: NOT APPLICABLE	S T.I.D.	3.7E4							
ACCUR. DEM.: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51	SRSA	COMB. TEST & SUPPL. REVIEW	/	NONE	
SPECIFICATIONS:	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B	SRSS	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #:									
PLANT LOC.: AB51									
COORDINATES X- 1607. Y- 1652. Z- 305.0									
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O		REFERENCES:				CES#-5106	
*QUALIF:	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A						REVISION # :00	
	SURMERGENCE	S						DATE :	
EQ. PCK # :	U58R CATEG.: A							SYSTEM : ESS.SER.CHILLD WATER	
	APPENDIX E							TAG : 3CX-W24SB-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-V130SA-1	OPEPABIL-ITY	LATER	LATEP	OPER. REVIEW	LATEP	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DRA				SRSO				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT-URE	104F 104F	NORM DRA	LATER	TAB51A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS ATMOS	NORM DRA	LATER	PAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR : SUPPLIER	RELATIVE HUMIDITY	20-90% 100%	NORM DRA	LATER	HAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: EA-180	CHEMICAL SPRAY	NOT APPLICABLE		LATER	CAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
SERIAL #	R GAPMA	3.7E4		LATER	RAB5125 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
FUNCT. DES: ESSENTIAL SER & SERVICE	S T.I.D.	100%			SRSR				
CX FOR AH-17 (1-4A-SA)	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		LATER	10 CFR50 PARA.50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
ACCUR. SPEC: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE		LATER	SAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	PARAMETER	SUPPL. REVIEW							
SPECIFICATIONS:	OPERABILITY								FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:
P.O #:	TEMPERATURE	T							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
PLANT LOC.: AB51	PRESSURE	P							CES#-5107
COORDINATES X- 1648.	REL. HUMDTY	H							
Y- 1687.	CHEM. SPRAY	C							
Z- 305.0	RADIATION	R							
INSTALLED (Y/N): LTR	AGING	A							
INSTAL. REF: BY-FLO	SUBMERGENCE	S							
QUALIF EXEMPTN: NOT APPLIC	OSRP CATEG.:	A							
*****	APPENDIX E								
*QUALIF: LATER									
*STATUS									
*									
*									

EQ. PCK # :									REVISION # :00
									DATE :
									SYSTEM :ESS.SER.CHILDD WATER
									TAG :3CH-V130SA-1

A/E: EBAS SERVICES INC.
UTILITY: ATLANTA POWER & LIGHT

FACILITY: SHEARON HARRIS UNIT - 1
COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PLR
CAPACITY: 900 MW(E)

0
5108

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	JUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : 3CH-V85SB-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 107300 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	#	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : SUPPLIER	HAMMEL DAHL/CON OFLOW				SRSO 9.1SH1				
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES: & SERVICE	POSITION INDICATION				SRSO 9.1SH1				
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	2.74E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	
P.O #: 435176					SRSA 9.1SH1				
PLANT LOC.: AB51									
COORDINATES X- 1648. Y- 1665. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW							
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							
EQ. PCK # : 9.1SH1	0588 CATEG.: A APPENDIX E								

REPLACEMENT:
SEE NOTE (1)

MAINTAIN.:
SEE NOTE (1)

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT
NOTE:

(1) PG.4-3,4-3.1 &
4-3.2 OF REPORT
QTR-105 REV 3
DATED 8/20/81.

SAFETY FUNCTION:
SS

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

QUALIFICATION SIGN-OFF
FOUND IN DOCUMENTATION
PACKAGE: 9.1SH1

CESA-5108

REFERENCES: (1) NAMCO CONTROLS DIVISION
QUALIFICATION REPORT QTR-105
REVISION 3 DATED 8/20/81.

REVISION # : 00
DATE : 09/18/84

SYSTEM : ESS.SER.CHILLD
WATER
TAG : 3CH-V85SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS		
TAG NO : 3CH-V129SB-1	OPERABILITY	40YRS NORM 50G CYC	40YRS NORM 100% CYC	OPER. REVIEW	REF(1) PG. 4-4 & 4-5. SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB51A FSAR SEC 3.11B	REF(1) PG. 10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO										
MAJOR SUPPLIER: HAMMEL DAHL/CON FLOW	PRESSURE	ATMOS NORM ATMOS DBA	4TM NORM 4TM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG. 10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG. 4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE EQUIPPED BY THIS EQUIPMENT NOTE: (1) PG. 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	3.7E4 100X 3.7E4	2.74E8	RAB5125 FSAR SEC 3.11B	REF(1) PG. 10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR 50 PARA. 50.51	REF(1) PG. 4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51										
COORDINATES X- 1648. Y- 1687. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: RY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY O	9.1SH1								
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1								CESV-5109
*	REL. HUMDTY H	9.1SH1								
*	CHEM. SPRAY C	9.1SH1								
*****	RADIATION R	9.1SH1								
	AGING A	9.1SH1								
	SUBMERGENCE S	9.1SH1								
EQ. PCK #: 9.1SH1				REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						REVISION #: 00 DATE: 09/18/84
	OS88 CATEG.: A APPENDIX E									SYSTEM: ESS.SER.CHILLO WATER TAG: 3CH-V129SB-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : 3CX-V114SA-1	OPERABILITY	40YRS NORM 500 CYC	140YRS NORM 10000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE					
EQUIPMENT TYPE: VALVES	NORM/TEST DRA	1YR D9A	1YR D9A		SRSO 9.1SH1	REVIEW							
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DRA	104F NORM 104F DRA	TAB51A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS D9A	ATM NORM ATM D9A	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)				
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW					SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:				
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DRA	100% NORM 100% DRA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.				
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1SH1	REVIEW							
ACCUR. DEP.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100%	2.04E9	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE					
SPECIFICATIONS: M-66H					SRSR 9.1SH1	REVIEW							
P.O #: 435176	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS				
PLANT LOC.: AB51					SRSA 9.1SH1	REVIEW							
COORDINATES X- 1648. Y- 1681. Z- 305.0	SURPERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE					
INSTALLED (Y/H): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1			
*****	OPERABILITY O	9.1SH1		REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.						CEM-5111			
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1SH1											
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1SH1											
*	REL. HUMDTY H	9.1SH1											
*	CHEM. SPRAY C	9.1SH1											
*****	RADIATION R	9.1SH1											
	AGING A	9.1SH1											
	SUBMERGENCE S	9.1SH1											
EQ. PCK #: 9.1SH1	OSR8 CATEG.: A APPENDIX E									REVISION #: 00 DATE: 09/18/84 SYSTEM: ESS.SER.CHILLO WATER TAG: 3CX-V114SA-1			

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V113SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DBA					SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO					SRST				MAINTAIN.:	
MAJOR SUPPLIER:	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: ESSENTIAL SER CX FOR AH-15(1A-SA)	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D P SHIELD S T.I.D.	3.7E4 100%	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
SPECIFICATIONS:					SRSR					
P.O #: 40 YEARS	AGE- INST LIFE (PER 323-1974 DEF.)		LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1607. Y- 1687. Z- 305.0	SURMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: CES#-5112
*QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMPTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S			REFERENCES:						REVISION # : 00 DATE :
EQ. PCK # :	0588 CATEG.: A APPFNDIX E									SYSTEM : ESS.SER.CHILLO WATER TAG : 3CX-V113SA-1



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V111SA-1	OPERABIL- ITY	40YRS NORM 500 CYC	40YRS NORM 1000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA	104F NORM 104F DBA	TAR51A FSAR SEC 3.11B	REF(1) PG.1G-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.1G-14 & 4-4	COMB. TEST & SUPPL.	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR : SUPPLIER	HAMMEL DAHL/COM OFLOW				SRSO 9.1SH1	REVIEW			SUBCOMPONENTS:	
MODEL AND: SERIAL #	EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE:
FUNCT. DES: & SERVICE	POSITION INDICATION				SRSO 9.1SH1	REVIEW			(1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE		CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.: NOT APPLICABLE		R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	2.74E8	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	H	NONE	
SPECIFICATIONS: M-66H		AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40YPS		10 CFR50 PARA-50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTION: SS
P.O #: 435176						SRSA 9.1SH1				
PLANT LOC.: AB51										
COORDINATES X- 1647. Y- 1654. Z- 307.0		SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTH: NOT APPLIC		PARAMETER	SUPPL. REVIEW	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1		
***** *QUALIF: QUALIFIED-AWAITING *STATUS CONFIRMATORY DATA * *****		OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	0 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1 9.1SH1							CES#-5113
EQ. PCK # : 9.1SH1		OSER CATEG.: A APPENDIX E		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 - REVISION 3 DATED 8/20/81.						REVISION # : 00 DATE : 09/18/84
										SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V111SA-1



A/E: EBASCO SERVICES INC.
 UTILITY: CINCINNATI POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

CES 5114

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-D2SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA	100%							
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	3.7E4			SRSR				
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR5J PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1606. Y- 1667. Z- 314.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR	FOR PUNCLIST ITEMS SEE SH EO PACKAGE:								QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
INSTAL. REF: BY-FLD	OPERABILITY O								CES#-5114
QUALIF EXEMPTN: NOT APPLIC	*TEMPERATURE T								
*****	*PRESSURE P								
*QUALIF: LATER	*REL. HUMDTY H								
*STATUS	*CHEM. SPRAY C								
*	*****								
*	RADIATION R								
	AGING A								REVISION # : 30
	SUBMERGENCE S								DATE :
EQ. PCK # :	OSRP CATEG.: A								SYSTEM : CONTROL ROOM
	APPENDIX F								HVAC
									TAG : CZ-D2SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS					
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.								
TAG NO : CZ-D20SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
EQUIPMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.								
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:				
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:				
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:				
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT				
FUNCT. DES. & SERVICE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE					
ACCUR. SPEC: NOT APPLICABLE	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR53 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS				
ACCUR. DEM.: NOT APPLICABLE	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE					
SPECIFICATIONS:	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2			
P.O #:	OPERABILITY O	9.1/9.2		REFERENCES:						CES#-5115			
PLANT LOC.: AB51	TEMPERATURE T	9.1/9.2											
COORDINATES X- 1626.	PRESSURE P	9.1/9.2											
Y- 1655.	REL. HUMIDTY H	9.1/9.2											
Z- 305.0	CHEM. SPRAY C	9.1/9.2											
INSTALLED (Y/N): LTR	RADIATION R	9.1/9.2											
INSTAL. REF: BY-FLD	AGING A	9.1/9.2											
QUALIF EXEMPTN: NOT APPLIC	SUBMERGENCE S	9.1/9.2											

*QUALIF: LATER													
*STATUS													
*													
*													

EQ. PCK # : 9.1/9.2	0588 CATEG.: A												
	APPENDIX E												
									REVISION # : 00				
									DATE :				
									SYSTEM : CONTROL ROOM				
									HVAC				
									TAG : CZ-D20SB-1				

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : CZ-023SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	P	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	EA-180								NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	REMOTE INDICATION OF DAMPER POSITION				SRSR 9.1/9.				
ACCUR. SPEC:	NOT APPLICABLE				SRSR 9.1/9.				
ACCUR. DEM.:	NOT APPLICABLE				SRSR 9.1/9.				
SPECIFICATIONS:									
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.:	AB51				SRSA 9.1/9.				
COORDINATES X- Y- Z-	1645. 1655. 305.6								
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD									
QUALIF EXEMPTN: NOT APPLIC									
*****	PARAMETER SUPPL. REVIEW								FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2
*QUALIF: LATER	OPERABILITY O	9.1/9.2							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
*STATUS	TEMPERATURE T	9.1/9.2							CES#-5116
*	PRESSURE P	9.1/9.2							
*	REL. HUMIDTY H	9.1/9.2							
*	CHEM. SPRAY C	9.1/9.2							
*****	RADIATION R	9.1/9.2							REFERENCES:
	AGING A	9.1/9.2							
	SUBMERGENCE S	9.1/9.2							
EQ. PCK # :	9.1/9.2								REVISION # :00 DATE :
	US88 CATEG.: A								SYSTEM : CONTROL ROOM HVAC
	APPENDIX E								TAG : CZ-023SA-1




EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-024SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE	NORM/TEST DBA				SRSO					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE		
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
FUNCT. DES. & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
ACCUR. SPEC: NOT APPLICABLE	D B SHIELD	100%			SRSR					
ACCUR. DEM.: NOT APPLICABLE	S T.I.D.	3.7E4								
SPECIFICATIONS:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
P.O #:	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1645. Y- 1653. Z- 305.0					SRSS					
INSTALLED (Y/N): LTR	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:		
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW						CES#-5117		
QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O								
*QUALIF: LATER	TEMPERATURE	T								
*STATUS	PRESSURE	P								
*	REL. HUMIDTY	H								
*	CHEM. SPRAY	C								
*****	RADIATION	R								
	AGING	A								
	SURMERGENCE	S								
EQ. PCK # :	REFERENCES:							REVISION # : 00 DATE :		
	0588 CATEG.: A								SYSTEM : CONTROL ROOM HVAC	
	APPENDIX E								TAG : CZ-024SB-1	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:
 SS





A/E: EBAS SERVICES INC.
 UTILITY: ATLANTA POWER & LIGHT

FACILITY: SHEPARD HARDWARE - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5119

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEF. QUALIF.	ACTUAL	DEF. QUALIF.				
TAG NO : CZ-D19SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES. & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	4 BETA								
ACCUR. DEP.: NOT APPLICABLE	D B SHIELD	100%							
SPECIFICATIONS:	S T.I.D.	3.7E4							
P.O #:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMP. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1626. Y- 1657. Z- 305.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	OPERABILITY	O	9.1/9.2	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2	
*QUALIF: LATER	TEMPERATURE	T	9.1/9.2	REFERENCES:				CES#-5119	
*STATUS	PRESSURE	P	9.1/9.2						
*	REL. HUMIDTY	H	9.1/9.2						
*	CHEM. SFRAY	C	9.1/9.2						
*****	RADIATION	R	9.1/9.2						
	AGING	A	9.1/9.2						
	SUBMERGENCE	S	9.1/9.2						
EQ. PCK # : 9.1/9.2	OS&F CATEG.: A								
	APPENDIX E								
								REVISION # : 00 DATE :	
								SYSTEM : CONTROL ROOM HVAC TAG : CZ-D19SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF.	H/M	OUTS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.	METHOD		ITEMS	
TAG NO : CZ-D10SB-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO 9.1/9.1				
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMP. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	REMOTE INDICATION OF DAMPER POSITION				SRSR 9.1/9.1				
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1/9.1				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS:					SRSR 9.1/9.1				
P.O #:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR 50 PARA. 50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51					SRSA 9.1/9.1				
COORDINATES X- 1641. Y- 1667. Z- 315.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PAPA-METER	SUPPL. REVIEW							FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2
*QUALIF: LATER *STATUS	OPERABILITY C TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S	9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2 9.1/9.2							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2
EQ. PCK # : 9.1/9.2	CS88 CATFG.: A APPENDIX E								REFERENCES: REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D10SB-1

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : CZ-D1SA-1	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: DBA					SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F 400M 104F 22A	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO					SRST 9.1/9.					
MAJOR SUPPLIER:	PRESSURE	ATMOS 400M ATMOS 22A	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:	
					SRSP 9.1/9.				SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180	RELATIVE HUMIDITY	20-90% 170% 22A	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1/9.					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 10UX 3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:					SRSR 9.1/9.					
P.O #: 1606.	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA 9.1/9.					
COORDINATES X- 1606. Y- 1674. Z- 314.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
					SRSS 9.1/9.					
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
*****	OPERABILITY O	9.1/9.2		REFERENCES:				CES#-5121		
*QUALIF: LATER	*TEMPERATURE T	9.1/9.2								
*STATUS	*PRESSURE P	9.1/9.2								
*	*REL. HUMIDTY H	9.1/9.2								
*	*CHEM. SPRAY C	9.1/9.2								
*****	*RADIATION R	9.1/9.2								
	*AGING A	9.1/9.2								
	*SURMERGENCE S	9.1/9.2								
EQ. PCK # : 9.1/9.2	OS8R CATEG.: A APPENDIX E							REVISION # : 00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : CZ-D1SA-1		

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : R-2 (1R-SB)	OPEPABIL- ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO					
COMPONENT: DOOR SWITCH(2 OF 4)	TEMPERAT- URE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:	
MANUFACTURER: NAMCO					SRST				MAINTAIN.:	
MAJOR : SUPPLIER	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	SUBCOMPONENTS:	
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT	
FUNCT. DES: & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D P SHIELD S T.I.D.	3.7E4 100%	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS:					SRSR					
P.O #:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	LATER	10 CFR5J PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA					
COORDINATES X- 1634. Y- 1693. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMPTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S			REFERENCES:						CES#-5122
EQ. PCK # :	0588 CATEG.: A APPENDIX E									REVISION # :00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : R-2 (1R-SB)



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : R-2 (1B-SB)	OPEFABIL-ITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO				
COMPONENT: DOOR SWITCH(3 OF 4)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND: EA-180-11302 SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICATION OF DAMPER POSITION & SERVICE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
ACCUR. SPEC: NOT APPLICABLE	A BETA								
ACCUR. DEM.: NOT APPLICABLE	D B SHIELD	100X							
SPECIFICATIONS:	S T.I.D.	3.7E4			SRSR				
P.O #:	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
PLANT LOC.: AB51	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
COORDINATES X- 1634. Y- 1693. Z- 305.0	PARAMETER	SUPPL. REVIEW							
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:								QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
***** *QUALIF: LATER *STATUS * * *****	OPEABILITY	O							CES#-5123
	*TEMPERATURE	T							
	*PRESSURE	P							
	*REL. HUMDTY	H							
	*CHEM. SPRAY	C							
	***** *RADIATION *AGING *SUBMERGENCE	R A S							REVISION # :00 DATE :
EQ. PCK # :	OSPB CATEG.: A APPENDIX E								SYSTEM : CONTROL ROOM HVAC TAG : R-2 (1B-SB)



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG-NO : R-2 (1A-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO				
COMPONENT: DOOR SWITCH(2 OF 4)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: HAMCO	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:
MODEL AND SERIAL #	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	ACCUR. SPEC:	NOT APPLICABLE			SRSP				
REMOTE INDICATION OF DAMPER POSITION	ACCUR. DEM.:	NOT APPLICABLE			SRSH				
	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE	
	A BETA								
	D B SHIELD	100%							
	S T.I.O.	3.7E4			SRSR				
SPECIFICATIONS:	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS
P.O #:	PLANT LOC.:	AB51			SRSA				
COORDINATES X- 1620. Y- 1693. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR	PARAMETER	SUPPL. REVIEW			SRSS				
INSTAL. REF:BY-FLD	OPERABILITY								FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:
QUALIF EXEMPTN: NOT APPLIC	TEMPERATURE								QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:
*QUALIF: LATER	PRESSURE								CES#-5125
*STATUS	REL. HUMPTY								
*	CHEM. SPRAY								
*	RADIATION								
*****	AGING								REFERENCES:
	SUBMERGENCE								
EQ. PCK # :	G588 CATEG.:	A							REVISION # : 30
	APPENDIX E								DATE :
									SYSTEM : CONTROL ROOM
									HVAC
									TAG : R-2 (1A-SA)

A/E: EBAS SERVICES INC.
 UTILITY: CALINA POWER & LIGHT

FACILITY: SHEARON HARBOR PP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 5126

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. MTHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.			
TAG NO : R-2 (1A-SA)	OPERABILITY	LATER	LATER	OPER. REVIEW	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: DBA					SRSO			
COMPONENT: DCOR SWITCH(3 OF 4)	TEMPERATURE	104F NORM 104F DBA	LATER	TAB51A FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: NAMCO					SRST			
MAJOR SUPPLIER:	PRESSURE	ATMOS NORM ATMOS DBA	LATER	PAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	M	NONE
					SRSF			
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	LATER	HAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: REMOTE INDICATION OF DAMPER POSITION					SRSR			
ACCUR. SPEC: NOT APPLICABLE	CHEMICAL SPRAY	NOT APPLICABLE	LATER	CAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.7E4	LATER	RAB5125 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	H	NONE
	A BETA							
	D B SHIELD	100%						
SPECIFICATIONS:	S T.I.O.	3.7E4			SRSR			
P.O #:	AGE-INST LIFE	40 YEARS	LATER	10 CFR50 PARA.50.51	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
PLANT LOC.: AB51	(PER 323-1974 DEF.)				SRSA			
COORDINATES X- 1620. Y- 1693. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	LATER	SAB51 FSAR SEC 3.11B	LATER	COMB. TEST & SUPPL. REVIEW	/	NONE
					SRSS			
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:			QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
***** *QUALIF: LATER *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S			REFERENCES:			CES#-5126	
EQ. PCK # :	US88 CATEG.: A APPENDIX E						REVISION # :00 DATE : SYSTEM : CONTROL ROOM HVAC TAG : R-2 (1A-SA)	

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION: SS

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-D78SA-1	OPERABIL- ITY NORM/TEST DBA	40YRS NORM 500 CYC 1YR DBA	47YRS NORM 10700 CYC 1YR DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE	DAMPERS								
COMPONENT:	LIMIT SWITCH (2 OF 2)	TEMPERAT- URE	95F NORM 95F DBA	104F NORM 176F DBA	TYD31R FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER:	NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M NONE	MAINTAIN.: SEE NOTE (1)
MAJOR : SUPPLIER	RUSKIN	RELATIVE HUMIDITY	10-12% NORM 100% DBA	10% NORM 10% DBA	HYD31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/ NONE	SUBCOMPONENTS: NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
MODEL AND: SERIAL #	EA-180	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/ NONE	NONE	
FUNCT.DES: & SERVICE	REMOTE INDICAT ION OF DAMPER POSITION	ACCUR. SPEC:	NOT APPLICABLE						
ACCUR. DEM.:	NOT APPLICABLE	R GAPMA A BETA D B SHIELD S T.I.D.	9.1E4 100X 9.1E4	2.34E8	RAB21R8 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H NONE	
SPECIFICATIONS:	BE-25	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS 40 YRS		10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/ NONE	SAFETY FUNCTION: SS
P.O #:	435205	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	N/A COMB. TEST & SUPPL. REVIEW	/ NONE	NONE	
PLANT LOC.:	AB21	COORDINATES X- Y- Z-	1602. 1630. 250.0						
INSTALLED (Y/N):	LTR	PARAMETER	SUPPL. REVIEW						
INSTAL. REF:	BY-FLD	OPERABILITY O	9.1SH1						
QUALIF EXEMPT:	NOT APPLIC	TEMPERATURE T	9.1SH1						
*QUALIF:	QUALIFIED-AWAITING	PRESSURE P	9.1SH1						
*STATUS	CONFIRMATORY DATA	REL. HUMIDTY H	9.1SH1						
*		CHEM. SPRAY C	9.1SH1						
*		RADIATION R	9.1SH1						
		AGING A	9.1SH1						
		SURMERGENCE S	9.1SH1						
EQ. PCK # :	9.1SH1	USRP CATEG.:	A						
		APPENDIX	E						

FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1

QUALIFICATION SIGN-OFF
 FOUND IN DOCUMENTATION
 PACKAGE: 9.1SH1

CES#-5128

REFERENCES: (1) NAMCO CONTROLS DIVISION
 QUALIFICATION REPORT QTR-105
 REVISION 3 DATED 8/20/81.

REVISION # : 00
 DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG
 HVAC
 TAG : AV-D78SA-1

A/E: EBAS SERVICES INC.
 UTILITY: MAINE POWER & LIGHT

FACILITY: SHEPARD HARRIS - 1
 COMPONENT EVALUATION S

NSSS: WESTINGHOUSE - FWR
 CAPACITY: 900 MW(E)

0
 C-5130

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : 3AF-P1SA-1	OPERABIL- ITY			OPER. REVIEW		/	NONE	
EQUIPMENT: TYPE	NORM/TEST DBA				SRSO			
COMPONENT: LIMIT SWITCH#2 (2 OF 2)	TEMPERAT- URE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B		M	NONE	
MANUFACTURER: ITT HAMMEL DAHL /CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B		M	NONE	
MAJOR : SUPPLIER					SRSP			
MODEL AND: SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B		/	NONE	
FUNCT. DES: & SERVICE					SRSH			
	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSC			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A RETA D B SHIELD S T.I.D.	2.6E4 100% 2.6E4		RAB21P7 FSAR SEC 3.11B		H	NONE	
SPECIFICATIONS:					SRSR			
P.O #:	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR53 PARA. 50.51		/	NONE	
PLANT LOC.: AB21					SRSA			
COORDINATES X- 1484. Y- 1521. Z- 248.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD					SRSS			
QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY O		REFERENCES:				CES#-5130	
*QUALIF:	*TEMPERATURE T							
*STATUS	*PRESSURE P							
*	*REL. HUMIDTY H							
*	*CHEM. SPRAY C							
*****	*RADIATION R							
	AGING A						REVISION # : 00	
	SUBMERGENCE S						DATE :	
EQ. PCK # :	OSRR CATEG.: A						SYSTEM : AUXILIARY FEEDWTR	
	APPENDIX E						TAG : 3AF-P1SA-1	

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/P	OUTS ITEMS	
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.				
TAG NO : 3AF-P2SB-1	OPERABILITY			OPER. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT TYPE	NORM/TEST DBA				SRSO				
COMPONENT: LIMIT SWITCH#2 (2 OF 2)	TEMPERATURE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT:
MANUFACTURER: ITT HAMMEL DAHL / CONOFLOW	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.:
MAJOR SUPPLIER					SRSO				SUBCOMPONENTS:
MODEL AND SERIAL #	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES. & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE					SRSO				
ACCUR. DEP.: NOT APPLICABLE	R GAMMA	2.6E4		RAB21R7 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE	
SPECIFICATIONS:	A BETA								
P.O #:	D B SHIELD	100%			SRSR				
PLANT LOC.: AB21	S T.I.D.	2.6E4							
COORDINATES X- 1499. Y- 1520. Z- 248.0	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS		10 CFR50 PARA.50.51		COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: CRHR
INSTALLED (Y/N): LTR	SUBMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTAL. REF: BY-FLD					SRSS				
QUALIF EXEPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
*****	OPERABILITY	O		REFERENCES:				CES-5131	
*QUALIF:	TEMPERATURE	T							
*STATUS	PRESSURE	P							
*	REL. HUMIDTY	H							
*	CHEM. SPRAY	C							
*****	RADIATION	R							
	AGING	A						REVISION # : 00	
	SUBMERGENCE	S						DATE :	
EQ. PCK # :	0588 CATEG.: A							SYSTEM : AUXILIARY	
	APPENDIX E							FEEDTR	
								TAG : 3AF-P2SB-1	



EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CX-V244SB-1	OPERABILITY	40YRS NORM 500 CYC	40YRS NORM 100% DBA	OPER. REVIEW	REF(1) PG.4-4 & 4-5 SRSO 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES										
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 104F DBA	TAB31A FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRST 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO									MAINTAIN.:	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB31 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4 SRSP 9.1SH1	COMB. TEST & SUPPL. REVIEW	M	NONE	SEE NOTE (1)	
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5 SRSH 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SUBCOMPONENTS:	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB31 FSAR SEC 3.11B	N/A SRSC 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1)PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
ACCUR. SPEC: NOT APPLICABLE										
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.O.	2.6E4 4.4E5 100% 2.6E4	2.04E8	RAB3111 FSAR SEC 3.11B	REF(1) PG.10-7 SRSR 9.1SH1	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H										
P.O #: 435176	AGE-INST LIFE (PER 323-1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12 SRSA 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB31										
COORDINATES X- 1546. Y- 1626. Z- 263.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB31 FSAR SEC 3.11B	N/A SRSS 9.1SH1	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1						QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	OPERABILITY	O 9.1SH1							CES#-5132	
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE	T 9.1SH1								
*STATUS CONFIRMATORY DATA	PRESSURE	P 9.1SH1								
*	REL. HUMIDTY	H 9.1SH1								
*	CHEM. SPRAY	C 9.1SH1								
*****	RADIATION	R 9.1SH1								
	AGING	A 9.1SH1								
	SUBMERGENCE	S 9.1SH1								
EQ. PCK #: 9.1SH1	OSRR CATEG.: A APPENDIX E				REFERENCES: (1)NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				REVISION #: 30 DATE: 09/18/84	
									SYSTEM: ESS.SER.CHILLD WATER TAG: 3CX-V244SB-1	

A/E: EBAS VICES INC.
 UTILITY: CALINA POWER & LIGHT

FACILITY: SHEARON HARRIS PP - 1
 COMPONENT EVALUATION REPORT

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 CES-5141

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.				
TAG NO : AV-0155A-1	OPERABIL-ITY	40YRS NORM	140YRS NORM	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	
EQUIPMENT: DAMPERS TYPE	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1SH1	REVIEW			
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERAT-URE	95F NORM	106F NORM	TYD31R FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	/	NONE	REPLACEMENT: SEE NOTE (1)
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM	ATM NORM	PAB21 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL.	/	NONE	MAINTAIN.: SEE NOTE (1)
MAJOR SUPPLIER: RUSKIN	ATMOS DBA	ATM DBA	ATM DBA		SRSP 9.1SH1	REVIEW			SUBCOMPONENTS:
MODEL AND: EA-180-22302 SERIAL #	RELATIVE HUMIDITY	10-100% NORM	100% NORM	HYD31 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL.	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT
FUNCT. DES: REMOTE INDICAT ION OF DAMPER POSITION & SERVICE	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB21 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL.	/	NONE	NOTE: (1) PG 4-3, 4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81
ACCUR. SPEC: NOT APPLICABLE	R GAMMA	1.8E4	2.04E8	RAB211C FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL.	/	NONE	
ACCUR. DEM.: NOT APPLICABLE	A BETA								
SPECIFICATIONS: BE-25	D B SHIELD	100%							
P.O #: 435205	S T.I.D.	1.8E4			SRSR 9.1SH1	REVIEW			
PLANT LOC.: AB21	AGE- INST LIFE (PER 323-1974 DEF.)	40 YEARS	40 YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL.	/	NONE	SAFETY FUNCTIONS: SS
COORDINATES X- 1595 Y- 1695 Z- 244.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB21 FSAR SEC 3.11B	SRSA 9.1SH1	REVIEW	/	NONE	
INSTALLED (Y/N): LTR									
INSTAL. REF: BY-FLD	PARAMETER	SUPPL. REVIEW							FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1SH1
QUALIF EXEMPTH: NOT APPLIC	OPERABILITY	O 9.1SH1							QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1SH1
*****	TEMPERATURE	T 9.1SH1							
*QUALIF: QUALIFIED-AWAITING	PRESSURE	P 9.1SH1							
*STATUS CONFIRMATORY DATA	REL. HUMDTY	H 9.1SH1							
*	CHEM. SPRAY	C 9.1SH1							
*	RADIATION	R 9.1SH1							
*****	AGING	A 9.1SH1							
	SURMERGENCE	S 9.1SH1							
EQ. PCK # : 9.1SH1									REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105- REVISION 3 DATED 8/20/81.
	C588 CATEG.: A								
	APPENDIX E								

CES-5141

REVISION # : 00
 DATE : 09/18/84

SYSTEM : REAC.AUX.BLDG HVAC
 TAG : AV-0155A-1






A/E: EBAS SERVICES INC.
 UTILITY: CALIFORNIA POWER & LIGHT

FACILITY: SHEARON HARBOR
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 CES-5144

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS		
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL	DEM. QUALIF.					
TAG NO : 3CH-V128SA-1	OPERABILITY	40YRS NORM 500 CYC	14YRS NORM 110000 CYC	OPER. REVIEW	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE		
EQUIPMENT TYPE: VALVES	NORM/TEST DBA	1YR DBA	1YR DBA		SRSO 9.1/9.					
COMPONENT: LIMIT SWITCH (2 OF 2)	TEMPERATURE	104F NORM 104F DBA	104F NORM 106F DBA	TAB51A FSAR SEC 3.11B	REF(1). PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	REPLACEMENT: SEE NOTE (1)	
MANUFACTURER: NAMCO	PRESSURE	ATMOS NORM ATMOS DBA	ATM NORM ATM DBA	PAB51 FSAR SEC 3.11B	REF(1) PG.10-14 & 4-4	COMB. TEST & SUPPL. REVIEW	M	NONE	MAINTAIN.: SEE NOTE (1)	
MAJOR SUPPLIER: HAMMEL DAHL/CON OFLOW					SRSP 9.1/9.				SUBCOMPONENTS:	
MODEL AND SERIAL #: EA-180-11302	RELATIVE HUMIDITY	20-90% NORM 100% DBA	100% NORM 100% DBA	HAB51 FSAR SEC 3.11B	REF(1) PG.4-4 & 4-5	COMB. TEST & SUPPL. REVIEW	/	NONE	NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT NOTE: (1) PG.4-3,4-3.1 & 4-3.2 OF REPORT QTR-105 REV 3 DATED 8/20/81.	
FUNCT. DES. & SERVICE: POSITION INDICATION	CHEMICAL SPRAY	NOT APPLICABLE	N/A	CAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
ACCUR. SPEC: NOT APPLICABLE					SRSC 9.1/9.					
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100X 3.7E4	2.74E3	RAB5125 FSAR SEC 3.11B	REF(1) PG.10-7	COMB. TEST & SUPPL. REVIEW	H	NONE		
SPECIFICATIONS: M-66H					SRSR 9.1/9.					
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS	40YRS	10 CFR50 PARA.50.51	REF(1) PG.4-7 & 4-12	COMB. TEST & SUPPL. REVIEW	/	NONE	SAFETY FUNCTION: SS	
PLANT LOC.: AB51					SRSA 9.1/9.					
COORDINATES X- 1648. Y- 1689. Z- 305.0	SUBMERGED LEVEL	NOT APPLICABLE	N/A	SAB51 FSAR SEC 3.11B	N/A	COMB. TEST & SUPPL. REVIEW	/	NONE		
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLO					SRSS 9.1/9.					
QUALIF EXEMPTH: NOT APPLIC	PARAMETER	SUPPL. REVIEW		FOR PUNCLIST ITEMS SEE SH EQ PACKAGE: 9.1/9.2				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE: 9.1/9.2		
*****	OPERABILITY O	9.1/9.2		REFERENCES: (1) NAMCO CONTROLS DIVISION QUALIFICATION REPORT QTR-105 REVISION 3 DATED 8/20/81.				CES#-5144		
*QUALIF: QUALIFIED-AWAITING	TEMPERATURE T	9.1/9.2								
*STATUS CONFIRMATORY DATA	PRESSURE P	9.1/9.2								
*	REL. HUMDTY H	9.1/9.2								
*	CHEM. SPRAY C	9.1/9.2								
*****	RADIATION R	9.1/9.2								
	AGING A	9.1/9.2								
	SUBMERGENCE S	9.1/9.2								
EQ. PCK # : 9.1/9.2	0588 CATEG.: A APPENDIX E								REVISION # : 00 DATE : 09/18/84	
									SYSTEM : ESS.SER.CHILLO WATER TAG : 3CH-V128SA-1	



A/E: EBAS SERVICES INC.
 UTILITY: DELINA POWER & LIGHT

FACILITY: SHEARON HARRIS JPP - 1
 COMPONENT EVALUATION

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 9JC MW(E)

0
 5243

EQUIPMENT DESCRIPTION	ENVIRONMENT		DEM. QUALIF.	DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS
	PARAMETER	ACTUAL		ACTUAL	DEM. QUALIF.			
TAG NO : 2CS-V744SN-1	OPERABILITY			OPFR. REVIEW		COMB. TEST & SUPPL. REVIEW	/	NONE
EQUIPMENT TYPE: VALVES	NORM/TEST DBA				SRSO			
COMPONENT: CHECK 4	TEMPERATURE	104F NORM 104F DBA		TAB21A FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE
MANUFACTURER: ROCKWELL INTERNATIONAL	PRESSURE	ATMOS NORM ATMOS DBA		PAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	M	NONE
MAJOR SUPPLIER: ROCKWELL INTERNATIONAL					SRST			
MODEL AND SERIAL #: FIG. 36174F316T3	RELATIVE HUMIDITY	20-90% NORM 100% DBA		HAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
FUNCT. DES. & SERVICE: RCP 1C-SH NO. 1 SEAL LKOFF TO BUTT WELD ENDS	CHEMICAL SPRAY	NOT APPLICABLE		CAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
ACCUR. SPEC: NOT APPLICABLE					SRSH			
ACCUR. DEM.: NOT APPLICABLE	R GAMMA	3.0E4		RAB21R6 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	H	NONE
SPECIFICATIONS: M-34R	A BETA	7.2E4						
P.O #: 435C57	D B SHIELD	100%			SRSR			
PLANT LOC.: AB21	S T.I.O.	3.0E4						
COORDINATES X- 1570. Y- 1685. Z- 236.0	AGE- INST LIFE (PEP 323-1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51		COMB. TEST & SUPPL. REVIEW	/	NONE
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	SURMERGED LEVEL	NOT APPLICABLE		SAB21 FSAR SEC 3.11B		COMB. TEST & SUPPL. REVIEW	/	NONE
***** *QUALIF: *STATUS * * *****	PARAMETER	SUPPL. REVIEW			SRSA			
EQ. PCK # :	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMIDTY H CHEM. SPRAY C RADIATION R AGING A SURMERGENCE S				SRSS			
	0588 CATEG.: D APPENDIX E							

REPLACEMENT:
 MAINTAIN.:
 SUBCOMPONENTS:
 NO UNIQUE TAGGED SUBCOMPONENTS ARE ENVELOPED BY THIS EQUIPMENT

SAFETY FUNCTION:

FOR PUNCHLIST ITEMS SEE SH EQ PACKAGE:

QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:

CES#-5243

REFERENCES:

REVISION # :
 DATE :

SYSTEM : CHEM. & VOLUME CONTROL
 TAG : 2CS-V744SN-1



A/E: EBASCO SERVICES INC.
 UTILITY: CHINA POWER & LIGHT

FACILITY: SHEARON HARRIS - 1
 COMPONENT EVALUATION SHEET

NSSS: WESTINGHOUSE - PWR
 CAPACITY: 900 MW(E)

0
 CE: 5265

EQUIPMENT DESCRIPTION	ENVIRONMENT		DOCUMENTATION		QUALIF. METHOD	H/M	OUTS ITEMS	
	PARAMETER	ACTUAL	DEM. QUALIF.	ACTUAL				DEM. QUALIF.
TAG NO : 3CX-V110SB-1	OPERABIL- ITY			OPER. REVIEW	COMB. TEST & SUPPL. REVIEW	/	NONE	
EQUIPMENT: TYPE VALVES	NORM/TEST DBA			SRSO				
COMPONENT: GLOBE . 2 / 2	TEMPERAT- URE	104F NORM 104F DRG		TAB51A FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	
MANUFACTURER: ITT HAMMEL DAHL FLOW	PRESSURE	ATMOS NORM ATMOS DRG		PAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	M	NONE	
MAJOR : ITT HAMMEL DAHL SUPPLIER CO				SRSP				
MODEL AND: SERIAL # V50JXGC82CAZ9Z	RELATIVE HUMIDITY	20-90% NORM 100% DRG		HAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
FUNCT. DES: & SERVICE ESSENTIAL SER CX FOR TEMP CONN TO A H-15(2B-SB)	CHEMICAL SPRAY	NOT APPLICABLE		CAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
ACCUR. SPEC: NOT APPLICABLE				SRSC				
ACCUR. DEM.: NOT APPLICABLE	R GAMMA A BETA D B SHIELD S T.I.D.	3.7E4 100% 3.7E4		RAB5125 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	H	NONE	
SPECIFICATIONS: M-66H				SRSR				
P.O #: 435176	AGE- INST LIFE (PER 323- 1974 DEF.)	40 YEARS		10 CFR50 PARA. 50.51	COMB. TEST & SUPPL. REVIEW	/	NONE	
PLANT LOC.: AB51				SRSA				
COORDINATES X- 1644. Y- 1654. Z- 307.0	SUBMERGED LEVEL	NOT APPLICABLE		SAB51 FSAR SEC 3.11B	COMB. TEST & SUPPL. REVIEW	/	NONE	
INSTALLED (Y/N): LTR INSTAL. REF: BY-FLD QUALIF EXEMPTN: NOT APPLIC	PARA- METER	SUPPL. REVIEW	FOR PUNCLIST ITEMS SEE SH EQ PACKAGE:				QUALIFICATION SIGN-OFF FOUND IN DOCUMENTATION PACKAGE:	
***** *QUALIF: *STATUS * * *****	OPERABILITY O TEMPERATURE T PRESSURE P REL. HUMDTY H CHEM. SPRAY C RADIATION R AGING A SUBMERGENCE S		REFERENCES:				CES#-5265	
EQ. PCK # :	OS88 CATEG.: D APPENDIX E						REVISION # : DATE :	
							SYSTEM : ESS.SER.CHILLD WATER TAG : 3CX-V110SB-1	

REPLACEMENT:

MAINTAIN.:

SUBCOMPONENTS:

NO UNIQUE TAGGED
SUBCOMPONENTS ARE
ENVELOPED BY THIS
EQUIPMENT

SAFETY FUNCTION:

