

DEC 31 1984

50-400

MEMORANDUM FOR: John A. Olshinski
Division of Reactor Projects
Region II

IE FILE COPY

FROM: Gary G. Zech, Chief
Vendor Program Branch
Division of Quality Assurance,
Safeguards and Inspection Programs
Office of Inspection and Enforcement

SUBJECT: STEAM LINE ELBOWS FURNISHED BY SOUTHWEST
FABRICATING & WELDING COMPANY FOR STEAM
GENERATORS AT SHEARON HARRIS UNIT 1 WERE
FOUND BY UT TO HAVE WELDS BELOW SPECIFIED
THICKNESS. (VITS NO. 84-072)

The above item is closed without action, based on Carolina Power & Light Company's final report, dated April 16, 1984, to J. P. O'Reilly, which indicates that the March 14, 1984, potentially reportable subject item has been evaluated by Carolina Power & Light Company and is considered not to be reportable per provisions of 10 CFR 50.55(e) and 10 CFR Part 21.

If you should have any questions concerning this matter please contact Mr. R. E. Ollner (8-492-9634).

ORIGINAL SIGNED BY:
GARY G. ZECH

Gary G. Zech, Chief
Vendor Program Branch
Division of Quality Assurance,
Safeguards, and Inspection Programs
Office of Inspection and Enforcement

Distribution
R. Oller, IE
EMerschhoff, IE
G. Zech, IE
VPB Reading
DMB-IE:09

VPB/DQASIP/IE
R01ler:gmK
12/1/84

SE/VPB/DQASIP/IE
EMerschhoff
12/21/84

BC/VPB/DQASIP/IE
GZech
12/21/84

8501020285 841231
PDR ADDCK 05000400
S PDR

SECRET