

QUARTERLY DATA REPORT
SHNPP SEISMIC MONITORING PROGRAM
JANUARY 1, 1985 - MARCH 31, 1985

Carolina Power & Light Company (CP&L) has completed another quarter of operation of its seismic monitoring program at the Shearon Harris Nuclear Power Plant site near New Hill, North Carolina. During this period a total of 84 cultural events were recorded with an S-P of less than five seconds. No local earthquakes were detected.

Of these 84 events, 73 were confirmed as being explosions by responsible companies or agencies. The remaining 11 events displayed the signature and arrival pattern typical of previously identified cultural events and none occurred at night or on a weekend or holiday.

8505070340 850430
PDR ADOCK 05000400
R PDR

(1024CKR/pdc)



11

L