

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8610090482 DDC. DATE: 86/10/01 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH. NAME AUTHOR AFFILIATION
 ZIMMERMAN, S. R. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Forwards addl info re emergency operating procedures in response to audit conducted on 860710 & 11. Encl responses satisfy util commitments re training program documented in 860929 ltr & 860814 meeting.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 70
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME		LTR	ENCL		
	PWR-A ADTS	1	1		PWR-A EB	1	1		
	PWR-A EICSB	2	2		PWR-A FOB	1	1		
	PWR-A PD2 LA	1	1		PWR-A PD2 PD	7	7		
	BUCKLEY, B	1	1		PWR-A PSB	1	1		
	PWR-A RSB	1	1						
INTERNAL:	ADM/LFMB	1	0		IE/DEPER/EPB	3	3		
	NRR BWR ADTS	1	1		NRR PAULSON, W	1	1		
	NRR PWR-B ADTS	1	1		NRR/DSRO EMRIT	1	1		
	NRR/DSRO/EPB	1	1		NRR/DSRO/RSIB	1	1		
	REG FILES	1	1		RGN2	1	1		
EXTERNAL:	LPDR	1	1		NRC PDR	1	1		
	NSIC	1	1						

TOTAL NUMBER OF COPIES REQUIRED: LTR 31 ENCL 30

1. The purpose of this document is to provide a comprehensive overview of the current status of the project and to identify the key areas of concern. The information presented herein is for internal use only and should be handled accordingly.

2. The project has made significant progress since the last report, with several key milestones achieved. However, there are still several areas that require attention and resources to ensure the project is completed on time and within budget.

3. The following table provides a detailed breakdown of the project's financial performance, including revenue, expenses, and profit margins. This data is essential for understanding the project's economic viability and for making informed decisions regarding future funding and resource allocation.

Category	Item	Quantity	Unit Price	Total Cost
Materials	Raw Materials	1000	\$5.00	\$5000.00
	Components	500	\$10.00	\$5000.00
	Assembly	200	\$15.00	\$3000.00
	Finishing	100	\$20.00	\$2000.00
Labor	Direct Labor	1000	\$10.00	\$10000.00
	Indirect Labor	500	\$10.00	\$5000.00
	Overhead	200	\$15.00	\$3000.00
Overhead	Factory Overhead	100	\$20.00	\$2000.00
	Administrative	50	\$40.00	\$2000.00
Total	Materials			\$10000.00
	Labor			\$15000.00
Total Project Cost				\$25000.00



Carolina Power & Light Company

SERIAL: NLS-86-379

OCT 1 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NO. 1 - DOCKET NO. 50-400
EMERGENCY OPERATING PROCEDURES

Dear Mr. Denton:

Carolina Power & Light Company (CP&L) hereby submits additional information concerning the Shearon Harris Nuclear Power Plant (SHNPP) Emergency Operating Procedures. The attached information (Enclosure 1) is provided in response to NRC concerns identified during an audit of the SHNPP Emergency Operating Procedures conducted on July 10 and 11, 1986. Resolution of these concerns was discussed in a subsequent meeting with the NRC on August 14, 1986. The attached responses satisfy CP&L's commitments concerning the training program documented in CP&L letter dated August 29, 1986 and discussed in the August 14, 1986 meeting.

Several of the NRC's concerns relate to the Procedures Generation Package (PCP). It should be noted, however, that the PCP is not the governing document for licensed operator training at SHNPP. Plant Training Instructions and the SHNPP FSAR provide the training requirements for operators. Emergency Operating Procedure training and evaluation have always been a requirement of these documents. The PCP will be revised to cover the NRC's comments, but it should be recognized that the Training Instructions and the FSAR remain the controlling documents.

If you have any questions on this subject or require additional information, please contact me at (919) 836-6242

Yours very truly,

S. R. Zimmerman
Manager
Nuclear Licensing Section

JHE/mf (5019JDK)

Enclosure

cc: Mr. B. C. Buckley (NRC)
Mr. G. F. Maxwell (NRC-SHNPP)
Dr. J. Nelson Grace (NRC-RII)

8610090482 86100
PDR ADOCK 05000400
F PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

A003
1/1



1
2
3
4
5

6

7
8
9

10

11
12

13
14

15
16
17

18

19
20

Concern IA

Certain plant-specific information which is called for in the Westinghouse ERC's has not yet been provided in the Harris EOPs. The applicant should perform a systematic review of training to assure that the information that is missing has been included in the training program. Evidence that current operators have all of the required skills and knowledge necessary to implement the EOPs should be documented for NRC review.

Response

A systematic review of the SHNPP EOP network and training to support the EOP network has been completed. Attachment 1 is a WOG/SHNPP Step Matrix identifying where plant specific information was not provided. Attachment 2, "Emergency Procedures and Task Training Matrix" provides documentation as to where training to support the "deleted plant specific information" was conducted. The matrix includes both the Cold License Training Program which has been completed and the Hot License Training Program which will be conducted beginning in mid 1987. The materials to support the Hot License Training Program are presently under development and are scheduled to be completed by mid 1987.

In our letter of August 29, 1986, CP&L committed to complete additional training and/or EOP revision to ensure operator skill in using the EOPs prior to fuel load. Attachment 2 shows that training on plant specific information required to execute Emergency Operating Procedures is adequately provided in Cold License System Training, Continuing Training (1985), and Prelicense Review Training. CP&L considers the current status of EOPs and training to be adequate to ensure operator skill in using the EOPs. The commitments in Attachment 1 to revise the procedures are enhancements to the training that has already been provided, and are not necessary prior to fuel load. These revisions will be completed by December 12, 1986 along with the human factors update as committed to in our August 29, 1986 letter.

Three tasks have been identified for which additional training will be provided. These tasks are considered to be minor items and are listed in Attachment 3. This training will be incorporated in the Licensed Requalification Program and completed by December 31, 1986.

Attachment 2 also shows that training on the deleted plant specific information is covered by the various portions of the Hot License Training Program. Specifically the Hot License EOP Training will include step-by-step discussion of each procedure and bases for each step. Additionally, the EOPs will be fully exercised during the simulator portion of the Hot License Training.



100

100

100

100

100

100

100

Evidence that current operators have all the required skills and knowledge necessary to implement the EOPs is provided by the following:

1. The NRC licenses each operator. The licensing process includes a written exam, simulator exam, and a plant oral walk-through. Each exam relates in part to the emergency operating procedures. Successful completion of the exam provides adequate evidence that the operator is capable of utilizing the Emergency Operating Procedures.
2. Prior to the NRC exam, CP&L administers an NRC-style written, simulator and plant oral walk-through exam to ensure that the operators are well prepared to operate safely and are ready to be licensed by the NRC.
3. During the simulator training program (approximately 9 weeks for Cold License) the students are evaluated on their performance. The scenarios include normal operations, off-normal operations, and emergency operating procedures. The scenarios have single and multiple failures included. Three examples of simulator scenarios are provided as Attachment 4.
4. Written exams are given throughout the classroom training phases. These exams also include emergency operating procedures.
5. NRC Region II conducted an Operational Readiness Inspection during June, 1986. The training program for Cold License was reviewed and it was determined that the training program was satisfactory with only minor inspector follow-up items.
6. As indicated by the matrix, all EOPs were reviewed by Cold License Candidates in either the Continuing Training Program or Pre-license Review. This training included a step-by-step discussion of the EOP's and the bases for the steps.
7. The training program for Cold License meets or exceeds regulatory requirements.

Concern 1B:

Develop or provide evidence of a training program that systematically assures that information gaps in flowcharts and textual procedures are addressed specifically during future training; the program should include development of standards for the evaluation of task-level performance so that the applicant can identify whether all operators possess the appropriate enabling skills and knowledge to implement the EOPs.

Vertical text on the left side, possibly a page number or header.

Small text fragment in the lower-left quadrant.

Small text fragment in the lower-left quadrant.

Small text fragment in the lower-left quadrant.

Small text fragment in the lower-center area.

Small text fragment in the center-right area.

Small text fragment in the center-right area.

Small text fragment in the center-right area.

Small text fragment in the center-right area.

Faint text or markings in the top right corner.

Response

As stated in response in IA above, Attachment 2 is provided showing the task listing for the Hot License Training Program. Also, as stated in IA response above, the program is under development and will be completed prior to conducting Hot License Training for future operators. The program is based on an INPO job task analysis. Attachment 2 will also be used to ensure that items referenced as training required for the usage of the EOPs will be included in the Hot License Program.

Evaluation of the operators to ensure they possess the appropriate skills and knowledge to implement the EOPs, will be similar to the Cold License Training Program which is: 1) written exams during classroom training 2) evaluation during simulator exercises 3) CP&L (NRC style) written, simulator, and plant oral walk-through exams prior to the NRC licensing exams; 4) NRC licensed operator exams which include written, simulator, and plant oral walk-through. Tasks identified by the INPO task analysis are to be incorporated into the simulator scenarios now in development. The operators will be evaluated individually on each task. The simulator exercise guides will reference the tasks and include the criteria for evaluation. Unsatisfactory performance of an evolution requires a repeat of that particular scenario.

Training conducted during the Cold License Training Program Continuing Training and Pre-license Review Training was based on present emergency operating procedures. As changes are made to EOPs they are formally factored into the training program (Refer to Response to Comment 2 for discussion of process).


Enclosure 4 Detailed Comments (Training Program)

Comment 1:

The extensive use of flowcharts in the EOPs as described in the writer's guide reduces the amount of information that procedures can provide to operators. The training program must compensate for this lack of written information, i.e., the operators knowledge of plant procedures must be greater. A training program description must be provided which specifically describes how the training program will maintain the high level of operator knowledge necessary for the use of flowchart EOPs. This program description should address training program for EOPs distinct from training on other plant operating procedures.

Response

Plant Training Instruction 200 (TI-200), "Licensed Operator Requalification Program", maintains operator knowledge of the EOPs through three portions of the program. The "On-The-Job Training" portion requires that the EOPs be reviewed quarterly by each operator. Additionally, the "Formal Classroom Lectures" portion includes a session on Emergency Operating Procedures. Finally, the simulator portion requires sixty-four (64) hours of simulator training each year for each



licensed operator. Exercising the EOPs and ensuring operators can utilize the procedures is a major part of the simulator requalification training program. A review of the EOPs, with emphasis on the plant specific information required is scheduled for the lecture portion of the Requalification Program for 1986.

In order to ensure adequate operator knowledge, TI-200 requires that the following be performed as a part of the requalification training program: 1) Operators will be evaluated during simulator training as to their ability to implement EOPs 2) CP&L will administer annual NRC-style written requalification exams, simulator exams, and plant oral walk-throughs. Additionally, the NRC may examine selected operators yearly in conjunction with the requalification program.

Comment 2:

- * The PGP should describe a program of retraining to be used in the event of revision of EOPs, including explicit designation of how the need to retrain is to be determined (e.g., assignment of an individual to monitor revisions and retraining).

Response:

Plant Training Instruction 901A, "Dissemination of Training Related Information" describes the mechanism for review of revisions to plant procedures and EOPs. The instruction gives guidance for review of revisions and provides a tracking mechanism to ensure that the appropriate changes are included into training materials and training is conducted as appropriate. The Harris Training Unit assigns individuals as Subject Matter Experts to review the material. The material is then routed as appropriate and tracked to ensure that the required training is completed. As described in the response to Comment 1 of Enclosure 4, Plant Training Instruction TI-200 "License Operator Requalification Program" requires that the EOPs be reviewed, and exercised on the simulator as a part of the training program on a continuing cycle with emphasis on any changes.

Additionally, On-Site Nuclear Safety (ONS) reviews reports (LERs, SOERS, etc.) concerning operational incidents at SHNPP and other plants. ONS makes recommendations as to inclusion of the information into training. HTU is a member of the ONS review group. The PGP will be reviewed and submitted to the NRC by April 15, 1987.

Comment 3A:

Although the PGP states that a simulator will be used for operator training, the training program description should be expanded to address the following:

Discuss the method to be used to train the operators in areas where the simulator is not like the control room or does not react like the plant, and in parts of the EOPs that can not be run on the simulator.

1300-2000

1

2000-2100

2

2100-2200

3

Response:

A lesson plan titled "Simulator Differences" is used in simulator training programs. If parts of the EOPs can not be run on the simulator, they are discussed as part of the lesson plan or critiqued at the end of the exercise. ANSI/ANS 3.5 Section 3.1 dated 1981 requires that the simulator respond the same as the plant. The requirement goes into effect 18 months after the plant is in commercial operation. Until that time, if the simulator responds differently (now or once the plant is on line) the differences will be discussed in the "Simulator Differences" lesson plan.

Comment 3B:

Indicate the use of a wide variety of scenarios including multiple (simultaneous and sequential) failures, to fully exercise the EOPs on the simulator and thus expose the operators to a wide variety of EOP uses.

Response

Attached are three (3) scenarios (including evaluation check sheets) indicating the use of a wide variety of scenarios including multiple (simultaneous and sequential) failures. This is only a sampling of the large number of scenarios that we utilize in the simulator training program. The scenarios are from the Cold License Training Program that was conducted for the presently licensed operators.

Comment 4:

The PGP should include a commitment to train every operator on every EOP prior to EOP implementation in the control room.

Response

The presently licensed operators have been trained on all EOPs in the classroom and have been evaluated on simulator scenarios fully exercising the EOPs. The EOP review to be conducted in the 1986 Requalification Program will include training on changes and the EOP User's Guide. For future licensed operator training programs the operators will also be trained on all EOPs and have simulator training fully implementing the EOP procedures. The PGP will be revised to include comment 4 prior to startup following the first refueling outage as requested.

Comment 5:

The training program should indicate that operators will perform their assigned roles during training and that operators will be trained as teams.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Response:

Plant Training Instructions, TI-201, "Reactor Operator Replacement Training Program", TI-202, "Senior Reactor Operator Replacement Training Program" and TI-200, "License Operator Requalification Program", AI-26, "Simulator Training", emphasize simulator training both in the team concept and in the individual role. Operators are evaluated during simulator exercises as a team as well as individual roles.

Comment 6:

The PGP should indicate that operators will be evaluated after training and that all operators will be evaluated.

Response:

As the part of the training program, operators are evaluated by written exams during classroom training and during the simulator training they are evaluated on the exercises conducted. Unsatisfactory simulator evaluations require a repeat of the scenario. Prior to being licensed by the NRC, CP&L conducts NRC-style written, simulator, and plant oral walk-through exams to ensure that the operators possess the required knowledge to be licensed operators. The NRC provides written, simulator and plant oral walk-through exams to the operator prior to issuing individual licenses. Plant Training Instructions TI-200 "Licensed Operator Requalification Program, TI-201 "Reactor Operator Replacement Training Program", and TI-202 "Senior Reactor Operator Replacement Training Program" require that these evaluations be conducted. The requirement to evaluate operators will be added to the PGP by April 15, 1987.

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047

2048

2049

2050

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>E-0,RND 36a E-1,RND 11a</p> <p>Try to restore offsite power to ac emergency busses. <u>IF</u> offsite power can <u>NOT</u> be restored, <u>THEN</u> load the following equipment on ac emergency busses:</p> <p>[Enter plant specific list].</p>	<p>G1,RND 47a1)</p> <p>Try to restore offsite power to ac emergency busses. Verify EDGs properly loaded</p>	<p>10 13</p>	<p>Procedure will be revised to indicate how to verify proper loading.</p>
<p>E-3,RND 11</p> <p>Try to restore offsite power. <u>IF</u> necessary, <u>THEN</u> manually load the following equipment on the ac emergency busses:</p> <p>[Enter plant specific list].</p>	<p>G2,RND 19</p> <p>Verify the following:</p> <ol style="list-style-type: none"> 1) EDG properly loaded 2) Turbine DC lube oil pumps - RUNNING 3) Turbine seal oil backup pump - RUNNING 4) Instrument air compressors - RUNNING 	<p>10 13</p>	<p>Procedure will be revised to indicate how to verify proper loading.</p>
<p>E-1,12a</p> <p>Verify cold leg recirculation capability:</p> <ol style="list-style-type: none"> 1) Power to low-head SI pumps - AVAILABLE 2) [Enter plant specific list] 	<p>G1,66a</p> <p>RHR system - CAPABLE OF COLD LEG RECIRCULATION</p>	<p>4</p>	<p>PATH GUIDE will be revised to include list of required items.</p>
<p>E-1,12b</p> <p>Check auxiliary building radiation - NORMAL</p> <p>[Enter plant specific list]</p>	<p>G1,66b</p> <p>Check auxiliary and waste processing building radiation - NORMAL</p>	<p>14</p>	<p>None.</p>

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>E-1,RNO 12b</p> <p>Try to identify and isolate leakage:</p> <p>[Enter plant specific means].</p>	<p>G1,RNO 66b</p> <p>Try to identify and isolate leakage.</p>	<p>14 22</p>	<p>None.</p>
<p>E-1,12c</p> <p>Obtain samples:</p> <p>[Enter plant specific list]</p>	<p>G1,37 G1,51</p> <p>Request Periodic Activity Samples Of All SGs</p>	<p>15 16 24</p>	<p>This step falls at the end of the LOCA guideline under the high level step "Evaluate Plant Status." At this time, this would be directed by the Technical Support Center vice the Control Room.</p>
<p>E-1,12d</p> <p>Evaluate plant equipment:</p> <p>[Enter plant specific list]</p>	<p>None.</p>	<p>24 25</p>	<p>This step falls at the end of the LOCA guideline under the high level step "Evaluate Plant Status." At this time, this would be directed by the Technical Support Center vice the Control Room.</p>
<p>E-1,12e</p> <p>Start additional plant equipment to assist in recovery:</p> <p>[Enter plant specific list]</p>	<p>None.</p>	<p>24 25 26</p>	<p>This step falls at the end of the LOCA guideline under the high level step "Evaluate Plant Status." At this time, this would be directed by the Technical Support Center vice the Control Room. The operator is continually evaluating this need and doing it.</p>
<p>E-1,15b</p> <p>Check SGs radiation - NORMAL</p> <p>[Enter plant specific means]</p>	<p>G1,69b</p> <p>Check SG radiation - NORMAL</p>	<p>15</p>	<p>None.</p>

124

1900

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

1900

1900

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>E-1,17</p> <p>At () Hours After Event Initiation Prepare For Hot Leg Recirculation:</p> <p>Check control room valve switches in the following position:</p> <p>[Enter plant specific list of normally deenergized valves used for transfer to hot leg recirculation with their correct position during cold leg recirculation]</p> <p>Check circuit breakers so that the following valves are energized:</p> <p>[Enter plant specific list of valves used for transfer to hot leg recirculation]</p>	<p>G1,70</p> <p>At 18 Hours After Event Initiation, Align SI System For Hot Leg Recirculation Using EPP-011, "TRANSFER TO HOT LEG RECIRCULATION," Step 1.</p>	<p>4</p>	<p>This is not a time critical step. There is no explicit need to prepare for doing EPP-011.</p>
<p>E-3,2</p> <p>High radiation from any SG blowdown line:</p> <p>[Enter plant specific means]</p>	<p>G1,31</p> <p>SG blowdown radiation - NORMAL</p>	<p>14 15</p>	<p>None.</p>
<p>E-3,RND 19 1)</p> <p>Monitor following conditions for indication of leakage from PRZR PORV:</p> <p>[Enter plant specific list].</p>	<p>G2,RND 28 1)</p> <p>Monitor PRT conditions</p>	<p>17</p>	<p>The procedure will be revised to list which parameters to monitor.</p>



21 12 1955

12

12

12

12

21 12 1955

12

12 12 1955

12

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>E-3,31</p> <p>Minimize Secondary System Contamination:</p> <p>[Enter plant specific means]</p>	<p>G2,45</p> <p>Minimize Secondary System Contamination</p> <p>a. Isolate Main Steam from Auxiliary Steam System by locally shutting IMS-121.</p> <p>b. Isolate hotwell spillover to CST by locally shutting</p> <p>ICE-139 ICE-146</p> <p>c. Establish condensate flow through condensate polishers to maximize removal of secondary radioactivity.</p> <p>d. Place CVPETS in service.</p>	<p>23</p>	<p>The additional detail in this step will also appear in the EPPs where appropriate.</p>
<p>ES-3.1,RND 5c ES-3.2,RND 5b ES-3.3,RND 5b ES-3.3,RND 14c</p> <p>Manually or locally dump steam from intact SG(s):</p> <p>o Use PORV.</p> <p>--OR--</p> <p>o [Enter plant specific means].</p>	<p>EPP-017,RND 5c EPP-018,RND 5c EPP-019,RND 5b EPP-019,RND 14c</p> <p>Dump steam with intact SG PORVs.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>

100

100

100

100

100

100

100

100

100

100

100

100

100

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-1.1,RNO 3b</p> <p>Manually or locally dump steam from intact SG(s):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-012,RNO 3b</p> <p>Dump steam from intact SG(s) using PORV.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ECA-1.1,RNO 17a</p> <p>Manually or locally dump steam at maximum rate from intact SG(s):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-012,RNO 17a</p> <p>Dump steam at maximum rate using intact SG PORVs.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ECA-1.1,RNO 18a</p> <p>Manually or locally dump steam from intact SG(s) as necessary to maintain RVLIS full range indication at (10):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-012,RNO 18a</p> <p>Dump steam using intact SG PORVs.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>



1
2

100

100

100

100

100

1000 10000 100000 1000000 10000000 100000000 1000000000

100

100

100

100

100

100000

100

100

100

1000

100

Attachment 1 - WOG/SINPP Step Matrix

WOG Step	SINPP Step	Task	Comments
<p>ECA-1.1,RNO 21b ECA-1.1,RNO 23b</p> <p>Manually or locally dump steam from intact SG(s):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-012,RNO 21b EPP-012,RNO 23b</p> <p>Dump steam using intact SG PORV.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ECA-3.1,RNO 10c ECA-3.2,RNO 5c</p> <p>Manually or locally dump steam from intact SG(s):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-020,RNO 11c EPP-021,RNO 5c</p> <p>Dump steam using intact SG PORVs.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ECA-3.3,RNO 25b ECA-3.3,RNO 33c</p> <p>Manually or locally dump steam from intact SG(s):</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>EPP-022,RNO 26b EPP-022,RNO 34c</p> <p>Dump steam using intact SG(s) PORV.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>



100

100

100

100

100

100

100

100

100

100

100

100

100

100

100

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-0.1,8</p> <p>Establish SG Pressure Control:</p> <p>a. Set each SG PORV controller to maintain existing SG pressure</p> <p>b. Place each SG PORV controller in automatic mode</p> <p>c. Locally return SG PORVs to remote control:</p> <p>[Enter plant specific means]</p>	<p>EPP-002,10</p> <p>Establish SG Pressure Control:</p> <p>a. Coordinate with local operator and control SG PORVs to maintain existing SG pressure</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ES-0.1,RND 4b</p> <p>Manually place in service:</p> <p>[Enter plant specific means].</p>	<p>EPP-004, None.</p>	<p>2</p>	<p>EPP-004 says to verify charging and letdown in service. This means if they are not in service to place them in service.</p>
<p>ECA-3.3,4e</p> <p>Try To Establish Auxiliary Spray:</p> <p>e. Establish auxiliary spray flow:</p> <p>[Enter plant specific means]</p>	<p>EPP-022,5</p> <p>Try To Establish Auxiliary Spray:</p> <p>a. Check the following:</p> <p>1) CSIPs running</p> <p>2) Auxiliary spray path lined up</p> <p>3) Auxiliary spray available</p>	<p>18</p>	<p>None.</p>
<p>ECA-1.2,1c</p> <p>Verify Proper Valve Alignment:</p> <p>c. Other paths to outside containment - CLOSED</p> <p>[Enter plant specific list]</p>	<p>EPP-013,1c</p> <p>Verify Proper Valve Alignment:</p> <p>c. Check any valves which failed to align in accordance with SI verification as a possible coolant loss flow path.</p>	<p>20 22</p>	<p>None.</p>



54

121

12

12

12

12

12

12

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-0.0,RND 16b</p> <p>Locally dump steam using SG PORVs:</p> <p>[Enter plant specific means]</p>	<p>EPP-001,RND 15b</p> <p>Locally operate SG PORVs.</p>	<p>9</p>	<p>This step will be revised to address the plant OP on PORV local operations.</p>
<p>ECA-1.1,7c</p> <p>Align spray for recirculation:</p> <p>[Enter plant specific means]</p>	<p>EPP-012,7c</p> <p>Align CNMT spray for recirculation</p>	<p>5</p>	<p>This procedure will be revised to list requirements.</p>
<p>ECA-0.2,RND 1a</p> <p>Manually align valves to establish cold leg recirculation alignment:</p> <p>[Enter plant specific list].</p>	<p>EPP-003,RND 1a1)</p> <p>Align valves to establish cold leg recirculation.</p>	<p>4</p>	<p>This procedure will be revised to list valve alignment.</p>
<p>ECA-0.1,RND 7a</p> <p>ECA-0.2,RND 6a</p> <p>Establish required AFW valve alignment:</p> <p>[Enter plant specific list]</p>	<p>EPP-002,RND 9a</p> <p>EPP-003,RND 6a</p> <p>Establish required AFW valve alignment.</p>	<p>6</p>	<p>None.</p>
<p>ECA-3.1,29</p> <p>ECA-3.2,23</p> <p>ECA-3.3,17</p> <p>Minimize Secondary System Contamination:</p> <p>[Enter plant specific means]</p>	<p>EPP-020,29</p> <p>EPP-021,22</p> <p>EPP-022,19</p> <p>Minimize Secondary System Contamination</p>	<p>14</p> <p>23</p>	<p>This procedure will be revised to provide more detail. See PATH-2 GUIDE, Step 45.</p>



01 92.12 100 10

4.

10

10

10

10

10

10

10

10

10

10

10

10

10

10

10

Attachment 1 - WOG/SHNPP Step Matrix

HOG Step	SHNPP Step	Task	Comments
<p>ECA-1.2,2</p> <p>Try To Identify And Isolate Break:</p> <p>Sequentially close and open the following valves and monitor for an RCS pressure increase:</p> <p>1) Low-head SI pump cold leg injection valves</p> <p>2) [Enter plant specific list]</p>	<p>EPP-013,2</p> <p>Try To Identify And Isolate Break:</p> <p>a. Dispatch an operator to RAB to investigate.</p> <p>b. Use Radiation Monitoring System to determine possible source of leakage.</p>	<p>14 22</p>	<p>None.</p>
<p>ECA-0.0,26</p> <p>Verify Service Water System Operation:</p> <p>a. Verify valve alignment - PROPER ALIGNMENT</p> <p>[Enter plant specific list]</p> <p>b. Verify pump - RUNNING</p>	<p>EPP-001,24</p> <p>Check ESW System Operation:</p> <p>a. Check ESW and ESW booster pumps running.</p>	<p>7</p>	<p>This procedure will be revised to provide more detail and to verify ESW lineup to the EDGs.</p>
<p>ECA-3.1,RND 7a</p> <p>Try to identify and isolate leakage:</p> <p>[Enter plant specific means].</p>	<p>EPP-020,RND 8a</p> <p>Perform the following:</p> <p>o Try to identify and isolate leakage.</p> <p>o EAL FLAG: <u>IF</u> RCS leakage exists outside CVNT, <u>THEN</u> reference EAL, entry points U and V.</p>	<p>14 22</p>	<p>None.</p>

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-3.1,7</p> <p>Initiate Evaluation Of Plant Status:</p> <p>a. Check auxiliary building radiation - NORMAL</p> <p>[Enter plant specific means]</p> <p>b. Obtain samples:</p> <p>[Enter plant specific means]</p> <p>c. Evaluate plant equipment:</p> <p>[Enter plant specific list]</p> <p>d. Start additional plant equipment to assist in recovery:</p> <p>[Enter plant specific list]</p>	<p>EPP-020,8</p> <p>Initiate Evaluation Of Plant Status:</p> <p>a. Check auxiliary building radiation - NORMAL</p> <p>b. Obtain samples of RCS, SGs, and CNMT sump as needed.</p> <p>c. Evaluate plant equipment.</p> <p>d. Start additional plant equipment to assist in recovery.</p>	<p>14</p> <p>15</p> <p>16</p> <p>24</p> <p>25</p> <p>26</p>	<p>None.</p>
<p>ECA-0.0,12</p> <p>Check If SG Tubes Are Not Ruptured:</p> <p>o Condenser air ejector radiation - NORMAL</p> <p>o SG blowdown radiation - NORMAL</p> <p>o [Enter plant specific means]</p>	<p>EPP-001,11</p> <p>Identify Any Ruptured SG(s) by using Radiation Monitoring System.</p> <p>o Condenser vacuum effluent treatment monitor - NORMAL</p> <p>o SG blowdown radiation monitor - NORMAL</p> <p>o Main steamline radiation monitors - NORMAL</p>	<p>15</p>	<p>None.</p>

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>E-2,6a</p> <p>Request periodic activity samples of all SGs:</p> <p>[Enter plant specific means]</p>	<p>EPP-014,7a</p> <p>Request periodic activity samples of all SGs.</p>	<p>16</p>	<p>None.</p>
<p>ES-0.2,3</p> <p>Verify Cold Boron Shutdown Concentration By Sampling:</p> <p>[Enter plant specific means]</p>	<p>EPP-005,3</p> <p>Verify Cold Boron Shutdown Concentration By Sampling.</p>	<p>16</p>	<p>None.</p>
<p>ES-0.2,17 ES-0.3,8 ES-0.4,7</p> <p>Maintain Required RCP Seal Injection Flow:</p> <p>[Enter plant specific means]</p>	<p>EPP-005,17 EPP-006,18 EPP-007,17</p> <p>Maintain Required RCP Seal Injection Flow.</p>	<p>8</p>	<p>No specific instructions are necessary to maintain seal injection.</p>
<p>ECA-3.3,24</p> <p>Maintain Required RCP Seal Injection Flow:</p> <p>[Enter plant specific means]</p>	<p>EPP-022,21</p> <p>Check RCP Cooling - NORMAL</p> <ul style="list-style-type: none"> o RCP CDW system flow o RCP seal injection flow 	<p>8</p>	<p>The SHNPP step has the operator check both seal cooling mechanisms, and the RND column directs the operator to restore them if not normal.</p>



23

10 20 30 40

*

.

.

*

.

.

.

.

10 20 30 40

10 20 30 40

10 20 30 40

10 20 30 40

.

.

.

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-0.1,20</p> <p>Try To Restore Offsite Power To All AC Busses:</p> <p>[Enter plant specific means]</p>	<p>EPP-002,21</p> <p>Try To Restore Offsite Power To All AC Busses. <u>IF</u> necessary, <u>THEN</u> perform the following:</p> <ul style="list-style-type: none"> a. Verify EDGs have started. b. Verify EDGs have assumed the proper loads. c. Verify turbine DC emergency bearing oil and air side seal oil backup pumps are running. d. Verify adequate EDG capacity and load equipment as necessary to establish stable conditions. e. Determine the cause of the loss of offsite power. If due to a failure of the startup transformer, request assistance from maintenance crews to restore power from either the main or spare startup transformer. If the loss of power is the result of a loss of grid, obtain assistance from the Load Dispatcher. 	<p>10 13</p>	<p>None.</p>



1950

1951

1952

1953

1954

1955

1956

1957

1958

1959

1960

1961

1962

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ES-1.1,RND 22 ES-1.2,RND 4 ECA-2.1,RND 30 ECA-3.1,RND 4</p> <p>Try to restore offsite power. <u>IF</u> necessary, <u>THEN</u> manually load the following equipment on the ac emergency busses:</p> <p>[Enter plant specific list].</p>	<p>EPP-006,RND 21 EPP-009,RND 4 EPP-015,RND 31 EPP-020,RND 4</p> <p>Try to restore offsite power. <u>IF</u> necessary, <u>THEN</u> perform the following:</p> <ol style="list-style-type: none"> a. Verify EDGs have started. b. Verify EDGs have assumed the proper loads. c. Verify turbine DC lube oil and air side seal oil backup pumps are running. d. Verify adequate EDG capacity and load the following equipment on the EDGs: <ol style="list-style-type: none"> 1) One instrument air compressor 2) Battery chargers 3) PRZ heaters, as needed. e. Determine the cause of the loss of offsite power. If due to a failure of the startup transformer, request assistance from maintenance crews to restore power from either the main or spare startup transformer. If the loss of power is the result of a loss of grid, obtain assistance from the Load Dispatcher. 	<p>10 13</p>	<p>None.</p>

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-0.0,5a2)</p> <p>Verify ac emergency bus automatically energized:</p> <p>[Enter plant specific means]</p>	<p>EPP-001,5b</p> <p>Verify AC emergency bus automatically energized.</p>	<p>10</p>	<p>This step will be revised to provide more detail.</p>
<p>ES-0.1,RND 7</p> <p>Perform the following:</p> <p>a. <u>IF</u> necessary, <u>THEN</u> verify diesel generators have assumed the following loads:</p> <p>[Enter plant specific list].</p> <p>b. Try to restore offsite power:</p> <p>[Enter plant specific means].</p> <p>c. <u>IF</u> necessary, <u>THEN</u> manually load the following equipment on the ac emergency busses:</p> <p>[Enter plant specific list].</p>	<p>EPP-004,RND 8</p> <p>Perform the following as necessary:</p> <p>a. Verify EDGs have started.</p> <p>b. Verify EDGs have assumed the proper loads.</p> <p>c. Verify turbine DC Emergency bearing oil and air side seal oil backup pumps are running.</p> <p>d. Verify adequate EDG capacity and load the following equipment on the EDGs:</p> <p>1) One instrument air compressor</p> <p>2) Battery chargers</p> <p>3) PRZ heaters, as needed.</p> <p>e. Determine the cause of the loss of offsite power. If due to a failure of the startup transformer, request assistance from maintenance crews to restore power from either the main or spare startup transformer. If the loss of power is the result of a loss of grid, obtain assistance from the Load Dispatcher.</p>	<p>10 13</p>	<p>None.</p>



1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>ECA-0.0,RNO 5a1)-2)</p> <p>1) Emergency start diesel generator:</p> <p>[Enter plant specific means]</p> <p>2) Manually energize ac emergency bus. <u>IF</u> bus can <u>NOT</u> be energized, <u>THEN</u> manually trip diesel generator and energize ac emergency bus using any available power supply:</p> <p>[Enter plant specific means]</p>	<p>EPP-001,RNO 5a1)-2)</p> <p>1) Start EDGs by actuating SI from the MCB</p> <p>IF EDGs will not start, <u>THEN</u> go to Step 5b.</p> <p>2) Energize AC emergency bus. <u>IF</u> bus can <u>NOT</u> be energized, <u>THEN</u> attempt to locally energize emergency busses at switchgear.</p>	<p>13</p>	<p>None.</p>
<p>ECA-0.1,3b1)</p> <p>Check valve alignment and start CCH pump:</p> <p>1) Check valve alignment:</p> <p>[Enter plant specific list]</p>	<p>EPP-002, None.</p>		<p>The CCH pump is started in a following step. It will be put here to be consistent with the ERGs and to provide additional guidance on valve alignment.</p>
<p>FRP-S.1,RNO 5a</p> <p>Dispatch operator to locally trip reactor:</p> <p>[Enter plant specific means].</p>	<p>FRP-S.1,RNO 5a</p> <p>Dispatch an operator to locally trip reactor trip breakers or rod drive motor generator sets.</p>	<p>19</p>	<p>None.</p>
<p>FRP-S.1,RNO 5b</p> <p>Dispatch operator to locally trip turbine:</p> <p>[Enter plant specific means].</p>	<p>FRP-S.1,RNO 5b</p> <p>Dispatch an operator to locally trip turbine.</p>	<p>12</p>	<p>None.</p>



10-10-1944

1

2

3

4

5

6-10-1944

6

7

8

9

10

11

12

13

14

15

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>FRP-C.1,RNO 2</p> <p>Start pumps and align valves as necessary. Try to establish any other high pressure injection:</p> <p>[Enter plant specific list]</p>	<p>FRP-C.1,RNO 2</p> <p>Start pumps</p> <p>Verify SI valve alignment - PROPER EMERGENCY ALIGNMENT</p> <p>Try to establish charging flow to RCS.</p> <p>Go to Step 3.</p> <p>Verify RHR valve alignment - PROPER EMERGENCY ALIGNMENT</p>	<p>4</p>	<p>None.</p>
<p>FRP-C.2,RNO 2a-b</p> <p>a. Start pumps and align valves as necessary. Try to establish any other high pressure injection:</p> <p>[Enter plant specific list]</p> <p>b. Start pumps and align valves as necessary. Try to establish any other high pressure injection:</p> <p>[Enter plant specific list]</p>	<p>FRP-C.2,RNO 2a-b</p> <p>Start pumps</p> <p>Verify SI valve alignment - PROPER EMERGENCY ALIGNMENT</p> <p>Try to establish charging flow to RCS.</p>	<p>4</p>	<p>None.</p>
<p>FRP-C.1,RNO 15 FRP-C.1,RNO 22 FRP-C.2,RNO 15</p> <p>Continue efforts to establish SI flow. Try to establish any other high pressure injection:</p> <p>[Enter plant specific list].</p>	<p>FRP-C.1,RNO 15 FRP-C.1,RNO 22 FRP-C.2,RNO 15</p> <p>Continue efforts to establish SI flow. Try to establish charging flow to RCS.</p>	<p>2 4</p>	<p>None.</p>



11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>FRP-C.1,19</p> <p>Try To Locally Depressurize All Intact SGs To Atmospheric Pressure:</p> <ul style="list-style-type: none"> o Use PORV --OR-- o [Enter plant specific means] 	<p>FRP-C.1,19</p> <p>Try To Locally Depressurize All Intact SGs To Atmospheric Pressure.</p>	<p>9</p>	<p>This step will be revised to include steam drains upstream of MSIVs, and will address the OP on local operation of SG PORVs.</p>
<p>FRP-C.2,RND 10b FRP-C.2,RND 14b</p> <p>Manually or locally dump steam from SGs:</p> <ul style="list-style-type: none"> o Use PORV. --OR-- o [Enter plant specific means]. 	<p>FRP-C.2,RND 10b FRP-C.2,RND 14b</p> <p>Dump steam using SG PORVs.</p>	<p>9</p>	<p>This step will be revised to reference the plant OP on local SG PORV operations.</p>
<p>FRP-H.1,5c</p> <p>Establish Main FW Flow: [Enter plant specific means]</p>	<p>FRP-H.1,4c</p> <p>Establish Main FW flow.</p>	<p>11</p>	<p>None.</p>
<p>FRP-H.3,8</p> <p>Establish Blowdown From Affected SG(s): [Enter plant specific means]</p>	<p>FRP-H.3,8</p> <p>Establish Blowdown From Affected SG(s) to Lower SG Level.</p>	<p>21</p>	<p>This step will be revised to address the plant OP on SG blowdown.</p>



DATE: 10/10/1964

10/10/64

10/10/64


10/10/64

10/10/64

10/10/64

Attachment 1 - WOG/SHNPP Step Matrix

WOG Step	SHNPP Step	Task	Comments
<p>FRP-7.1,3c</p> <p>Verify spray system valve alignment - PROPER EMERGENCY ALIGNMENT</p> <p>[Enter plant specific list for injection and recirculation phases]</p>	<p>FRP-J.1,3c</p> <p>Verify CNMT spray system valves - PROPER EMERGENCY ALIGNMENT</p>	<p>5</p>	<p>This step will be revised to list requirements.</p>
<p>FRP-1.3,16a</p> <p>Isolate containment:</p> <p>[Enter plant specific list]</p>	<p>FRP-I.3,16a</p> <p>Verify CNMT ventilation isolation</p>	<p>20</p>	<p>This step will be revised to refer to the checklist in order to verify components.</p>



ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
1	Check If SI Is Actuated	<p>CLC-1-1-B, pp. 3 & 4 Simulator Control Room Differences</p> <p>CLC-2-4-1A, p. 3 Review: Rx Trip Procedure</p> <p>CLC-3-4-2B, p. 6. Review: AOP-16, EPP-7, 8, 9 and 10</p> <p>CLC-3-5-1A, pp. 2-4 SI Demonstration</p> <p>CLC-3-5-1B/3-5-2, p. 7 CLC-4-1-1B/4-1-2A, pp. 7-9 CLC-4-3-1B/4-2, pp. 9 & 10 CLC-4-4-2, pp. 6 & 7 CLC-5-1-1, pp. 5 & 6 CLC-5-3-2, p. 5 CLC-5-4-2, pp. 6 & 7 CLC-5-5-1, pp. 10 & 11 CLC-5-1-2, pp. 7 & 8 CLC-6-1-1, pp. 6 & 7 CLC-6-1-2B, p. 5 CLC-6-3-2, pp. 5 & 6 CLC-7-2-1, pp. 7 & 8 CLC-7-2-2, p. 8 CLC-7-4-2, pp. 8 & 9 CLC-7-5-1, pp. 8 & 9 CLC-7-5-2, pp. 8 & 9 CLC-8-1-1, pp. 13 & 14 CLC-8-1-2, pp. 9 & 10 CLC-8-2-2, pp. 5 & 6 CLC-8-3-2, pp. 5 & 6 CLC-9-1-1, p. 7 CLC-9-1-2, pp. 14 & 15 CLC-9-2-2, p. 4 CLC-9-3-2, pp. 8 & 9</p>	<p>Light panels & Permissive Status Panel reviewed. SI status indicated on panel.</p> <p>Discusses kickout to EPP-4 if SI <u>not</u> required.</p> <p>Discussion on SI verification.</p> <p>Demo on SI indications and verification. Also, each trainee walks through each role.</p> <p>CLC Exercises with SI actuation exercises.</p>	<p>EOP-LP-3.1 Path-1, EPP-004, EPP-008 (In development)</p> <p>SIS-LP-3.0 Safety Injection System</p> <p>PLR-LP-3.2 Emergency Operating Procedures (To be developed)</p> <p>RO Hot License Simulator Scenarios (In development)</p> <p>SRO Hot License Simulator Scenarios (In development)</p>	<p>Steps and bases for Path-1. Task required by procedure.</p> <p>COC Systems Training. Indications for SI (Permissive Status Panel).</p> <p>RO Procedures Review.</p> <p>Exercises involving use of Path-1.</p>

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments PLR Exercises with SI actuation	Hot License Training	Comments
		SS7221H			
		SS7222H			
		SS7232H			
		SS7241H			
		SS7242H			
		SS7251H			
		SS7311H			
		SS7312H			
		SS7322H			
		SS7341H			
		SS7342H			
		SS7421H			
		SS7422H			
		SS7431H			
		SS7441H			
		SS7442H			
		SS7451H			
		EOP Review, Section 1 Prelicense Review	Discussion on use of Paths & EPPs. Walk through of MCB for SI actuation Included.		
2	Placing charging and letdown in service	CVCS-LP-1.0 Chemical Volume Control System	CLC Systems Training.	CVCS-LP-3.0 Chemical Volume Control System (In development)	COC Systems Training. Includes flowpath and interlocks.
		CLC-3-4-2B	EPP-008 (EPP-007 in old numbering system) reviewed. Requires operator to manually align charging and letdown.	EOP-LP-3.1 Path-1, EPP-004, 008	Specific steps and bases for EPP-008. Requires manual alignment of charging and letdown.
		CLC-3-5-1A	SI DEMO. Each operator required to implement SI actuation & termination procedures. Requires placing L/D & Charging in service.	RO Hot License Simulator Scenarios (In development)	Exercises Involving: 1) EPP-004, Rx Trip Response
		CLC-5-1-1 CLC-5-5-1, p. 12 CLC-6-1-2B CLC-7-2-2 CLC-9-3-2 SS7242H	Simulator Scenarios Involving SI termination procedure. Requires placing L/D & Charging in service.	SRO Hot License Simulator Scenarios (In development)	2) EPP-008, SI Termination (Manual alignment of letdown letdown and charging)

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training SS734IH	Comments	Hot License Training	Comments
3	Placing excess letdown in service	CVCS-LP-1.0 Chemical Volume Control System	CLC Systems Training. Flowpath and Interlocks Included.	CVCS-LP-3.0 Chemical Volume Control System (In development)	COC System Training. Flowpath and Interlocks Included
		CLC-3-3-1B CLC-5-3-1 CLC-7-4-1	Exercises requiring excess letdown be placed in service.	RO Hot License Simulator Scenarios (In development)	Exercises requiring excess letdown be placed in service.
		SS7322H SS722H		SRO Hot Licenses Simulator Scenarios (In development)	
4	Alignment of SI for Injection and recirculation	SIS-LP-1.0, Sections 2.6.2 and 2.6.3 SI System	CLC Systems Training. Includes flowpath and bases for switchover.	RHR-LP-3.0, Section 2.6.2 & 2.6.3 Residual Heat Removal System	COC Systems Training. Includes flowpaths and bases for switchover.
		RHR-LP-1.0, Sections 2.7.2 and 2.3.3 RHR System	CLC Systems Training. Includes flowpaths and bases for switchover.	SIS-LP-3.0, Section 2.7.2 & 2.7.2 Safety Injection System	COC Systems Training. Includes flowpath and bases for switchover.
		PFR-LP-1.0, Sections 2.5.2 and 2.5.3	Phase Four Training reviews flowpaths and bases for switchover.	MCD-LP-2.1, Section 2.3.3 Post Accident Cooling	SRO Mitigating Core Damage Training. Includes bases for switchover.
		MCD-LP-1.1, Section 2.3.3 Post Accident Cooling	Bases for Switchover.	EOP-LP-3.3 EPP-009, 010, 011, 012, 013. (In development)	Specific steps and bases for EPPs-010 and 011. Task required by procedures.
		EOP-009 Continuing Training - 1985 Week 1/Lesson 3	Specific Steps of EPPs 9, 10 & 11. Task required by procedures.		
		RHR System Prelicense Review	Review of RHR System.	RO Hot License Simulator Scenarios (In development)	Exercises Involving switchover to Hot Leg Recirculation.
		RHR & SI Systems (RQ86203) Requalification Training - 1986	Flowpaths and Interlocks emphasized.		
CLC-6-1-1 SS722IH	Simulator Scenarios Involving switchover to H. L. Reclrc. (See Task #1 for all exercise involving SI actuation).	SRO Hot License Simulator Scenarios (In development)			

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
	Alignment of CNMT Spray for Injection and recirculation	CSS-LP-1.0 Containment Spray System	CLC System Training. Flowpaths, actuation signals and interlocks included.	CSS-LP-3.0 Containment Spray System (In development)	COC System Training. Includes flowpaths, actuation signals, and interlocks.
		Containment Spray System Prelicense Review	Emphasis on operation and response to accidents.	EOP-LP-3.13 FRP-J.1, J.2	Specific steps and bases for FRP-J.1. Task required by procedure.
		Containment Spray (R086204) Requalification Training-1986	Emphasis on system mods, operation and interlocks.	RO Hot License Simulator Scenarios (In development)	Exercises requiring Spray Actuation.
		EOP Review Prelicense Review	FRP-J.1 reviewed.		
		EPPs-009, 010, 011 Continuing Training 1985 Week 1/Lesson 3	Review of steps and bases for EPPs 9, 10 & 11 (EPP-10 address alignment for recirculation).	SRO Hot License Simulator Scenarios (In development)	
		CLC-5-3-1 CLC-5-5-1, p. 11 CLC-6-1-1 CLC-8-2-2 CLC-8-3-1	Simulator Scenarios requiring use FRP-J.1 or CV Spray.		
		SS7221H SS7341H SS7342H			
6	Verify AFW Valves properly aligned.	AFS-LP-1.0 Auxiliary FW System	CLC Systems Training. Includes flowpaths, interlocks & pump operations.	AFS-LP-3.0 Auxiliary FW System (In development)	COC Systems Training. Includes flowpaths, interlocks & pump operations.
		ESWS-LP-1.0 Normal & Emergency Service Water	CLC Systems Training. Emergency water source for AFW.	ESW-LP-3.0 Normal and Emergency Service Water (In development)	CLC Systems Training. Emergency source for AFW.
		Auxiliary FW System Prelicense Review	Review of AFW operations.	EOP-L.P-3.1 Path-1, EPP-004, 008 (In development)	Specific steps and Bases for Path-1. Task required by procedure.
		Auxiliary FW System (R086205) Requalification Training - 1986	Interlocks and pump operations emphasized.	RO Hot License Simulator Scenarios (In development)	Exercises involving AFW failures.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training CLC-3-5-1A, pp. 2-4	Comments	Hot License Training SRO Hot License Simulator Scenarios	Comments
			Demo on SI Indications & verification. Each trainee walks through each role. (For scenario with SI actuation see Task #1).	(In development.)	
		CLC-6-3-1 CLC-8-1-1 SS7342H SS7242H	Simulator Exercises Involving AFW failures.		
7	Alignment of ESW on Safety Injection	ESWS-LP-1.0 Normal and Emergency Service Water	CLC Systems Training. Alignment for SI Included.	ESWS-LP-3.0 Normal and Emergency Service Water (In development)	COC Systems Training. Alignment for SI Included.
		Normal and Emergency Service Water Preliminary Review	Review of SW operation.	SEQ-LP-3.0 Safeguards Sequencer	COC Systems Training. List components started in each Load Block.
		Normal and Emergency Service Water (RQ86213) Requalification Training-1986	Flowpaths, pump operations and interlocks emphasized.	EOP-LP-3.1 Path-1, EPP-004, 008 (In development)	Specific steps and bases for Path-1. Task required by procedure.
		CLC-3-5-1A, pp. 2-4 SI Demonstration	Demo on SI Indications and verification. Each trainee walks through each role. (For scenarios with SI actuated see Task #1).	RO Hot License Simulator Scenarios (In development)	Exercises with ESW Failures.
		SS7221H SS7341H SS7421H	Simulator Exercises with ESW failures.	SRO Hot License Simulator Scenarios (In development)	
8	Maintaining RCP Seal Injection	CVCS-LP-1.0 Chemical Volume Control System	CLC Systems Training. Injection and return flowpath Included.	CVCS-LP-3.0 Chemical Volume Control System (In development)	COC Systems Training. Seal Injection and return path included.
		RCP-LP-1.0 Reactor Coolant Pumps	CLC System Training. RCP Seals & Seal Injection discussed.		

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		MCD-LP-1.0, pp. 3-6	Seal Degradation and steps of EPPs-1, 2 & 3 discussed. Task required by EPP-2.	RCS-LP-3.0 Reactor Coolant System	COC Systems Training. RCP seal construction and operations included.
		EOP Review Pre-license Review	Specific Steps of EPPs 1,2 & 3 discussed. Task required by EPP-2.	AOP-LP-3.11 AOP-018, 030 (To be developed)	Steps for AOP-018, Abnormal RCR Operations. Loss of seal Injection discussed.
		CLC-4-2-1A	Review of AOP-018, RCP Abnormal Ops. Loss of Seal Injection discussed.	EOP-LP-3.7 EPP-001, 002, 003 (In development)	Steps and bases for EPPs-001, 002, 003. Task required by EPP-002.
		CLC-6-5-1A	Review of AOP-014, Loss of CCM.		
		CLC-4-2-1B CLC-5-4-1B CLC-7-2-1 SS7113H	Simulator Scenarios involving RCP cooling malfunctions.	MCD-LP-2.9 Loss of All AC	SRO Mitigating Core Damage. Loss of RCP Seal Cooling Included.
		SS7142H SS7421H	Simulator Scenarios with Loss Seal Injection.	R0 Hot License Simulator Scenarios (In development)	Exercises Involving: 1) RCP seal cooling malfunctions 2) Loss of seal injection 3) Loss of all AC
		SS7312H	Simulator Scenario with loss of all AC.	SRO Hot License Simulator Scenarios (In development)	
9	Locally dumping steam using S/G PORVs	MSSS-LP-1.0, Section 2.2.3 Main Steam Supply System	CLC System Training. (Does <u>not</u> address manual ops. of S/G PORV).	MSSS-LP-3.0 Main Steam System (In development)	COC Systems Training.
		MCD-LP-1.3, Section 2.4 Loss of Feedwater Induced LOCAs	FRP-H.1 reviewed. Copy of Generic MOG Procedure included. Task required by procedure.	EOP-LP-3.10 FRP-C.1, C.2 and C.3 In development)	Specific steps and bases for for FRPs-C.1 and C.2. Task required by procedures.
		EOP-Review (Handout) Pre-license Review	Steps and bases reviewed for FRP-C.1, C.2 & H.1.	EOP-LP-3.11 FRP-H.1, H.2, H.3, H.4 & H.5 (In development)	Specific steps and bases for FRP-H.1. Task required by procedures.
		EOP Update Requalification Training-1986	Manual operation of S/G PORVs to be included in Week III.	MCD-LP-2.1 Small Break LOCA with NO HHSI	ICC Indications and strategies.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CLC-8-1-1	Simulator Scenarios Involving use of FRP-H.1. Task required by procedure.	MCD-LP-2.3	Reviews indications and strategies for loss of FW.
		SS7242H		Loss of Feedwater Induced LOCAs	
		SS57211H	Simulator Scenario Involving use of FRP-C.2.	RO Hot License Simulator Scenarios (In development)	Exercises Involving: 1) Use of FRP-C.1 2) Use of FRP-C.2 3) Use of FRP-H.1 4) Local control of S/G PORVs
				SRO Hot License Simulator Scenarios (In development)	
10	Verify proper operation of the Sequencer	SEQ-LP-1.0 Safeguards Sequencer	CLC System Training.	SEQ-LP-3.0 Safeguards Sequencer	COC System Training
		Sequences Operations, Prelicense Review	Review of operations.	EOP-LP-3.1 Path-1, EPP-004, 008	Specific steps and bases for Path-1. Task required by procedure.
		EOP Review Prelicense Review	Steps and bases for EPPs-001, 002 & 003. Task required by procedures.	EOP-LP-3.7 EPP-001, 002, 003	Specific steps and bases for EPPs-001, 002 & 003. Task required by procedures.
				RO Hot License Simulator Scenarios (In development)	Exercises Involving 1) Loss of off-site power 2) SI actuation
		CLC-3-5-1A, pp. 2-4	SI Demonstration. Each trainee practices each role.	SRO Hot License Simulator Scenarios (In development)	
		CLC-3-4-1/3-4-2A CLC-5-5-1	Exercises Involving: 1) Station Blackout w/EDG functioning 2) Loss of All AC		
11	Establishing Main FW Flow	CFW-LP-1.0 Sections 2.2.6 through 2.2.10, 2.4.6 through 2.4.10, & 2.4.13 Condensate and Feedwater	CLC Systems Training: Includes flowpath, components and I&C.	CFW-LP-3.0 Condensate and Feedwater (In development)	COC Systems Training Includes, flowpath, components permissives & interlocks.
		FW System Continuing Training - 1985 Week 1/Lesson 9	Flowpath, interlocks & permissives emphasized.	EOP-LP-3.11 FRP-H.1, H.2, H.3, H.4, H.5 (In development)	Specific steps and bases for FRP-H.1. Task required by procedure.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CND & FW System			
		ERA-01H Prelicense Review	CND & FW Review. Emphasis on valve interlocks and permissives.		
		FW System (R086201) Requalification Training-1986	Emphasis on interlocks & permissives.	MCD-LP-2.3 Loss of FW Induced LOCAs	Reviews indications and strategies for loss of FW.
		EOP Review (Handout) Prelicense Review	Bases & steps of FRP-H.1 reviewed. Task required by procedure.	RO Hot License Simulator Scenarios (In development)	Exercises involving use of FRP-H.1.
		CLC-8-1-1 SS7242H	Simulator Scenarios involving use of FRP-H.1.	SRO Hot License Simulator Scenarios (In development)	
12	Locally tripping turbine	EHC-LP-1.0, Section 2.5.1 Electrohydraulic Control.	CLC Systems Training. Includes Mechanical Overspeed Trip Mechanism and local trip.	EHC-LP-3.0 Electrohydraulic Control (In development)	COC Systems Training. Includes Mechanical Overspeed Trip Mechanism and local trip.
		T&AA-LP-1.20, Section 2.7 Anticipated Transient without Trip.	Bases for FRP-S.1 Included.	EOP-LP-3.15 FRP-S.1, S.2 (In development)	Specific steps and bases for FRP-S.1.
		EOP Review (Handout) Prelicense Review	Steps for FRP-S.1 reviewed. Task required by procedure.		
		CLC-2-4-1A, p.4	FRP-S.1 reviewed.	T&AA-LP-2.14 Anticipated Transient without Trip (In development)	ATWS analysis included for failure of turbine to trip.
		CLC-8-1-1	Simulator Scenario in which turbine fails to trip.	RO Hot License Simulator Scenarios (In development)	Exercises involving ATWS with failure of turbine to trip.
				SRO Hot License Simulator Scenarios (In development)	
13	Local Operation of Switchgear BKR's	6.9 KV-LP-1.0 6.9 KV Auxiliary	CLC Systems Training and OJT.	6.9KV-LP-3.0 6.9KV Auxiliary	COC Systems Training.
		480V-LP-1.0, 480V Auxiliary	CLC Systems Training and OJT.	480V-LP-3.0 480V Auxiliary	COC Systems Training.
		120VAC-LP-1.0 208/120 VAC	CLC Systems Training and OJT.		

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		120V UPS-LP-1.0 120V Uninterruptible Power	CLC Systems Training and OJT.		
		DCP-LP-1.0 DC Power	CLC Systems Training and OJT.		
		SACP-LP-1.0 Standby AC Power	CLC System Training and OJT. Emergency Diesel Generator.	120V-LP-3.0 208/120VAC (In development)	COC Systems Training.
		SEQ-LP-1.0 Safeguards Sequencer	CLC Systems Training.	UPS-LP-3.0 120V UPS	COC Systems Training.
		AOP-Review Requalification Training-1986	AOP-025, Loss of one 6.9 KV Emergency Bus or one DC Emergency Bus. To be covered in Week III.	DCP-LP-3.0 DC Power (In development)	COC Systems Training.
		Sequencer Operations, Prelicense Review	Includes Load shedding and reenergizing busses.	PLIS-LP-3.0 Plant Light System	COC Systems Training.
		PZR Heater Operations Prelicense Review	Effects of sequencer Operations on PZR Heater.	SEQ-LP-3.0 Safeguards Sequencer	COC Systems Training. Includes Load Shedding and and reenergizing busses.
		MCD-LP-1.10 Loss of All AC	EPPs-1, 2 & 3 Reviewed.	EOP-LP-3.7 EPP-001, 002, 003 (In development)	Specific steps and bases of EPPs-001, 002 & 003. Task required by procedure.
		AOP-004: Control Room Inaccessible Prelicense Review	Review of AOP-004. Walkthrough of ACP & Power Supplies. Requires operation of switchgear	AOP-LP-3.12 AOP-024, 025, 028, 029 (To be developed)	Steps of AOP-25, Loss of One 6.9 KV Emergency Bus or One DC Emergency Bus.
		AOP-004, (RQ86210) Requalification Training - 1986	Review of AOP-004. Requires local operation of switchgear.	RO Hot License Simulator Scenarios (In development)	Exercises Involving Loss of all AC.
		EOP-Review Prelicense Review	Includes specific steps of specific steps of EPPs-1, 2 & 3. Task required by procedures.	SRO Hot License Simulator Scenarios (In development)	
		CLC-3-3-2A, pp. 4-8	Simulator Review of EPP-1, 2 & 3.	AOP-LP-3.0 AOP-004	Steps and bases of AOP-004. Requires manual operations of switchgear.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		SS7312H SS7121H SS7442H SS7342H	Simulator Scenario with: 1) Loss of all AC, or 2) Use of AOP-25		
14	Check radiation NORMAL for RAB, SGs, Secondary and CNMT	RMS-HO-1.0 Radiation Monitoring System	CLC Systems Training.	RMS-LP-3.0 Radiation Monitoring System (To be developed)	COC Systems Training. Operations and response to alarms.
		RH-23, 11 & 80/Gen Atomic Rad Monitor Prelicense Review	Reviews operation and response to alarms.	AOP-LP-3.3 AOP-005 (To be developed)	Steps for AOP-005. Response for alarms specified.
		SAMP-LP-1.0, pp. 1-19 Sampling System	CLC System Training. Includes flowpath.	SAMP-LP-3.0 Sampling System (In development)	COC Systems Training. Includes flowpaths.
		CIS-LP-1.0 Containment Isolation System	CLC Systems Training. Lists valves receiving CIAS.	CIS-LP-3.0 Containment Isolation System	COC Systems Training. List valves receiving CIAS.
		LWPS-LP-1.0 Liquid Waste Processing System	CLC Systems Training. RCB Equipment Drain Subsystem Included.	PASS-LP-3.0 Post Accident Sampling System (In development)	COC System Training. Operation of PASS.
		Post Accident Sampling System Continuing Training - 1985 Week 2/Lesson 8	Continuing Training Lesson. . Operation of PASS.	LWPS-LP-3.0 Liquid Waste Processing System (To be developed)	COC System Training.
				AOP-LP-3.9 APP-016, 023, 031 (To be developed)	Steps for AOP-016, RCS Leakage, including leak identification strategies.
		CLC-1-1-1B, p. 6	CLC Simulator/SHNPP Differences including RMS.	RO Hot License Simulator Scenarios (To be developed)	Exercises involving use of RMS.
		SS7112H, p. 3	PLR Simulator/SHNPP Differences including RMS.	SRO Hot License Simulator Scenarios (To be developed)	
		CLC-3-4-2B, pp. 2-5	Review AOP-16, RCS Leakage, including Leak Identification strategies.		



1 2
3 4

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CLC-4-1-1A, pp. 4-6	Reviews SGTR Identification and use of RMS.		
		CLC-4-4-2B CLC-7-5-2 CLC-8-1-2 CLC-9-1-1 CLC-9-1-2 CLC-9-2-2 CLC-5-5-2 CLC-6-3-2 CLC-7-2-1 CLC-7-2-2 CLC-8-2-2	Simulator Scenarios including use of RMS.		
		SS7251H SS7232H SS7222H SS7211H SS7321H SS7322H SS7331H SS7332H SS7311H SS7442H SS7421H			
15	Identify a Ruptured S/G	SGTR: Plant Response Continuing Training - 1985 Week 1/Lesson 6	Primary and Secondary Response to SGTR.	EOP-LP-3.1 Path-2, EPP-016 (In development)	Specific steps and bases for Path-2 and EPP-016. Task required by procedure
		Path-2/EPP-16 Continuing Training - 1985 Week 1/Lesson 7	Specific steps and bases for Path 2 including identification of ruptured SG. Task required by procedure.	AOP-LP-3.3 AOP-005 (In development)	Steps and bases for AOP-005, RMS. Includes response to RMS alarms.
		SAMP-LP-1.0 Sampling System	CLC Systems Training.	AOP-LP-3.9 AOP-016, 023, 031 (In development)	Steps and bases for AOP-016, RCS Leakage.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX


Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CLC-3-4-2B, pp. 2 & 3	Reviews AOP-016, RCS Leakage, including methods of identification.	SAMP-LP-3.0 Sampling System (In development)	COC Systems Training.
		CLC-4-1-1A	Reviews SGTR Identification per Path-1.	RO Hot License Simulator Scenarios (In development)	Exercises with SGTRs.
		CLC-4-4-2	Exercises with SGTR.	SRO Hot License Simulator Scenarios (In development)	
		CLC-7-5-2			
		CLC-8-1-2			
		CLC-9-1-1			
		CLC-9-1-2			
		CLC-9-2-2			
		SS7251H			
		SS7321H			
		SS7322H			
		SS7331H			
		SS7332H			
		SS7311H			
		SS7442H			
16	Requesting samples from Chemistry - SG activity - RCS - Containment H ₂ - RCS Boron - Containment Sump	SAMP-LP-1.0 Sampling System	CLC Systems Training. Includes flowpaths.	SAMP-LP-3.0 Sampling System (In development)	COC System Training. Includes flowpaths.
		CIS-LP-1.0 Containment Isolation System	CLC Systems Training. Lists valves receiving CIAS.	PASS-LP-3.0 Post Accident Sampling System (In development)	COC Systems Training.
		LWPS-LP-1.0 Liquid Waste Processing System	CLC Systems Training. Includes RCB Equipment Drains Subsystem.	CIS-LP-3.0 Containment Isolation System	COC System Training. Lists valves receiving CIAS.
		GP-LP-1.5, p. 22	Relates that sampling is done by chemistry.	LWPS-LP-3.0 Liquid Waste Processing System (To be developed)	COC Systems Training. Includes RCB Equipment Drains Subsystem.
		MCD-LP-2.7 Post Accident Primary Radiochemistry	SRO Mitigating Core Damage Training. Describes changes in RCS chemistry and personnel hazards.	MCD-LP-2.7 Post Accident Primary Radiochemistry	SRO Mitigating Core Damage Training. Describes changes in RCS chemistry including personnel hazards.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		Post Accident Sampling System, Continuing Training - 1985 Week 2/Lesson 8	Continuing Training Lesson. Includes operation of PASS.	RT-LP-3.14 S/D Reactivity Considerations	RO Rx Theory Training. Includes SDM Calculations.
		T&AA-LP-1.7, Section 2.5 Normal Transient Analysis	Includes SDM Calculations.	RO Hot License Simulator Scenarios (To be developed)	Simulator Exercises Involving use of Sampling System.
		CLC-7-2-1, pp. 9 & 10 SS7411H	Exercises with failed fuel. Relates that chemistry does sampling.	SRO Hot License Simulator Scenarios (To be developed)	
		CLC-4-4-2B CLC-7-5-2 CLC-8-1-2 CLC-9-1-1 CLC-9-1-2 CLC-9-2-2 CLC-5-5-2 CLC-6-3-2 CLC-7-2-1 CLC-7-2-2 CLC-8-2-2 SS7251H SS7232H SS7222H SS7211H SS7321H SS7322H SS7311H SS7442H SS7421H	Exercises Involving uses of sampling systems.		
17	Monitoring Conditions Indicative of PZR PORV Leakage	PZR-LP-1.0 Pressurizer	CLC Systems Training. I&C Included.	PZR-LP-3.0 Pressurizer	COC System Training. I&C Included.
		RCS-LP-1.0 Reactor Coolant System	CLC System Training. PZR and PRT I&C Included.	RCS-LP-3.0 Reactor Coolant System	COC System Training. PZR and PRT I&C Included.

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training FF-LP-1.1, Sect 2.12.2	Comments Isenthalpic Process discussed	Hot License Training FF-LP-3.2, Section 2.5.2	Comments Isenthalpic Process discussed
		Fluid Flow: Fluid Mechanics In Pumps and Pipes	with examples using PZR PORVs leakage.	Fluid Flow: Fluid Mechanics In Pump and Pipes	with example using PZR PORVs.
		CLC-3-3-1A	Review of AOP-019, Malfunction of RCS Pressure Control. Includes Indication of PORV leakage.	AOP-LP-3.10 AOP-017, 019 (To be developed)	Steps and bases for AOP-019, Malfunction of RCS Pressure Control. Includes Indications of PORV Leakage.
		CLC-3-4-2B	Review of AOP-016, RCS Leakage.	AOP-LP-3.9 AOP-016, 023, 031	Steps and bases for AOP-016, RCS Leakage.
		CLC-4-5-2 CLC-5-2-2 CLC-7-2-2 CLC-8-1-2 SS7332H	Exercises Involving leaking or open PZR PORV.	RO Hot License Simulator Scenarios (In development) SRO Hot License Simulator Scenarios (In development)	Exercises Involving leaking or open PZR PORV.
18	Establish Auxiliary Spray	CVCS-LP-1.0 Chemical Volume Control System	CLC Systems Training. Flowpaths Included.	CVCS-LP-3.0 Chemical Volume Control System (In development)	COC Systems Training. Flowpaths Included.
		PZR-LP-1.0 Pressurizer	CLC Systems Training. Auxiliary Spray Included.	PZR-LP-3.0 Pressurizer	COC Systems Training. Aux Spray Included.
		EPP-022 Continuing Training - 1985 Week 2/Lesson 5	Specific steps and bases for EPP-022. Task required by procedure.	EOP-LP-3.6 EPP-005, 006, 007 (In development)	Specific steps and bases for EPPs-22. Task required by procedure.
		EPPs-005,006 & 007 Continuing Training - 1985 Week 2/Lesson 6	Specific steps and bases for EPPs-005, 006 & 007. Natural circulation cooldown requires auxiliary spray.	EOP-LP-3.8 EPP-005, 006, 007 (In development)	Specific steps and bases for EPPs-005, 006 & 007. N.C. cooldown requires auxiliary spray.
		GP-LP-1.7 Normal Plant Cooldown	Steps include use of auxiliary spray.	GP-LP-3.7 Normal Plant Cooldown	Steps include use of auxiliary spray.



ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CLC-2-3	Exercises involving use of		
		CLC-9-2-1 SS7121H SS7151H	auxiliary spray.		
		CLC-9-1-2 SS7311H	Exercises requiring use of EPP-22.		
19	Local tripping of Rx Trip Bkrs and MG sets	RODCS-LP-1.0, Section 2.4.6 Rod Control System	CLC Systems Training.	RODCS-LP-3.0 Rod Control System (In development)	COC Systems Training.
		EOP-Review (Handout) Pre-license Review	Steps and bases for FRP-S.1. Task required by procedure	EOP-LP-3.15 FRP-S.1, S.2	Specific steps and bases for FRP-S.1. Task required by procedure.
		CLC-2-4-1A	Review of FRP-S.1.	RO Hot License Simulator Scenarios (In development)	Exercises using FRP-S.1.
		CLC-2-5-2B CLC-4-2-1B CLC-4-3-1B/4-3-2 CLC-6-2 CLC-8-1-1	Exercises involving use of FRP-S.1.	SRO Hot License Simulator Scenarios (In development)	
20	Verification of CMT Isolation	CVS-LP-1.0 Containment Ventilation System	CLC Systems Training. Response to CIAS Included.	CVS-LP-3.0 Containment Ventilation System	COC Systems Training. Response to CIAS Included.
		CAVES-LP-1.0 Containment Atmosphere Purge and Exhaust	CLC Systems Training. Response to CIAS Included.	CIS-LP-3.0	COC Systems Training. List of valves receiving CIAS Included.
		CIS-LP-1.0 Containment Isolation System	CLC Systems Training. List of valves receiving CIAS Included.	EOP-LP-3.12 FRP-1.1, 1.2, 1.3	Specific steps and bases of FRP-1.3. Task required by procedure.
		Containment Ventilation System Prelicense Review	Includes operations and Plant Mods.	RO Hot License Simulator Scenarios (In development)	Exercises with SI actuation. (See Task #1).
		EOP-Review Prelicense Review	Specific steps for FRP-1.3 discussed. Task required by procedure.	SRO Hot License Simulator Scenarios (In development)	

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		CLC-3-5-1A	SI Demonstration. Each trainee walks through each role for SI actuation. (See Task #1 for exercises with SI actuation).		
21	Establishing Blowdown from S/Gs.	<p>SGBS-LP-1.0 S/G Blowdown System</p> <p>SG-LP-1.0 Steam Generator</p> <p>EPPs-017, 018, 019 Continuing Training-1985 Week 1/Lesson 8</p> <p>EOP-Review (Handout) Prelicense Review</p>	<p>CLC Systems Training.</p> <p>CLC Systems Training.</p> <p>Steps and bases of EPP-018 reviewed. BD used to depressurize ruptured S/G.</p> <p>Steps for FRP-H.5, Reponse to S/G High Level. Task required by procedure.</p>	<p>SGBS-LP-3.0 S/G Blowdown System</p> <p>SG-LP-3.0 Steam Generators</p> <p>EOP-LP-3.11 FRP-H.1, H.2, H.3, H.4 & H.5</p>	<p>COC Systems Training.</p> <p>COC Systems Training.</p> <p>Specific steps and bases for FRP-H.5. Task required by procedure.</p>
22	Try to Identify & Isolate leak	<p>CLC-3-4-2B, pp. 2 & 3</p> <p>RMS-H0-1.0</p> <p>RM-23, 11 & 80/Gen Atomic Rad Monitors Prelicense Review</p> <p>EPP-20 & 21 Continuing Training-1985 Week 2/Lesson 4</p> <p>CLC-7-5-2 CLC-8-1-2 CLC-9-2-2 SS7322H SS7331H</p>	<p>Review of AOP-16, RCS Leakage, and discussion of methods of identifying leakage.</p> <p>CLC Systems Training.</p> <p>Operation of RMS reviewed. Walk through included.</p> <p>Specific Steps of EPPs-20. Task required by procedure.</p> <p>Simulator Scenarios in which EPP-20 implemented.</p>	<p>EOP-LP-3.5 EPPs-20 & 21 (In development)</p> <p>RMS-LP-3.0 Radiation Monitoring System (In development)</p> <p>AOP-LP-3.9 AOPs-016, 023, 031 (To be developed)</p> <p>AOP-LP-3.3 AOP-005 (To be developed)</p> <p>RO Hot License Simulator Scenarios (In development)</p> <p>SRO Hot License Simulator Scenarios (In development)</p>	<p>Specific steps and bases for for EPP-20. Task required by procedure.</p> <p>COC Systems Training. RMS used in leak identification.</p> <p>Steps for AOP-16, RCS Leakage. Leak identification strategies included.</p> <p>Steps for AOP-005, RMS, Response for alarms specified.</p> <p>Exercises requiring use of EPP-20.</p>

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
	Minimize secondary contamination	SGTR: Radiological Consequences Continuing Training - 1985 Week 1/Lesson 3	Includes mechanisms of radionuclide transport and actions to minimize.	EOP-LP-3.2 Path-2/EPP-16 (In development)	Specific steps and bases for Path-2. Task required by procedure.
		RM-23, 11 & 80/Gen Atomics Rad Monitor Prelicense Review		AOP-LP-3.3 AOP-005	Steps reviewed for AOP-005. AOP-005 includes actions that minimize contamination
		MSSS-LP-1.0 Main Steam System	CLC Systems Training. Secondary Systems effected by contamination. Knowledge of flowpaths aids operator in taking action to accomplish task.	MSSS-LP-3.0 Main Steam System	CLC Systems Training. Secondary Systems potentially effected by contamination. Knowledge of flowpaths aids operator in taking action to accomplish task.
		SDS-LP-1.0 Steam Dump System		SDS-LP-3.0 Steam Dump System	
		CFW-LP-1.0 CND and FW Systems MSR-LP-1.0 MSR & FW HTRS		CFW-LP-3.0 CND and FW Systems MSR-LP-3.0 MSR and FW HTRS	
		MCES-LP-1.0 Main Condenser Evacuation System		MCES-LP-3.0 Main Condenser Evacuation System	
		MTSS-LP-1.0 Main Turbine Sealing Steam and Exhaust		MTSS-LP-3.0 Main Turbine Sealing Steam and Exhaust	
		CPDS-LP-1.0 Condensate Polishing & Demineralizing System		CPDS-LP-3.0 Condensate Polishing & Demineralizing System	
		Path-2/EPP-016 Continuing Training - 1985 Week 1/Lesson 7	Specific steps and bases for Path-2. Task required by procedure.	RO Hot License Simulator Scenarios (In development)	Exercises with SGTRs.
		EOP Update Requalification Training-1986	Actions added to procedures discussed. Included in Week III.	SRO Hot License Simulator Scenarios (In development)	

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments		
		CLC-4-4-2	Exercises Involving SGTRs.	RWO Qual Cards	Steps to:		
24	Evaluate Plant Status	CLC-7-5-2	CLC-9-1-1 involves a SGTR with the associated MSIV stuck open. Path-2 specifies actions that minimizes secondary contamination for that situation. Some of the actions are applicable for SGTRs in general.	1) QC 05.84H Performance III.15 2) QC 08.80H Performance III.5	1) Isolate Main Steam to Auxiliary Steam 2) Place CND Polishing System In service		
		CLC-8-1-2					
		CLC-9-1-1					
		CLC-9-1-2					
		CLC-9-2-2					
		SS7251H					
		SS7321H				AO Qual Card	Steps to:
		SS7322H					1) Isolate Main Steam to Auxiliary Steam
		SS7331H					2) Isolate Hotwell spillover to CST
		SS7332H					3) Place CVPETS In service
	SS7311H						
	SS7442H						
	GP-LP-1.0, Sections 2.24 & 2.25 Conduct of Operations	Procedures Training on Conduct of Operations. Continual evaluation of plant status and use of redundant instrumentation is emphasized.	PP-LP-3.0 OMM-001, 009	RO Procedures Training. OMM-1, Conduct of Operations, discusses Continual evaluation of plant status and emphasizes use of redundant instrument.			
	CLC-1-1-2, pp. 2-5	Conduct of Operations Reviewed.	ADOP-LP-2.0, SRO Duties and Responsibilities	SRO Advanced Operating Procedures Training. Conduct of Operations reviewed.			
	Cover sheet for simulator Exercise Guides	Evaluates shift Conduct of Operation for each exercise.					
	MCD-LP-1.1 Post Accident Cooling	Mitigating Core Damage Course describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies	MCD-LP-2.1 Post Accident Cooling	Mitigating Core Damage Course describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies			
	MCD-LP-1.2 Small Bkr LOCA with no HSI		MCD-LP-2.2 Small Bkr LOCA with no HSI				
	MCD-LP-1.3 Loss of FW Induced LOCAs		MCD-LP-2.3 Loss of FW Induced LOCA				
	MCD-LP-1.4 Vital Process Instrumentation		MCD-LP-2.4 Vital Process Instrumentation				

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		MCD-LP-1.5 Accident Response of Incore Instrumentation		MCD-LP-2.5 Accident Response of Incore Instrumentation	
		MCD-LP-1.6 Accident Response of Excore Instrumentation		MCD-LP-2.6 Accident Response of Excore Instrumentation	
		MCD-LP-1.7 Post Accident Primary Radiochemistry		MCD-LP-2.7 Post Accident Primary Radiochemistry	
		MCD-LP-1.8 Radiological Aspects of Core Damage		MCD-LP-2.8 Radiological Aspects of Core Damage	
		MCD-LP-1.9 Loss of All AC Power		MCD-LP-2.9 Loss of All AC Power	
		MCD-LP-1.10 Class 9 Events			
		MCD-LP-1.11 Instrument Qualification and Accident Response			
		EOP-020 & 021 Continuing Training - 1985 Week 2/Lesson 4	Steps and bases for EPP-20. Task required by procedure.	EOP-LP-3.5 EPPs-020, 021	Specific steps and bases for EPP-020. Task required by procedure.
		CLC-7-5-2 CLC-8-1-2 CLC-9-2-2 SS7322H SS7331H	Simulator Scenarios requiring use of EPP-20. (Note: Almost all simulator exercises require use of task).	RO Hot License Simulator Scenarios (In development) SRO Hot License Simulator Scenarios (In development)	Exercises involving EPP-020. (Note: Almost all simulator exercises require use of task.)
25	Evaluate Plant Equipment	CLC Systems Training Continuing Training - 1985 Prelicense Review Training Requalification Training-1986	Operations of all system covered in CLC Training. Reviews and updates covered in Continuing Training, Prelicense Review and Requalification Training.	COC Systems Training	Operations of all systems, including the Operating Procedures, covered in COC Training.



ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		MCD-LP-1.1	Mitigating Core Damage Course	MCD-LP-2.1	Mitigating Core Damage Course
		Post Accident Cooling	describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies	Post Accident Cooling	describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies
		MCD-LP-1.2		MCD-LP-2.2	
		Small Bkr LOCA with no HHSI		Small Bkr LOCA with no HHSI	
		MCD-LP-1.3		MCD-LP-2.3	
		Loss of FW Induced LOCAs		Loss of FW Induced LOCA	
		MCD-LP-1.4		MCD-LP-2.4	
		Vital Process Instrumentation		Vital Process Instrumentation	
		MCD-LP-1.5		MCD-LP-2.5	
		Accident Response of Incore Instrumentation		Accident Response of Incore Instrumentation	
		MCD-LP-1.6		MCD-LP-2.6	
		Accident Response of Excore Instrumentation		Accident Response of Excore Instrumentation	
		MCD-LP-1.7		MCD-LP-2.7	
		Post Accident Primary Radiochemistry		Post Accident Primary Radiochemistry	
		MCD-LP-1.8		MCD-LP-2.8	
		Radiological Aspects of Core Damage		Radiological Aspects of Core Damage	
		MCD-LP-1.9		MCD-LP-2.9	
		Loss of All AC Power		Loss of All AC Power	
		MCD-LP-1.10			
		Class 9 Events			
		MCD-LP-1.11			
		Instrument Qualification and Accident Response			

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX


Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		EPP-020 & 021	Steps and bases of EPP-20.		
		Continuing Training - 1985 Week 2/Lesson 4	Task required by procedure.		
		SS7114H SS7121H	Simulator Scenarios Involving multiple failures of RHR, CCH, etc. Operators are required to evaluate equipment status and initiate recovery with available systems.	EOP-LP-3.5 EPP-020, 021 (In development)	Specific steps and bases for EPP-20. Task required by procedure.
		CLC-7-5-2 CLC-8-1-2 CLC-9-2-2	Simulator Scenarios In which EPP-20 is required. (Note: Almost all simulator exercises require task.)	SRO Hot License Simulator Scenarios (In development)	
26	Start additional plant equipment to assist in recovery	CLC Systems Training	Each accident requires operation of a unique set of systems. Any system that might be required is taught in systems training.	COC Systems Training	Each accident requires a unique set of systems be put into operation. Any system that might be required is taught in COC Systems Training including associated OPs and AOPs.
		MCD-LP-1.1 Post Accident Cooling	Mitigating Core Damage Course describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies	MCD-LP-2.1 Post Accident Cooling	Mitigating Core Damage Course describes: 1) plant response to accidents 2) strategies for assessing damage 3) strategies for recovery 4) equipment required to implement recovery strategies
		MCD-LP-1.2 Small Bkr LOCA with no HSI		MCD-LP-2.2 Small Bkr LOCA with no HSI	
		MCD-LP-1.3 Loss of FW Induced LOCAs		MCD-LP-2.3 Loss of FW Induced LOCA	
		MCD-LP-1.4 Vital Process Instrumentation		MCD-LP-2.4 Vital Process Instrumentation	
		MCD-LP-1.5 Accident Response of Incore Instrumentation		MCD-LP-2.5 Accident Response of Incore Instrumentation	

ATTACHMENT #2 EMERGENCY PROCEDURES TASK TRAINING MATRIX

Task Number	Task	Cold License Training	Comments	Hot License Training	Comments
		MCD-LP-1.6		MCD-LP-2.6	
		Accident Response of Excure Instrumentation		Accident Response of Excure Instrumentation	
		MCD-LP-1.7		MCD-LP-2.7	
		Post Accident Primary Radiochemistry		Post Accident Primary Radiochemistry	
		MCD-LP-1.8		MCD-LP-2.8	
		Radiological Aspects of Core Damage		Radiological Aspects of Core Damage	
		MCD-LP-1.9		MCD-LP-2.9	
		Loss of All AC Power		Loss of All AC Power	
		MCD-LP-1.10			
		Class 9 Events			
		MCD-LP-1.11			
		Instrument Qualification and Accident Response			
		EPP-20	Specific steps of EPP-20.		
		Continuing Training	Tasks required by procedure.		
		Week 2/Lesson 4			
		SS7114H	Simulator Scenarios involving multiple failures of RHR, CCH, etc. Operators are required to evaluate plant status and initiate recovery with <u>available</u> systems.	EOP-LP-3.5	Specific steps and bases for EPP-20. Tasks required for procedure.
		SS7121H		EPP-20 & 21 (In development)	
				RO Hot License Simulator Scenarios (In development)	Exercises requiring use of EPP-20. (Most simulator scenarios require task).
		CLC-7-52	Simulator scenarios in which EPP-20 implemented. (Most simulator scenarios require task).		
		CLC-8-1-2		SRO Hot License Simulator Scenarios (In development)	
		CLC-9-2-2			
		SS7322H			
		SS7331H			

ATTACHMENT 3
ADDITIONAL COLD LICENSE TRAINING

<u>Task</u>	<u>Comments</u>
Locally Dumping steam using S/G PORVs	Manual operation of S/G PORVs will be described and procedure reviewed. A walkthrough of operations will be conducted. Local operations on the S/G PORV have been incorporated into the applicable nonlicense Qualification Card.
Minimize Secondary Contamination	Actions that are being incorporated in the revised EOPs will be described. Manual actions that require local operations have been incorporated into the applicable non-licensed Qualification Cards.
Local Operation of Switchgear BKR's	Electrical plant response to SI and LOSP will be discussed including requirement to monitor conditions and manipulate switchgear



ATTACHMENT 4
SIMULATOR SCENARIOS

1. CLCL-7-2-2: Load Rejection/ATWS/RCS Depressurization
2. CLCL-7-5-2: S/G Tube Leak/Rupture/ATWS/S/G PORV Failed Open
3. SS7421H: Inadvertent SI/SW Malfunctions/LOCA without CSIPs

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100



EXERCISE: Load Rejection/ATWS/RCS
Depressurization

FILE NO. CLC-7-2-2

TIME: 4 hours

OBJECTIVES: Upon completion of this exercise, the student will be able to:

1. Perform a power escalation without violating any tech spec or administrative limits.
2. Take appropriate actions on load rejection without steam dumps to stabilize plant in a safe condition.
3. Identify an ATWS event and take actions to prevent core damage and radioactive releases to the environment.
4. Identify a failed open PZR PORV and take corrective actions to stop RCS depressurization.

RELATED LER's, UER's, POER's, etc:

Salem ATWS SEP 14, 83 (2/83) - Breakers failed open (UV part of mechanical latch)

INITIAL CONDITIONS: IC-7 (BOL) . Present

Present power 8 hours

51%

571

875

174 D

PWR

T_{avg}

Boron

Rod Hgt

Previous

100%

586

839

208 D

INSTRUCTOR GUIDE:

Update PRODAC. Increase R_x power to 100%. FI-122A failure (low) causes actual charging flow to increase. CSIP failure requires placing "C" pump in service. External load breakers opening with no auto dumps should cause reactor first out (Lo-Lo S/G Lvl). ATWS causes RCS pressure to increase. When spray valves open, fail PCV-444B open. (Note: Do not trip R_x remotely until PORV opened). RCS will become saturated and remain saturated until block valve closed. Allow block valve to close after I&C and maintenance investigates. (Upon completion of exercise, reset for shift turnover per CLC-7-2-1).

SHIFT TURNOVER INFORMATION:

Decreased power to 50% for feed pump maintenance. Feed pump tested and running.

MALFUNCTIONS		OVERRIDES		REMOTE OPS
T-0	All Auto Reactor Trip Functions (Disabled)	T-0	PZR PORV Iso Vlv 8000C (Open)	
T-0	Auto Steam Dump Controller (Inhibited)	T-50	FI-122 A Charging Header Flow (Low)	
T-0	Manual Reactor Trips (Disabled)	T-90	Charging Pump "A" (Stop)	
T-120	External Load Breakers 52-8 & 52-9 (Open)	T-VAR	PCV-444B Pressurizer Relief Valve (Open-- Fail when sprays open)	

SUPPLEMENTAL INFORMATION:

Charging Flow - Transmitter failure

Charging Pump "A" - Motor bearing seized

External Load Breakers - Phase differential relay


PCV-444B - Controller failure/valve jammed on backseat

Block Valve - Breaker tripped (overcurrent relay failed)

ATWS - Trip breaker binding/improper lubrication

EXPECTED RESPONSE: AS PER SERIAL RELATED CHECKOFF

SUCCESSFUL COMPLETION OF THIS EXERCISE FULFILLS THE FOLLOWING NRC AND INPO REQUIREMENTS: 5B, 5D, 17, 18, 19, 8, 10, 16, 20, 21, 23, 24



SIMULATOR EXERCISE PERFORMANCE/OBSERVATION RECORD

Course _____ Group _____ Date _____

Instructors _____

Grading: S = Satisfactory U = Unsatisfactory

I. Exercise _____


A. Initial Conditions/Scenario - exercise guide _____

B. Shift Assignments	R _y S/U		Manipulations	
	Per.	Sup.	Per.	Sup.
1. SF _____	_____	_____	_____	_____
2. SRO _____	_____	_____	_____	_____
3. RO _____	_____	_____	_____	_____
4. BOP _____	_____	_____	_____	_____
5. STA _____	_____	_____	_____	_____

II. Evaluation

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>STA</u>
--	-----------	------------	-----------	------------	------------

A. General					
1. Supervisory ability--					
a. Effective supervision of others	_____	_____	_____	_____	_____
b. Effective direction of other	_____	_____	_____	_____	_____
2. Operator communications--passes along information accurately and promptly	_____	_____	_____	_____	_____
3. Annunciator response--immediately responds--uses alarm procedure	_____	_____	_____	_____	_____
4. Use of procedures--pulls procedure and utilizes	_____	_____	_____	_____	_____
5. Systematic and logical approach to problems	_____	_____	_____	_____	_____
6. a. Attentive to instrumentation and controls			_____	_____	
b. Compares redundant channels			_____	_____	
c. Compares meter to recorder			_____	_____	
7. Alertness--aware of plant status at all times	_____	_____	_____	_____	_____
B. Shift Turnover					
1. Oral turnover	_____	_____	_____	_____	_____
2. Hourly logs	_____	_____	_____	_____	_____
3. Review control board	_____	_____	_____	_____	_____
4. Test annunciator lights	_____	_____	_____	_____	_____



C. Exercise Performance

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>ST</u>
1. <u>Power Escalation 50% to 100%</u>					
a. Maintains T_{avg}/T_{ref}	_____	_____	_____	_____	_____
b. Turbine Load Limits	_____	_____	_____	_____	_____
c. Generator Loading (MVARs)	_____	_____	_____	_____	_____
d. S/G Level Control	_____	_____	_____	_____	_____
e. MSR Operation	_____	_____	_____	_____	_____
f. Maintains CAOC	_____	_____	_____	_____	_____
g. Anticipates Xenon Transients	_____	_____	_____	_____	_____
h. Uses Curves	_____	_____	_____	_____	_____
i. Secondary Calorimetric at 90%	_____	_____	_____	_____	_____
2. <u>Charging Flow Indicator Failure(low)</u>					
a. Immediate Actions					
(1) Identifies Charging Flow Low	_____	_____	_____	_____	_____
(2) Identifies Charging Pump Running	_____	_____	_____	_____	_____
(3) Verifies PZR Level Increasing	_____	_____	_____	_____	_____
(4) Takes Manual Control of FCV-122	_____	_____	_____	_____	_____
b. Subsequent Actions					
(1) Stabilizes Plant	_____	_____	_____	_____	_____
(2) Maintains RZR Programmed Level	_____	_____	_____	_____	_____
(3) Investigates Cause	_____	_____	_____	_____	_____
3. <u>Charging Pump "A" Trip</u>					
a. Immediate Actions					
(1) Acknowledge Annunciators	_____	_____	_____	_____	_____
(2) Starts "B" Pump	_____	_____	_____	_____	_____
b. Subsequent Actions					
(1) Stabilizes Plant With PZR Level In Band	_____	_____	_____	_____	_____
(2) Refers to Tech Specs	_____	_____	_____	_____	_____
(3) Investigates Cause	_____	_____	_____	_____	_____
(4) Initiates Request to Place "C" Pump in Service	_____	_____	_____	_____	_____
4. <u>Generator Breakers Open</u>					
a. Identification					
(1) Generator Output OCBs Open	_____	_____	_____	_____	_____
(2) Rapid Load Decrease to Unit Auxiliary Loads	_____	_____	_____	_____	_____
(3) Increased S/G Pressure	_____	_____	_____	_____	_____
(4) Inward Rod Motion	_____	_____	_____	_____	_____
b. Immediate Actions					
(1) Verifies Automatic Actions	_____	_____	_____	_____	_____
(2) Observes Failure of Steam Dumps	_____	_____	_____	_____	_____
(3) Verifies S/G PORVs Open	_____	_____	_____	_____	_____
(4) Refers to AOP-15	_____	_____	_____	_____	_____
(5) Places Steam Dumps in Pressure Control	_____	_____	_____	_____	_____
c. Subsequent Actions					
(1) Stabilizes Plant	_____	_____	_____	_____	_____
(2) Investigates Cause	_____	_____	_____	_____	_____

C. Exercise Performance (continued)

SF

SRD

RD

BOP

STA

- (3) Transfers Aux Loads
- (4) Identifies ATWS

5. ATWS

a. Immediate Actions

- (1) Attempts To Manually Trip R_x
- (2) Drives Rods In
- (3) Sends Personnel To
 - (a) Trip MG Sets
 - (b) Trip R_x Trip Breakers
 - (c) Trip MG Set Supply Breakers
- (4) Emergency Borate
- (5) Refers to FPP-1, FPP-2, or FRP-S.1

b. Subsequent Actions

- (1) Investigate Cause
- (2) Initiates PEP (Alert)

6. Reactor Trip

a. Immediate Actions

- (1) Verifies R_x Trip
- (2) Verifies Turbine Trip
- (3) Checks Power to AC Emergency Buses
- (4) Checks SI Actuated
- (5) Refers to FPP-1 or FPP-2

b. Subsequent Actions

- (1) Verifies Plant Parameters Stabilizing at No-load Values
 - (a) T_{avg}
 - (b) S/G Level
 - (c) PZR Pressure and Level
- (2) Conducts "Dead-Bus" Transfer to S/U Transformers
- (3) Verifies Source Range Energized
- (4) Secures Unnecessary Equipment
- (5) Stabilizes Plant at No-load Conditions


7. PZR PORV Failure

a. Identification

- (1) PZR Pressure Decreasing
- (2) Relief Line Temp Increase/Alarm
- (3) PORV Indicates Open
- (4) PRT Parameters Increasing
- (5) PZR Sprays Indicate Open

b. Immediate Actions

- (1) Attempts To Close Block PORV
- (2) Energizes Heaters
- (3) Refers to AOP-19
- (4) Observes SI Initiates



C. Exercise Performance (continued)

SF

SRD

RD

BOP

STA

c. Subsequent Actions

- (1) Investigates Failure of Block Valve
- (2) Closes after I&C Repair

8. Safety Injection

- a. Refers to FPP-1 or FPP-2
- b. Performs Immediate Actions
- c. Stops RCPs (1400 psig)
- d. Verifies Plant Recovery
- e. Identifies Cause
- f. Terminates SI When Criteria Met

_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

9. Natural Circulation


- a. Identification
 - (1) No RCPs Running
 - (2) Heat Sink Available
- b. Subsequent Actions
 - (1) Refer To EPP-5
 - (2) S/G Press < 1110 psig
 - (3) RCS 40°F
 - (4) RCS Δ T < 60°F

_____	_____	_____	_____	_____
-------	-------	-------	-------	-------

10. Added Malfunctions


- a. _____
- b. _____
- c. _____
- d. _____

_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____



C. Exercise Performance (continued)

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>STA</u>
5. <u>S/G Tube Leak</u> 150 gpm					
a. Identification					
(1) Increased Charging Flow	_____	_____	_____	_____	_____
(2) Leak Rate OST Performed					
(3) RMS increase R-19					
(4) Performs Leak Isolation or Identifies Source					
(5) Checks all Instrumentation					
b. Immediate Actions					
(1) Determines Appropriate S/G	_____	_____	_____	_____	_____
(2) Checks Tech Specs					
(3) Commences R _x S/D					
(4) Shifts Condenser Exhaust					
(5) Refers to AOP-16					
(6) Observes Blowdown Isolated					
6. <u>ATWS</u>					
a. Immediate Actions					
(1) Attempts to Manually Trip R _x	_____	_____	_____	_____	_____
(2) Drives Rods In					
(3) Sends Personnel to Trip R _x Breakers					
(4) Emergency Borate					
(5) Refers to FRP-S.1					
b. Subsequent Actions					
(1) Investigates Cause	_____	_____	_____	_____	_____
(2) Initiates PEP (Alert)					
7. <u>Reactor Trip</u>					
a. Immediate Actions					
(1) Verifies R _x Trip	_____	_____	_____	_____	_____
(2) Verifies Turbine Trip					
(3) Checks Power to AC Emergency Buses					
(4) Checks SI actuated					
(5) Refers to FPP-1 or FPP-2					
b. Subsequent Actions					
(1) Verifies Plant Parameters Stabilizing at No-load values	_____	_____	_____	_____	_____
(a) T _{avg}					
(b) S/G level					
(c) PZR Pressure and Level					
(2) Verifies Transfer to SU Transformers					
(3) Verifies Source Range Energized					
(4) Secures Unnecessary Equipment					
(5) Stabilizes Plant at No-load Conditions					



FILE NO. CLC-7-5-2

C. Exercise Performance (continued)	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>STA</u>
c. Initiates PEP (unusual event)	_____	_____	_____	_____	_____
8. <u>Safety Injection/S/G PORV Failed Open</u>					
a. <u>Completes Immediate Actions of FPP-1 or FPP-2</u>	_____	_____	_____	_____	_____
(1) Identifies RHR Pump A Tripped	_____	_____	_____	_____	_____
(2) Restarts RHR Pump A	_____	_____	_____	_____	_____
b. Identifies SGTR as Cause	_____	_____	_____	_____	_____
c. Identifies Ruptured S/G	_____	_____	_____	_____	_____
d. Isolates Ruptured S/G	_____	_____	_____	_____	_____
e. Identifies S/G PORV Failed Open	_____	_____	_____	_____	_____
f. <u>Begins RCS Depressurization and Cooldown</u>	_____	_____	_____	_____	_____
g. <u>Maintains Ruptured S/G Level Between 10% and 50%</u>	_____	_____	_____	_____	_____
h. <u>Implements FPP-17</u>	_____	_____	_____	_____	_____
(1) Resets SI/Phase A	_____	_____	_____	_____	_____
(2) <u>Cooldowns to 200°F at < 100°F/hour</u>	_____	_____	_____	_____	_____
(3) <u>Depressurizes to Minimize RCS Subcooling at 40°F</u>	_____	_____	_____	_____	_____
(4) Maintains PZR Level	_____	_____	_____	_____	_____
(5) Terminates SI	_____	_____	_____	_____	_____
(6) Restores LP and Charging	_____	_____	_____	_____	_____
(7) Isolates Accumulator	_____	_____	_____	_____	_____
9. <u>Intermediate Range Undercompensated</u>					
a. <u>Identifies Undercompensation</u>	_____	_____	_____	_____	_____
b. <u>Manually Energizes Sources Ranges</u>	_____	_____	_____	_____	_____
10. <u>Added Malfunctions</u>					
a. _____	_____	_____	_____	_____	_____
b. _____	_____	_____	_____	_____	_____
c. _____	_____	_____	_____	_____	_____



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

[Faint, illegible text covering the majority of the page, possibly bleed-through from the reverse side.]

D. Simulator Exercise Comments:

Lined area for handwritten simulator exercise comments.

Vertical text on the left margin, possibly a page number or header.

Horizontal text in the upper middle section of the page.

Horizontal text in the lower middle section of the page.

E. Exercise Critique:

SRO - S/U

RO - S/U

Eval. - S/U

SF - S/U


BOP - S/U

STA - S/U

Overall Group

F. Student Comments/Simulator Improvement:

Instructor's Signature



SHNPP SIMULATOR EXERCISE GUIDE

EXERCISE: Inadvertent SI/SW Malfunctions
LOCA W/O CSIPs

LESSON CODE: SS7421H

OBJECTIVES: Upon completion of this exercise, the student will be able to:

1. Perform the immediate actions required of operators following a R_x trip and SI.
2. Use the EOP network inclusive of the Flow Paths, End Path Procedures and Foldouts to direct operator actions.
3. Complete the appropriate attachments of OMM-004 following an activation of the ESFAS.
4. Identify a need to and make notifications required by the PEP.
5. Identify a stuck control rod and make required adjustments in shutdown margin.
6. Use AOP-001 to correct for a stuck control rod.
7. Use available MCB indications plus requested information to identify a leak from the CCW to ESW system.
8. Use OWPs to place the protective cabinets in the correct alignment as required by Tech Specs following an instrument failure.
9. Detect and take corrective action for a failure of the steam dumps to control temperature.
10. Use EPP-001 to mitigate the consequences of a loss of both CSIPs in conjunction with a small break LOCA.

<u>INITIAL CONDITIONS:</u> IC 43 ()	<u>Present</u>		<u>Previous</u>
Present conditions for: >100 Hrs	100%	PWR	
	588°F	T _{avg}	same
	527ppm	Boron	
	"D" at 192 steps	Rod Hgt.	

SHIFT TURNOVER INFORMATION: Presently on line within one day of exceeding CP&Ls Nuclear on-line record. No surveillances scheduled. No testing allowed. Anticipate no changes CSIP under clearance for bearing replacement. "C" CSIP will be available in six hours, two hours into action statement.

INSTRUCTOR GUIDE: Reset to IC 43, reboot RMS, ERFIS and conduct shift turnover. With lamp test complete override the Vacuum pump trip alarms to off and the operating vacuum pump red light to "on". Fail the operating vacuum pump. When requested, report the motor operating but a drastic drop in noise level (coupling sheared). With stability restored insert the inadvertent SI. After restoration have the SF complete an OMM-004. With this report ongoing insert the CCW-ESW leak. With trouble shooting ongoing and temperature restored to 557 fail P-12. Allow both conditions to run their course and be corrected. With all systems restored to normal fail the operating CSIP. Give time for immediate action and fail the seal stack on any RCP (insert ≈ 100 gpm leak to provide the leakage of the seal failure). If EPP-001 not addressed the instructor should prod in that direction before the situation degrades too far.

1000

MALFUNCTIONS	OVERRIDES	REMOTE OPS.
T-0 CRF3A untripable for P-8		
T-0 CRF3A untripable for K-14		
T-15 CND4A(B) to active	T-0 CND 94 (99) to low	T-0 CSIP racking status
T-30 SIS 1 to activate	T-0 CND 104 to low	
T-75 CCW 3 to 30 gpm	T-0 CNE 28 (29) D to "hi"	
T-90 MSS9 to fail		
T-120 CVC 5 for operating unit		
TVAR RCS14A(B)(C) to 60 gpm		
TVAR RCS15A(B)(C)		
TVAR RCS16A(B)(C)		

SUPPLEMENTAL INFORMATION:

1. Inadvertent SI to ensure completion of OMM-004 prior to Exam.
2. Vacuum Pump coupling break occurred at HBR.
3. Loss of both CSIPs to use EPP-001 for this condition.

EXPECTED RESPONSE: AS PER SERIAL RELATED CHECKOFF

SUCCESSFUL COMPLETION OF THIS EXERCISE FULFILLS THE FOLLOWING NRC AND INPO REQUIREMENTS: 5C, 11, 17, 19, 24



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side. The text is scattered across the page and is not readable.]

SIMULATOR EXERCISE PERFORMANCE/OBSERVATION RECORD

Course _____ Group _____ Date _____

Instructors _____

Grading: S = Satisfactory U = Unsatisfactory

I. Exercise _____


A. Initial Conditions/Scenario - exercise guide _____

B. Shift Assignments	R _x S/U		o Manipulati	
	Per.	Sup.	Per.	SU
1. SF _____	_____	_____	_____	_____
2. SRO _____	_____	_____	_____	_____
3. RO _____	_____	_____	_____	_____
4. BOP _____	_____	_____	_____	_____
5. STA _____	_____	_____	_____	_____

II. Evaluation

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>ST</u>
--	-----------	------------	-----------	------------	-----------

A. General					
1. Supervisory ability--					
a. Effective supervision of others	_____	_____	_____	_____	_____
b. Effective direction of others	_____	_____	_____	_____	_____
2. Operator communications--passes along information accurately and promptly	_____	_____	_____	_____	_____
3. Annunciator response--immediately responds--uses alarm procedure	_____	_____	_____	_____	_____
4. Use of procedures--pulls procedure and utilizes	_____	_____	_____	_____	_____
5. Sytematic and logical approach to problems	_____	_____	_____	_____	_____
6. a. Attentive to instrumentation and controls			_____	_____	
b. Compares redundant channels			_____	_____	
c. Compares meter to recorder			_____	_____	
7. Alertness--aware of plant status at all times	_____	_____	_____	_____	_____
B. Shift Turnover					
1. Oral turnover	_____	_____	_____	_____	_____
2. Hourly logs	_____	_____	_____	_____	_____
3. Review control board	_____	_____	_____	_____	_____
4. Test annunciator lights	_____	_____	_____	_____	_____



LESSON CODE: SS7421H

C. Exercise Performance	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>
1. <u>Loss of Condenser Vacuum</u>				
a. Notes change in efficiency, reports same and investigates			—	—
b. Notes change in condenser vacuum and performs immediate actions-of AOP-012			—	—
c. Refers to AOP-012 for auto and immediate action verification		—	—	—
d. Performs follow-up action of AOP-012		—	—	—
e. Request sufficient information of A.O. to diagnose problem	—	—	—	—
f. Initiates corrective maintenance	—	—	—	—
g. Makes notifications required	—	—	—	—
2. <u>Inadvertent SI</u>				
a. Recognizes condition and takes appropriate immediate actions	—	—	—	—
b. Uses EOP path 1 for action verification	—	—	—	—
c. Recognizes SI termination criteria	—	—	—	—
d. Address foldout A and B of EOP network	—	—	—	—
e. Terminates SI IAW EPP-004	—	—	—	—
f. Initiates investigation	—	—	—	—
g. Performs required administrative duties	—	—	—	—
h. Address PEP and make notifications	—	—	—	—
i. Performs required portions of OMM-004	—	—	—	—
3. <u>Stuck Rods</u>				
a. Recognizes mispositioned control rods		—	—	—
b. Recognizes SI flow sufficient to meet emergency boration requirements		—	—	—
c. Following SI realignment verifies sufficient SDM	—	—	—	—
d. Address AOP-001 for corrective action following SI termination	—	—	—	—
e. Initiates corrective action	—	—	—	—
4. <u>Steam Dump Failure</u>				
a. Notes SG-PORVs operating with condenser available		—	—	—
b. Investigates and finds steam dump malfunction		—	—	—
c. Investigates cause and corrects	—	—	—	—
d. Initiates corrective action	—	—	—	—
5. <u>CCW Leak</u>				
a. Interprets indications and recognizes a loss of CCW		—	—	—
b. Perform immediate action of AOP-014		—	—	—
c. Refers to AOP-014 for auto and immediate action verification		—	—	—
d. Performs follow-up action of AOP-014		—	—	—



11-11-11

[Faint, illegible text covering the majority of the page, possibly bleed-through from the reverse side.]

C. Exercise Performance (continued)	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>
e. Trouble shoots and isolates leak to source	_____	_____	_____	_____
f. Performs system realignment to isolate leak	_____	_____	_____	_____
g. Address potential environmental concerns	_____	_____	_____	_____
6. <u>Loss of second CSIP</u>				
a. Recognizes severity of failure	_____	_____	_____	_____
b. Immediately takes action to reduce RCS inventory loss	_____	_____	_____	_____
c. Takes action to recover any CSIP	_____	_____	_____	_____
d. Addresses EPP-001 as the only procedure that remotely covers the situation	_____	_____	_____	_____
7. <u>RCP seal failure (LOCA)</u>				
a. Perform immediate action of AOP-016	_____	_____	_____	_____
b. Addresses AOP-016 for verification	_____	_____	_____	_____
c. Recognizes impact of excessive leakage W/O CSIPs	_____	_____	_____	_____
d. Initiates rapid cooldowns to allow depressurization to reduce leakage	_____	_____	_____	_____
e. Classifies event and makes notifications as required by the PEP	_____	_____	_____	_____
f. Properly injects accumulators	_____	_____	_____	_____
g. Request assistance from plant staff	_____	_____	_____	_____
h. Places RHR in service when allowable	_____	_____	_____	_____
8. <u>Added Malfunctions</u>				
a. _____	_____	_____	_____	_____
b. _____	_____	_____	_____	_____
c. _____	_____	_____	_____	_____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102

103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

E. Exercise Critique:

SF-S/U

BOP-S/U

SRO - S/U

STA-S/U

RO - S/U

Overall Group Eval.,-S/U

F. Student Comments/Simulator Improvement:

Instructor's Signature

100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100

100

SHNPP SIMULATOR EXERCISE GUIDE

EXERCISE: S/G Tube Leak/Rupture/ATWS/ FILE NO. CLC-7-5-2 TIME: 4 hrs
S/G PORV Failed Open

OBJECTIVES: Upon completion of this exercise, the student will be able to:

1. Identify a S/G tube leak, take corrective actions with the S/G PORV failed open to stabilize the plant, and minimize radioactive releases to the environment per EPP-17.
2. Take proper actions to put the reactor in a safe shutdown condition following an ATWS event.

RELATED LER's, UER's, POER's, etc: Ginna - January 25, 1982--S/G tube rupture; HBR - LER-80-009 tube leak; HBR - LER-81-026 tube leak; HBR - LER-81-022 tube leak.

INITIAL CONDITIONS	IC-11 (MOL)	Present	Previous
Present Power 3 1/2 hrs.		5% PWR	75%
		5579°F T _{avg}	578°F
		380 ppm Borden	450 ppm
		103 on "D" Rod Hgt.	194 on "D"

INSTRUCTOR GUIDE:

Update PRODAC. Conduct shift turnover. Increase power to ~ 100%. At 20% power, fail CCW pump. Fail N-42 after 90% calorimetric, and insert S/G tube leak during subsequent pwr increase. Increase tube leak severity to cause SI actuation. An ATWS event will occur.

SHIFT TURNOVER INFORMATION:

Give plant conditions. Plant at 5% power following trip of "B" condensate pump (BKR malfunction). Repairs are completed. Synchronize to grid and increase power to 100%.

MALFUNCTIONS	OVERRIDES	REMOTE OPS.
T-0 All Auto R _x Trip Functions (Disabled)	T-0 PZR heaters Gr-A (off)	
T-0 Manual R _x Trips (Disabled)	T-0 "A" RHR pump (stop)	
T-0 IR Channel 35 (Undercompensated)	T-30 "A" CCW pump (stop)	
T-90 PR Channel 42 (Instr. Power Fuses Blown)		
T-130 Rather Than C-Loop, Leak in (A-Loop)		
T-130 Generator Tube Leak (24 GPM, Increase to 600 GPM)		
T-VAR Power Oper. Rel. Valve (Failed Open).		

SUPPLEMENTAL INFORMATION:

"A" CCW pump - seized motor bearing
PZR heaters Gr-A breaker tripped at control cabinet - due to overcurrent (heater grounds)
ATWS - BKR failure
TR-412 ΔT pen - stuck pen
"A" RHR pump - electrical circuit breaker closing mechanism failure
N-42 - Instrument power fuses blown

EXPECTED RESPONSE: AS PER SERIAL RELATED CHECKOFF

SUCCESSFUL COMPLETION OF THIS EXERCISE FULFILLS THE FOLLOWING NRC AND INPO REQUIREMENTS: 2, 3, 5A, 7, 8, 14, 16, 19, 21, 23, 24, 25, 26, 31

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1

62

11
12
13
14
15
16
17
18
19
20

2

5

11
12
13

11
12
13

SIMULATOR EXERCISE PERFORMANCE/OBSERVATION RECORD

Course _____ Group _____ Date _____

Instructors _____

Gradings: S = Satisfactory U = Unsatisfactory

I. Exercise _____

A. Initial Conditions/Scenario - exercise guide _____

B. Shift Assignments	R _x S/U		ρ Manipulations	
	Per.	Sup.	Per.	Sup.
1. SF _____	_____	_____	_____	_____
2. SRO _____	_____	_____	_____	_____
3. RO _____	_____	_____	_____	_____
4. BOP _____	_____	_____	_____	_____
5. STA _____	_____	_____	_____	_____

II. Evaluation

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>STA</u>
--	-----------	------------	-----------	------------	------------

A. General					
1. Supervisory ability--					
a. Effective supervision of others	_____	_____	_____	_____	_____
b. Effective direction of other	_____	_____	_____	_____	_____
2. Operator communications--passes along information accurately and promptly	_____	_____	_____	_____	_____
3. Annunciator response--immediately responds--uses alarm procedure	_____	_____	_____	_____	_____
4. Use of procedures--pulls procedure and utilizes	_____	_____	_____	_____	_____
5. Systematic and logical approach to problems	_____	_____	_____	_____	_____
6. a. Attentive to instrumentation and controls			_____	_____	
b. Compares redundant channels			_____	_____	
c. Compares meter to recorder			_____	_____	
7. Alertness--aware of plant status at all times	_____	_____	_____	_____	_____
B. Shift Turnover					
1. Oral turnover	_____	_____	_____	_____	_____
2. Hourly logs	_____	_____	_____	_____	_____
3. Review control board	_____	_____	_____	_____	_____
4. Test annunciator lights	_____	_____	_____	_____	_____

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

C. Exercise Performance

	<u>SF</u>	<u>SRO</u>	<u>RO</u>	<u>BOP</u>	<u>STA</u>
1. <u>Reactor Critical with Reactor Power < 3%</u>					
a. Verifies Initial Conditions	_____	_____	_____	_____	_____
b. Maintains Primary and Secondary	_____	_____	_____	_____	_____
(1) S/G Level	_____	_____	_____	_____	_____
(2) R _x Power < 3%	_____	_____	_____	_____	_____
(3) T _{ave} /T _{ref}	_____	_____	_____	_____	_____
c. Generator Start-up	_____	_____	_____	_____	_____
(1) Voltage Control	_____	_____	_____	_____	_____
(2) Synchronizing	_____	_____	_____	_____	_____
2. <u>Power Escalation</u>					
a. Maintains T _{avg} /T _{ref}	_____	_____	_____	_____	_____
b. Turbine Load Limits	_____	_____	_____	_____	_____
c. Generator Loading (MVARs)	_____	_____	_____	_____	_____
d. S/G Level Control	_____	_____	_____	_____	_____
e. MSR Operation	_____	_____	_____	_____	_____
f. Maintains CAOC	_____	_____	_____	_____	_____
g. Anticipates Xenon Transients	_____	_____	_____	_____	_____
h. Secondary Calorimetric at 90%	_____	_____	_____	_____	_____
i. Uses Curves	_____	_____	_____	_____	_____
j. Identifies ΔT pen failure	_____	_____	_____	_____	_____
3. <u>Component Cooling Water Pump Failure</u>					
a. Identification					
(1) Acknowledges Annunciators	_____	_____	_____	_____	_____
(2) Checks Flow Indicators	_____	_____	_____	_____	_____
b. Immediate Actions					
(1) Starts Backup Pump	_____	_____	_____	_____	_____
(2) Verifies flow	_____	_____	_____	_____	_____
(3) Refers to AOP-14	_____	_____	_____	_____	_____
c. Subsequent Actions					
(1) Investigates Cause	_____	_____	_____	_____	_____
(2) Checks Tech Specs	_____	_____	_____	_____	_____
(3) Informs I&C	_____	_____	_____	_____	_____
(4) Fills Out Work Request	_____	_____	_____	_____	_____
(5) Aligns C Pump as Backup	_____	_____	_____	_____	_____
4. <u>Power Range NI Failure</u>					
a. Immediate Actions					
(1) Stabilizes Plant	_____	_____	_____	_____	_____
(2) Refers to Tech Specs	_____	_____	_____	_____	_____
b. Subsequent Actions					
(1) Rod Stop Bypassed	_____	_____	_____	_____	_____
(2) Comparator Channels Defeated	_____	_____	_____	_____	_____
(3) Fuses Removed	_____	_____	_____	_____	_____
(4) OP-OT ΔT Bistables Tripped	_____	_____	_____	_____	_____
(5) Writes Clearance	_____	_____	_____	_____	_____
(6) Refers to AOP & OWP	_____	_____	_____	_____	_____

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201

202

203

204

205

206

207

208

209

210

211

212

213

214

215

216

217

218

219

220



• • 810.

Vertical text or markings along the left edge of the page, appearing as a series of small, illegible characters or symbols.

Faint, illegible markings or text located in the lower-left quadrant of the page.

E. Exercise Critique:

SRO - S/U

RO - S/U

Eval. - S/U

SF - S/U

BOP - S/U

STA - S/U

Overall Group

F. Student Comments/Simulator Improvement:

Instructor's Signature

