

BFN-17

TABLE 11.9-1

QUALITY REQUIREMENTS FOR CONDENSATE IN STORAGE

Specific Conductivity $\mu\text{mho/cm}$	≤ 1.0
Silica (as SiO_2), ppm	≤ 0.05
Chloride (as Cl), ppm	≤ 0.05
Filterable Iron ppm,	≤ 0.2