

306/14/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-387/388

REC: REAGAN W
NRC

ORG: RUHA N M
US ENVIRON PROTEC AGENCY

DOC DATE: 06/08/78
DATE RCVD: 06/13/78

DOCTYPE: LETTER - NOTARIZED: NO
SUBJECT: -----

COPIES RECEIVED
LTR 1 ENCL 0

FURNISHING COMMENTS ON THE ENVIRON REPT OF SUBJECT FACILITY.

PLANT NAME: SUSQUEHANNA -- UNIT 1
SUSQUEHANNA -- UNIT 2

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL: M

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

ENVIRONMENTAL COMMENTS
(DISTRIBUTION CODE COO2)

FOR ACTION: ASST DIR MOORE**LTR ONLY(1) BR CHIEF EPB#2 BC**LTR ONLY(1)
PROJ MGR BAJWA**LTR ONLY(1) LIC ASST DUNCAN**LTR ONLY(1)

FOR INFO: VASSALLO**LTR ONLY(1) LWR#3 BC**LTR ONLY(1)
FOR INFO: MINER**LTR ONLY(1) RUSHBROOK**LTR ONLY(1)

INTERNAL: REG FILE**LTR ONLY(1) NRC PDR**LTR ONLY(1)
I & E**LTR ONLY(2) OELD**LTR ONLY(1)
HANAUER**LTR ONLY(1) DIRECTOR DSE**LTR ONLY(1)
AD FOR ENV TECH**LTR ONLY(1) ENVIRO SPEC BR**LTR ONLY(1)
COST BENEFIT ANLYS**LTR ONLY(1) AD FOR SITE TECH**LTR ONLY(2)
AD FOR SITE ANLYS**LTR ONLY(1) ACCIDENT ANALYSIS**LTR ONLY(1)
EFFLUENT TREAT SYS**LTR ONLY(1) RAD ASSESSMENT BR**LTR ONLY(1)

EXTERNAL: LPDR'S
WILKES BARRE, PA**LTR ONLY(1)
NATL LAB ANL**LTR ONLY(6)
NSIC**LTR ONLY(1)
TIC**LTR ONLY(1)
ACRS CAT B**LTR ONLY(0)

DISTRIBUTION: LTR 34 ENCL 0
SIZE: 2P

CONTROL NBR: 781650003
Env. 460

***** THE END *****

U.S. NUCLEAR REGULATORY COMMISSION
DAILY ACCESSION LIST

05/10/78

PAGE 13

FILE LOCATION

#2
78125-0068
LETTER
IP+IP
TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

RECP AFFILIATION: NRC
ORG AFFILIATION: CONSOL EDISON OF NY

J
DURING LICENSEE EVENT REPT (RO 50-247/78-011/03L-0) ON 04/01/78 CONCERNING
TEMPERATURE SHUTOFF VALVES IN THE MAIN STEAM SUPPLY TO NO. 22 AUX BOILER
PUMP WOULD NOT OPERATE VIA AUTO SIGNALS, ALTHOUGH THEY WOULD MANUALLY
FULL STROKE.

78125-0069
LETTER
IP+IP+IP
TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

RECP AFFILIATION: NRC
ORG AFFILIATION: CONSOL EDISON OF NY

J
DURING LICENSEE EVENT REPT (RO 50-247/78-012/03L-0) ON 03/14/78 CONCERNING
SURVEILLANCE TEST, THE LIFT SETTING OF ONE OF THE THREE PRESSURIZER
VALVES (PCV-468) WAS FOUND TO BE APPROX. 0.8% BELOW ITS MINIMUM ALLOWABLE
AS SPECIFIED IN TECH SPECS.

78128-0014
LETTER
IP+5P+13P
TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

A
J
RECP AFFILIATION: NRC
ORG AFFILIATION: CONSOL EDISON OF NY

DURING ADDL INFO REQUESTED BY NRC TO COMPLETE REVIEW OF APPLICANT'S
78 LTR CONCERNING STEAM GENERATOR INSPECTION PROGRAM AND RESULTS & MAPS
CONDITIONS OF TUBES WHICH DID NOT PERMIT PASSAGE OF THE 700 MIQ PROBE OF
THE FACILITY.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III

6TH AND WALNUT STREETS
PHILADELPHIA, PENNSYLVANIA 19106

JUN 8 1978

50-387
388



Mr. William Reagan
Branch Chief
Branch #2 Environmental Projects
Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Reagan:

We have completed our review of the Environmental Report concerning the Susquehanna Steam Electric Station Units One and Two. Our comments do not include any items involving radiation as Dr. Bettenhausen, our regional specialist, has not had the opportunity to complete the reading of the three volume document. His comments may be expected by the end of June.

Our concerns are as follows:

1. On page 2.4-10, volume two, the topic of heavy metal concentrations in the Susquehanna River is described. Some of these parameters already exceed the toxic limits for aquatic organisms. In the normal operation of the plant water will be lost due to evaporation. This evaporative process will probably concentrate these metals to a greater degree.

On page 3.3-3, volume two, it is also mentioned that this evaporative loss of water will concentrate the dissolved river salts to a degree where they may become insoluble. The applicant has stated that he will acidify the waters to convert the salts to more soluble form. The text also relates that the blowdown limits the concentration of salts to less than four times the river concentration.

If the river water concentration of heavy metals and other dissolved salts, are, at the present time, greater than the recommended levels, concentrating them through evaporation to almost four times ambient levels may result in environmentally unacceptable impact on the ecosystem.

2. Page 3.4-11, volume two. It is related on this page that during an emergency, in order to reduce the formation of chemical scale on heat transfer surfaces, sulfuric acid and a "proprietary organic phosphate" may be added batchwise to the spray ponds. Any excess water in the

781650003


COO2/E/S *
1/0

spray pond will pass over a level control weir and return to the river via the diffuser. The impact of the addition of phosphates and acid to the spray ponds with ultimate discharge directly into the river should be discussed in detail.

3. It has been noted that figures in volume two, specifically figures 3.4-3 and 3.4-4, do not show a scale for the map or dimensions on the plans for the intake structure. It is very possible that there are other charts within the report that lack these important features. A careful check should be made to determine the completeness of all figures and tables throughout the document

We thank you for the opportunity to review the environmental report. If you have any questions concerning our review you may contact Dr. S. F. Thoumsin of my staff at 215-597-0961.

Sincerely yours,



Nicholas M. Ruha
Chief

EIS and Wetlands Review Section



Faint, illegible text scattered across the upper half of the page, possibly bleed-through from the reverse side. The text is too light to transcribe accurately.