BFN-26

APPENDIX C

STRUCTURAL QUALIFICATION OF SUBSYSTEMS AND COMPONENTS

TABLE OF CONTENTS

Introduction C.0-1

C.1 Scope C.0-1

C.2 Loading Conditions, Definitions, and Overview C.0-1
- C.2.1 Seismic Classification C.0-1
- C.2.2 Loading Conditions C.0-2
- C.2.3 Definitions C.0-3
- C.2.4 Seismic Design Input C.0-4
- C.2.5 Overview of Structural Qualification C.0-5
- C.2.6 Safety Margins C.0-6

C.3 Piping and Pipe Supports C.0-8
- C.3.1 Large Bore Piping C.0-9
- C.3.2 Small Bore Piping C.0-11
- C.3.3 Instrument Tubing C.0-13
- C.3.4 Buried Piping C.0-14
- C.3.5 Torus Attached Piping Systems C.0-14
- C.3.6 Pipe and Tubing Supports C.0-18
- C.3.7 Computer Programs for Class I Piping System Analysis C.0-22

C.4 Major Components C.0-25
- C.4.1 Reactor Pressure Vessel (RPV), RPV Internals, and Supports C.0-25
- C.4.2 Primary System Components Stress Analysis C.0-29

C.5 Primary Containment System and Penetrations C.0-29
- C.5.1 Primary Containment Vessels Stress Analysis C.0-30
- C.5.2 Primary Containment Bellows Stress Analysis C.0-31
- C.5.3 Long Term Torus Integrity Program (LTTIP) C.0-31
- C.5.4 Wetwell/Drywell Vacuum Breakers C.0-33

C.6 Equipment C.0-33
- C.6.1 Equipment Seismic Loading (Historical) C.0-34
- C.6.2 Equipment Seismic Analysis (Historical) C.0-35
- C.6.3 Seismic Qualification of New Equipment and Replacements for Existing Equipment from March 1988 until July 2007 ..... C.0-36
- C.6.4 Equipment Seismic/Structural Qualification (ESQ) after July 2007 ..... C.0-37
- C.6.5 Qualification of Equipment in Torus Attached Piping Systems C.0-38
- C.6.6 Interface Loads from Class I Piping Analysis C.0-38

C.7 Heating, Ventilation, and Air Conditioning (HVAC) Ductwork and Supports C.0-38
- C.7.1 Scope C.0-39
- C.7.2 Ductwork System Seismic Analysis C.0-39
- C.7.3 Ductwork Load Combinations and Allowable Stresses C.0-40

C.8 Control of Heavy Loads C.0-42
C.8.1 Introduction/Licensing Background C.0-42
C.8.2 Safety Basis C.0-44
C.8.3 Scope of Heavy Load Handling Systems C.0-44
C.8.4 Control of Heavy Loads Program C.0-45
C.8.5 Safety Evaluation C.0-50

C.9 References C.0-51

APPENDIX C

LIST OF TABLES

Table	Title
C.2-1	Deformation Limit
C.2-2	Primary Stress Limit
C.2-3	Buckling Stability Limit
C.2-4	Fatigue Limit
C.3-1A	Load Combinations and Allowable Stress Criteria for Class I Piping and Tubing (Piping other than RRS, MS, FW, and CRDH Systems)
C.3.1B	Load Combinations and Allowable Stress Criteria of Class I Piping for Reactor Recirculation (RRS), Main Steam (MS), and Feedwater (FW) Systems
C.3.1C	Load Combinations and Allowable Stress Criteria for Control Rod Drive Hydraulic Piping
C.3-2	Load Combinations and Allowable Stresses for Class I Pipe and Tubing Supports
C.4-1	Reactor Vessel, Reactor Vessel Internals, and Supports - Critical Load Combinations, Locations, and Allowables.
C.4-2	Primary System Components - Critical Load Combinations, Locations, and Allowables.
C.5-1	Drywell Loading Conditions and Allowable Stresses