

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

January 12, 1979

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET  
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-296/7834

The enclosed report provides details concerning the relief valve on  
the discharge of standby liquid control pump 3A, PGV-63-512, which  
was observed to open at 1,150 psig instead of the design setting of  
1,425 + 75 psig as required by technical specification 3.4.A.1 during  
normal power operation while performing surveillance instruction  
4.4.A.1. This report is submitted in accordance with Browns Ferry  
unit 3 technical specification 6.7.2.6.2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox  
Director of Power Production

REGULATORY DOCKET FILE COPY

Enclosure (3)  
cc (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

R. F. Sullivan, NRC Inspector, Browns Ferry

7901170215

AOI-4  
A002  
5/11

... ..  
... ..  
... ..

...

... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..

...

...

...

(1) ... ..  
... ..  
... ..  
... ..

(2) ... ..  
... ..  
... ..

...