

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

| | | |
|---|--|---|
| TO: NRC | FROM: Pa Pwr & Light Co Allentown, Pa N W Curtis | DATE OF DOCUMENT 3-23-76 |
| <input checked="" type="checkbox"/> LETTER <input checked="" type="checkbox"/> ORIGINAL <input type="checkbox"/> COPY | | DATE RECEIVED 3-29-76 |
| <input type="checkbox"/> NOTORIZED <input checked="" type="checkbox"/> UNCLASSIFIED | PROP | NUMBER OF COPIES RECEIVED one signed |

DESCRIPTION

Ltr furnishing info concerning modification to question 5.37 which will be included with material submitted in Amdt #16 to the PSAR....

PLANT NAME: Susquehanna 1 & 2

ENCLOSURE

DO NOT REMOVE

ACKNOWLEDGED

| SAFETY | FOR ACTION/INFORMATION | ENVIRO |
|------------------|------------------------|-------------|
| ASSIGNED AD : | <i>De Young</i> | 3-31-76 ent |
| BRANCH CHIEF : | <i>Butler</i> | |
| PROJECT MANAGER: | <i>Minor</i> | |
| LIC. ASST. : | <i>Rushbrook</i> | |

| INTERNAL DISTRIBUTION | | | |
|---|----------------|----------------------|---------------|
| <input checked="" type="checkbox"/> REG FILE | SYSTEMS SAFETY | PLANT SYSTEMS | ENVIRO TECH |
| <input checked="" type="checkbox"/> NRC PDR | HEINEMAN | TEDESCO | ERNST |
| <input checked="" type="checkbox"/> I & E (2) | SCHROEDER | BENAROYA | BALLARD |
| <input checked="" type="checkbox"/> OELD | | LAINAS | SPANGLER |
| GOSSICK & STAFF | ENGINEERING | IPPOLITO | |
| MIPC | MACCARY | | SITE TECH |
| CASE | KNIGHT | OPERATING REACTORS | GAMILL (2) |
| HANAUER | SIHWEIL | STELLO | STEPP |
| HARLESS | PAWLICKI | | HULMAN |
| | | OPERATING TECH | |
| PROJECT MANAGEMENT | REACTOR SAFETY | EISENHUT | SITE ANALYSIS |
| BOYD | ROSS | SHAO | VOLLMER |
| P. COLLINS | NOVAK | BAER | BUNCH |
| HOUSTON | ROSZTOCZY | SCHWENCER | J. COLLINS |
| PETERSON | CHECK | GRIMES | KREGER |
| MELTZ | | | |
| HELTEMES | AT & I | SITE SAFETY & ENVIRO | |
| SKOVHOLT | SALTZMAN | ANALYSIS | |
| | RUTBERG | DENTON & MULLER | |

| EXTERNAL DISTRIBUTION | | | CONTROL NUMBER |
|--|------------------|---------------------|----------------|
| <input checked="" type="checkbox"/> LPDR: <i>Wilkes Barre Pa</i> | NATL LAB | BROOKHAVEN NATL LAB | 3112 |
| <input checked="" type="checkbox"/> TIC | REG. V-IE | ULRIKSON(ORNL) | |
| <input checked="" type="checkbox"/> NSIC | LA PDR | | |
| <input checked="" type="checkbox"/> ASLB | CONSULTANTS | | |
| <input checked="" type="checkbox"/> ACRS 16 HOLDING/SENT TO LA | <i>Rushbrook</i> | | |



17 2 14

.....

.. (..)

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA 18101 PHONE: (215) 821-5151

March 23, 1976

REGULATORY DOCKET FILE COPY

Director of Nuclear Reactor Regulation
Light Water Reactors Branch No. 1-2
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Dr. Walter R. Butler, Chief

SUSQUEHANNA STEAM ELECTRIC STATION
MODIFICATION TO QUESTION 5.37
ER 100450 FILE 840-2
PLA-110

Docket Nos. 50-387
50-388



Dear Dr. Butler:

We are in the process of writing our Structural Integrity Test Procedure to be submitted to you in late April, 1976. In Amendment #16, we submitted an amended response to Question 5.37 on compliance with Regulatory Guide 1.18. This response listed our exceptions to Regulatory Guide 1.18. We have two additional exceptions. They are as follows:

1. Reference: Paragraph C.2 of the Regulatory Guide. We intend to select the number and distribution of measuring points for monitoring radial deflections so that the as-built conditions can be considered in the assessment of general shell response.

In general the locations of measuring points for radial deflections are in agreement with Figure B, except point 1. Point 1 is provided at a distance of two times the wall thickness (12') from the base slab. This variation is made to properly predict the containment behavior near the base slab to wall connection. If point 1 were to be provided at a height of three times the wall thickness (18') it would be located very close to point 2 (suppression chamber wall midheight is 26') and would not yield any additional behavior pattern of the containment.

2. Reference: Paragraph C.5 of the Regulatory Guide. Because of the current state of the art, triaxial concrete strain distortion measurements, while taken, may not be used to evaluate the containment strain distribution. The concrete strain will be evaluated using linear strain measurements in the meridional and radial directions.

3112

[The text in this block is extremely faint and illegible, appearing as scattered noise or bleed-through from the reverse side of the page.]

Page 2
March 23, 1976

As we stated before, we intend to submit our Structural Integrity Test Procedure in late April and would like your comments on these exceptions prior to that date.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction

NWC:AAW

THE UNITED STATES OF AMERICA
DEPARTMENT OF THE INTERIOR
BUREAU OF LAND MANAGEMENT

WYOMING

Section 10

100-100000-100000

100000