

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8110280265 DOC. DATE: 81/10/19 NOTARIZED: YES JOCKET #
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee ~~05000260~~
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296
 AUTH. NAME: AUTHR AFFILIATION
 MILLS, L. M. Tennessee Valley Authority
 RECIP. NAME: RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application to amend Licenses DPR-33, DPR-52 & DPR-69,
 changing Tech Spec increase interval for integrated leak
 rate testing from 3-1/3-yrs & or-8 months to 3-1/3-yrs & or-
 10 months. Class I & II amend fees will be sent.

DISTRIBUTION CODE: A0015 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 278
 TITLE: General Distribution for after Issuance of Operating License

NOTES: 1cy: FCAF/VMS 05000259
 1cy: FCAF/VMS 05000260
 1cy: FCAF/VMS 05000296

ACTION:	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	DR3 #2 BC	01	13	13				
INTERNAL:	ELD		1	0	I&E	06	2	2
	NRR/DHES DEPY03		1	1	VRR/DL DIR		1	1
	DR-ASSESS 3R		1	0	RAD ASMT BR		1	1
	REG. FILE	04	1	1				
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

NOV 01 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 40
~~41~~ ~~39~~

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

October 19, 1981

TVA BFNP TS 168

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555



Dear Mr. Denton:

In the Matter of the) Docket Nos. 50-259
Tennessee Valley Authority) 50-260
50-296

In accordance with the provisions of 10 CFR Part 50.59, we are enclosing 40 copies of a requested amendment to licenses DPR-33, DPR-52, and DPR-68 to change the technical specifications of Browns Ferry Nuclear Plant units 1, 2, and 3 (Enclosure 1). Also enclosed is the justification for the proposed changes (Enclosure 2). These proposed changes increase the interval for integrated leak rate testing from 3-1/3 years \pm 8 months to 3-1/3 years \pm 10 months, making the Browns Ferry technical specifications consistent with BWR Standard Technical Specifications. We request your approval of these proposed changes by February 1, 1982.

In accordance with the requirements of 10 CFR Part 170.22, we have determined this proposed amendment to be Class II for unit 1 and Class I for units 2 and 3. These classifications are based on the facts that the proposed amendment is an administrative change that has no safety significance for unit 1, and the proposed amendments for units 2 and 3 are duplicates of the unit 1 proposed amendment. The remittance for \$2,000 (\$1,200 for unit 1 and \$800 for units 2 and 3) is being wired to the NRC, Attention: Licensing Fee Management Branch.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

E. M. Mills
E. M. Mills, Manager
Nuclear Regulation and Safety

Subscribed and sworn to before
me this 19th day of Oct. 1981.

Bryant M. Lowery
Notary Public

My Commission Expires 4/4/82

Enclosures
cc: See page 2

*Pool
5/11*

8110280265 811019
PDR ADCK 05000259
P PDR

Mr. Harold R. Denton

October 19, 1981

cc (Enclosures):

Mr. Charles R. Christopher
Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Dr. Ira L. Myers
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104