

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8106120200 DOC. DATE: 81/06/10 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Forwards annual const noise progress rept, "Sound Level Measurements Near Susquehanna Steam Electric Station Site Const 1980."

DISTRIBUTION CODE: R0015 COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 1x29
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000387
 Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000388

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
ACTION:	A/O LICENSNG	1	0	LIC BR #2 BC	1	0
	LIC BR #2 LA	1	0	STARK, R.	04	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EMRG PRP DEV 35	1	1
	EMRG PRP LIC 36	3	3	EQUIP QUAL BR13	3	3
	FEMA-REP DIV 39	1	1	GEOSCIENCES 28	2	2
	HUM FACT ENG 40	1	1	HYD/GEO BR 30	2	2
	I&C SYS BR 16	1	1	I&E 06	3	3
	LIC GUID BR 33	1	1	LIC QUAL BR 32	1	1
	MATL ENG BR 17	1	1	MECH ENG BR 18	1	1
	MPA	1	0	NRC PDR 02	1	1
	OELD	1	0	OP LIC BR 34	1	1
	POWER SYS BR 19	1	1	PROC/TST REV 20	1	1
	QA BR 21	1	1	RAD ASSESS BR22	1	1
	REAC SYS BR 23	1	1	REG FILE 01	1	1
	SIT ANAL BR 24	1	1	STRUCT ENG BR25	1	1
	EXTERNAL:	ACRS 41	16	16	LPDR 03	1
NSIC 05		1	1			

MAY

JUN 16 1981

63

57

TOTAL NUMBER OF COPIES REQUIRED: LTTR 62 ENCL 56



PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101

PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

June 10, 1981

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



SUSQUEHANNA STEAM ELECTRIC STATION
CONSTRUCTION NOISE PROGRESS REPORT
ER 100450 FILE 991-2
PLA-837

Dear Mr. Schwencer:

Enclosed for your information are forty copies of the annual Construction Noise Progress Report, "Sound Level Measurements Near Susquehanna Steam Electric Station Site Construction 1980."

Very truly yours,

B. H. Hennikson for

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

RRS/mks

Attachments (40)

Boo1
s
1/40

8106120200

R

PENNSYLVANIA POWER & LIGHT COMPANY

Bolt Beranek and Newman Inc.



Report No. 3024A-5

**Sound Level Measurements Near Susquehanna Steam Electric
Station Site Construction 1980**

Construction Noise Progress Report

J.D. Barnes and E.W. Wood

March 1981

**Prepared for:
Pennsylvania Power and Light Company**

8106120 202

SUBJECT: Study on Torsional effect on the seismic
response analysis of (1) ESSW Pumphouse
(2) Diesel Generator Building

As requested by NRC analysis has been performed to study the effects of including torsion in the dynamic response analysis for (a) ESSW Pumphouse (b) Diesel Generator Building.


The Analytical Procedure used in this study consists of:

- (i) The eccentricities of these structures were calculated.
- (ii) The structures were represented by a fixed base 3-D stick models with structural masses properly lumped at the calculated eccentricities, as shown in Figure 1 and 2.
- (iii) Modal frequency analyses of the 3-D stick models were performed to determine the structure frequencies.
- (iv) The frequencies determined are then compared with the corresponding frequencies associated with the fixed base models having zero eccentricities.

The results of comparison for the ESSW Pumphouse is shown on Table-1 and for the Diesel Generator building is shown on Table-2. These results indicate that there are insignificant shifts in the structural frequencies by including the eccentricities in the dynamic analysis.

From the results of this study, it is concluded that the structures modeled by lumped stick models without the inclusion of eccentricities in the dynamic analysis is adequate for the prediction of desired structural responses.

CONTROL#	910620200
DATE-	6/10/81




COORDINATES			
NODES	X	Y	Z
1	0.0	0.0	660.0
2	0.0	0.0	685.5
3	0.0	8.0	685.5
4	0.0	0.0	716.0
5	0.0	1.1	716.0

MASSSES AT NODES 3 AND 5

FIGURE-1

ESSW PUMP HOUSE

3-D STICK MODEL



MASSSES AT NODES 4,8,9,10

COORDINATES			
NODES	X	Y	Z
1	0.0	0.0	660.0
2	0.0	0.0	677.0
3	0.0	0.0	701.3
4	0.0	0.0	710.8
5	0.0	0.0	723.0
6	0.0	0.0	737.1
7	0.5	-1.0	677.0
8	8.9	-6.8	701.3
9	19.5	-1.3	723.0
10	0.3	-3.1	737.1

FIGURE 2

DIESEL GENERATOR BUILDING

3-D STICK MODEL

Table-1: ESSW PUMPHOUSE:
Frequencies with and without
eccentricities
(See Figure-1)

Mode #	Frequencies (cps)	
	With Eccentricity	Without Eccentricity
1	13.93	13.94
2	18.05	18.06
3	28.94	28.97
4	38.83	40.01

Table-2: DIESEL GENERATOR BUILDING:
Frequencies with and without
eccentricities
(See Figure-2)

Mode #	Frequencies (cps)	
	With Eccentricity	Without Eccentricity
1	8.86	8.96
2	9.65	9.71
3	22.56	23.42
4	31.69	32.04
5	33.45	33.66

SUBJECT: Equivalence of Fixed Base and Flexible Base Models
used for the analysis of Primary Containment
for seismic loads.

In continuation of our response to the NRC question 130.20 as desired by NRC, a study has been made on the above subject. The object of this study is to demonstrate that as the shear wave velocity is increased, the results from the flexible base model converge to the results of the fixed base model.

The study considers the vertical seismic analysis for SSE for (a) a fixed base model (b) flexible base models for various foundation flexibilities defined by shear wave velocities V_S , $2V_S$, $5V_S$, $10V_S$ where V_S for the Susquehanna site is 6200 ft./sec. This corresponds to an equivalent vertical spring constant as shown in Table-1. A sketch of the flexible base vertical seismic model is shown in figure 3.7b-8 of FSAR (See Attachment #1).

A damping value of 5% of critical was used for all fixed base structural modes. The damping determination technique described in reference 3.7b-3 of FSAR [BC-Top-4A, Rev. 3, Appendix D] has been used to calculate the composite modal damping for the flexible base model.

The results for the fixed base and the flexible models are shown in Table-2 and Table-3, in terms of frequencies and modal damping values. The seismic (SSE) responses in terms of axial forces are presented in Table-4. The results indicate the following:

- (a) Table-2: Frequencies values approach fixed base conditions for $5V_S$.
- (b) Table-3: Modal damping values approach the fixed base condition for $5V_S$.
- (c) Table-4: Seismic responses approach fixed base conditions for $2V_S$.

These results demonstrate that as the shear wave velocity is increased to 2 to 5 times the actual site shear wave velocity, the results from the flexible base model converge to the results of the fixed base model. Thus use of the flexible base model for the seismic analysis of the containment structure is more realistic.



Table-1: CONTAINMENT: Equivalent Vertical Spring Constants.

From FSAR Section 3.7b.5, Reference 3.7b-3
(BC-Top-4-A, Page 3-15)

$$\text{Equivalent Vertical Spring Constant, } k_z = \frac{4GR}{(1-\nu)}$$

Where ν = Poisson's ratio = 0.3

R = Radius of Circular base mat = 50 ft.

G = Shear Modulus = ρV_s^2

V_s = Shear Wave Velocity = 6200 ft./sec.

ρ = Mass density of foundation medium = 4.3478×10^{-3} k.sec²/ft⁴ (γ = 140 lbs/cft.)

$V_s = V_s$ $k_z = 4.78 \times 10^7$ k/ft.

$V_s = 2V_s$ $k_z = 1.912 \times 10^8$ k/ft.

$V_s = 5V_s$ $k_z = 1.195 \times 10^9$ k/ft.

$V_s = 10V_s$ $k_z = 4.78 \times 10^{10}$ k/ft.

Table-2: CONTAINMENT: Vertical Seismic Model
Flexible Base Vs. Fixed Base Frequencies. (Cps)

Frequencies (Cps)

Mode #	Flexible Base				Fixed Base
	$V_s = 6200 \text{ ft/sec.}$	$2V_s$	$5V_s$	$10V_s$	
1	16.19	17.24	17.45	17.47	17.48
2	20.95	23.18	24.09	24.23	24.28
3	38.24	38.63	38.75	38.77	38.78

Table-3: CONTAINMENT: Vertical Seismic Model
Flexible Base Vs. Fixed Base
Modal Damping (% Critical)

Modal Damping (% Critical)

Mode #	Flexible Base				Fixed Base
	$V_s = 6200 \text{ ft/sec.}$	$2V_s$	$5V_s$	$10V_s$	
1	9.3	5.3	5.0	5.0	5.0
2	9.1	6.1	5.0	5.0	5.0
3	5.0	5.1	5.0	5.0	5.0




Table-4: CONTAINMENT: Axial Forces (SSE) (kips)
See Figure 3.7b-8 of FSAR, (Attachment #1)
for location of members.

Member #	Flexible Base				Fixed Base
	$V_S =$ 6200 ft/sec.	$2V_S$	$5V_S$	$10V_S$	
1	14.5	21.8	22.2	21.9	21.9
2	84.7	127.5	130.0	127.7	127.8
3	239.9	360.7	367.7	360.8	361.1
4	412.2	617.9	629.1	617.0	617.6
5	576.5	860.7	874.9	857.7	858.4
6	734.5	1090.8	1106.6	1084.3	1085.1
7	866.9	1280.4	1296.1	1269.5	1270.3
8	991.5	1454.3	1468.5	1437.7	1438.4
9	1095.4	1595.9	1607.5	1573.1	1573.7
10	1319.0	1773.8	1774.7	1733.2	1733.2
11	1479.1	1968.3	1956.7	1909.4	1908.7
12	1611.6	2107.5	2078.2	2025.5	2024.0
13	1701.4	2177.3	2128.2	2071.5	2069.0
14	34.9	34.8	33.1	31.7	31.6
15	127.3	126.3	119.6	114.3	113.8
16	201.3	197.3	185.9	176.9	176.2
17	843.4	842.7	787.2	743.4	739.6
18	899.6	895.0	835.9	789.3	785.2
19	759.5	727.5	680.6	642.5	639.2
20	799.1	762.2	712.5	672.5	669.1

TABLE-4 (Cont'd)

Member #	Flexible Base				Fixed Base
	$V_s =$ 6200 ft/sec.	$2V_s$	$5V_s$	$10V_s$	
21	829.5	786.9	734.8	693.5	689.9
22	845.3	797.2	743.3	701.5	697.8
23	602.9	611.5	571.5	540.0	537.3
24	602.9	611.5	571.5	540.0	537.3
25	76.9	78.2	73.2	69.3	68.9
26	234.2	238.4	223.1	211.0	209.9
27	418.5	426.1	398.4	376.6	374.7
28	1701.3	2177.3	2128.2	2071.5	2069.0
29	845.3	797.2	743.3	701.5	697.8
30	83.2	82.6	80.9	77.1	77.5



SUSQUEHANNA STEAM ELECTRIC STATION
UNITS 1 AND 2
FINAL SAFETY ANALYSIS REPORT

VERTICAL SEISMIC
MODEL OF CONTAINMENT
WITH FLEXIBLE BASE

FIGURE 3.7b-8

SUSQUEHANNA SES UNIT 1 AND 2
DOCKET NUMBERS 50-387 AND 50-388
CATEGORY I MASONRY WALLS

PREFAMBLE:

Safety related masonry walls are interior partitions whose primary function is to provide shielding and fire protection. Masonry walls are not used as primary shear walls for seismic resistance of the structure. All category I masonry walls are reinforced with all cells fully grouted. The infill material of double wythe walls is either grout or concrete. The minimum specified compressive strength for grout, concrete, and mortar is 2500 psi. Mortar infill is not used on SSES masonry walls. Metal ties, between the wythes of double wythe walls, are provided at 24" spacing maximum in horizontal and vertical directions. Seismic design is in accordance with SSES FSAR Section 3.7. Allowable stresses are as noted in FSAR Section 3.8, Table 3.8-8 and Table 3.8-9. Safety related masonry walls are Q-listed and have been added to the FSAR Design Criteria Summary (Table 3.2-1), in response to NRC, Quality Assurance Branch, Question No. 260.1-b (34).

QUESTION NO. 1:

In your response to Question 2, you indicated that S_m is the allowable stress as specified in UBC. For extreme and/or abnormal loading combinations, you increase the allowable stress by a factor of 1.67, which is in conformance with the practice of SRP Sections 3.8.3 and 3.8.4, for reinforced concrete structures. However, concrete masonry walls are quite different from reinforced concrete walls, particularly the unreinforced ones, the use of such a practice may not result in an adequate design. Depending on the types of stress, that is, tensile, shearing or axial compressive, the factor may vary from 0 to 2.5 (see enclosure 2). Specify the masonry design strength f'_m used in Susquehanna masonry walls and the allowable values for all types of stresses.

RESPONSE:

Code allowable stresses for masonry tension, shear, compression, and bond are increased by a factor of 1.67 for load combinations involving abnormal and/or extreme environmental conditions which are credible but highly improbable. Since code allowable stresses are generally associated with a factor of safety of 3, the 1.67 increase provides a factor of safety against failure of 1.8 ($3 \div 1.67$) (see Table 4 for the increase allowed for each type of stress). There are no unreinforced masonry walls on SSES project. Susquehanna SES masonry walls are designed based on an ultimate compressive strength, f'_m , of 1500 psi as specified in UBC 1976, for solid grouted hollow masonry. Minimum compressive strength at 28 days for mortar, grout, and concrete is 2500 psi. Materials are in accordance with FSAR Appendix 3.8C. The allowable stresses are as listed in Table 1.



TABLE 1.

SSES ALLOWABLE STRESSES

Materials and Stress Type	Allowable Stress: UBC - 1976 (1) psi
1. <u>Masonry:</u>	$f'_m = 1500$ (see note 2)
Compression:	
Flexural	$.33f'_m = 500$
Axial	$.20f'_m \times (1-(h/40t)^3)$ h = clear height, in. t = wall thickness, in.
Flexural Shear	$1.1 \sqrt{f'_m} = 43$
Bond (deformed bars)	140
Bearing	$.25f'_m = 375$
Bed Joint tension	
Normal	(See note 3)
Parallel	25
Modulus of elasticity, E_m	$1000f'_m = 1,500,000$
Modulus of rigidity, E_v	$400f'_m = 600,000$
2. <u>Reinforcement:</u>	
Tension:	
Grade 40 Steel	20,000 (used for ties only)
Grade 60 Steel	24,000
Compression:	
Grade 40 Steel	16,000 (used for ties only)
Grade 60 Steel	24,000

- Notes: (1) For stress increase allowed for abnormal, or extreme environmental load combinations - See Table 4.
- (2) Ultimate compressive strength as specified in UBC - 1976 for solid grouted hollow concrete units - Grade N.
- (3) Zero tension normal to bed joint is used.



QUESTION NO. 2

In the note to your response to Question 2, you stated that the allowable shear or tension between masonry block and concrete or grout infill is considered to be equal to three percent of the compressive strength of the block. The allowable shear or tension as specified by you is in the staff's opinion too high. To specify the allowable shear or tension of the vertical joint between wythes in terms of the compression strength of the block is in the first place unconservative and the use of seemingly low percentage of 3% may actually result in an allowable shearing stress greater than its corresponding strength. Therefore, a revision of the stress criterion is required.

RESPONSE:

The specified shear and tension, for the interface of masonry block and concrete or grout infill, of three percent of compressive strength, f'_m , is based on the relationship $1.1 \sqrt{f'_m}$ given in ACI-531-79. For $f'_m = 1500$ psi, this relationship yields a value of 43 psi compared to 45 psi ($.03 \times 1500$) allowed for evaluation of project masonry walls. The difference of 2 psi is justified by the fact that the ultimate compressive strength of masonry f'_m is generally higher than 1500 psi.

The values for shear and tension as specified above have been used only as a guide in evaluating double wythe walls, where infill thickness is greater than 8 inches (24" thick walls and larger). For walls having an infill thickness of less than 8 inches (total of four walls), zero tension/shear is assumed for evaluation purposes.

For SSES masonry walls, the actual shear stress, as determined by VQ/Ib for uncracked sections, and in the compression zone of cracked sections ranges from 5-10 psi; except for three walls. For these three walls shearing stress is in the range of 10-15 psi.

QUESTION NO. 3

In your response to Question 4: (1) It is indicated that response spectrum method is used for the dynamic analysis of the concrete masonry walls. However, there is no mention as to which of the response spectra is used, upper floor or lower floor response spectrum or the average of the two. It is required that an upper bound envelope of the individual floor is used. (2) Though the use of ACI 318 formula the cracking of concrete masonry wall is considered. The use of such a formula is questionable in view of the fact that in a concrete masonry wall the weakest section is the bed joint and the modulus of rupture is equal to that of neither the concrete block nor the mortar. Indicate how the modulus of rupture is established in your computation.

RESPONSE ITEM (1):

Response spectrum for the lower floor has been used for evaluation of cracked/uncracked behavior of masonry walls, as applicable, for vertical motion, and for walls cantilevered from the floor. For horizontal motion, the lower floor response spectrum has been used in the initial evaluation of cracked/uncracked behavior, as applicable, for walls spanning between two floors and walls having side connection at concrete walls. These walls have also been re-evaluated based on the average acceleration of the upper and lower floors. Where the upper floor acceleration is less than the lower floor acceleration, the lower floor acceleration is used. For justification of using average acceleration, see Enclosure 1.

RESPONSE ITEM (2):

Although ACI-318 formula is derived for cracked concrete sections, the use of the formula for masonry walls takes into consideration the difference in material strengths. The difference between masonry behavior and concrete behavior is recognized and allowances are provided in selection of seismic acceleration within a frequency variation of plus or minus fifteen percent of the natural frequency.

The modulus of rupture (f_r) for masonry is approximated by increasing the UBC allowable flexural tensile stress by a factor of safety of 3 and then applying a 33% reduction to arrive at a lower bound value. This value is used only for stiffness and frequency calculations of the cracked section and not for strength. Allowance for uncertainties in the modulus of rupture is accounted for in the frequency variation of $\pm 15\%$ of the natural frequency.

QUESTION NO. 4:

In response to Question 5, it is stated that when the design stresses of masonry walls exceed the allowable stresses, fixes are designed such that the criteria is satisfied. Indicate the number of walls where such fixes are needed and provide examples.

RESPONSE:

The number of masonry walls requiring fixes for cracked section criteria is 36. Wall location, thickness, and elevation are as shown in Table 2. Typical fixes are shown in details type 1, type 2, type 3, and type 4 (see Enclosure 2).

TABLE 2

SSES - MASONRY WALLS
WALLS WHICH REQUIRED FIXES FOR CRACKED SECTION CRITERIA

BLDG.	FLOOR ELEVATION	WALL THICKNESS	NO. OF WALLS	REF. DWG.
Control	656'-0	8"	2	C-1301
Control	741'-0	6"	2	C-1304
Control	741'-0	8"	3	C-1304
Control	753'-0	8"	1	C-1304
Control	771'-0	8"	16	C-1304
Control	783'-0	1'-0"	3	C-1307
Control	806'-0	8"	3	C-1308
Control	806'-0	1'-0"	1	C-1308
Reactor	728'-0	8"	1	C-1202
Reactor	799'-0	8"	4	C-1205



QUESTION NO. 5:

Provide justification for any deviation from the attached staff's interim criteria in your design and analysis of the masonry walls.

RESPONSE:

Deviations and justification for differences between SSES criteria and SEB interim criteria are as noted in the following paragraphs.

Items which are not specifically addressed are in accordance with the criteria or not applicable to the project.

ITEM NO. 1: General Requirements

The materials, testing, analysis, design, construction and inspection related to the design and construction of safety-related concrete masonry walls shall conform to the applicable requirements contained in Uniform Building Code - 1979, unless specified otherwise, by the provisions in this criteria.

RESPONSE:

Uniform Building Code, 1976 edition, has been used for design and evaluation of Susquehanna masonry walls. A comparison of 1976 and 1979 editions of UBC shows no significant difference in criteria applicable to SSES masonry walls. In addition, ACI-531-79 is used to supplement UBC allowable stresses, and ACI-318 1977 in stiffness calculations.

ITEM NO. 2: Loads and Load Combinations

The loads and load combinations shall include consideration of normal loads, severe environmental load, extreme environmental load, and abnormal loads. Specifically, for operating plants, the load combinations provided in plant's FSAR shall govern. For operating license applications, the following load combinations shall apply for definition of load terms, (see SRP Section 3.8.4.11-3).

RESPONSE:

For comparison of SEB interim load combinations and load combinations used for masonry walls evaluation see Table 3. Definition of terms is as shown below.

Notation

D = Dead load of structure plus any other permanent loads contributing stress.

L = Live loads expected to be present when the plant is operating, including movable equipment, piping, cables.



- P = Design basis accident pressure loads.
- R = Steam/water jet forces or reactions resulting from rupture of process piping.
- T_O = Thermal effects during normal operating conditions including temperature gradient and equipment and pipe reactions.
- H_O = Force on structure due to thermal expansion of pipes under operating conditions.
- T_a = Added thermal effects (over and above operating thermal effects) which occur during a design accident.
- H_a = Force on structure due to thermal expansion of pipes under accident conditions.
- E = Load due to Operating Basis Earthquake.
- E' = Load due to Design Basis Earthquake.
- W = Wind load.
- W' = Tornado wind load.
- D_S = Force on blockwall due to story drift under Operating Basis Earthquake Loading.
- D'_S = Force on blockwall due to story drift under Safe Shutdown Earthquake Loading.

TABLE 3. - LOAD COMBINATION COMPARISON

LOAD COMBINATION	SEB INTERIM CRITERIA	SSES FSAR CRITERIA	COMMENTS
Service Load Condition	1. $D + L$ 2. $D + L + E$ 3. $D + L + W$	1. $D + L$ 2. $D + L + E + D_s$ 3. Not Applicable	No wind pressure
	1a. $D + L + T_o + R_o$ 2a. $D + L + T_o + R_o + E$ 3a. $D + L + T_o + R_o + W$	1a. $D + L + T_o + H_o$ 2a. $D + L + T_o + H_o + E$ 3a. Not Applicable	No wind pressure
Extreme environmental	4. $D + L + T_o + R_o + E'$ 5. $D + L + T_o + R_o + W_t$	4. $D + L + T_o + H_o + E' + D'_s$ 5. $D + L + T_o + H_o + W'$	See note 2
abnormal	6. $D + L + T_a + R_a + 1.5 P_a$	6. $D + L + (T_o + T_a) + R + 1.25 P_a + H_a$	See note 1
abnormal/severe environmental	7. $D + L + T_a + 1.25 P_a + 1.0 (Y_r + Y_j + Y_m) + 1.25 E + R_a$	7. $D + L + (T_o + T_a) + 1.25 P_a + R + 1.25 E + D_s$	
abnormal/extreme environmental conditions	8. $D + L + T_a + R_a + 1.0 P + 1.0 (Y_r + Y_j + Y_m) + 1.0 E'$	8. $D + L + (T_o + T_a) + R + 1.0 P + 1.0 E' + D'_s$	

- Notes: (1) Abnormal load combination in SSES-FSAR Table 3.8-9. Part C will be revised to read $D + L + (T_o + T_a) + R + 1.5 P_a + H_o$. All other load combinations will remain unchanged.
- (2) W' does not include W_m , tornado missile. Masonry walls are not used for protection of safety related equipment against tornado missiles.

ITEM NO. 3: Allowable Stresses

Allowable stresses provided in chapter 24 of UBC-79, as supplemented by the following modifications/exceptions shall apply.

- (a) When wind or seismic loads (OBE) are considered in the loading combinations, no increase in the allowable stresses are permitted.

RESPONSE:

Design and evaluation of masonry walls is based on a 33% increase in the allowable stress. This increase is permissible per UBC, 1979 and per ACI-531-79. The factor is also compatible with the 25% increase in stress noted in SSES FSAR for Working Stress Design Method.

- ITEM NO. 3: (b) Use of allowable stresses corresponding to special inspection category shall be substantiated by demonstration of compliance with the inspection requirements of the NRC criteria.

RESPONSE:

Stresses corresponding to special inspection have been used in the design and evaluation of SSES masonry walls. Inspection required to assure that masonry construction is in accordance with Appendix "D" and amendments to the PSAR, and to assure that materials are in accordance with FSAR Appendix 3.8C is implemented. Documentation of this inspection is in project jobsite files.

- ITEM NO. 3: (c) For load conditions, which represent extreme environmental, abnormal, abnormal/severe environmental, and abnormal/extreme environmental conditions the allowable working stresses may be multiplied by the factors shown in the following table: (See table 4).

TABLE 4.

STRESS INCREASE FACTOR COMPARISON

	SEB	SSES	
	FACTOR	FACTOR	JUSTIFICATION/COMMENT
Axial or flexural compression	2.5	1.67	See Response Question #1
Bearing	2.5	1.67	"
Reinforcement stress except shear	2.0	1.67	See note 1
Shear Reinforcement and/or bolts	1.5	1.5	Anchor bolts are not used in safety related masonry walls
Masonry tension Parallel to bed joint	1.5	1.5	
Shear carried by masonry	1.0	1.67	See note 2
Masonry tension perpendicular to bed joint			
For reinforced masonry	0	0	
For unreinforced masonry	1.0	N/A	No unreinforced masonry walls

(1) Shall not exceed .90 fy

(2) The actual shear stress carried by masonry is within the allowable shear stress given in UBC Table 24-H with no increase factor applied.

RESPONSE:

See table above.



QUESTION NO. 5: Design and Analysis Considerations

ITEM 4g:

In new construction, no unreinforced masonry wall is permitted, also all grout in concrete masonry walls shall be compacted by vibration.

RESPONSE:

- a. There are no unreinforced masonry walls in SSES project.
- b. Cell grout and/or infill grout or concrete is compacted by either mechanical vibrators or by rodding.

ITEM 4i:

Special constructions (e.g., multiwythe, composite) or other items not covered by the code shall be reviewed on a case by case basis for their acceptance.

RESPONSE:

Double wythe walls are designed as composite sections, except as noted in response to Question No. 2. Allowable stresses are per ACI-531-79.

ITEM 4j:

Licensees or applicants shall submit QA/QC information, if available, for staff's review.

RESPONSE:

Applicable QA/QC information is available at SSES jobsite and will be submitted upon request.



ENCLOSURE 1.

JUSTIFICATION FOR THE USE OF

AVERAGE RESPONSE SPECTRA
(13 PAGES)



JUSTIFICATION OF USING APPROXIMATION METHOD TO

DETERMINE MAXIMUM WALL PANEL RESPONSES TO SEISMIC MOTION

The evaluations herein demonstrate that: (1) The use of the average floor acceleration response spectra to calculate the response of the wall panel is appropriate, and (2) The use of uniform inertia load with magnitude equal to the average spectral acceleration for the fundamental mode, in calculating the maximum seismic responses is a good approximation, even considering the higher mode effect.

For the purposes of this evaluation, the seismic response of a simply-supported, uniform beam simulating a strip of the wall panel with unit width is considered, as shown in Figure 1.

(1) Use of Average Spectra

The equation of motion of an undamped, simply-supported beam can be written in terms of the total displacement with respect to some fixed reference axis as:

$$m \frac{\partial^2 u}{\partial t^2} + EI \frac{\partial^4 u}{\partial x^4} = 0 \quad (1)$$

Where m and EI are the mass density and flexural rigidity of the beam. Denote the seismic excitations at the ends of the



the beam as U_a and U_b . Then the total displacement $u(x,t)$ can be expressed in terms of the two seismic motions and the relative displacement to the seismic motions as:

$$u(x,t) = (x/L) U_b + (1 - x/L) U_a + r(x,t) \quad (2)$$

Where L is the length of the beam. The relation expressed by the above equation is shown in Figure 2. The relative displacement $r(x,t)$ needs to satisfy the following simply-supported conditions:

$$r(0,t) = r(L,t) = 0 \quad (3)$$

$$\frac{\partial^2 r}{\partial x^2} \Big|_{x=0} = \frac{\partial^2 r}{\partial x^2} \Big|_{x=L} = 0 \quad (4)$$

Substitute Equation 2 into Equation 1, the equation of motion in terms of relative displacement $r(x,t)$ can be expressed as:

$$m \frac{\partial^2 r}{\partial t^2} + EI \frac{\partial^4 r}{\partial x^4} = -m(x/L) \ddot{U}_b - m(1 - x/L) \ddot{U}_a \quad (5)$$



The eigen-function solutions for the homogeneous equation associated with Equation 5 that satisfy the boundary conditions specified by Equations 3 and 4 are:

$$\sin \frac{n\pi x}{L}, \quad n = 1, 2, 3, \dots,$$

and the corresponding frequencies of vibration are:

$$\omega_n = n^2 \pi^2 \sqrt{\frac{EI}{mL^4}}, \quad n = 1, 2, 3, \dots \quad (6)$$

So, the solution of Equation 5 can be expressed as:

$$r(x,t) = \sum_{n=1}^{\infty} a_n(t) \sin \frac{n\pi x}{L} \quad (7)$$

Substitute Equation 7 into Equation 5, and multiply the latter by $\sin \frac{n\pi x}{L}$, and then integrate it with respect

to x over the full length of the beam, the equation of motion can be transformed into modal equations of motion as:

$$\ddot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a + \ddot{u}_b}{2} \right) \quad n = 1, 3, 5, \dots \quad (8a)$$

and

$$\ddot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a - \ddot{u}_b}{2} \right) \quad n = 2, 4, 6, \dots \quad (8b)$$

where r_n = participation factor

$$= \frac{4}{n\pi} \quad (9)$$

If damping in the form of modal damping ratio is included, Equations 8a and 8b becomes:

$$\ddot{a}_n + 2\xi_n \omega_n \dot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a + \ddot{u}_b}{2} \right) \quad n = 1, 3, 5, \dots \quad (10a)$$

and

$$\ddot{a}_n + 2\xi_n \omega_n \dot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a - \ddot{u}_b}{2} \right) \quad n = 2, 4, 6, \dots \quad (10b)$$

Where ξ_n is the damping ratio of the n^{th} mode.



Equation 10a means that the odd-number modes which are symmetrical about the mid-span of the beam will be excited by the average of the two seismic excitations; while equation 10b means that the even-number modes which are antisymmetrical about the mid-span of the beam will be excited by half of the difference between the two seismic excitations.

Expressing the maximum modal displacement response in equations 10a and 10b in terms of absolute acceleration response spectra gives:

$$|a_n|_{\max} \leq |r_n| \left[\frac{S_a(\xi_n, \omega_n)}{2\omega_n^2} + \frac{S_b(\xi_n, \omega_n)}{2\omega_n^2} \right]$$

$$< \frac{4mL^4}{n^5 \pi^5 EI} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (11)$$

$$n = 1, 2, 3, \dots$$

This illustrates that the use of the average of two floor acceleration response spectra to calculate the modal response of a wall panel is appropriate.

(2) Contribution of Higher Modes

From Equation 11, the relative importance of modes can be evaluated by examining the frequency ratios, modal participation ratios, and maximum modal response ratios for constant acceleration which can be shown as:

$$\omega_1 : \omega_2 : \omega_3 : \dots = 1 : 4 : 9 : \dots \quad (12)$$

$$\Gamma_1 : \Gamma_2 : \Gamma_3 : \dots = 1 : -1/2 : 1/3 : \dots \quad (13)$$

$$\frac{\Gamma_1}{\omega_1^2} : \frac{\Gamma_2}{\omega_2^2} : \frac{\Gamma_3}{\omega_3^2} : \dots = 1 : -\frac{1}{32} : \frac{1}{243} : \dots \quad (14)$$

For an SRSS method of combining maximum response, the contribution of higher modes is clearly negligible.

If for example, the fundamental frequency ω_1 is above 8 H_z , the second frequency is above 32 H_z which is already in the rigid range, i.e., in the range of no amplification. Thus the S_a and S_b values associated with modes other than the fundamental will be the Zero-Period-Acceleration (ZPA) values of the two seismic motions U_a and U_b . Using the absolute sum (ABS) method of combining the modal maximum responses, ^{in this case} the contribution of higher modes is not more than .4% of the fundamental mode.

The relative importance of modes can also be evaluated by examining the moment and shear responses in the beam for each mode, as shown in the following.

The moment in the beam due to the n^{th} mode can be evaluated by:

$$M_n(X) = EI \frac{\partial^2}{\partial X^2} \left[a_n \sin \left(\frac{n\pi X}{L} \right) \right] \quad (15)$$

$$< \frac{4mL^2}{n^3 \pi^3} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \sin \left(\frac{n\pi X}{L} \right)$$

$$n = 1, 2, 3, \dots$$

The moment at the mid-span of the beam is contributed only by the symmetrical modes and can be expressed as follows:

$$M_n \left(\frac{L}{2} \right) < \frac{4mL^2}{n^3 \pi^3} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (16)$$

$$n = 1, 3, 5, \dots$$

For a constant spectral acceleration, the contribution to the mid-span moment of the beam from each mode can be expressed in the following ratio:

$$M_1\left(\frac{L}{2}\right) : M_3\left(\frac{L}{2}\right) : M_5\left(\frac{L}{2}\right) : \dots = 1 : \frac{1}{27} : \frac{1}{125} : \dots \quad (17)$$

Using the SRSS Method of combining modal responses, the contribution of the higher modes to the mid-span moment is less than 1% of that from the fundamental modes. Using the ABS method of combining modal responses, the contribution of higher modes is less than about 5%.

The shear force in the beam due to the n^{th} mode can be evaluated as:

$$Q_n(X) = EI \frac{\partial^3}{\partial X^3} \left[a_n \sin\left(\frac{n\pi X}{L}\right) \right]$$

$$< \frac{4mL}{n^2\pi^2} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \cos\left(\frac{n\pi X}{L}\right) \quad (18)$$

$$n = 1, 2, 3, 4, \dots$$

The maximum shear occurs at the support of the beam and can be expressed as:

$$Q_n(0) \leq \frac{4mL}{n^2\pi^2} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (19)$$

$$n = 1, 2, 3, 4, \dots$$

The contribution of the higher modes to the maximum shear at the beam support relative to that of the fundamental mode can be evaluated by comparing the modal effective masses (MEM) associated with the fundamental mode and the higher modes. The modal effective mass of the fundamental mode is

$$MEM_1 = \frac{8mL}{\pi^2} = 0.81 \text{ mL} \quad (20a)$$

The modal effective mass associated with modes higher than the fundamental mode can be calculated as

$$MEM_1' = (1 - 0.81)mL = 0.19 \text{ mL} \quad (20b)$$

The ratio of MEM_1' TO MEM_1 is $0.19/0.81 = 23\%$. That is the contribution of higher modes to the maximum shear is at most 23% of the contribution due to the fundamental mode. This ratio does not take into account the ratio of the spectral

acceleration for the fundamental mode to the ZPA value for the higher modes. When the difference in spectral accelerations is accounted for, the contribution of higher modes to the maximum shear would be less than 23%. For example, if the spectral acceleration for the fundamental mode is 1.5 ZPA, then the ratio of higher mode contribution would be $0.19/(0.81 \times 1.5) = 16\%$.

(3) Uniform Inertia Load Approximation

Using the modal responses, the maximum moment and shear of the beam can be calculated. This moment and shear can then be compared to the moment and shear based on a uniform inertia load using the average of the two floor spectral accelerations at the fundamental mode of the beam.

The maximum moment occurred at the mid-span of the beam induced by a uniform load with the following magnitude:

$$f(X) = m \left[\frac{S_a (\xi_1, \omega_1) + S_b (\xi_1, \omega_1)}{2} \right] \quad (21)$$

can be expressed as:

$$M^* \left(\frac{L}{2} \right) = \frac{mL^2}{8} \left[\frac{S_a (\xi_1, \omega_1) + S_b (\xi_1, \omega_1)}{2} \right] \quad (22)$$



From Equation 16, the moment at the mid-span of the beam due to the fundamental mode is:

$$M_1\left(\frac{L}{2}\right) < \frac{4mL^2}{\pi^3} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (23)$$

The maximum difference between the moments from Equations 22 and 23 is about 3%.

The maximum shear occurred at the support of the beam induced by the uniform load expressed in Equation 21, can be written as:


$$Q^*(0) = \frac{mL}{2} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (24)$$

From Equation 19, the shear at the support of the beam due to the fundamental mode is:

$$Q_1(0) < \frac{4mL}{\pi^2} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (25)$$


The shear from Equation 24 is greater than the shear from Equation 25 by about 25%. This margin can well cover the contribution to the shear due to the higher mode effect, as discussed previously.

From the above comparison, it can be concluded that the use of a uniform inertia load with the magnitude of the averaged floor spectral acceleration at the fundamental mode, provides a good approximation for calculating the seismic response in the wall panel.



IDEALIZED SIMPLY-SUPPORTED UNIFORM BEAM

FIGURE No 1



RELATION BETWEEN SEISMIC EXCITATION
AND RELATIVE DISPLACEMENT

FIGURE No 2




ENCLOSURE 2


TYPICAL WALL FIXES

TYPE 1
TYPE 2
TYPE 3
TYPE 4







TYPE 1
ANGLE BRACING TO CONCRETE



TYPE 2
ANGLE BRACING TO STEEL



TYPE 3
CONTINUOUS ANGLE



TYPE 4
INTERMITTENT SUPPORTS

CALCULATION COVER SHEET

DB NO. 8856

DISCIPLINE MECHANICAL

COVER SH. A OF A
CALC. NO. M152-7
NO. OF SHEETS 10
Q. NO. SLP

TITLE ALTERNATE SHUTDOWN COOLING

CALC. SHEET CONTROL:

SUBJECT CORE SPRAY PUMP OPERATION IN
THE ALTERNATE SHUTDOWN COOLING
MODE.

STATEMENT OF PROBLEM DETERMINE CORE SPRAY
PUMP OPERATING POINTS IN ALTERNATE
SHUTDOWN COOLING MODE WITH ONE OR
MORE MAINSTREAM RELIEF VALVES OPEN.

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: HBB-104-1, REV. 8, GBB-101-2, REV. 3
DBB-113-1 REV. 3, DCA-109-1 REV. 5, DCA-107-1, REV. 11.

SOURCES OF FORMULAE & REFERENCES 1) CORE SPRAY PUMP CALCS M152-6, REV. 1
2) CRANE TECHNICAL PAPER NO. 410, 1979 EDITION
3) CORE SPRAY PUMP PERFORMANCE CURVE 8856-M1-E21-30-1
4) CORE SPRAY PROCESS DIAGRAM 8856-M1-E21-15-2
5) CROSBY VALVE ENGINEERING AND CAPACITY DATA, CAT. #302, SUP. 1
6) PSV OUTLINE DWG. 8856-M1-B21-64-2

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
	4/23/81	J. J. Brunner / <i>[Signature]</i>	David Yang	5/4/81	E. Connolly	5/4/81

*Preliminary calcs checked only at group supervisor's request.

**Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.

8856-QA-2(1/74)



CALCULATION SHEET

CALC. NO. M 162-7 REV. NO. 0ORIGINATOR J. J. Brunner DATE 4/23/81 CHECKED B. Yang DATE 5-4-81PROJECT SUSQUEHANNA JOB NO. 8856SUBJECT CORE SPRAY PUMPS IN SHEET NO. 1 of 10ALTERNATE SHUTDOWN COOLING MODE

ASSUMPTIONS

1. Based on vendor catalog information the C_v value for fully open main steam relief valve (PSV F013) is assumed to be within the range of 400 to 500 gpm. Both values (400 & 500) were used in these calculations. An estimate of the C_v value is presented in Appendix A of this calculation.
2. Backpressure in PSV discharge line is neglected because of large line diameter (12").
3. Friction losses in main steam piping are negligible and thus are omitted.
4. Calculation reflects a steady state condition. Inlet flow is equal to outlet flow. Water level in RPV is assumed to be 3 ft above center line of main steam nozzle.
5. No venting of RPV dome occurs.

SUMMARY AND CONCLUSIONS

- a) With only one PSV open, pumps will pressurize RPV above shutdown initiation pressure of 98 psig. This could be prevented by throttling with core spray valve. It is preferable, however, that a second PSV be opened to lower reactor pressure below shutdown initiation pressure.
- b) Calculations show (see page 9) that with 4 PSV open, runout flow of 7900 gpm will be reached with a valve C_v of 500.



CALCULATION SHEET

ORIGINATOR J. J. Brunner

DATE 4/23/81

CALC. NO. 17152-7

REV. NO. 0

PROJECT SUSQUEHANNA

CHECKED guy

DATE 5-4-81

SUBJECT Core Spray Pumps in Alt.
Shutdown Cooling Mode


JOB NO. 8856

SHEET NO. 2 OF 10

Use Core Spray Mode D

PRPV = 105 psig (use 98 psig for
TRPV = 332 °F shutdown cooling
Tpool = 170 °F initiation)
Ppool = 14.7 psia } (Ref. 4)

Assume water level ~ 3 ft above M.S. nozzle





CALCULATION SHEET

ORIGINATOR J. J. BrunnerDATE 4/23/81CALC. NO. M152-7REV. NO. 0PROJECT SUSQUEHANNACHECKED QuigDATE 5-4-81SUBJECT CORE SPRAY PUMPS INJOB NO. 8856SHEET NO. 3 of 10ALTERNATE SHUTDOWN COOLING MODE

TOTAL SYSTEM'S RESISTANCE

$$H_T = H_s + H_p + H_f$$

Static Head - with water level at approx. 3 ft above main steam nozzle ϕ

$$H_s = 790' - 670' = 120'$$

Pressure Head

$$H_p = \frac{144}{\rho} \cdot P_{psv} - H_0$$

where:

$$\Delta P_{psv} = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2 \quad (\text{Ref. 2})$$

with zero back pressure. $\Delta P_{psv} = P_{psv}$
 $H_0 = \text{stat. head at PSV } \phi = 45.9' \text{ (see page 9)}$

Friction Head

$$H_f = \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

condition calculated for Mode D
(see Ref 1 sht. 78)

$$\begin{aligned} Q_c \text{ (2 pumps)} &= 6350 \text{ gpm} \\ H_{fc} &= 277.3 \text{ ft} \end{aligned}$$

$$H_T = H_s + \frac{144}{\rho} \left(\frac{Q}{C_v} \right)^2 - H_0 + \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

$$\text{RPV Pressure} = P_{psv} - \frac{\rho}{144} H_0$$



CALCULATION SHEET

ORIGINATOR I. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
 PROJECT SUSQUEHANNA CHECKED JWJ DATE 5-4-81
 SUBJECT Core Spray Pumps in Alternate Shutdown Mode JOB NO. 8856
 SHEET NO. 4 of 10
ONE PSV IS OPEN

$$C_v = 400$$

Q	2000	4000	6000	8000
H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{400} \right)^2 - 45.9$	11.8	184.9	473.3	877
H _f = $\left(\frac{Q}{6350} \right)^2 \times 277.3$	27.5	110	247.5	440
H _{tot}	159.3	414.9	840.8	1437

$$C_v = 500$$

H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{500} \right)^2 - 45.9$	9	101.8	286	545
H _f	27.5	110	247.5	440
H _{tot}	N/A	331.8	653.5	1105

PRPV with 1 PSV @ C_v = 400 Q = 5,450 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{5450}{400} \right)^2 - 45.9 \right] = 149.3 \text{ psig}$$

PRPV with 1 PSV @ C_v = 500 Q = 6,130 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{6130}{500} \right)^2 - 45.9 \right] = 117.4 \text{ psig}$$



CALCULATION SHEET

CALC. NO. 17152-7 REV. NO. 0
 CHECKED QWJ DATE 5-4-81
 JOB NO. 8856
 SHEET NO. 5 of 10

ORIGINATOR J. J. Brunner DATE 4/23/81
 PROJECT SUSQUEHANNA
 SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode

TWO PSV OPEN

$$C_v = 400$$

Q TOTAL

2000 4000 6000 8000

Q PSV

1000 2000 3000 4000

H_s

120 120 120 120

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{400} \right)^2 - 45.9$$

-31.5 11.8 83.9 184.9

$$H_f = \left(\frac{Q}{6350} \right)^2 \cdot 277.3$$

27.5 110 247.5 440

H_{tot}

N/A 241.8 451.4 744.9

$$C_v = 500$$

H_s

120 120 120 120

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{500} \right)^2 - 45.9$$

-36.7 -9 37.2 101.8

$$H_f = \left(\frac{Q}{6350} \right)^2 \cdot 277.3$$

27.5 110 247.5 440

N/A N/A 404.7 661.8

PRPV @ C_v = 400

$$Q_{psv} = 7,150/2 = 3,575 \text{ gpm}$$

$$P_{RPV} = \frac{57.2}{144} \left[\frac{144}{62.4} \left(\frac{3575}{400} \right)^2 - 45.9 \right] = 55 \text{ psig}$$

PRPV @ C_v = 500

$$Q_{psv} = 7420/2 = 3,710 \text{ gpm}$$

$$P_{RPV} = \frac{58}{144} \left[\frac{144}{62.4} \left(\frac{3710}{500} \right)^2 - 45.9 \right] = 32.7 \text{ psig}$$





CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M/52-7 REV. NO. 0
 PROJECT Susquehanna CHECKED JWG DATE 5-4-81
 SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode JOB NO. 8856
 SHEET NO. 6 of 10

THREE PSV OPEN

$$C_v = 400$$

Q_{TOTAL}

3000 6000 9000

Q_{PSV}

1000 2000 3000

$$H_s = 120$$

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{400} \right)^2 - 45.9$$

$$H_f = (Q_t / 6350)^2 \cdot 277.3$$

$$H_{tot}$$

120	120	120
-31.5	11.8	83.9
61.9	247.5	557.0
N/A	379.3	760.9

$$C_v = 500$$

$$H_s = 120$$

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{500} \right)^2 - 45.9$$

$$H_f = (Q_t / 6350)^2 \cdot 277.3$$

$$H_{tot}$$

120	120
-9	37.2
247.8	557.
N/A	714.2

$P_{RPV} @ C_v = 400$

$$Q_{PSV} = 7600 / 3 = 2,533 \text{ gpm}$$

$$P_{RPV} = \frac{58.4}{144} \left[\frac{144}{62.4} \left(\frac{2,533}{400} \right)^2 - 45.9 \right] = 18.9 \text{ psig}$$

$P_{RPV} @ C_v = 500$

$$Q_{PSV} = 7720 / 3 = 2,590 \text{ gpm}$$

$$P_{RPV} = \frac{59.5}{144} \left[\frac{144}{62.4} \left(\frac{2,590}{500} \right)^2 - 45.9 \right] = 6.6 \text{ psig}$$



CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81

CALC. NO. M152-7 REV. NO. 0

CHECKED DWJ DATE 5-4-81

PROJECT Susquehanna

JOB NO. 8856

SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode

SHEET NO. 7 of 10

FOUR PSV OPEN

$$C_V = 400$$

Q_{TOT}

6000 8000 9000

Q_V

1500 2000 2250

$$H_S = \frac{144}{62.4} \left(\frac{Q_V}{400} \right)^2 - 45.9$$

$$H_P = \left(Q_V / 6350 \right)^2 \cdot 277.3$$

$$H_{tot}$$

120	120	120
-13.4	11.8	27.1
247.8	440	557
N/A	571.8	704.1

$$C_V = 500$$

$$H_S = \frac{144}{62.4} \left(\frac{Q_V}{500} \right)^2 - 45.9$$

$$H_P = \left(Q_V / 6350 \right)^2 \cdot 277.3$$

$$H_{tot}$$

120	120
-9	0.8
440	557
N/A	677.8

$$PRPV @ C_V = 400$$

$$Q_{PSV} = 7780 / 4 = 1945 \text{ gpm}$$

$$PRPV = \frac{59.6}{144} \left[\frac{144}{62.4} \left(\frac{1945}{400} \right)^2 - 45.9 \right] = 3.5 \text{ psig}$$

$$PRPV @ C_V = 500$$

$$Q_{PSV} = 7900 / 4 = 1975 \text{ gpm}$$

$$PRPV = \frac{59.8}{144} \left[\frac{144}{62.4} \left(\frac{1975}{500} \right)^2 - 45.9 \right] =$$

(NEG)

atmospheric





CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
PROJECT SUREVEHANNA CHECKED guy DATE 5-4-81
SUBJECT CORE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE JOB NO. 8856 SHEET NO. 8 of 10

Determine Amount of Throttling Required to Match Initiation Pressure of 98 psig with one PCV open.

With 0 back pressure:

$$P_{PSV} = P_{RPV} + \frac{P_{HD}}{144} = 98 + \frac{56.2 \cdot 45.9}{144} = 115.9 \text{ psig}$$

Flow through PSV

$$P_{PSV} = \frac{P}{62.4} \left(\frac{Q}{C_V} \right)^2$$

$$\therefore Q = \left(P_{PSV} \frac{62.4}{P} \cdot C_V^2 \right)^{0.5} = C_V \cdot \left(P_{PSV} \frac{62.4}{P} \right)^{0.5}$$

$$\text{For } C_V = 400: Q = 400 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 4528$$

$$\text{For } C_V = 500: Q = 500 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 5660 \text{ gpm}$$

Amount of throttling for above flows are shown on sht. 9.



CORE SPRAY PUMP OPERATION IN ALTERNATE SHUTDOWN COOLING MODE

Y-axis: HEAD (FT) [0 to 1000]

X-axis: FLPW (1000 GPM) [0 to 8]

Curves shown:

- TWO PUMPS (downward sloping)
- PRPV = 98 (vertical line)
- PRPV = 149.3 (vertical line)
- PRPV = 298 (vertical line)
- PRPV = 447.4 (vertical line)
- PRPV = 596.4 (vertical line)
- PRPV = 745.4 (vertical line)
- PRPV = 894.4 (vertical line)
- PRPV = 1043.4 (vertical line)
- PRPV = 1192.4 (vertical line)
- PRPV = 1341.4 (vertical line)
- PRPV = 1490.4 (vertical line)
- PRPV = 1639.4 (vertical line)
- PRPV = 1788.4 (vertical line)
- PRPV = 1937.4 (vertical line)
- PRPV = 2086.4 (vertical line)
- PRPV = 2235.4 (vertical line)
- PRPV = 2384.4 (vertical line)
- PRPV = 2533.4 (vertical line)
- PRPV = 2682.4 (vertical line)
- PRPV = 2831.4 (vertical line)
- PRPV = 2980.4 (vertical line)
- PRPV = 3129.4 (vertical line)
- PRPV = 3278.4 (vertical line)
- PRPV = 3427.4 (vertical line)
- PRPV = 3576.4 (vertical line)
- PRPV = 3725.4 (vertical line)
- PRPV = 3874.4 (vertical line)
- PRPV = 3923.4 (vertical line)
- PRPV = 3972.4 (vertical line)
- PRPV = 4021.4 (vertical line)
- PRPV = 4070.4 (vertical line)
- PRPV = 4119.4 (vertical line)
- PRPV = 4168.4 (vertical line)
- PRPV = 4217.4 (vertical line)
- PRPV = 4266.4 (vertical line)
- PRPV = 4315.4 (vertical line)
- PRPV = 4364.4 (vertical line)
- PRPV = 4413.4 (vertical line)
- PRPV = 4462.4 (vertical line)
- PRPV = 4511.4 (vertical line)
- PRPV = 4560.4 (vertical line)
- PRPV = 4609.4 (vertical line)
- PRPV = 4658.4 (vertical line)
- PRPV = 4707.4 (vertical line)
- PRPV = 4756.4 (vertical line)
- PRPV = 4805.4 (vertical line)
- PRPV = 4854.4 (vertical line)
- PRPV = 4903.4 (vertical line)
- PRPV = 4952.4 (vertical line)
- PRPV = 5001.4 (vertical line)
- PRPV = 5050.4 (vertical line)
- PRPV = 5099.4 (vertical line)
- PRPV = 5148.4 (vertical line)
- PRPV = 5197.4 (vertical line)
- PRPV = 5246.4 (vertical line)
- PRPV = 5295.4 (vertical line)
- PRPV = 5344.4 (vertical line)
- PRPV = 5393.4 (vertical line)
- PRPV = 5442.4 (vertical line)
- PRPV = 5491.4 (vertical line)
- PRPV = 5540.4 (vertical line)
- PRPV = 5589.4 (vertical line)
- PRPV = 5638.4 (vertical line)
- PRPV = 5687.4 (vertical line)
- PRPV = 5736.4 (vertical line)
- PRPV = 5785.4 (vertical line)
- PRPV = 5834.4 (vertical line)
- PRPV = 5883.4 (vertical line)
- PRPV = 5932.4 (vertical line)
- PRPV = 5981.4 (vertical line)
- PRPV = 6030.4 (vertical line)
- PRPV = 6079.4 (vertical line)
- PRPV = 6128.4 (vertical line)
- PRPV = 6177.4 (vertical line)
- PRPV = 6226.4 (vertical line)
- PRPV = 6275.4 (vertical line)
- PRPV = 6324.4 (vertical line)
- PRPV = 6373.4 (vertical line)
- PRPV = 6422.4 (vertical line)
- PRPV = 6471.4 (vertical line)
- PRPV = 6520.4 (vertical line)
- PRPV = 6569.4 (vertical line)
- PRPV = 6618.4 (vertical line)
- PRPV = 6667.4 (vertical line)
- PRPV = 6716.4 (vertical line)
- PRPV = 6765.4 (vertical line)
- PRPV = 6814.4 (vertical line)
- PRPV = 6863.4 (vertical line)
- PRPV = 6912.4 (vertical line)
- PRPV = 6961.4 (vertical line)
- PRPV = 7010.4 (vertical line)
- PRPV = 7059.4 (vertical line)
- PRPV = 7108.4 (vertical line)
- PRPV = 7157.4 (vertical line)
- PRPV = 7206.4 (vertical line)
- PRPV = 7255.4 (vertical line)
- PRPV = 7304.4 (vertical line)
- PRPV = 7353.4 (vertical line)
- PRPV = 7402.4 (vertical line)
- PRPV = 7451.4 (vertical line)
- PRPV = 7500.4 (vertical line)
- PRPV = 7549.4 (vertical line)
- PRPV = 7598.4 (vertical line)
- PRPV = 7647.4 (vertical line)
- PRPV = 7696.4 (vertical line)
- PRPV = 7745.4 (vertical line)
- PRPV = 7794.4 (vertical line)
- PRPV = 7843.4 (vertical line)
- PRPV = 7892.4 (vertical line)
- PRPV = 7941.4 (vertical line)
- PRPV = 7990.4 (vertical line)
- PRPV = 8039.4 (vertical line)
- PRPV = 8088.4 (vertical line)
- PRPV = 8137.4 (vertical line)
- PRPV = 8186.4 (vertical line)
- PRPV = 8235.4 (vertical line)
- PRPV = 8284.4 (vertical line)
- PRPV = 8333.4 (vertical line)
- PRPV = 8382.4 (vertical line)
- PRPV = 8431.4 (vertical line)
- PRPV = 8480.4 (vertical line)
- PRPV = 8529.4 (vertical line)
- PRPV = 8578.4 (vertical line)
- PRPV = 8627.4 (vertical line)
- PRPV = 8676.4 (vertical line)
- PRPV = 8725.4 (vertical line)
- PRPV = 8774.4 (vertical line)
- PRPV = 8823.4 (vertical line)
- PRPV = 8872.4 (vertical line)
- PRPV = 8921.4 (vertical line)
- PRPV = 8970.4 (vertical line)
- PRPV = 9019.4 (vertical line)
- PRPV = 9068.4 (vertical line)
- PRPV = 9117.4 (vertical line)
- PRPV = 9166.4 (vertical line

CALCS H152-7, REV 0

BY: ~~SA~~ 4/28/01 CHKD: DMW 5-4-8/

SHEET 9 OF 10



CALCULATION SHEET

ORIGINATOR J. J. Brunner

DATE 4/30/81

CALC. NO. M152-7 REV. NO. 0

CHECKED guy DATE 5-4-81

PROJECT SHISHUEHANNA

JOB NO. 8856

SUBJECT CORE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE SHEET NO. 10 OF 10

APPENDIX A

ESTIMATE OF VALVE FLOW COEFFICIENT C_V

Valve capacity (per Ref. 5 for liquid)

$$Q = 27.2 C_A A K_{sg} \sqrt{\frac{P - P_b}{\Delta P}}$$

(gpm)

where: C_A = correction factor for accum. press.
assume 1

$$K_{sg} = 1 \text{ (for water)}$$

$$P_b = 0 \text{ assuming no back pressure.}$$

$$A = 16 \text{ orifice area for Crosby style 6 R10HB-65-BP (see Ref. 5 & 6)}$$

$$Q = 27.2 \cdot 16 \cdot \sqrt{\Delta P} = 435.2 \sqrt{\Delta P}$$

$$\text{From flow equation } \Delta P = \frac{Q^2}{62.4 \left(\frac{Q}{C_V}\right)^2}$$

$$\text{or: } Q = C_V \sqrt{\frac{62.4}{Q} \Delta P}$$

By substitution:

$$435.2 \sqrt{\Delta P} = C_V \sqrt{\frac{62.4}{Q} \Delta P}$$

$\therefore$

$$C_V = \frac{435.2}{\sqrt{\frac{62.4}{Q}}}$$

$$P = 59.8 \text{ lb/ft}^2$$

$$P = 14.7 \text{ psia}$$

$$T = 212^\circ F$$

$$C_V = \frac{435.2}{\sqrt{\frac{62.4}{59.8}}} = 427$$





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

JOB NO. 8856

DISCIPLINE MECHANICAL/NUCLEAR

COVER SH. A OF A-B
CALC. NO. 152-6
NO. OF SHEETS 102
Q NO. 51.0

TITLE CORE SPRAY CALCULATIONS

SUSQUEHANNA STATION UNITS 1 & 2
PENNSYLVANIA P & L JOB 8856

SUBJECT PRESSURE DROPS IN THE CORE SPRAY SYSTEM
OF UNITS 1 AND 2 FOR VARIOUS MODES OF
OPERATION.

STATEMENT OF PROBLEM COMPUTE PRESSURE DROPS IN THE
CORE SPRAY SYSTEM FOR UNITS 1 AND 2 UNDER
VARIOUS MODES OF OPERATION IN ORDER TO SIZE
FLOW ORIFICES AND TO VERIFY LINE SIZES, NPSH,
AND OPERATING CONDITIONS.

CALC. SHEET CONTROL:

REVISION 0:
REVISED PAGES:
3, 6, 12, 14, 15, 18, 26, 35, 36,
40, 48, 51, 56, 60, 68, 71, 77, 78
ADDED PAGES:
12A, 12B, 12C, 12D, 12E, 12F,
78A, 78B, 78C.
DELETED PAGE: 57

REVISION 1:
REVISED PAGES:
3, 35, 38, 49, 58, 69, 80
ADDED PAGE: 3A

CAR CHECKED ☒

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: 8856-DBB-113-1 Rev 2, DBB-113-2 Rev 3, DCA-107-1 Rev 7, DCA-107-2 Rev 7,
DCA-109-1 Rev 4, DCA-109-2 Rev 4, GBB-101-1 Rev 4, GBB-101-2 Rev 3, GBB-101-3 Rev 2, GBB-101-4 Rev 7,
GBB-107-1 Rev 7, GBB-102-2 Rev 5, GBB-102-3 Rev 6, GBB-103-1 Rev 2, GBB-103-2 Rev 2, HCB-104-1 Rev 6,
HCB-104-2 Rev 7, HCB-103-1 Rev 3, HCB-103-2 Rev 3, HCB-101-2 Rev 4, HCB-101-1 Rev 3, HCB-102-1 Rev 2,
HCB-101-1 Rev 2, HCB-101-1 Rev 4, DBB-213-1 Rev 2, DBB-213-2 Rev 1, DCA-207-1 Rev 1, DCA-207-2 Rev 1,
DCA-204-1 Rev 1, DCA-209-2 Rev 1, GBB-201-1 Rev 2, GBB-201-2 Rev 3, GBB-201-3 Rev 2, GBB-201-4 Rev 2,
GBB-202-1 Rev 4, GBB-202-2 Rev 3, GBB-202-3 Rev 3, GBB-203-1 Rev 3, GBB-203-2 Rev 3, CONT NEXT PAGE

SOURCES OF FORMULAE & REFERENCES (1) CRANE TECHNICAL PAPER No. 410 (1965)
(2) G.E. PROCESS DIAGRAM, PROCESS DATA 8856-MI-E21-15-2 ✓
(3) GLOVER, TRAVIS F., "UNDERSTANDING NPSH FOR PUMPS" PLANT ENGINEERING, DEC. 24, 1975.
(4) PUMP PERFORMANCE CURVE 8856-MI-E21-30-1 ✓ (VPF No. 3308-149-1)
(5) DANIEL STEAM-LIQUID ORIFICE FLOW CALCULATOR
(6) PIPING SPECIFICATION M-199 Rev. 30
(7) POSTA, BENJENY, "BASIC GUIDANCE TO AVOID CAVITATION OF ORIFICES + VALVES" JUNE 21, 1974.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NOS. 152-5
152-4, 152-3, 152-2, 152-1

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
	6/21/79	G. KALINAUSKAS / H. Kalinauskas	W. Brown	8/20/79	R. M. Jackson	8/21/79
C	3/27/79	G. KALINAUSKAS / H. Kalinauskas	J. C. McCune	3-30-79	R. M. Jackson	4/6/79
A	11/8/78	G. KALINAUSKAS / H. Kalinauskas	E. Cornell	12-2-78	R. M. Jackson	1/2/79

*Preliminary calcs checked only at group supervisor's request.

**Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.



SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

JOB NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. B OF A-B
CALC. NO. 152-6
NO. OF SHEETS 1
Q NO. 510

TITLE CORE SPRAY CALCULATIONS

SUSQUEHANNA STATION UNITS 1 & 2
PENNSYLVANIA P & L JOB 8856

CALC. SHEET CONTROL:

SUBJECT

STATEMENT OF PROBLEM

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA CONT FROM PAGE 1: HBB-204-1 Rev 4, HBB-204-2 Rev 5, HBD-283-1 Rev 2,
HBD-283-2 Rev 1, HCB-201-1 Rev 5, HCD-211-1 Rev 3, HCD-215-1 Rev 6

VALVE Cr: 8856-P10A-1B-6 Rev D, P12A-15-4 Rev B, P12A-19-4 Rev C, P12A-22-7 Rev E,
P12A-25-5 Rev C, P12A-56-3 Rev A, P12A-63-5 Rev C, P12BC-15-6 Rev D, P12A-17-4 Rev B,
P17A-21-6 Rev D, P17A-26-5 Rev D, P18AC-2-6 Rev 4.

ORIFICE SIZES - J-30-39 Rev 0

SOURCES OF FORMULAE & REFERENCES

(8) P. & I. D. - CORE SPRAY - M-152 Rev 9

(9) AREA DRAWING - M-35-2 Rev 9

(10) EQUIPMENT LOCATION DRAWING - M-247 Rev 8.

(11) G.E. P. & I. D. - M1-E21-14-2

(12) G.E. DESIGN SPECIFICATION & DATA SHEETS - DOC. NO. 22A3053 Rev 0

(13) P. & I. D. - M-108 Rev 12

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

1	6/21/79	A. Kalinauskas				
3	3/27/79	A. Kalinauskas	J.C. McCague	3-30-79	B.M. Jackson	4/6/79
A	11/8/78	A. Kalinauskas	E. Connolly	12-2-78	B.M. Jackson	1/2/79
REV						



CALCULATION SHEET

CALC. NO. 152-6 REV. NO. 0
 CHECKED ECC DATE 12-2-78
 JOB NO. 8856
 SHEET NO. 79

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2
 SUBJECT PENNSYLVANIA P & L SPRAY CALCULATIONS JOB 8856

1 SECTION 3

2 NPSH CALCULATIONS

3 MODE A

$$5 \text{ NPSHA} = h_s - h_f + h_a - h_{vpa} \quad (\text{ref 3})$$

$$6 \text{ } h_f (120^\circ \text{F})$$

TABLE A-1

NODE	Eq. LENGTH on Cr	d (in.)	d ⁵ (in ⁵)	v (ft/sec)	ΔP (psi)
12 STRAINER - 2.1	ΔP = 2 psi C _v = 20,700	15.25	8.25 × 10 ⁵	11.14	2.0
13		15.25	8.25 × 10 ⁵	11.14	0.09
14	136'	15.25	8.25 × 10 ⁵	11.14	1.15
15 2.1 - 2.2	36'	15.25	8.25 × 10 ⁵	11.14	0.30
16 2.2 - 3 B	127'	15.25	8.25 × 10 ⁵	5.57	0.28
TOTAL ΔP =					3.82 psi

$$17 \rho (120^\circ \text{F}) = 61.73 \text{ lb/ft}^3 \quad (\text{ref 1 pg A-6})$$

$$18 \mu (120^\circ \text{F}) = 0.51 \text{ cp.} \quad (\text{ref 1 pg A-3})$$

20 STRAINER - 2.1 FOR VALVE FOOLB

$$21 \Delta P = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2 \quad (\text{ref 1 pg 2.9})$$

$$22 \Delta P = \frac{61.73}{62.4} \left(\frac{6350}{20,700} \right)^2$$

$$23 \Delta P = 0.09 \text{ psi}$$

26 FOR PIPE + FITTINGS:

$$27 v = 0.408 \frac{Q}{d^2} = 0.408 \frac{(6350)}{(15.25)^2} = 11.14 \text{ ft/sec.}$$

$$28 Re = 123.9 \frac{d v \rho}{\mu} = 123.9 \frac{(15.25)(11.14)(61.73)}{(0.51)} = 2.55 \times 10^6$$

$$30 f = 0.013 \quad (\text{from ref 1 pg A-25})$$

$$31 \Delta P = 0.000216 \frac{f L \rho Q^2}{d^5} = 0.000216 \frac{(0.013)(136)(61.73)(6350)^2}{8.25 \times 10^5}$$

$$32 \Delta P = 1.15 \text{ psi}$$





(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 1
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA PUMP & ACTIONS JOB 8856 JOB NO. 8856
 SHEET NO. 80

1 2.1 - 2.2

2 FOR PIPE + FITTINGS:

$$3 \quad \Delta P = 0.000216 \frac{f L Q^2}{d^5} = 0.000216 \frac{(0.013)(36)(61.73)(6350)^2}{8.25 \times 10^5}$$

$$4 \quad \Delta P = 0.30 \text{ psi}$$

5 2.1 - 3B

6 FOR PIPE + FITTINGS:

$$7 \quad v = 0.408 \frac{Q}{d^2} = 0.408 \frac{(3175)}{(15.25)^2} = 5.57 \text{ ft/sec} \rightarrow Q = 3175 \text{ gpm (ref 2)}$$

$$8 \quad Re = 123.9 \frac{d v \rho}{\mu} = 123.9 \frac{(15.25)(5.57)(61.73)}{(0.51)} = 1.27 \times 10^6$$

$$9 \quad f = 0.0135 \text{ (from ref 1 pg A-25)}$$

$$10 \quad \Delta P = 0.000216 \frac{f L Q^2}{d^5} = 0.000216 \frac{(0.0135)(127)(61.73)(3175)^2}{8.25 \times 10^5}$$

$$11 \quad \Delta P = 0.28 \text{ psi}$$

$$12 \quad h_f = 3.82 \text{ psi} \left(\frac{1}{61.73} \frac{\text{ft}^3}{\text{hr}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

$$13 \quad h_f = 8.91 \text{ ft}$$

$$14 \quad z_2 = 670' \text{ (min. water level in pool - assumed 1' below normal M-247 Rev 8)}$$

$$15 \quad z_1 = 646' 10^{5/8} \text{ (inlet level to pump - iso HBB-104-2 Rev 6)}$$

$$16 \quad h_s = (670' - 646' 10^{5/8})$$

$$17 \quad h_s = 23.11 \text{ ft}$$

$$18 \quad h_a = 33.16 \text{ ft (by calculation from ref 3 Table I)}$$

$$19 \quad h_{vpa} = 1.692 \frac{\text{hr}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{61.73 \text{ hr}} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 3.95 \text{ ft (ref 1 pg A-6)}$$

$$20 \quad \therefore \text{NPSHA} = h_s - h_f + h_a - h_{vpa} = 23.11 - 8.91 + 33.16 - 3.95$$

$$21 \quad \text{NPSHA} = 43.41 \text{ ft} \quad \text{NPSHR} = 2 \text{ ft (ref 4) or pg 13}$$



● CALCULATION SHEET ●

 CALC. NO. 152-6 REV. NO. 0

 ORIGINATOR G. KALINAUSKAS DATE NOV 08 1970 CHECKED ΣCC DATE 12-2-78

 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 JOB NO. 8856

 SUBJECT CORE SPRAY CALCULATIONS JOB 8856 SHEET NO. 81

1 MODE B

2

3
$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

4

 5 h_f

6

NODE

TABLE B.1

TABLE B.1

 ΔP

 OR C_r

(psi)

ENTRANCE

62'

0.27

15-16

250'

1.10

 $C_r = 18,470$

0.21

124'

0.72

 $C_r = 20,700$

0.16

108'

1.63

2.1-2.2

136'

0.54

2.2-3B

127'

0.51

 TOTAL $\Delta P = 6.14$ psi

$$h_f = 6.14 \text{ psi} \left(\frac{1 \text{ ft}^3}{62.27 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{1 \text{ ft}^2} \right)$$

$$h_f = 14.20 \text{ ft}$$

$$h_s = z_2 - z_1 \quad z_2 = 673' 9'' \text{ (outlet level from tank - see HCB-1-2 Rev 4)}$$

$$h_s = (673' 9'' - 646' 10 \frac{5}{8}'') \quad z_1 = 646' 10 \frac{5}{8}'' \text{ (inlet level to pump - see HBB-104-1 Rev 6)}$$

$$h_s = 26.86 \text{ ft}$$

$$h_a (674') = 33.16 \text{ ft} \quad (\text{by calculation from ref 3 Table I})$$

$$h_{vpa} (70^\circ F) = 0.363 \frac{\text{ft}}{\text{in}} \times \frac{1 \text{ ft}^3}{62.27 \text{ lb}} \times \frac{144 \text{ in}^2}{1 \text{ ft}^2} = 0.84 \text{ ft} \quad (\text{ref 1 pg A-6})$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 26.86 - 14.20 + 33.16 - 0.84$$

$$NPSHA = 44.98 \text{ ft.}$$

$$NPSHR = 19 \text{ ft (ref 2).}$$



(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA P&S CALCULATIONS JOB 8856 SHEET NO. 82

1 MODE C

2

3
$$NPSHA = h_s - h_f + h_a - h_{upa}$$

4

5 TABLE C.1

6

7 NODE	8 EQ. LENGTH OR C_v	9 ΔP (psi)
10 STRAINER - 2.1	11 $\Delta P = 2 \text{ psi}$ 12 $C_v = 20,700$	13 2.0
	14 136'	15 9.2×10^{-4}
16 2.1 - 2.2	17 36'	18 1.32×10^{-2}
19 2.2 - 3B	20 127'	21 3.5×10^{-3}
		22 3.35×10^{-3}
		23 TOTAL $\Delta P = 2.02 \text{ psi}$

24

25
$$h_f = 2.02 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ ft}^3} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

26

27
$$h_f = 4.84 \text{ ft}$$

28

29
$$h_s = z_2 - z_1$$

30
$$h_s = 23.11 \text{ ft}$$

31
$$z_2 = 670' \text{ (as before)}$$

32
$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

33
$$h_a (670') = 33.16 \text{ ft}$$

34

35
$$h_{upa} (200^\circ \text{F}) = 11.53 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.13 \text{ ft}^3} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 27.61 \text{ ft (ref 1 pg A-6)}$$

36
$$\therefore NPSHA = h_s - h_f + h_a - h_{upa}$$

$$NPSHA = 23.11 - 4.84 + 33.16 - 27.61$$

$$NPSHA = 23.82 \text{ ft}$$

$$NPSHR = 2 \text{ ft (ref 4) or pg 13}$$



(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-6-78
 SUBJECT CORE SPRAY CALCULATIONS JOB NO. 8856 SHEET NO. 83

1 MODE D

2

3
$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

4

5 TABLE D-1

6 NODE	7 EQ. LENGTH OR C_v	8 ΔP (psi)
9 STRAINER - 2-1	10 $\Delta P = 2 \text{ psi}$	11 2.0
	12 $C_v = 20,700$	13 0.09
	14 136'	15 1.09
16 2-1 - 2-2	17 36'	18 0.29
19 2-2 - 3B	20 127'	21 0.27
		22 TOTAL $\Delta P = 3.74 \text{ psi}$

23

24
$$h_f = 3.74 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

25

26
$$h_f = 8.86 \text{ ft}$$

27

28
$$h_s = z_2 - z_1$$

29
$$z_2 = 670' \text{ (as before)}$$

30
$$h_s = 23.11 \text{ ft}$$

31
$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

32

33
$$h_a (670') = 33.16 \text{ ft}$$

34

35
$$h_{vpa} (170^\circ \text{F}) = 5.99 \frac{\text{ft}}{\text{in}^2} \times \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}} \right) \times \frac{144 \text{ in}^2}{\text{ft}^2} = 14.19 \text{ ft} \quad (\text{ref 1 pg A-6})$$

36

37
$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

38
$$NPSHA = 23.11 - 8.86 + 33.16 - 14.19$$

39
$$NPSHA = 33.22 \text{ ft}$$

40

41
$$NPSHR = 2 \text{ ft (ref 4) or pg 13}$$





(CALCULATION SHEET)

CALC. NO. 15A-6 REV. NO. 0

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CHECKED ECC DATE 12-2-78

PROJECT SUSQUEHANNA STATION UNITS 1 & 2 JOB NO. 8856

SUBJECT CORE PENNSYLVANIA P & L SPRAY CALCULATIONS JOB 8856 SHEET NO. 84

1 MODE E

2

3

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

4

5

TABLE E-1

6

NODE

EQ. LENGTH

ΔP

7

or C_v

(psi)

STRAINER - 2.1

$$\Delta P = 2 \text{ psi}$$

2.0

2.2

$$C_v = 20,700$$

0.09

136'

1.08

2.1 - 2.2

36'

0.28

2.2 - 3B

127'

0.26

$$\text{TOTAL } \Delta P = 3.71 \text{ psi}$$

$$h_f = 3.71 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ ft}} \right) \left(\frac{144 \text{ in}^2}{1 \text{ ft}^2} \right)$$

$$h_f = 8.88 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$z_2 = 670' \text{ (as before)}$$

$$h_s = 23.11 \text{ ft}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a (670') = 33.16 \text{ ft}$$

$$h_{vpa} (200^\circ \text{F}) = 11.53 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.13 \text{ ft}} \times 144 \frac{\text{in}^2}{\text{ft}^2} = 27.61 \text{ ft (ref 1 pg A-6)}$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 8.88 + 33.16 - 27.61$$

$$NPSHA = 19.78 \text{ ft}$$

$$NPSHR = 11 \text{ ft. (ref 2)}$$





(CALCULATION SHEET)

ORIGINATOR G. KALINDIASKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ECC DATE 12-2-78
 SUBJECT CORE SPRAY CALCULATIONS JOB NO. 8856 SHEET NO. 85

MODE F

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

TABLE F.1

NODE	EQ. LENGTH or C_r	ΔP (psi)
STRAINER - 2.1	$\Delta P = 2 \text{ psi}$	2.0
	$C_r = 20,700$	0.12
	136'	1.50
2.1 - 2.2	36'	0.40
2.2 - 3B	127'	0.36
TOTAL $\Delta P =$		4.38 psi

$$h_f = 4.38 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}^3} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

$$h_f = 10.38 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$h_s = 23.11 \text{ ft}$$

$$z_2 = 670' \text{ (as before)}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a(670') = 33.16 \text{ ft}$$

$$h_{vpa}(170^\circ \text{F}) = 5.99 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.79 \text{ ft}^3} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 14.19 \text{ ft} \text{ (ref 1 pg A-6)}$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 10.38 + 33.16 - 14.19$$

$$NPSHA = 31.70 \text{ ft}$$

$$NPSHR = 2.5 \text{ ft. (ref 4) or pg 13}$$



CALCULATION SHEET

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA P&B'S JOB NO. 8856 SHEET NO. 86

MODE G

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

TABLE G.1

NODE	ED. LENGTH OR C_v	ΔP (psi)
STRAINER - 2.1	$\Delta P = 2 \text{ psi}$	2.0
	$C_v = 20,700$	0.14
	136'	1.68
2.1 - 2.2	36'	0.44
2.2 - 3B	127'	0.41

$$\text{TOTAL } \Delta P = 4.67 \text{ psi.}$$

$$h_f = 4.67 \text{ psi} \left(\frac{1}{60.57} \frac{\text{ft}^3}{\text{ft}} \right) \left(144 \frac{\text{in}^2}{\text{ft}^2} \right)$$

$$h_f = 11.10 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$h_s = 23.11 \text{ ft}$$

$$z_2 = 670' \text{ (as before)}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a(670') = 33.16 \text{ ft}$$

$$h_{vpa}(180^\circ\text{F}) = 7.51 \frac{\text{ft}}{\text{ft}} \times \frac{1 \text{ ft}^3}{60.57 \text{ ft}} \times 144 \frac{\text{in}^2}{\text{ft}^2} = 17.85 \text{ ft} \quad (\text{ref 1 pg A-6})$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 11.10 + 33.16 - 17.85$$

$$NPSHA = 27.32 \text{ ft}$$

$$NPSHR = 16 \text{ ft} \quad (\text{ref 2})$$

REPORT OF PERFORMANCE TEST FOR PUMP S/N 107384

2356-M1-E21-30-1

A performance test was conducted 8 September 1976 for a pump on order 006-36051 (AE 231). All necessary data associated with the hydraulic performance was obtained. The serial numbers for the impeller and casings are as follows:

<u>Stage No.</u>	<u>Casings</u>	<u>Impellers</u>
1	66044	57303
2	64953	68422
3	64946	68449
4	64957	55611
5	64703	69496
6	70976	68404

Vibration was found to be satisfactory as indicated by the data sheets. The NPSH points for a flow of 3004 GPM towards shut-off have been plotted on Curve N-831, Rev. 0 and fall on the head capacity curve. The NPSH data from 3625 GPM to runout is also plotted on N-831, Rev. 0.

FF128510

SUSQUEHANNA 1,2
MPL # E21-C001

TAG - 1P206 A, B, C & D

GENERAL ELECTRIC	
NUCLEAR ENERGY DIVISION	
☐	Disapproved per comments. Revise and resubmit for approval.
☐	Approved with Comments. Revise and resubmit IN FINAL FORM.
☐	Refer to EDS No. _____
☐	Approved. No further action req'd.
☐	Approved. Submit certified copy.
☒	Certified by Seller and Approved by Buyer.
Reviewed by <u>R. Lemp</u>	
Date <u>25 Oct 1976</u>	
VPF No. <u>3308-149-1</u>	

CERTIFICATE OF COMPLAINT

The performance test on Pump S/N 107384 on order 006-36051 (AE 231) was conducted in accordance with Procedure QCP-1085, Rev. 4 except the test was conducted in the Cameron shell.

R. Lemp / D. Shablin


R. Lemp.
Cameron Test Dept.

CUSTOMER **G.E.A.P.E.D.**PROPOSAL NO. **006-3606/ITEM-2**

SPECIAL NOTES

**PUMP SN 107384
TESTED IN CAMERON SHELL**

DESIGN CONDITIONS

GPM **3175** EFF **-**T.H. (FT.) **668** BHP **-** SG. **1.0**RPM **1780** DRIVER **700 HP MOTOR**
WITH **1.0 S.F.****Ingersoll-Rand**DRAWN
BY **D.P.W.****9-14-76**
DATECURVE **N-831, REV.0.**PUMP **25APHD-6**CURVE **N-831, REV.0**

PUMP SN 107384

PART OF PERFORMANCE CURVE N-831, REV. 0

NOTE:

- ⊙ PERFORMANCE DATA FOR HEAD, FLOW, EFFICIENCY & BHP
- △ NPSH TEST BASIS NPSH HELD CONSTANT AT APPROXIMATELY 6.4 FT. REF. TO C.L. SUCTION NOZZLE (2.3 FT. CORRECTION INCLUDED).
- ▣ NPSHA FROM 3625 GPM TOWARDS RUN-OUT, REF. TO C.L. SUCTION NOZZLE (2.3 FT. CORRECTION INCLUDED).

5

CAMERON PUMP DIVISION		INGERSOLL-RAND COMPANY								TEST RECORD			
HEAD 3.56 @ 300 GPM	DISCHARGE HEAD	AS READ 0508	479	651	727	807	845	891	927	948			
		CORRECTED ELEVATION	479	652	729	809	847	893	929	950			
	SUCTION LIFT FT. ZERO DEPRESSED	0.120 FT.	61	61	62	62	62	63	63	63			
	CHANGE IN VELOCITY HEAD IN FEET	24 x 12	3	2	1	1	0	0	0	0			
	TOTAL HEAD		421	594	669	749	786	831	867	888			
CAPACITY	VENTURI TUBES	18" TUBE	4380	0	0	0	0	0	0	0			
		CORRECTED	4411	0	0	0	0	0	0	0			
	SIZES AND READINGS	10" TUBE	0	3647	3218	2581	1804	1084	375	0			
		CORRECTED	0	3632	3182	2491	1715	1098	395	0			
	TOTAL G.P.M.		4411	3632	3182	2491	1715	1098	395	0			
WATER H.P.			468.9	543.9	536.8	470.5	340.0	230.1	86.4	0			
POWER	WATTMETER	AS READ	.732	.727	.702	.649	.570	.526	.479	.477			
	700 T.R. KW		512.4	508.9	491.4	454.3	399.0	368.2	335.3	333.9			
	TOP OF MOTOR VIB.	1.1			1.0				2.0				
		1.6			.7				1.6				
	BRAKE H. P.		644	640	618	572	506	465	417	415			
SHAFT VIB. H ₂ O°F			1.7	76	76	2.1	77	77	77	77	3.4	77	
SEAL LEAKAGE Specific Gravity			NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	
PUMP EFFICIENCY %			72.8	85.0	86.7	82.3	67.2	49.5	20.7	0			
DRIVER 700 HP MOTOR		FULL LOAD SPEED		R.P.M.		PUMP NO. 107384		SIZE 25		TYPE APKD		STAGES 6	
LIQUID H ₂ O		NOTES: T-R SHELL		G.P.M. 3175		TOTAL HEAD IN FT. 668		SUCT. 1780		R.P.M. 1780		EFF. %	
TEMP.		SHUTDOWN TIME: 30 SEC.		IMPELLER		DIA.		VANE DIA		DIFFUSOR			
VISCOS.		WITNESSED BY [Signature] 9-8-76		SUCTION CONNECTION TO C.L. PUMP		C.L. PUMP TO C.L. DISC. GAUGE							
GRAVITY 1.0				TEST PROCEDURE CQCP - 1085 REV. 4									
TEST STAND #16				CUSTOMER G.E.A.P.E.D.									
TESTED BY R. LEMP				ORDER NO. 006-36051		ITEM NO. 2							
APP. BY				DATE SEPT. 8, 1976		TEST NO.							

7



UMP S/N 107384	SIZE 25	TYPE APHD-6	DATE SEPT. 8, 1976	TEST STAND #16	SPSH+ [BARO-VPY1.133] - SUC.+LIFT + VEL. HD SP. GR.
PELLER	DIA	CUSTOMER G.E.A.P.E.D.		DATA BY R. LEMP	2.2 SUBMERGENCE + 2.3 CORRECTION
I-R SHELL		ORDER NO. 006-36051	ITEM NO. 2	WITNESSED BY 9-8-76	TOTAL HEAD= CORR. DISCH HD + VEL. HD + SUCT. HD

I-R SHELL

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION +15.8 FT. ELEV.	VELOCITY HEAD 24 to 12	VACUUM AT C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (°F)	10 1/8" TUBE GPM	CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER ..(INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG).	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. CUST. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
1	822	837.8	0	21.5	860	80	430	450	485	340	999	29.83	none	3.6	0	1.03	28.80	32.63	6.4	21.4	424	23.0
2	795	810.8	.1	21.5	833	80	970	988	520	364				3.3	.01	1.03	28.80	32.63	6.4	21.4	460	45.1
3	760	775.8	.4	21.5	798	80	1665	1580	557	390				3.2	.02	1.03	28.80	32.63	6.4	21.4	495	64.3
4	726	741.8	.7	21.6	765	80	2350	2272	619	433				2.9	.05	1.03	28.80	32.63	6.3	21.5	547	80.1
5	657	671.8	1.3	21.7	695	81	3068	3004	685	480	↓	↓	↓	2.8	.08	1.07	28.76	32.59	6.2	21.6	604	87.3
6	558	572.8	1.9	19.9	596	82	3585	3625	722	505	998	29.83	none	2.8	.12	1.10	28.73	32.55	8.1	19.7	635	85.7
	555	569.8	1.9	22.9	596	82			722	505				2.8	.12	1.10	28.73	32.55	5.0	22.8	635	85.7
	553	567.8	1.9	23.9	595	82			722	505				2.7	.12	1.10	28.73	32.55	4.0	23.8	635	85.6
	549	563.8	1.9	25.9	593	83			725	508				2.7	.12	1.14	28.69	32.51	1.9	25.9	638	84.9
	521	535.8	1.9	26.4	565	83	↓	↓	719	503	↓	↓	↓	2.5	.12	1.14	28.69	32.51	1.4	26.4	633	81.6

8856-M1-E21-30-1

FF/26510

BECHTEL
COMMENT

Comments -

1. Page 6 of 6 is missing.

DEC 06 1976

APED DRAWING REVIEW	
COMMENTS AS CHECKED BELOW	
E ☐ NO COMMENTS. F ☐ COMMENTS AS INDICATED, FOR APED'S INFORMATION AND USE ONLY. NO REPLY REQUIRED. G ☒ COMMENTS AS INDICATED, WHEN DIRECTLY AFFECTING BECHTEL RESPONSIBILITY, REPLY REQUIRED IF NOT INCORPORATED BY APED.	
FORWARDED BY	DATE
<i>Handwritten signature</i>	1/24/77
REVIEWED	C E I L M
BECHTEL SAN FRANCISCO	JOB NO. 8856

DISTRIBUTION		
	NO.	DATE
VENDOR	2P	
CLIENT	1T	
FIELD	2F	
Q.E.		
CIVIL		
ELECT.		
PLT. DES.		
MECH.	1	
CON. SYS.		
ARCH.		
PURCH.		
EXPED.		
INSPECT		
SCHED.		
START-UP		
RECORD	1F+2K	
BECHTEL SAN FRANCISCO		

S	
DESCRIPTION-DRAWING	
LOCATION	





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

9346

JOB NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. A OF A-D
CALC. NO. 151-26
NO. OF SHEETS 263
Q NO. 49.0

FILE R.H.R. 4P CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

REVISION 1:

REVISED PAGES:
4, 6, 21, 34, 54, 66, 83, 86,
109, 174, 199, 209, 218,
223, 224, 226

ADDED PAGES:
4A, 5A

SUBJECT PRESSURE DROPS IN THE R.H.R. SYSTEM
OF UNITS 1 AND 2 FOR VARIOUS MODES (A-J) OF
OPERATION

REVISION 2:

REVISED PAGES:
131-153
ADDED PAGES:
153 A, B, C, D, E

STATEMENT OF PROBLEM COMPUTE PRESSURE DROPS IN THE
R.H.R. SYSTEM FOR UNITS 1 AND 2 UNDER
VARIOUS MODES OF OPERATION IN ORDER TO SIZE
FLOW ORIFICES AND TO VERIFY LINE SIZES.

SAR CHECKED ☒

SAR CHANGE REQ'D. ☒

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: 8856-DBB-107-1 Rev 3, DBB-107-2 Rev 3, DBB-115-1 Rev 7, DCA-108-1 Rev 7,
DCA-110-1 Rev 6, DCA-110-2 Rev 9, DCA-111-1 Rev 8, DCA-111-2 Rev 5, DCB-102-1 Rev 4, GBA-104-1 Rev 7,
GBB-104-2 Rev 4, GBB-104-3 Rev 7, GBB-104-4 Rev 4, GBB-105-1 Rev 5, GBB-105-2 Rev 5, GBB-106-1 Rev 7,
GBB-106-2 Rev 7, GBB-107-1 Rev 4, GBB-107-2 Rev 4, GBB-108-1 Rev 5, GBB-109-1 Rev 6, GBB-109-2 Rev 7,
GBB-110-1 Rev 7, GBB-110-2 Rev 6, GBB-111-1 Rev 7, GBB-111-2 Rev 4, GBB-112-1 Rev 7, GBB-112-2 Rev 5,
GBB-115-1 Rev 4, GBB-116-1 Rev 5, GBB-116-2 Rev 5, GBB-117-1 Rev 2, GBB-118-1 Rev 5, GBB-118-2 Rev 2,
GBB-118-3 Rev 1, GBB-118-4 Rev 2, GBB-120-1 Rev 3, HBB-110-1 Rev 8, HBB-110-2 Rev 6, CON'T: EXT PAGE

SOURCES OF FORMULAE & REFERENCES: ① CRANE TECHNICAL PAPER No. 410 (1965)
② G.E. PROCESS DIAGRAM & PROCESS DATA 8856-M1-E11-3(1)-8 ✓
③ FLOW ORIFICE CURVE 8856-M1-E11-25-1
④ PUMP PERFORMANCE CURVE 8856-M1-E11-53-1 - see
⑤ DANIEL STEAM-LIQUID ORIFICE FLOW CALCULATOR
⑥ GLOVER, TRAVIS, F., "UNDERSTANDING NPSH FOR PUMPS", PLANT ENGINEERING, DEC. 24, 1975.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. 151-23,

151-22, 151-19, 151-16, 151-14, 151-13, 151-12 (CON'T NEXT PG.)

REV. NO.	DATE	CALCULATION BY	CHECKED BY	DATE	APPROVED BY	DATE
	12/11/79	G. KALINAUSKAS / H. Kalinauskas	J. Brown	1/25/80	M. Jackson	1/29/80
	6/20/79	G. KALINAUSKAS / H. Kalinauskas	J. Brown	8/20/79	B.M. Jackson	8/21/79
0	1/16/79	G. KALINAUSKAS / H. Kalinauskas	JCM	4-4-79	B.M. Jackson	5/10/79

*Preliminary calcs checked only at group supervisor's request.
*Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

COVER SH. B OF A-D
CALC. NO. 151-26
NO. OF SHEETS —
Q NO. 49.0

NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

TITLE R.H.R. AP CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

SUBJECT _____

STATEMENT OF PROBLEM _____

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA HBB-110-3 Rev 6, HBB-110-4 Rev 6, HBB-111-1 Rev 5, HBB-111-2 Rev 3, HBB-113-1 Rev 6,
HBB-113-3 Rev 3, HBD-185-1 Rev 1, HBD-186-1 Rev 4, DBB-207-1 Rev 1, DBB-207-2 Rev 2, DBB-215-1 Rev 5,
DCA-208-1 Rev 1, DCA-210-1 Rev 2, DCA-210-2 Rev 2, DCA-211-1 Rev 2, DCA-211-2 Rev 2, DCA-211-3 Rev 2,
DCB-202-1 Rev 2, GBB-204-1 Rev 6, GBB-204-2 Rev 5, GBB-204-3 Rev 6, GBB-204-4 Rev 4, GBB-205-1 Rev 4,
GBB-205-2 Rev 4, GBB-206-1 Rev 5, GBB-206-2 Rev 4, GBB-207-1 Rev 6, GBB-207-2 Rev 4, GBB-208-1 Rev 2,
GBB-209-1 Rev 4, GBB-209-2 Rev 5, GBB-210-1 Rev 3, GBB-210-2 Rev 3, GBB-211-1 Rev 2, GBB-211-2 Rev 3,
GBB-212-1 Rev 4, GBB-212-2 Rev 3, GBB-215-1 Rev 4, GBB-216-1 Rev 3, GBB-216-2 Rev 3, CONT NEXT PAGE

SOURCES OF FORMULAE & REFERENCES _____

- ⑦ POSTA, BEKENY, "BASIC GUIDANCE TO AVOID CAVITATION OF ORIFICES, VALVES" JUNE 21, 1974.
- ⑧ SPRAY ENGINEERING COMPANY - CATALOG # 73 - BURLINGTON, MASS. 01803.
- ⑨ ASME STEAM TABLES (1967)
- ⑩ P.I.D. - RESIDUAL HEAT REMOVAL - M-151 Rev 12
- ⑪ G.E. - P.I.D. - RESIDUAL HEAT REMOVAL - M1-E11-2 Rev 6
- ⑫ AREA DRAWING - M-257 Rev 3

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. 151-11,

151-10, 151-9, 151-8, 151-6, 151-5, 151-4, 151-3, 151-2, 151-1

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
----------	------	----------------	--------------	------	-------------	------

*Preliminary calcs checked only at group supervisor's request.
**Consider PSAB codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.



SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. C OF A-D
CALC. NO. 151-26
NO. OF SHEETS 1
Q NO. 49.0

TITLE R.H.R. OP CALCULATIONS

**SUSQUEHANNA STEAM
ELECTRIC STATION**

SUBJECT _____

STATEMENT OF PROBLEM _____

CALC. SHEET CONTROL:

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA G8B-217-1 Rev 2, G8B-218-1 Rev 1, G8B-218-2 Rev 2, G8B-218-3 Rev 2, G8B-218-4 Rev 2,
G8B-220-1 Rev 3, H8B-210-1 Rev 5, H8B-210-2 Rev 5, H8B-210-3 Rev 5, H8B-210-4 Rev 5, H8B-211-1 Rev 3,
H8B-211-2 Rev 3, H8B-213-1 Rev 4, H8B-213-2 Rev 1, H8D-285-1 Rev 1, H8D-285-2 Rev 1, H8D-286-1 Rev 3,
8856-M1-B31-16(2) Rev 10.

VALVE Cv: 8856-P1DA-74-5 Rev C, P12A-11-7 Rev D, P12A-12-6 Rev C, P12A-13-5 Rev C, P12A-18-7 Rev D,
P12A-20-10 Rev G, P12A-24-7 Rev E, P12A-60-6 Rev D, P12A-61-5 Rev D, P12A-62-6 Rev D, P12A-71-4 Rev B,
P12A-72-1 Rev C, P12A-74-4 Rev B, P12A-75-5 Rev C, P12A-80-3 Rev B, P12BC-14-9 Rev G, P12A-14-5 Rev C

CON'T NEXT PAGE

SOURCES OF FORMULAE & REFERENCES _____

- (13) G.E. REACTOR VESSEL DRAWING - M1-B11-234 Rev 7.
- (14) CALCULATIONS - M-111-17 Rev 0
- (15) GB-76-171 (4/22/76)
- (16) GB-79-72 (3/29/79) and BWG-1999 (1/24/79)
- (17) CALCULATIONS - C-11-A Rev 6
- (18) SPRAY NOZZLE PURCHASE ORDER - 8856-M154-10-1

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
----------	------	----------------	--------------	------	-------------	------

*Preliminary calcs checked only at group supervisor's request.
**Consider PSAR codes and standards redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. D OF A-D
CALC. NO. 151-26
NO. OF SHEETS —
Q NO. 49.0

TITLE R.H.R. ΔP CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

SUBJECT _____

STATEMENT OF PROBLEM _____

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA P17A-15-4 Rev B, P17A-16-4 Rev C, P17A-17-4 Rev B, P17A-18-6 Rev E
P17A-23-5 Rev D, P17A-27-4 Rev C, P17A-62-3 Rev A, P17BC-2,
J-28 Rev 1

SOURCES OF FORMULAE & REFERENCES (19) SPRAY NOZZLE P.O. - 8856-MISH-2-2
(20) PIPING SPECIFICATION M-199 Rev 31.
(21) R.H.R. PUMPS - M1-E11-21-1
(22) R.H.R. HEAT EXCHANGER - M1-E11-23-2
(23) EMC-4262 (6/28/79)
(24) EQUIPMENT LOCATION DRAWING M-247 Rev 8.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE

*Preliminary calcs checked only at group supervisor's request.

**Consider PSAR, codes and standards, redundancy and engineering, operability and maintainability, technical order, as applicable, and 1.1.



CALCULATION SHEET

CALC. NO. 151-26 REV. NO. 1

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CHECKED JCM DATE 4-4-79

PROJECT SUSQUEHANNA STEAM JOB NO. 8856

SUBJECT R.H.R. AP CALCULATIONS SHEET NO. 223

SECTION 3 - NPSH CALCULATIONS

2

3 MODE C-2

4

$$NPSHA = h_s - h_f + h_a - h_{vpa} \quad (\text{ref 6})$$

6

7 h_f

TABLE C-2.1			
NODE	EQ. LENGTH or Cr		$\Delta P_{9260 \text{ gpm}}$ (psi)
2B-3B	$\Delta P = 2 \text{ psi}$		2.0
3B-41B	$Cr = 49,000$		0.03
	299'		0.59
41B-5B	90'		0.18
	3'		1.79×10^{-3}

17

$$\Delta P = 2.80 \text{ psi}$$

19

$$h_f = 2.80 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

21

$$h_f = 6.70 \text{ ft}$$

23

$$h_s = z_2 - z_1 \quad z_2 = 670' \text{ (min. water level - assumed 1' below normal - M-247 Rev 8)} \quad \Delta$$

$$h_s = (670' - 648' 0 \frac{1}{2}'') \quad z_1 = 648' 0 \frac{1}{2}'' \text{ (inlet level to pump - iso HBB-110-2 Rev 6)} \quad \frac{7}{15}$$

$$h_s = 21.96 \text{ ft}$$

26

$$h_a (670') = 33.16 \text{ ft} \quad (\text{by calculation from ref 6 Table I})$$

29

$$h_{vpa} (200^\circ \text{F}) = 11.53 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right) = 27.61 \text{ ft} \quad (\text{ref 1 pg A-6})$$

32

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa} = 21.96 - 6.70 + 33.16 - 27.61$$

$$= 20.81 \text{ ft.}$$

34

$$NPSHR = 3 + 4 = 7 \text{ ft} \quad (\text{ref. 2 and ref 4 - G.E. requires additional 4 ft.})$$

36



() CALCULATION SHEET ()

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CALC. NO. 151-26 REV. NO. 1
 PROJECT SUSQUEHANNA STEAM CHECKED JCM DATE 4-4-79
 SUBJECT R.H.R. ΔP CALCULATIONS JOB NO. 8856 SHEET NO. 224

1 NPSH CALCULATION

2

3 MODE G

4

5
$$NPSHA = h_s - h_f + h_a - h_{vpa} \quad (\text{ref 6})$$

6

7 h_f

		TABLE G-1	
	MODE	EQ. LENGTH OR Cr	ΔP (psi)
8			
9			
10	2A-3A	$\Delta P = 2 \text{ psi}$	2.0
11	3A-41A	$Cr = 49,000$	0.07
12		380'	1.56
13	41A-5A	90'	0.37
14		3'	3.80×10^{-3}

15

16
$$\Delta P = 4.00 \text{ psi}$$

17
$$h_f = 4.00 \text{ psi} \left(\frac{1 \text{ ft}^3}{61.54 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

18
$$h_f = 9.36 \text{ ft}$$

20

21 $h_s = z_2 - z_1$ $z_2 = 670'$ (min. water level - assumed 1' below normal - H-247 Rev. 8)

22 $h_s = (670' - 648' 0\frac{1}{2}')$ $z_1 = 648' 0\frac{1}{2}''$ (inlet level to pump - iso HBB-110-1 Rev. 8)

23 $h_s = 21.96 \text{ ft}$

24

25 $h_a (670') = 33.16 \text{ ft}$ (by calculation from ref 6 Table I)

26

27 $h_{vpa} (130^\circ) = 2.22 \text{ psi} \left(\frac{1 \text{ ft}^3}{61.54 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right) = 5.19 \text{ ft}$ (ref 1 pg A-6)

28

29

30
$$\text{NPSHA} = h_s - h_f + h_a - h_{vpa} = 21.96 - 9.36 + 33.16 - 5.19$$

31
$$= 40.57 \text{ ft}$$

32

33

34
$$NPSHR = 5 + 4 = 9 \text{ ft}$$
 (ref 2. and ref. 4 - G.E. requires additional 4 ft)

35

36



CALCULATION SHEET

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CALC. NO. 151-26 REV. NO. 0
PROJECT SUSQUEHANNA STEAM CHECKED JCM DATE 4-4-79
SUBJECT R.H.R. AP CALCULATIONS JOB NO. 8856 SHEET NO. 225

In a similar fashion, the following table was constructed for the other modes of operation with suction from the suppression pool.

TABLE 1

MODE	h_s (ft)	h_f (ft)	h_a (ft)	h_{upa} (ft)	NPSH A (ft)	NPSH R (ft)
A	21.96	8.78	33.16	5.19	41.25	3
B	21.96	7.85	33.16	5.19	42.08	3
C ₁	21.96	5.48	33.16	12.69	36.95	2
C ₂	21.96	6.70	33.16	27.61	20.81	7
D ₂	21.96	6.95	33.16	3.94	44.23	3
G	21.96	9.36	33.16	5.19	40.57	9
H	21.96	8.76	33.16	0.84	45.52	3

FF/24510

APED DRAWING REVIEW															
COMMENTS AS CHECKED BELOW															
E ☒	No comments.														
F ☐	Comments as Indicated, for APED's Information and use only. No reply required.														
G ☐	Comments as Indicated, when directly affecting Bechtel responsibility. Reply required if not Incorporated by APED.														
<table border="1"> <tr> <td>FORWARDED BY <i>Attorney</i></td> <td>DATE 12-6-76</td> </tr> <tr> <td>Reviewed</td> <td> <table border="1"> <tr> <td>C</td> <td>E</td> <td>I</td> <td>L</td> <td>M</td> </tr> <tr> <td></td> <td></td> <td></td> <td><i>W</i></td> <td><i>W</i></td> </tr> </table> </td> </tr> </table>		FORWARDED BY <i>Attorney</i>	DATE 12-6-76	Reviewed	<table border="1"> <tr> <td>C</td> <td>E</td> <td>I</td> <td>L</td> <td>M</td> </tr> <tr> <td></td> <td></td> <td></td> <td><i>W</i></td> <td><i>W</i></td> </tr> </table>	C	E	I	L	M				<i>W</i>	<i>W</i>
FORWARDED BY <i>Attorney</i>	DATE 12-6-76														
Reviewed	<table border="1"> <tr> <td>C</td> <td>E</td> <td>I</td> <td>L</td> <td>M</td> </tr> <tr> <td></td> <td></td> <td></td> <td><i>W</i></td> <td><i>W</i></td> </tr> </table>	C	E	I	L	M				<i>W</i>	<i>W</i>				
C	E	I	L	M											
			<i>W</i>	<i>W</i>											
<table border="1"> <tr> <td>BECHTEL</td> <td>JOB NO.</td> </tr> <tr> <td>SAN FRANCISCO</td> <td>8856</td> </tr> </table>		BECHTEL	JOB NO.	SAN FRANCISCO	8856										
BECHTEL	JOB NO.														
SAN FRANCISCO	8856														

REPORT OF PERFORMANCE TEST FOR PUMP S/N 0573314

A performance test was conducted 26 July 1976 for a pump on order 006-36049 (AE 234). All necessary data associated with the hydraulic performance was obtained. The serial numbers for the impeller and casings are as follows:

<u>Stage</u>	<u>Casings</u>	<u>Impellers</u>
1	59910	66465
2	58664	66235
3	58665	68009
4	59882	65490

The vibration was found to be satisfactory as indicated by the Data Sheets. The NPSH points for a flow of 9898 GPM towards shut-off have been plotted on Curve N-810, Rev. 0 and fall on the head capacity curve. The NPSH data from 12081 GPM to runout is also plotted on N-810, Rev: 0.

 GENERAL ELECTRIC NUCLEAR ENERGY DIVISION	
☐	Disapproved per comments. Revise and resubmit for approval.
☐	Approved with Comments. Revise and resubmit IN FINAL FORM.
☐	Refer to EDS No. _____
☐	Approved. No further action req'd.
☐	Approved. Submit certified copy.
☒	Certified by Seller and Approved by Buyer.
Reviewed by <i>R. Lemp</i>	
Date <u>12 Aug 1976</u>	
VPF No. <u>3307-73-1</u>	

CERTIFICATE OF COMPLIANCE

The performance test of pump S/N 0573314 on order 006-36049 (AE 234) was conducted in accordance with Procedure CQCP-1085, Rev. 4.


R. Lemp / [Signature]

R. Lemp
Cameron Test Department

SUSQUEHANNA 1,2
MPL #E11C002

REC'D
2038
N.Y.

CUSTOMER G.E.A.P.E.D.	DESIGN CONDITIONS		 Ingersoll-Rand	CURVE N-810, REV. 0
	PROPOSAL NO. 006-36049 ITEM 2	GPM 10,000 EFF		PUMP 34 APKO-4
SPECIAL NOTES PUMP SN 0573314 PUMP TESTED IN CAMERON SHELL	T.H. (FT.) 600	BHP	SG. 1.0	DRAWN BY D.P.W. DATE 7-27-76
	RPM 1180	DRIVER HP 2000 HP MOTOR WITH 1.0 S.F.		



PUMP SN 0573314

PART OF CURVE N-810, REV. 0

NOTE:

- ⊙ PERFORMANCE DATA FOR HEAD, FLOW, EFFICIENCY & BHP,
- △ NPSH TEST BASIS NPSH HELD CONSTANT AT APPROXIMATELY 9.5 FT., REF. TO C.L. SUCTION NOZZLE (0.9 FT. CORRECTION INCLUDED)
- ▣ NPSHR DATA FROM 12081 GPM TOWARDS RUNOUT, REF. TO C.L. SUCTION NOZZLE (0.9 FT. CORRECTION INCLUDED)



ON PUMP DIVISION

INGERSOLL-RAND COMPANY

TEST RECORD.

HEAD 1.67 @ 10,000	DISCHARGE HEAD	050% AS READ	506	598	683	739	770	816	852	875			
		CORRECTED +2' RLEN	507	599	686	742	774	820	854	878			
	SUCTION LIFT FT. ZERO DEPRESSED	FT.	65	67	69	70	71	72	73	74			
	CHANGE IN VELOCITY HEAD IN FEET	24"x18"	3	2	2	1	1	0	0	0			
	TOTAL HEAD		446	536	621	676	707	751	784	807			
CAPACITY	VENTURI TUBES	18" TUBE "Hg	12459	11049	8948	6973	5712	0	0	0			
		GPM	12261	11033	8970	6915	5595	0	0	0			
	SIZES AND READINGS	10" TUBE "Hg	12.9	5.65	5.80	5.70	0	51.9	108.2	0			
		GPM	1681	1113	1127	1118	0	3372	1087	0			
	TOTAL G.P.M.		13942	12146	10097	8033	5595	3372	1087	0			
WATER H.P.			1567	1638	1578	1365	995	637	214	0			
POWER	METER WATT FOR T.P. 2800/1 CS	AS READ	562	548	518	470	419	378	348	350			
		CORRECTED FOR R.P.M. KW	1574	1534	1450	1316	1173	1058	974	980			
		R.P.M.											
	BRAKE H. P.		1935	1885	1775	1605	1424	1275	1170	1175			
SHAFT VIB. MILS			2.1	1.1	1.3	1.4	1.5	1.6	1.8	1.7			
SEAL LEAKAGE SP. GR.			NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE			
PUMP EFFICIENCY %			81.0	86.9	88.9	85.1	69.9	50.0	18.3	0			

DRIVER 2000 HP MOTOR		FULL LOAD SPEED		R.P.M.	PUMP NO. 0573314	SIZE 34	TYPE APKO	STAGES 4
LIQUID H ₂ O		NOTES: I-R SHELL			G.P.M. 10,000	TOTAL HEAD IN FT. 600	SUCT.	R.P.M. 1180
TEMP.		SHUTDOWN TIME: 70 SEC.			IMPELLER	DIA.	VANE DIA	DIFFUSOR
VISCOS.		WITNESS BY:			SUCTION CONNECTION TO C.L. PUMP		C.L. PUMP TO C.L. DISC. GAUGE	
GRAVITY 1.0		 7-26-76		TEST PROCEDURE C&CP-1085 REV. 4				
TEST STAND #16				CUSTOMER G.E.A.P.E.D.				
TESTED BY R. LEMP				ORDER NO. 006-36049				
APP. BY		DATE JULY 26 1976					ITEM NO. 2	



PUMP S/N 0573314	SIZE 34	TYPE AP15D-4	DATE JULY 26, 1976	TEST STAND #16	NPSH (BARO-VPY1.133) SP. GR.	SUC. + DIFT + VEL. HD SP. GR.
PELLER	DIA	CUSTOMER G.F.A.P.E.D.	DATA BY R.H. PH. LEMP	7.2 SUBMERGENCE + 9 CORRECTION		
I-R SHELL		ORDER NO. 006-36049	ITEM NO. 2	WITNESSED BY	TOTAL HEAD= CORR. DISCH HD + VEL. HD + SUCTION	

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION + 5.6 FT. ELEV.	VELOCITY HEAD 24 to 18" VACUUM AT C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (OF)	10" TUBE CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER (INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG)	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
1	743	760.1	0	781	106	1004	1016	317	972	994	ABW	3.9	0	2.31	27.59	31.26	9.4	15.9	114.8	17.0
2	710	726.9	2	748	108	49.8	7302	372	1056	993	ABW	3.7	1	2.45	27.45	31.10	9.4	15.9	1273	48.7
3	666	682.3	5	704	109	5718	417	1168	993	ABW	3.6	3	2.52	27.37	31.02	9.5	15.9	1419	71.2	
4	642	655.8	1.0	678	110	7793	467	1308	973	ABW	3.6	5	2.60	27.30	30.93	9.6	15.9	1597	82.9	
5	588	602.9	1.6	626	112	7817	512	1134	972	ABW	3.3	9	2.75	27.15	30.76	9.8	16.0	1759	88.2	
6	503	519.6	2.4	541	113	12081	543	1520	992	79.9	ABW	2.8	1.3	2.82	27.07	30.67	11.2	14.9	1865	87.8
	503	516.6	2.4	540	114		543	1520	992			2.7	1.3	2.91	26.99	30.58	9.1	16.9	1865	87.7
	501	515.6	2.4	541	115		543	1520	992			2.8	1.3	3.00	26.90	30.49	7.7	18.2	1865	87.7
	495	512.6	2.4	540	116		543	1520	992			2.6	1.3	3.08	26.82	30.37	5.5	20.3	1865	87.5
	473	507.6	2.4	537	117		543	1520	991			2.8	1.3	3.17	26.72	30.29	3.5	22.3	1865	87.0
	481	503.6	2.4	534	118		543	1520	991			2.7	1.3	3.26	26.64	30.18	2.6	23.1	1865	86.5
	430	494.6	2.4	525	118		546	1512	991			2.8	1.3	3.26	26.64	30.18	2.4	23.3	1857	85.4
	411	425.1	2.4	456	119		485	1365	971			2.4	1.3	3.35	26.55	30.06	1.9	23.7	16.72	82.4




2 2 2 2 2



PUMP S/N 0573314	SIZE 34	TYPE AP10-4	DATE JULY 26, 1976	TEST STAND #16	NPSH+ [(BARO-VP)/1.133] 2.0	SUC. LIFT SP. GR. 1.0	VEL. HD CORRECTION .9
IMPELLER	DIA	CUSTOMER G.E.A.P.E.D.		DATA BY RALPH LEMP	SUBMERGENCE + CORRECTION		
I-R SHELL		ORDER NO. 006-36049	ITEM NO. 2	WITNESSED BY	TOTAL HEAD= CORR. DISCH HD + VEL. HD + SUCTION HD		

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION + 15.6 FT. ELEV.	VELOCITY HEAD 24 to 18 VACUUM AT	C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (OF)	1/2" TUBE GPM	CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER (INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG)	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
7	416	477.6	2.8	15.9	503	122	129	129	551	1543	990	29.9	↓	2.7	1.5	3.45	28.45	29.97	7.8	15.9	1895	85.7
	414	478.6	2.8	16.0	504	121			551	1543	990			2.7	1.5	3.54	28.36	29.87	7.6	18.0	1895	85.9
		477.6	2.8	19.2	505	122			551	1543	990			2.6	1.5	3.64	26.26	29.75	6.2	19.3	1895	86.0
	457	471.6	2.8	20.4	500	123			551	1546	990			2.6	1.5	3.74	26.16	29.64	4.8	20.5	1892	85.3
	439	453.6	2.7	21.1	482	123			547	1532	990			2.7	1.5	3.74	26.16	29.64	4.1	21.2	1881	82.8
	409	423.6	2.7	21.3	452	124	↓	↓	527	1469	990	↓	↓	2.5	1.5	3.85	26.05	29.51	3.8	21.4	1795	81.3
8	415	429.6	3.2	15.4	453	125	130	137	553	1548	989	29.9	↓	2.5	1.7	3.95	25.95	29.40	9.9	15.4	1900	82.0
	414	428.6	3.2	16.4	453	126			553	1548	989			2.6	1.7	4.06	25.84	29.28	8.8	16.4	1900	82.0
	410	424.6	3.2	17.7	450	127			553	1541	989			2.5	1.7	4.18	25.72	29.14	7.4	17.7	1895	81.6
	405	419.6	3.2	18.3	446	128			551	1543	988			2.5	1.7	4.29	25.61	29.02	6.7	18.3	1895	80.9
	374	388.6	3.2	18.5	415	128	↓	↓	543	1520	988	↓	↓	2.5	1.7	4.29	25.61	29.02	6.5	18.5	1866	76.4




7-26 76



This drawing and the design it covers are the property of BSCYTEL. They are hereby loaned and as the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or in any way disclosed to the public without the express written permission of BSCYTEL.

27 L.F.



REFERENCE DRAWINGS

M-151 REV. 8 P I T D
M-31-2 : 7 PIPING PLAN AREA 31
M-31-3 : 6 : 31
M-34-3 : 6 : 34



COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8858-G-9 APPLIES

REV.	DATE	BY	CHKD.	APPD.
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



PENNSYLVANIA POWER & LIGHT COMPANY
ALLENTOWN, PENNSYLVANIA
BUSSYHARRIS STEAM ELECTRIC STATION - UNIT 1, UNIT 2
BSCYTEL - SAN FRANCISCO

ISOMETRIC - REACTOR BUILDING
RESIDUAL HEAT REMOVAL UNIT 2

REACTOR BLDG. UNIT 2

51-20 DRAWING NO.
DCB-202-1 2

DIMENSIONS ARE TO
CONTACT SURFACES
OF FLANGES.




M - 141 REV. C. P. & I. D.
M - 181 1.8.
M - 31-2 1.5. PIPING PLAN - AREA - 31
M - 31-4 1.5.

COMPONENTS ON
THIS DWG. ARE Q-LISTED.
SPEC. 8050-G-9 APPLIES

[illegible]



[illegible]

M - 141 REV.G P & I.D.
M - 151 : : B
M - 31-4 : : 5 PUMP PLAN AREA 21
M - 31-72 : : 9 P 21

10/1	SEE RPT FOR NOTE	MR	10/1						
10/2	SEE RPT FOR NOTE	MR	10/2						
10/3	SEE RPT FOR NOTE	MR	10/3						
10/4	SEE RPT FOR NOTE	MR	10/4						
10/5	SEE RPT FOR NOTE	MR	10/5						
10/6	SEE RPT FOR NOTE	MR	10/6						
10/7	SEE RPT FOR NOTE	MR	10/7						
10/8	SEE RPT FOR NOTE	MR	10/8						
10/9	SEE RPT FOR NOTE	MR	10/9						
10/10	SEE RPT FOR NOTE	MR	10/10						
10/11	SEE RPT FOR NOTE	MR	10/11						
10/12	SEE RPT FOR NOTE	MR	10/12						
10/13	SEE RPT FOR NOTE	MR	10/13						
10/14	SEE RPT FOR NOTE	MR	10/14						
10/15	SEE RPT FOR NOTE	MR	10/15						
10/16	SEE RPT FOR NOTE	MR	10/16						
10/17	SEE RPT FOR NOTE	MR	10/17						
10/18	SEE RPT FOR NOTE	MR	10/18						
10/19	SEE RPT FOR NOTE	MR	10/19						
10/20	SEE RPT FOR NOTE	MR	10/20						
10/21	SEE RPT FOR NOTE	MR	10/21						
10/22	SEE RPT FOR NOTE	MR	10/22						
10/23	SEE RPT FOR NOTE	MR	10/23						
10/24	SEE RPT FOR NOTE	MR	10/24						
10/25	SEE RPT FOR NOTE	MR	10/25						
10/26	SEE RPT FOR NOTE	MR	10/26						
10/27	SEE RPT FOR NOTE	MR	10/27						
10/28	SEE RPT FOR NOTE	MR	10/28						
10/29	SEE RPT FOR NOTE	MR	10/29						
10/30	SEE RPT FOR NOTE	MR	10/30						
10/31	SEE RPT FOR NOTE	MR	10/31						
11/1	SEE RPT FOR NOTE	MR	11/1						
11/2	SEE RPT FOR NOTE	MR	11/2						
11/3	SEE RPT FOR NOTE	MR	11/3						
11/4	SEE RPT FOR NOTE	MR	11/4						
11/5	SEE RPT FOR NOTE	MR	11/5						
11/6	SEE RPT FOR NOTE	MR	11/6						
11/7	SEE RPT FOR NOTE	MR	11/7						
11/8	SEE RPT FOR NOTE	MR	11/8						
11/9	SEE RPT FOR NOTE	MR	11/9						
11/10	SEE RPT FOR NOTE	MR	11/10						
11/11	SEE RPT FOR NOTE	MR	11/11						
11/12	SEE RPT FOR NOTE	MR	11/12						
11/13	SEE RPT FOR NOTE	MR	11/13						
11/14	SEE RPT FOR NOTE	MR	11/14						
11/15	SEE RPT FOR NOTE	MR	11/15						
11/16	SEE RPT FOR NOTE	MR	11/16						
11/17	SEE RPT FOR NOTE	MR	11/17						
11/18	SEE RPT FOR NOTE	MR	11/18						
11/19	SEE RPT FOR NOTE	MR	11/19						
11/20	SEE RPT FOR NOTE	MR	11/20						
11/21	SEE RPT FOR NOTE	MR	11/21						
11/22	SEE RPT FOR NOTE	MR	11/22						
11/23	SEE RPT FOR NOTE	MR	11/23	</					

WELDING REQUIREMENTS		Pipe Class	DLA
☐ P1-A-C-14	0.706-2	☐ Pre Heat: 60°F	
☐ P1-A7-14	0.6018	☐ Pre Heat: 700°F	
☐ P1-A	0.7018	☐ Preheat: 250°F	
☐ P1-A7-A	18.360	☐ Pre-Heat: 275°F	
☐ P1-A-A	18.360	☐ Pre Heat: 550°F	
☐ P1-A7-A	18.360-14	☐ Preheat:	
☐ P1-A7-14	0.7038-16	☐ Inlet Pipe: 350°F	
☐ P1-A7-14	0.8048-2	☐ Boring Ring Band	
☐ P1-A7	0.8048-8	☐ Argon Tung Band	
☐ P1-A7-A	0.8115	☐ Pre Welding Temp	
	ND 150-163	125-50-1	

Along Welding Requirements And Control Curves: 177-178-1

21	306	21	NOTE	JAN	1968	1	CL
22	307	22	NOTE	JAN	1968	1	CL


1156 RELEASE UNDER E.O. 14176

R.H.R. UNIT-2

1358	DCA-211-2	2
------	-----------	---

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below

This drawing and the designs it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and private use permitted by any written consent given by the lender to the borrower.



B = 3/8" DIA. BEND.

REFERENCE DRAWINGS

M-141 REV. C. P & L.D.
M-151 : D.
M-21-3 : B. PIPING PLAN - AREA-B1
M-21-4 : E.

COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8858-G-9 APPLIES

DATE	REVISED	BY	CHKD	APPD
10/1/54		REL		
PENNSYLVANIA POWER & LIGHT COMPANY ALL STATE, PENNSYLVANIA BUCKLEHARRA STEAM ELECTRIC STATION - UNIT 1, UNIT 2 BECHTEL - SAN FRANCISCO				
ISOMETRIC - REACTOR BLDG R.H.R. - UNIT-2				
41-13	41-13	41-13	41-13	41-13
8858	DCA-211-1	2		

ISO REACTOR BLDG R.H.R.



M-2151 REV. 0 P&ID
M-31-2 " 9 PIPING PLAN-AREA 81
M-31-3 " 2 " " " "
M-32-3 " 6 " " " 22

**COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8856-G-9 APPLIES**

[illegible]

Q



M-2151 REV. 0 P#10
M-31-2 " 2 PIPING PLAN - AREA 31
M-31-3 " 2 " " " "
M-34-3 " 6 " " " 34.

[illegible]

PENNSYLVANIA POWER & LIGHT COMPANY
 ALLENTOWN, PENNSYLVANIA
 BUCKLEMAN STEAM ELECTRIC STATION - UNITS 1, UNIT 2
 BECHTEL - SAN FRANCISCO

ISOMETRIC-REACTOR BLDG.
R.H.R. - UNIT # 2

	100 No.	51-25 000000 No.	01
	8858	DCA-210-1	4






ANY WELDED CONNECTIONS

12" O.D.B-118

75° K.

12-6000 THREADED 80 REQ'D. ON INLET TEE EACH SIDE OF CENTER

12-6000 THREADED 80 REQ'D. EQUAL SPACING



M-151 REV. 2 P.E.I.D.
M-26-12 " 2 PIPING PLAN-AREA 26

[illegible]

ALLIANCE POWER PLANTS
BIRMINGHAM STEAM ELECTRIC STATION - UNIT 1 UNIT 2

BOCUT EL - 34M / RAJONCO

ISOMETRIC- REACTOR BLDG.
RHR - UNIT 1

	JOB No.	51-19 DRAWING No.	REV.
	8856	GBB-118-4	2

10

6111 ISO REAC BLDG RHR





1011.F.



DETAIL ①

SPRAY NOZZLE CONNECTIONS



REFERENCE DRAWINGS

M-151 REV. 2 P.E.I.D.
M-263 " 3 PIPING PLAN - AREA 24

COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8858-G-9 APPLIES

NO.	DATE	DESCRIPTION	BY	CHKD.	APP'D.
1		ISSUED FOR CONSTRUCTION			
2		REVISION			
3		REVISION			
4		REVISION			
5		REVISION			
6		REVISION			
7		REVISION			
8		REVISION			
9		REVISION			
10		REVISION			
11		REVISION			
12		REVISION			
13		REVISION			
14		REVISION			
15		REVISION			
16		REVISION			
17		REVISION			
18		REVISION			
19		REVISION			
20		REVISION			
21		REVISION			
22		REVISION			
23		REVISION			
24		REVISION			
25		REVISION			
26		REVISION			
27		REVISION			
28		REVISION			
29		REVISION			
30		REVISION			
31		REVISION			
32		REVISION			
33		REVISION			
34		REVISION			
35		REVISION			
36		REVISION			
37		REVISION			
38		REVISION			
39		REVISION			
40		REVISION			
41		REVISION			
42		REVISION			
43		REVISION			
44		REVISION			
45		REVISION			
46		REVISION			
47		REVISION			
48		REVISION			
49		REVISION			
50		REVISION			
51		REVISION			
52		REVISION			
53		REVISION			
54		REVISION			
55		REVISION			
56		REVISION			
57		REVISION			
58		REVISION			
59		REVISION			
60		REVISION			
61		REVISION			
62		REVISION			
63		REVISION			
64		REVISION			
65		REVISION			
66		REVISION			
67		REVISION			
68		REVISION			
69		REVISION			
70		REVISION			
71		REVISION			
72		REVISION			
73		REVISION			
74		REVISION			
75		REVISION			
76		REVISION			
77		REVISION			
78		REVISION			
79		REVISION			
80		REVISION			
81		REVISION			
82		REVISION			
83		REVISION			
84		REVISION			
85		REVISION			
86		REVISION			
87		REVISION			
88		REVISION			
89		REVISION			
90		REVISION			
91		REVISION			
92		REVISION			
93		REVISION			
94		REVISION			
95		REVISION			
96		REVISION			
97		REVISION			
98		REVISION			
99		REVISION			
100		REVISION			

PENNSYLVANIA POWER & LIGHT COMPANY

REACTOR BUILDING
REACTOR BUILDING PLANT - UNIT 1, UNIT 2

ISOMETRIC - REACTOR BLDG.
RHR - UNIT 1

NO.	DATE	DESCRIPTION	BY	CHKD.	APP'D.
1		ISSUED FOR CONSTRUCTION			
2		REVISION			
3		REVISION			
4		REVISION			
5		REVISION			
6		REVISION			
7		REVISION			
8		REVISION			
9		REVISION			
10		REVISION			
11		REVISION			
12		REVISION			
13		REVISION			
14		REVISION			
15		REVISION			
16		REVISION			
17		REVISION			
18		REVISION			
19		REVISION			
20		REVISION			
21		REVISION			
22		REVISION			
23		REVISION			
24		REVISION			
25		REVISION			
26		REVISION			
27		REVISION			
28		REVISION			
29		REVISION			
30		REVISION			
31		REVISION			
32		REVISION			
33		REVISION			
34		REVISION			
35		REVISION			
36		REVISION			
37		REVISION			
38		REVISION			
39		REVISION			
40		REVISION			
41		REVISION			
42		REVISION			
43		REVISION			
44		REVISION			
45		REVISION			
46		REVISION			
47		REVISION			
48		REVISION			
49		REVISION			
50		REVISION			
51		REVISION			
52		REVISION			
53		REVISION			
54		REVISION			
55		REVISION			
56		REVISION			
57		REVISION			
58		REVISION			
59		REVISION			
60		REVISION			
61		REVISION			
62		REVISION			
63		REVISION			
64		REVISION			
65		REVISION			
66		REVISION			
67		REVISION			
68		REVISION			
69		REVISION			
70		REVISION			
71		REVISION			
72		REVISION			
73		REVISION			
74		REVISION			
75		REVISION			
76		REVISION			
77		REVISION			
78		REVISION			
79		REVISION			
80		REVISION			
81		REVISION			
82		REVISION			
83		REVISION			
84		REVISION			
85		REVISION			
86		REVISION			
87		REVISION			
88		REVISION			
89		REVISION			
90		REVISION			
91		REVISION			
92		REVISION			
93		REVISION			
94		REVISION			
95		REVISION			
96		REVISION			
97		REVISION			
98		REVISION			
99		REVISION			
100		REVISION			

Q

1011.F. 1011.F. 1011.F. 1011.F. 1011.F. 1011.F. 1011.F. 1011.F. 1011.F. 1011.F.



SUBJECT: Study on Torsional effect on the seismic
response analysis of (1) ESSW Pumphouse
(2) Diesel Generator Building

As requested by NRC analysis has been performed to study the effects of including torsion in the dynamic response analysis for (a) ESSW Pumphouse (b) Diesel Generator Building.


The Analytical Procedure used in this study consists of:

- (i) The eccentricities of these structures were calculated.
- (ii) The structures were represented by a fixed base 3-D stick models with structural masses properly lumped at the calculated eccentricities, as shown in Figure 1 and 2.
- (iii) Modal frequency analyses of the 3-D stick models were performed to determine the structure frequencies.
- (iv) The frequencies determined are then compared with the corresponding frequencies associated with the fixed base models having zero eccentricities.

The results of comparison for the ESSW Pumphouse is shown on Table-1 and for the Diesel Generator building is shown on Table-2. These results indicate that there are insignificant shifts in the structural frequencies by including the eccentricities in the dynamic analysis.

From the results of this study, it is concluded that the structures modeled by lumped stick models without the inclusion of eccentricities in the dynamic analysis is adequate for the prediction of desired structural responses.

CONTROL#	910620200
DATE-	6/10/81




COORDINATES			
NODES	X	Y	Z
1	0.0	0.0	660.0
2	0.0	0.0	685.5
3	0.0	8.0	685.5
4	0.0	0.0	716.0
5	0.0	1.1	716.0

MASSES AT NODES 3 AND 5

FIGURE-1

ESSW PUMP HOUSE

3-D STICK MODEL



MASSSES AT NODES 4,8,9,10

COORDINATES			
NODES	X	Y	Z
1	0.0	0.0	660.0
2	0.0	0.0	677.0
3	0.0	0.0	701.3
4	0.0	0.0	710.8
5	0.0	0.0	723.0
6	0.0	0.0	737.1
7	0.5	-1.0	677.0
8	8.9	-6.8	701.3
9	19.5	-1.3	723.0
10	0.3	-3.1	737.1

FIGURE 2

DIESEL GENERATOR BUILDING

3-D STICK MODEL

Table-1: ESSW PUMPHOUSE:
Frequencies with and without
eccentricities
(See Figure-1)

Mode #	Frequencies (cps)	
	With Eccentricity	Without Eccentricity
1	13.93	13.94
2	18.05	18.06
3	28.94	28.97
4	38.83	40.01

Table-2: DIESEL GENERATOR BUILDING:
Frequencies with and without
eccentricities
(See Figure-2)

Mode #	Frequencies (cps)	
	With Eccentricity	Without Eccentricity
1	8.86	8.96
2	9.65	9.71
3	22.56	23.42
4	31.69	32.04
5	33.45	33.66

SUBJECT: Equivalence of Fixed Base and Flexible Base Models
used for the analysis of Primary Containment
for seismic loads.

In continuation of our response to the NRC question 130.20 as desired by NRC, a study has been made on the above subject. The object of this study is to demonstrate that as the shear wave velocity is increased, the results from the flexible base model converge to the results of the fixed base model.

The study considers the vertical seismic analysis for SSE for (a) a fixed base model (b) flexible base models for various foundation flexibilities defined by shear wave velocities V_S , $2V_S$, $5V_S$, $10V_S$ where V_S for the Susquehanna site is 6200 ft./sec. This corresponds to an equivalent vertical spring constant as shown in Table-1. A sketch of the flexible base vertical seismic model is shown in figure 3.7b-8 of FSAR (See Attachment #1).

A damping value of 5% of critical was used for all fixed base structural modes. The damping determination technique described in reference 3.7b-3 of FSAR [BC-Top-4A, Rev. 3, Appendix D] has been used to calculate the composite modal damping for the flexible base model.

The results for the fixed base and the flexible models are shown in Table-2 and Table-3, in terms of frequencies and modal damping values. The seismic (SSE) responses in terms of axial forces are presented in Table-4. The results indicate the following:

- (a) Table-2: Frequencies values approach fixed base conditions for $5V_S$.
- (b) Table-3: Modal damping values approach the fixed base condition for $5V_S$.
- (c) Table-4: Seismic responses approach fixed base conditions for $2V_S$.

These results demonstrate that as the shear wave velocity is increased to 2 to 5 times the actual site shear wave velocity, the results from the flexible base model converge to the results of the fixed base model. Thus use of the flexible base model for the seismic analysis of the containment structure is more realistic.

WP26/25-1



Table-1: CONTAINMENT: Equivalent Vertical Spring Constants.

From FSAR Section 3.7b.5, Reference 3.7b-3
(BC-Top-4-A, Page 3-15)

$$\text{Equivalent Vertical Spring Constant, } k_z = \frac{4GR}{(1-\nu)}$$

Where ν = Poisson's ratio = 0.3

R = Radius of Circular base mat = 50 ft.

G = Shear Modulus = ρV_s^2

V_s = Shear Wave Velocity = 6200 ft./sec.

ρ = Mass density of foundation medium = 4.3478×10^{-3} k.sec²/ft⁴ (γ = 140 lbs/cft.)

$V_s = V_s$ $k_z = 4.78 \times 10^7$ k/ft.

$V_s = 2V_s$ $k_z = 1.912 \times 10^8$ k/ft.

$V_s = 5V_s$ $k_z = 1.195 \times 10^9$ k/ft.

$V_s = 10V_s$ $k_z = 4.78 \times 10^{10}$ k/ft.

Table-2: CONTAINMENT: Vertical Seismic Model
Flexible Base Vs. Fixed Base Frequencies. (Cps)

Frequencies (Cps)

Mode #	Flexible Base				Fixed Base
	$V_s = 6200 \text{ ft/sec.}$	$2V_s$	$5V_s$	$10V_s$	
1	16.19	17.24	17.45	17.47	17.48
2	20.95	23.18	24.09	24.23	24.28
3	38.24	38.63	38.75	38.77	38.78

Table-3: CONTAINMENT: Vertical Seismic Model
Flexible Base Vs. Fixed Base
Modal Damping (% Critical)

Modal Damping (% Critical)

Mode #	Flexible Base				Fixed Base
	$V_s = 6200 \text{ ft/sec.}$	$2V_s$	$5V_s$	$10V_s$	
1	9.3	5.3	5.0	5.0	5.0
2	9.1	6.1	5.0	5.0	5.0
3	5.0	5.1	5.0	5.0	5.0




Table-4: CONTAINMENT: Axial Forces (SSE) (kips)
See Figure 3.7b-8 of FSAR, (Attachment #1)
for location of members.

Member #	Flexible Base				Fixed Base
	$V_S =$ 6200 ft/sec.	$2V_S$	$5V_S$	$10V_S$	
1	14.5	21.8	22.2	21.9	21.9
2	84.7	127.5	130.0	127.7	127.8
3	239.9	360.7	367.7	360.8	361.1
4	412.2	617.9	629.1	617.0	617.6
5	576.5	860.7	874.9	857.7	858.4
6	734.5	1090.8	1106.6	1084.3	1085.1
7	866.9	1280.4	1296.1	1269.5	1270.3
8	991.5	1454.3	1468.5	1437.7	1438.4
9	1095.4	1595.9	1607.5	1573.1	1573.7
10	1319.0	1773.8	1774.7	1733.2	1733.2
11	1479.1	1968.3	1956.7	1909.4	1908.7
12	1611.6	2107.5	2078.2	2025.5	2024.0
13	1701.4	2177.3	2128.2	2071.5	2069.0
14	34.9	34.8	33.1	31.7	31.6
15	127.3	126.3	119.6	114.3	113.8
16	201.3	197.3	185.9	176.9	176.2
17	843.4	842.7	787.2	743.4	739.6
18	899.6	895.0	835.9	789.3	785.2
19	759.5	727.5	680.6	642.5	639.2
20	799.1	762.2	712.5	672.5	669.1

TABLE-4 (Cont'd)

Member #	Flexible Base				Fixed Base
	$V_s =$ 6200 ft/sec.	$2V_s$	$5V_s$	$10V_s$	
21	829.5	786.9	734.8	693.5	689.9
22	845.3	797.2	743.3	701.5	697.8
23	602.9	611.5	571.5	540.0	537.3
24	602.9	611.5	571.5	540.0	537.3
25	76.9	78.2	73.2	69.3	68.9
26	234.2	238.4	223.1	211.0	209.9
27	418.5	426.1	398.4	376.6	374.7
28	1701.3	2177.3	2128.2	2071.5	2069.0
29	845.3	797.2	743.3	701.5	697.8
30	83.2	82.6	80.9	77.1	77.5

ATTACHMENT #1



SUSQUEHANNA STEAM ELECTRIC STATION
UNITS 1 AND 2
FINAL SAFETY ANALYSIS REPORT

VERTICAL SEISMIC
MODEL OF CONTAINMENT
WITH FLEXIBLE BASE

FIGURE 3.7b-8

SUSQUEHANNA SES UNIT 1 AND 2
DOCKET NUMBERS 50-387 AND 50-388
CATEGORY I MASONRY WALLS

PREFAMBLE:

Safety related masonry walls are interior partitions whose primary function is to provide shielding and fire protection. Masonry walls are not used as primary shear walls for seismic resistance of the structure. All category I masonry walls are reinforced with all cells fully grouted. The infill material of double wythe walls is either grout or concrete. The minimum specified compressive strength for grout, concrete, and mortar is 2500 psi. Mortar infill is not used on SSES masonry walls. Metal ties, between the wythes of double wythe walls, are provided at 24" spacing maximum in horizontal and vertical directions. Seismic design is in accordance with SSES FSAR Section 3.7. Allowable stresses are as noted in FSAR Section 3.8, Table 3.8-8 and Table 3.8-9. Safety related masonry walls are Q-listed and have been added to the FSAR Design Criteria Summary (Table 3.2-1), in response to NRC, Quality Assurance Branch, Question No. 260.1-b (34).

QUESTION NO. 1:

In your response to Question 2, you indicated that S_m is the allowable stress as specified in UBC. For extreme and/or abnormal loading combinations, you increase the allowable stress by a factor of 1.67, which is in conformance with the practice of SRP Sections 3.8.3 and 3.8.4, for reinforced concrete structures. However, concrete masonry walls are quite different from reinforced concrete walls, particularly the unreinforced ones, the use of such a practice may not result in an adequate design. Depending on the types of stress, that is, tensile, shearing or axial compressive, the factor may vary from 0 to 2.5 (see enclosure 2). Specify the masonry design strength f'_m used in Susquehanna masonry walls and the allowable values for all types of stresses.

RESPONSE:

Code allowable stresses for masonry tension, shear, compression, and bond are increased by a factor of 1.67 for load combinations involving abnormal and/or extreme environmental conditions which are credible but highly improbable. Since code allowable stresses are generally associated with a factor of safety of 3, the 1.67 increase provides a factor of safety against failure of 1.8 ($3 \div 1.67$) (see Table 4 for the increase allowed for each type of stress). There are no unreinforced masonry walls on SSES project. Susquehanna SES masonry walls are designed based on an ultimate compressive strength, f'_m , of 1500 psi as specified in UBC 1976, for solid grouted hollow masonry. Minimum compressive strength at 28 days for mortar, grout, and concrete is 2500 psi. Materials are in accordance with FSAR Appendix 3.8C. The allowable stresses are as listed in Table 1.



TABLE 1.

SSES ALLOWABLE STRESSES

Materials and Stress Type	Allowable Stress: UBC - 1976 (1) psi
1. <u>Masonry:</u>	$f'_m = 1500$ (see note 2)
Compression:	
Flexural	$.33f'_m = 500$
Axial	$.20f'_m \times (1-(h/40t)^3)$ h = clear height, in. t = wall thickness, in.
Flexural Shear	$1.1 \sqrt{f'_m} = 43$
Bond (deformed bars)	140
Bearing	$.25f'_m = 375$
Bed Joint tension	
Normal	(See note 3)
Parallel	25
Modulus of elasticity, E_m	$1000f'_m = 1,500,000$
Modulus of rigidity, E_v	$400f'_m = 600,000$
2. <u>Reinforcement:</u>	
Tension:	
Grade 40 Steel	20,000 (used for ties only)
Grade 60 Steel	24,000
Compression:	
Grade 40 Steel	16,000 (used for ties only)
Grade 60 Steel	24,000

- Notes: (1) For stress increase allowed for abnormal, or extreme environmental load combinations - See Table 4.
- (2) Ultimate compressive strength as specified in UBC - 1976 for solid grouted hollow concrete units - Grade N.
- (3) Zero tension normal to bed joint is used.



QUESTION NO. 2

In the note to your response to Question 2, you stated that the allowable shear or tension between masonry block and concrete or grout infill is considered to be equal to three percent of the compressive strength of the block. The allowable shear or tension as specified by you is in the staff's opinion too high. To specify the allowable shear or tension of the vertical joint between wythes in terms of the compression strength of the block is in the first place unconservative and the use of seemingly low percentage of 3% may actually result in an allowable shearing stress greater than its corresponding strength. Therefore, a revision of the stress criterion is required.

RESPONSE:

The specified shear and tension, for the interface of masonry block and concrete or grout infill, of three percent of compressive strength, f'_m , is based on the relationship $1.1 \sqrt{f'_m}$ given in ACI-531-79. For $f'_m = 1500$ psi, this relationship yields a value of 43 psi compared to 45 psi ($.03 \times 1500$) allowed for evaluation of project masonry walls. The difference of 2 psi is justified by the fact that the ultimate compressive strength of masonry f'_m , is generally higher than 1500 psi.

The values for shear and tension as specified above have been used only as a guide in evaluating double wythe walls, where infill thickness is greater than 8 inches (24" thick walls and larger). For walls having an infill thickness of less than 8 inches (total of four walls), zero tension/shear is assumed for evaluation purposes.

For SSES masonry walls, the actual shear stress, as determined by VQ/Ib for uncracked sections, and in the compression zone of cracked sections ranges from 5-10 psi; except for three walls. For these three walls shearing stress is in the range of 10-15 psi.

QUESTION NO. 3

In your response to Question 4: (1) It is indicated that response spectrum method is used for the dynamic analysis of the concrete masonry walls. However, there is no mention as to which of the response spectra is used, upper floor or lower floor response spectrum or the average of the two. It is required that an upper bound envelope of the individual floor is used. (2) Though the use of ACI 318 formula the cracking of concrete masonry wall is considered. The use of such a formula is questionable in view of the fact that in a concrete masonry wall the weakest section is the bed joint and the modulus of rupture is equal to that of neither the concrete block nor the mortar. Indicate how the modulus of rupture is established in your computation.

RESPONSE ITEM (1):

Response spectrum for the lower floor has been used for evaluation of cracked/uncracked behavior of masonry walls, as applicable, for vertical motion, and for walls cantilevered from the floor. For horizontal motion, the lower floor response spectrum has been used in the initial evaluation of cracked/uncracked behavior, as applicable, for walls spanning between two floors and walls having side connection at concrete walls. These walls have also been re-evaluated based on the average acceleration of the upper and lower floors. Where the upper floor acceleration is less than the lower floor acceleration, the lower floor acceleration is used. For justification of using average acceleration, see Enclosure 1.

RESPONSE ITEM (2):

Although ACI-318 formula is derived for cracked concrete sections, the use of the formula for masonry walls takes into consideration the difference in material strengths. The difference between masonry behavior and concrete behavior is recognized and allowances are provided in selection of seismic acceleration within a frequency variation of plus or minus fifteen percent of the natural frequency.

The modulus of rupture (f_r) for masonry is approximated by increasing the UBC allowable flexural tensile stress by a factor of safety of 3 and then applying a 33% reduction to arrive at a lower bound value. This value is used only for stiffness and frequency calculations of the cracked section and not for strength. Allowance for uncertainties in the modulus of rupture is accounted for in the frequency variation of $\pm 15\%$ of the natural frequency.

QUESTION NO. 4:

In response to Question 5, it is stated that when the design stresses of masonry walls exceed the allowable stresses, fixes are designed such that the criteria is satisfied. Indicate the number of walls where such fixes are needed and provide examples.

RESPONSE:

The number of masonry walls requiring fixes for cracked section criteria is 36. Wall location, thickness, and elevation are as shown in Table 2. Typical fixes are shown in details type 1, type 2, type 3, and type 4 (see Enclosure 2).

TABLE 2

SSES - MASONRY WALLS
WALLS WHICH REQUIRED FIXES FOR CRACKED SECTION CRITERIA

BLDG.	FLOOR ELEVATION	WALL THICKNESS	NO. OF WALLS	REF. DWG.
Control	656'-0	8"	2	C-1301
Control	741'-0	6"	2	C-1304
Control	741'-0	8"	3	C-1304
Control	753'-0	8"	1	C-1304
Control	771'-0	8"	16	C-1304
Control	783'-0	1'-0"	3	C-1307
Control	806'-0	8"	3	C-1308
Control	806'-0	1'-0"	1	C-1308
Reactor	728'-0	8"	1	C-1202
Reactor	799'-0	8"	4	C-1205



QUESTION NO. 5:

Provide justification for any deviation from the attached staff's interim criteria in your design and analysis of the masonry walls.

RESPONSE:

Deviations and justification for differences between SSES criteria and SEB interim criteria are as noted in the following paragraphs.

Items which are not specifically addressed are in accordance with the criteria or not applicable to the project.

ITEM NO. 1: General Requirements

The materials, testing, analysis, design, construction and inspection related to the design and construction of safety-related concrete masonry walls shall conform to the applicable requirements contained in Uniform Building Code - 1979, unless specified otherwise, by the provisions in this criteria.

RESPONSE:

Uniform Building Code, 1976 edition, has been used for design and evaluation of Susquehanna masonry walls. A comparison of 1976 and 1979 editions of UBC shows no significant difference in criteria applicable to SSES masonry walls. In addition, ACI-531-79 is used to supplement UBC allowable stresses, and ACI-318 1977 in stiffness calculations.

ITEM NO. 2: Loads and Load Combinations

The loads and load combinations shall include consideration of normal loads, severe environmental load, extreme environmental load, and abnormal loads. Specifically, for operating plants, the load combinations provided in plant's FSAR shall govern. For operating license applications, the following load combinations shall apply for definition of load terms, (see SRP Section 3.8.4.11-3).

RESPONSE:

For comparison of SEB interim load combinations and load combinations used for masonry walls evaluation see Table 3. Definition of terms is as shown below.

Notation

D = Dead load of structure plus any other permanent loads contributing stress.

L = Live loads expected to be present when the plant is operating, including movable equipment, piping, cables.



- P = Design basis accident pressure loads.
- R = Steam/water jet forces or reactions resulting from rupture of process piping.
- T_O = Thermal effects during normal operating conditions including temperature gradient and equipment and pipe reactions.
- H_O = Force on structure due to thermal expansion of pipes under operating conditions.
- T_a = Added thermal effects (over and above operating thermal effects) which occur during a design accident.
- H_a = Force on structure due to thermal expansion of pipes under accident conditions.
- E = Load due to Operating Basis Earthquake.
- E' = Load due to Design Basis Earthquake.
- W = Wind load.
- W' = Tornado wind load.
- D_S = Force on blockwall due to story drift under Operating Basis Earthquake Loading.
- D'_S = Force on blockwall due to story drift under Safe Shutdown Earthquake Loading.

TABLE 3. - LOAD COMBINATION COMPARISON

LOAD COMBINATION	SEB INTERIM CRITERIA	SSES FSAR CRITERIA	COMMENTS
Service Load Condition	1. $D + L$ 2. $D + L + E$ 3. $D + L + W$	1. $D + L$ 2. $D + L + E + D_s$ 3. Not Applicable	No wind pressure
	1a. $D + L + T_o + R_o$ 2a. $D + L + T_o + R_o + E$ 3a. $D + L + T_o + R_o + W$	1a. $D + L + T_o + H_o$ 2a. $D + L + T_o + H_o + E$ 3a. Not Applicable	No wind pressure
Extreme environmental	4. $D + L + T_o + R_o + E'$ 5. $D + L + T_o + R_o + W_t$	4. $D + L + T_o + H_o + E' + D'_s$ 5. $D + L + T_o + H_o + W'$	See note 2
abnormal	6. $D + L + T_a + R_a + 1.5 P_a$	6. $D + L + (T_o + T_a) + R + 1.25 P_a + H_a$	See note 1
abnormal/severe environmental	7. $D + L + T_a + 1.25 P_a + 1.0 (Y_r + Y_j + Y_m) + 1.25 E + R_a$	7. $D + L + (T_o + T_a) + 1.25 P_a + R + 1.25 E + D_s$	
abnormal/extreme environmental conditions	8. $D + L + T_a + R_a + 1.0 P + 1.0 (Y_r + Y_j + Y_m) + 1.0 E'$	8. $D + L + (T_o + T_a) + R + 1.0 P + 1.0 E' + D'_s$	

- Notes: (1) Abnormal load combination in SSES-FSAR Table 3.8-9. Part C will be revised to read $D + L + (T_o + T_a) + R + 1.5 P_a + H_o$. All other load combinations will remain unchanged.
- (2) W' does not include W_m , tornado missile. Masonry walls are not used for protection of safety related equipment against tornado missiles.

ITEM NO. 3: Allowable Stresses

Allowable stresses provided in chapter 24 of UBC-79, as supplemented by the following modifications/exceptions shall apply.

- (a) When wind or seismic loads (OBE) are considered in the loading combinations, no increase in the allowable stresses are permitted.

RESPONSE:

Design and evaluation of masonry walls is based on a 33% increase in the allowable stress. This increase is permissible per UBC, 1979 and per ACI-531-79. The factor is also compatible with the 25% increase in stress noted in SSES FSAR for Working Stress Design Method.

- ITEM NO. 3: (b) Use of allowable stresses corresponding to special inspection category shall be substantiated by demonstration of compliance with the inspection requirements of the NRC criteria.

RESPONSE:

Stresses corresponding to special inspection have been used in the design and evaluation of SSES masonry walls. Inspection required to assure that masonry construction is in accordance with Appendix "D" and amendments to the PSAR, and to assure that materials are in accordance with FSAR Appendix 3.8C is implemented. Documentation of this inspection is in project jobsite files.

- ITEM NO. 3: (c) For load conditions, which represent extreme environmental, abnormal, abnormal/severe environmental, and abnormal/extreme environmental conditions the allowable working stresses may be multiplied by the factors shown in the following table: (See table 4).

TABLE 4.

STRESS INCREASE FACTOR COMPARISON

	SEB	SSES	
	FACTOR	FACTOR	JUSTIFICATION/COMMENT
Axial or flexural compression	2.5	1.67	See Response Question #1
Bearing	2.5	1.67	"
Reinforcement stress except shear	2.0	1.67	See note 1
Shear Reinforcement and/or bolts	1.5	1.5	Anchor bolts are not used in safety related masonry walls
Masonry tension Parallel to bed joint	1.5	1.5	
Shear carried by masonry	1.0	1.67	See note 2
Masonry tension perpendicular to bed joint			
For reinforced masonry	0	0	
For unreinforced masonry	1.0	N/A	No unreinforced masonry walls

(1) Shall not exceed .90 fy

(2) The actual shear stress carried by masonry is within the allowable shear stress given in UBC Table 24-H with no increase factor applied.

RESPONSE:

See table above.



QUESTION NO. 5: Design and Analysis Considerations

ITEM 4g:

In new construction, no unreinforced masonry wall is permitted, also all grout in concrete masonry walls shall be compacted by vibration.

RESPONSE:

- a. There are no unreinforced masonry walls in SSES project.
- b. Cell grout and/or infill grout or concrete is compacted by either mechanical vibrators or by rodding.

ITEM 4i:

Special constructions (e.g., multiwythe, composite) or other items not covered by the code shall be reviewed on a case by case basis for their acceptance.

RESPONSE:

Double wythe walls are designed as composite sections, except as noted in response to Question No. 2. Allowable stresses are per ACI-531-79.

ITEM 4j:

Licensees or applicants shall submit QA/QC information, if available, for staff's review.

RESPONSE:

Applicable QA/QC information is available at SSES jobsite and will be submitted upon request.



ENCLOSURE 1.

JUSTIFICATION FOR THE USE OF

AVERAGE RESPONSE SPECTRA
(13 PAGES)



JUSTIFICATION OF USING APPROXIMATION METHOD TO

DETERMINE MAXIMUM WALL PANEL RESPONSES TO SEISMIC MOTION

The evaluations herein demonstrate that: (1) The use of the average floor acceleration response spectra to calculate the response of the wall panel is appropriate, and (2) The use of uniform inertia load with magnitude equal to the average spectral acceleration for the fundamental mode, in calculating the maximum seismic responses is a good approximation, even considering the higher mode effect.

For the purposes of this evaluation, the seismic response of a simply-supported, uniform beam simulating a strip of the wall panel with unit width is considered, as shown in Figure 1.

(1) Use of Average Spectra

The equation of motion of an undamped, simply-supported beam can be written in terms of the total displacement with respect to some fixed reference axis as:

$$m \frac{\partial^2 u}{\partial t^2} + EI \frac{\partial^4 u}{\partial x^4} = 0 \quad (1)$$

Where m and EI are the mass density and flexural rigidity of the beam. Denote the seismic excitations at the ends of the



the beam as U_a and U_b . Then the total displacement $u(x,t)$ can be expressed in terms of the two seismic motions and the relative displacement to the seismic motions as:

$$u(x,t) = (x/L) U_b + (1 - x/L) U_a + r(x,t) \quad (2)$$

Where L is the length of the beam. The relation expressed by the above equation is shown in Figure 2. The relative displacement $r(x,t)$ needs to satisfy the following simply-supported conditions:

$$r(0,t) = r(L,t) = 0 \quad (3)$$

$$\frac{\partial^2 r}{\partial x^2} \Big|_{x=0} = \frac{\partial^2 r}{\partial x^2} \Big|_{x=L} = 0 \quad (4)$$

Substitute Equation 2 into Equation 1, the equation of motion in terms of relative displacement $r(x,t)$ can be expressed as:

$$m \frac{\partial^2 r}{\partial t^2} + EI \frac{\partial^4 r}{\partial x^4} = -m(x/L) \ddot{U}_b - m(1 - x/L) \ddot{U}_a \quad (5)$$



The eigen-function solutions for the homogeneous equation associated with Equation 5 that satisfy the boundary conditions specified by Equations 3 and 4 are:

$$\sin \frac{n\pi x}{L}, \quad n = 1, 2, 3, \dots,$$

and the corresponding frequencies of vibration are:

$$\omega_n = n^2 \pi^2 \sqrt{\frac{EI}{mL^4}}, \quad n = 1, 2, 3, \dots \quad (6)$$

So, the solution of Equation 5 can be expressed as:

$$r(x,t) = \sum_{n=1}^{\infty} a_n(t) \sin \frac{n\pi x}{L} \quad (7)$$

Substitute Equation 7 into Equation 5, and multiply the latter by $\sin \frac{n\pi x}{L}$, and then integrate it with respect

to x over the full length of the beam, the equation of motion can be transformed into modal equations of motion as:

$$\ddot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a + \ddot{u}_b}{2} \right) \quad n = 1, 3, 5, \dots \quad (8a)$$

and

$$\ddot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a - \ddot{u}_b}{2} \right) \quad n = 2, 4, 6, \dots \quad (8b)$$

where r_n = participation factor

$$= \frac{4}{n\pi} \quad (9)$$

If damping in the form of modal damping ratio is included, Equations 8a and 8b becomes:

$$\ddot{a}_n + 2\xi_n \omega_n \dot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a + \ddot{u}_b}{2} \right) \quad n = 1, 3, 5, \dots \quad (10a)$$

and

$$\ddot{a}_n + 2\xi_n \omega_n \dot{a}_n + \omega_n^2 a_n = r_n \left(\frac{\ddot{u}_a - \ddot{u}_b}{2} \right) \quad n = 2, 4, 6, \dots \quad (10b)$$

Where ξ_n is the damping ratio of the n^{th} mode.



Equation 10a means that the odd-number modes which are symmetrical about the mid-span of the beam will be excited by the average of the two seismic excitations; while equation 10b means that the even-number modes which are antisymmetrical about the mid-span of the beam will be excited by half of the difference between the two seismic excitations.

Expressing the maximum modal displacement response in equations 10a and 10b in terms of absolute acceleration response spectra gives:

$$|a_n|_{\max} \leq |r_n| \left[\frac{S_a(\xi_n, \omega_n)}{2\omega_n^2} + \frac{S_b(\xi_n, \omega_n)}{2\omega_n^2} \right]$$

$$< \frac{4mL^4}{n^5 \pi^5 EI} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (11)$$

$$n = 1, 2, 3, \dots$$

This illustrates that the use of the average of two floor acceleration response spectra to calculate the modal response of a wall panel is appropriate.

(2) Contribution of Higher Modes

From Equation 11, the relative importance of modes can be evaluated by examining the frequency ratios, modal participation ratios, and maximum modal response ratios for constant acceleration which can be shown as:

$$\omega_1 : \omega_2 : \omega_3 : \dots = 1 : 4 : 9 : \dots \quad (12)$$

$$\Gamma_1 : \Gamma_2 : \Gamma_3 : \dots = 1 : -1/2 : 1/3 : \dots \quad (13)$$

$$\frac{\Gamma_1}{\omega_1^2} : \frac{\Gamma_2}{\omega_2^2} : \frac{\Gamma_3}{\omega_3^2} : \dots = 1 : -\frac{1}{32} : \frac{1}{243} : \dots \quad (14)$$

For an SRSS method of combining maximum response, the contribution of higher modes is clearly negligible.

If for example, the fundamental frequency ω_1 is above 8 H_z , the second frequency is above 32 H_z which is already in the rigid range, i.e., in the range of no amplification. Thus the S_a and S_b values associated with modes other than the fundamental will be the Zero-Period-Acceleration (ZPA) values of the two seismic motions U_a and U_b . Using the absolute sum (ABS) method of combining the modal maximum responses, ^{in this case} the contribution of higher modes is not more than .4% of the fundamental mode.

The relative importance of modes can also be evaluated by examining the moment and shear responses in the beam for each mode, as shown in the following.

The moment in the beam due to the n^{th} mode can be evaluated by:

$$M_n(X) = EI \frac{\partial^2}{\partial X^2} \left[a_n \sin \left(\frac{n\pi X}{L} \right) \right] \quad (15)$$

$$< \frac{4mL^2}{n^3 \pi^3} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \sin \left(\frac{n\pi X}{L} \right)$$

$$n = 1, 2, 3, \dots$$

The moment at the mid-span of the beam is contributed only by the symmetrical modes and can be expressed as follows:

$$M_n \left(\frac{L}{2} \right) < \frac{4mL^2}{n^3 \pi^3} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (16)$$

$$n = 1, 3, 5, \dots$$

For a constant spectral acceleration, the contribution to the mid-span moment of the beam from each mode can be expressed in the following ratio:

$$M_1\left(\frac{L}{2}\right) : M_3\left(\frac{L}{2}\right) : M_5\left(\frac{L}{2}\right) : \dots = 1 : \frac{1}{27} : \frac{1}{125} : \dots \quad (17)$$

Using the SRSS Method of combining modal responses, the contribution of the higher modes to the mid-span moment is less than 1% of that from the fundamental modes. Using the ABS method of combining modal responses, the contribution of higher modes is less than about 5%.

The shear force in the beam due to the n^{th} mode can be evaluated as:

$$Q_n(X) = EI \frac{\partial^3}{\partial X^3} \left[a_n \sin\left(\frac{n\pi X}{L}\right) \right]$$

$$< \frac{4mL}{n^2 \pi^2} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \cos\left(\frac{n\pi X}{L}\right) \quad (18)$$

$$n = 1, 2, 3, 4, \dots$$

The maximum shear occurs at the support of the beam and can be expressed as:

$$Q_n(0) \leq \frac{4mL}{n^2\pi^2} \left[\frac{S_a(\xi_n, \omega_n) + S_b(\xi_n, \omega_n)}{2} \right] \quad (19)$$

$$n = 1, 2, 3, 4, \dots$$

The contribution of the higher modes to the maximum shear at the beam support relative to that of the fundamental mode can be evaluated by comparing the modal effective masses (MEM) associated with the fundamental mode and the higher modes. The modal effective mass of the fundamental mode is

$$MEM_1 = \frac{8mL}{\pi^2} = 0.81 \text{ mL} \quad (20a)$$

The modal effective mass associated with modes higher than the fundamental mode can be calculated as

$$MEM_1' = (1 - 0.81)mL = 0.19 \text{ mL} \quad (20b)$$

The ratio of MEM_1' TO MEM_1 is $0.19/0.81 = 23\%$. That is the contribution of higher modes to the maximum shear is at most 23% of the contribution due to the fundamental mode. This ratio does not take into account the ratio of the spectral

acceleration for the fundamental mode to the ZPA value for the higher modes. When the difference in spectral accelerations is accounted for, the contribution of higher modes to the maximum shear would be less than 23%. For example, if the spectral acceleration for the fundamental mode is 1.5 ZPA, then the ratio of higher mode contribution would be $0.19/(0.81 \times 1.5) = 16\%$.

(3) Uniform Inertia Load Approximation

Using the modal responses, the maximum moment and shear of the beam can be calculated. This moment and shear can then be compared to the moment and shear based on a uniform inertia load using the average of the two floor spectral accelerations at the fundamental mode of the beam.

The maximum moment occurred at the mid-span of the beam induced by a uniform load with the following magnitude:

$$f(X) = m \left[\frac{S_a (\xi_1, \omega_1) + S_b (\xi_1, \omega_1)}{2} \right] \quad (21)$$

can be expressed as:

$$M^* \left(\frac{L}{2} \right) = \frac{mL^2}{8} \left[\frac{S_a (\xi_1, \omega_1) + S_b (\xi_1, \omega_1)}{2} \right] \quad (22)$$



From Equation 16, the moment at the mid-span of the beam due to the fundamental mode is:

$$M_1\left(\frac{L}{2}\right) < \frac{4mL^2}{\pi^3} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (23)$$

The maximum difference between the moments from Equations 22 and 23 is about 3%.

The maximum shear occurred at the support of the beam induced by the uniform load expressed in Equation 21, can be written as:


$$Q^*(0) = \frac{mL}{2} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (24)$$

From Equation 19, the shear at the support of the beam due to the fundamental mode is:

$$Q_1(0) < \frac{4mL}{\pi^2} \left[\frac{S_a(\xi_1, \omega_1) + S_b(\xi_1, \omega_1)}{2} \right] \quad (25)$$


The shear from Equation 24 is greater than the shear from Equation 25 by about 25%. This margin can well cover the contribution to the shear due to the higher mode effect, as discussed previously.

From the above comparison, it can be concluded that the use of a uniform inertia load with the magnitude of the averaged floor spectral acceleration at the fundamental mode, provides a good approximation for calculating the seismic response in the wall panel.



IDEALIZED SIMPLY-SUPPORTED UNIFORM BEAM

FIGURE No 1



RELATION BETWEEN SEISMIC EXCITATION
AND RELATIVE DISPLACEMENT

FIGURE No 2




ENCLOSURE 2


TYPICAL WALL FIXES

TYPE 1
TYPE 2
TYPE 3
TYPE 4







TYPE 1
ANGLE BRACING TO CONCRETE



TYPE 2
ANGLE BRACING TO STEEL



TYPE 3
CONTINUOUS ANGLE



TYPE 4
INTERMITTENT SUPPORTS

CALCULATION COVER SHEET

DB NO. 8856

DISCIPLINE MECHANICAL

COVER SH. A OF A
CALC. NO. M152-7
NO. OF SHEETS 10
Q. NO. SLP

TITLE ALTERNATE SHUTDOWN COOLING

CALC. SHEET CONTROL:

SUBJECT CORE SPRAY PUMP OPERATION IN
THE ALTERNATE SHUTDOWN COOLING
MODE.

STATEMENT OF PROBLEM DETERMINE CORE SPRAY
PUMP OPERATING POINTS IN ALTERNATE
SHUTDOWN COOLING MODE WITH ONE OR
MORE MAINSTREAM RELIEF VALVES OPEN.

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: HBB-104-1, REV. 8, GBB-101-2, REV. 3
DBB-113-1 REV. 3, DCA-109-1 REV. 5, DCA-107-1, REV. 11.

SOURCES OF FORMULAE & REFERENCES 1) CORE SPRAY PUMP CALCS M152-6, REV. 1
2) CRANE TECHNICAL PAPER NO. 410, 1979 EDITION
3) CORE SPRAY PUMP PERFORMANCE CURVE 8856-M1-E21-30-1
4) CORE SPRAY PROCESS DIAGRAM 8856-M1-E21-15-2
5) CROSBY VALVE ENGINEERING AND CAPACITY DATA, CAT. #302, SUP. 1
6) PSV OUTLINE DWG. 8856-M1-B21-64-2

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
	4/23/81	J. J. Brunner / <i>[Signature]</i>	David Yang	5/4/81	E. Connolly	5/4/81

*Preliminary calcs checked only at group supervisor's request.

**Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.

8856-QA-2(1/74)



CALCULATION SHEET

CALC. NO. M 162-7 REV. NO. 0ORIGINATOR J. J. Brunner DATE 4/23/81 CHECKED B. Yang DATE 5-4-81PROJECT SUSQUEHANNA JOB NO. 8856SUBJECT CORE SPRAY PUMPS IN SHEET NO. 1 of 10ALTERNATE SHUTDOWN COOLING MODE

ASSUMPTIONS

1. Based on vendor catalog information the C_v value for fully open main steam relief valve (PSV F013) is assumed to be within the range of 400 to 500 gpm. Both values (400 & 500) were used in these calculations. An estimate of the C_v value is presented in Appendix A of this calculation.
2. Backpressure in PSV discharge line is neglected because of large line diameter (12").
3. Friction losses in main steam piping are negligible and thus are omitted.
4. Calculation reflects a steady state condition. Inlet flow is equal to outlet flow. Water level in RPV is assumed to be 3 ft above center line of main steam nozzle.
5. No venting of RPV dome occurs.

SUMMARY AND CONCLUSIONS

- a) With only one PSV open, pumps will pressurize RPV above shutdown initiation pressure of 98 psig. This could be prevented by throttling with core spray valve. It is preferable, however, that a second PSV be opened to lower reactor pressure below shutdown initiation pressure.
- b) Calculations show (see page 9) that with 4 PSV open, runout flow of 7900 gpm will be reached with a valve C_v of 500.



CALCULATION SHEET

ORIGINATOR J. J. Brunner

DATE 4/23/81

CALC. NO. 17152-7

REV. NO. 0

PROJECT SUSQUEHANNA

CHECKED guy

DATE 5-4-81

SUBJECT Core Spray Pumps in Alt.
Shutdown Cooling Mode


JOB NO. 8856

SHEET NO. 2 OF 10

Use Core Spray Mode D

PRPV = 105 psig (use 98 psig for
TRPV = 332 °F shutdown cooling
Tpool = 170 °F initiation)
Ppool = 14.7 psia } (Ref. 4)

Assume water level ~ 3 ft above M.S. nozzle





CALCULATION SHEET

ORIGINATOR J. J. BrunnerDATE 4/23/81CALC. NO. M152-7REV. NO. 0PROJECT SUSQUEHANNACHECKED QuigDATE 5-4-81SUBJECT CORE SPRAY PUMPS INJOB NO. 8856SHEET NO. 3 of 10ALTERNATE SHUTDOWN COOLING MODETOTAL SYSTEM'S RESISTANCE

$$H_T = H_s + H_p + H_f$$

Static Head - with water level at approx. 3 ft above main steam nozzle ϕ

$$H_s = 790' - 670' = 120'$$

Pressure Head

$$H_p = \frac{144}{\rho} \cdot P_{psv} - H_0$$

where:

$$\Delta P_{psv} = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2 \quad (\text{Ref. 2})$$

with zero back pressure. $\Delta P_{psv} = P_{psv}$
 $H_0 = \text{stat. head at PSV } \phi = 45.9' \text{ (see page 9)}$ Friction Head

$$H_f = \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

condition calculated for Mode D
(see Ref 1 sht. 78)

$$\begin{aligned} Q_c \text{ (2 pumps)} &= 6350 \text{ gpm} \\ H_{fc} &= 277.3 \text{ ft} \end{aligned}$$

$$H_T = H_s + \frac{144}{\rho} \left(\frac{Q}{C_v} \right)^2 - H_0 + \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

$$\text{RPV Pressure} = P_{psv} - \frac{\rho}{144} H_0$$



CALCULATION SHEET

ORIGINATOR I. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
 PROJECT SUSQUEHANNA CHECKED JWJ DATE 5-4-81
 SUBJECT Core Spray Pumps in Alternate Shutdown Mode JOB NO. 8856
 SHEET NO. 4 of 10
ONE PSV IS OPEN

$$C_v = 400$$

Q	2000	4000	6000	8000
H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{400} \right)^2 - 45.9$	11.8	184.9	473.3	877
H _f = $\left(\frac{Q}{6350} \right)^2 \times 277.3$	27.5	110	247.5	440
H _{tot}	159.3	414.9	840.8	1437

$$C_v = 500$$

H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{500} \right)^2 - 45.9$	9	101.8	286	545
H _f	27.5	110	247.5	440
H _{tot}	N/A	331.8	653.5	1105

PRPV with 1 PSV @ C_v = 400 Q = 5,450 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{5450}{400} \right)^2 - 45.9 \right] = 149.3 \text{ psig}$$

PRPV with 1 PSV @ C_v = 500 Q = 6,130 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{6130}{500} \right)^2 - 45.9 \right] = 117.4 \text{ psig}$$



CALCULATION SHEET

ORIGINATOR J. J. Brunner

DATE 4/23/81

CALC. NO. 17152-7

REV. NO. 0

PROJECT SUSQUEHANNA

CHECKED QWJ

DATE 5-4-81

SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode

JOB NO. 8856

SHEET NO. 5 of 10

TWO PSV OPEN

$$C_V = 400$$

Q TOTAL

2000 4000 6000 8000

Q PSV

1000 2000 3000 4000

H_s

120 120 120 120

$$H_P = \frac{144}{62.4} \left(\frac{Q_V}{400} \right)^2 - 45.9$$

-31.5 11.8 83.9 184.9

$$H_f = \left(\frac{Q}{6350} \right)^2 \cdot 277.3$$

27.5 110 247.5 440

H_{tot}

N/A 241.8 451.4 744.9

$$C_V = 500$$

H_s

120 120 120 120

$$H_P = \frac{144}{62.4} \left(\frac{Q_V}{500} \right)^2 - 45.9$$

-36.7 -9 37.2 101.8

$$H_f = \left(\frac{Q}{6350} \right)^2 \cdot 277.3$$

27.5 110 247.5 440

N/A N/A 404.7 661.8

PRPV @ C_V = 400

$$Q_{PSV} = 7,150/2 = 3,575 \text{ gpm}$$

$$P_{RPV} = \frac{57.2}{144} \left[\frac{144}{62.4} \left(\frac{3575}{400} \right)^2 - 45.9 \right] = 55 \text{ psig}$$

PRPV @ C_V = 500

$$Q_{PSV} = 7420/2 = 3,710 \text{ gpm}$$

$$P_{RPV} = \frac{58}{144} \left[\frac{144}{62.4} \left(\frac{3710}{500} \right)^2 - 45.9 \right] = 32.7 \text{ psig}$$





CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M/52-7 REV. NO. 0
 PROJECT Susquehanna CHECKED JWG DATE 5-4-81
 SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode JOB NO. 8856
 SHEET NO. 6 of 10

THREE PSV OPEN

$$C_v = 400$$

Q_{TOTAL}

3000 6000 9000

Q_{PSV}

1000 2000 3000

$$H_s = 120$$

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{400} \right)^2 - 45.9$$

$$H_f = (Q_t / 6350)^2 \cdot 277.3$$

$$H_{tot}$$

120	120	120
-31.5	11.8	83.9
61.9	247.5	557.0
N/A	379.3	760.9

$$C_v = 500$$

$$H_s = 120$$

$$H_p = \frac{144}{62.4} \left(\frac{Q_v}{500} \right)^2 - 45.9$$

$$H_f = (Q_t / 6350)^2 \cdot 277.3$$

$$H_{tot}$$

120	120
-9	37.2
247.8	557.
N/A	714.2

$P_{RPV} @ C_v = 400$

$$Q_{PSV} = 7600 / 3 = 2,533 \text{ gpm}$$

$$P_{RPV} = \frac{58.4}{144} \left[\frac{144}{62.4} \left(\frac{2,533}{400} \right)^2 - 45.9 \right] = 18.9 \text{ psig}$$

$P_{RPV} @ C_v = 500$

$$Q_{PSV} = 7720 / 3 = 2,590 \text{ gpm}$$

$$P_{RPV} = \frac{59.5}{144} \left[\frac{144}{62.4} \left(\frac{2,590}{500} \right)^2 - 45.9 \right] = 6.6 \text{ psig}$$



CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81

CALC. NO. M152-7 REV. NO. 0

CHECKED DWJ DATE 5-4-81

PROJECT Susquehanna

JOB NO. 8856

SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode

SHEET NO. 7 of 10

FOUR PSV OPEN

$$C_V = 400$$

Q_{TOT}

6000 8000 9000

Q_V

1500 2000 2250

$$H_S = \frac{144}{62.4} \left(\frac{Q_V}{400} \right)^2 - 45.9$$

$$H_P = \left(Q_V / 6350 \right)^2 \cdot 277.3$$

$$H_{tot}$$

120	120	120
-13.4	11.8	27.1
247.8	440	557
N/A	571.8	704.1

$$C_V = 500$$

$$H_S = \frac{144}{62.4} \left(\frac{Q_V}{500} \right)^2 - 45.9$$

$$H_P = \left(Q_V / 6350 \right)^2 \cdot 277.3$$

$$H_{tot}$$

120	120
-9	0.8
440	557
N/A	677.8

$$PRPV @ C_V = 400$$

$$Q_{PSV} = 7780 / 4 = 1945 \text{ gpm}$$

$$PRPV = \frac{59.6}{144} \left[\frac{144}{62.4} \left(\frac{1945}{400} \right)^2 - 45.9 \right] = 3.5 \text{ psig}$$

$$PRPV @ C_V = 500$$

$$Q_{PSV} = 7900 / 4 = 1975 \text{ gpm}$$

$$PRPV = \frac{59.8}{144} \left[\frac{144}{62.4} \left(\frac{1975}{500} \right)^2 - 45.9 \right] =$$

(NEG)

atmospheric





CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
PROJECT SUREVEHANNA CHECKED JWG DATE 5-4-81
SUBJECT CORE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE JOB NO. 8856
SHEET NO. 8 of 10

Determine Amount of Throttling Required to Match Initiation Pressure of 98 psig with one PCV open.

With 0 back pressure:

$$P_{PSV} = P_{RPV} + \frac{P_{HD}}{144} = 98 + \frac{56.2 \cdot 45.9}{144} = 115.9 \text{ psig}$$

Flow through PSV

$$P_{PSV} = \frac{P}{62.4} \left(\frac{Q}{C_V} \right)^2$$

$$\therefore Q = \left(P_{PSV} \frac{62.4}{P} \cdot C_V^2 \right)^{0.5} = C_V \cdot \left(P_{PSV} \frac{62.4}{P} \right)^{0.5}$$


$$\text{For } C_V = 400: Q = 400 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 4528$$

$$\text{For } C_V = 500: Q = 500 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 5660 \text{ gpm}$$

Amount of throttling for above flows are shown on sht. 9.



COKE SPRAY PUMP OPERATION IN ALTERNATE SHUTDOWN COOLING MODE



CHLCS 17152-7, REV 0

BY: *Sh. 4/2/91* CHCD: *DRW E-4-81*

SHEET 9 OF 10



CALCULATION SHEET

ORIGINATOR J. J. Brunner

DATE 4/30/81

CALC. NO. M152-7

REV. NO. 0

CHECKED GWJ

DATE 5-4-81

PROJECT SHISHKEHANNA

JOB NO. 8856

SUBJECT CORE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE

SHEET NO. 10 OF 10

APPENDIX A

ESTIMATE OF VALVE FLOW COEFFICIENT C_V

Valve capacity (per Ref. 5 for liquid)

$$Q = 27.2 C_A A K_{sg} \sqrt{\frac{P - P_b}{\Delta P}}$$

(gpm)

where: C_A = correction factor for accum. press.
assume 1

$$K_{sg} = 1 \text{ (for water)}$$

$$P_b = 0 \text{ assuming no back pressure.}$$

$$A = 16' \text{ orifice area for Crosby style 6 R10HB-65-BP (see Ref. 5 & 6)}$$

$$Q = 27.2 \cdot 16 \cdot \sqrt{\Delta P} = 435.2 \sqrt{\Delta P}$$

$$\text{From flow equation } \Delta P = \frac{Q^2}{62.4 \left(\frac{Q}{C_V}\right)^2}$$

$$\text{or: } Q = C_V \sqrt{\frac{62.4}{5} \Delta P}$$

By substitution:

$$435.2 \sqrt{\Delta P} = C_V \sqrt{\frac{62.4}{5} \Delta P}$$

$\therefore$

$$C_V = \frac{435.2}{\sqrt{\frac{62.4}{5}}}$$

$$P = 59.8 \text{ lb/ft}^2$$

$$P = 14.7 \text{ psia}$$

$$T = 212^\circ F$$

$$C_V = \frac{435.2}{\sqrt{\frac{62.4}{59.8}}} = 427$$





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

JOB NO. 8856

DISCIPLINE MECHANICAL/NUCLEAR

COVER SH. A OF A-B
CALC. NO. 152-6
NO. OF SHEETS 102
Q NO. 51.0

TITLE CORE SPRAY CALCULATIONS

SUSQUEHANNA STATION UNITS 1 & 2
PENNSYLVANIA P & L JOB 8856

SUBJECT PRESSURE DROPS IN THE CORE SPRAY SYSTEM
OF UNITS 1 AND 2 FOR VARIOUS MODES OF
OPERATION.

STATEMENT OF PROBLEM COMPUTE PRESSURE DROPS IN THE
CORE SPRAY SYSTEM FOR UNITS 1 AND 2 UNDER
VARIOUS MODES OF OPERATION IN ORDER TO SIZE
FLOW ORIFICES AND TO VERIFY LINE SIZES, NPSH,
AND OPERATING CONDITIONS.

CALC. SHEET CONTROL:

REVISION 0:
REVISED PAGES:
3, 6, 12, 14, 15, 18, 26, 35, 36,
40, 48, 51, 56, 60, 68, 71, 77, 78
ADDED PAGES:
12A, 12B, 12C, 12D, 12E, 12F,
78A, 78B, 78C.
DELETED PAGE: 57

REVISION 1:
REVISED PAGES:
3, 35, 38, 49, 58, 69, 80
ADDED PAGE: 3A

CAR CHECKED ☒

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: 8856-DBB-113-1 Rev 2, DBB-113-2 Rev 3, DCA-107-1 Rev 7, DCA-107-2 Rev 7,
DCA-109-1 Rev 4, DCA-109-2 Rev 4, GBB-101-1 Rev 4, GBB-101-2 Rev 3, GBB-101-3 Rev 2, GBB-101-4 Rev 7,
GBB-107-1 Rev 7, GBB-102-2 Rev 5, GBB-102-3 Rev 6, GBB-103-1 Rev 2, GBB-103-2 Rev 2, HCB-104-1 Rev 6,
HCB-104-2 Rev 7, HCB-103-1 Rev 3, HCB-103-2 Rev 3, HCB-101-2 Rev 4, HCB-101-1 Rev 3, HCB-102-1 Rev 2,
HCB-101-1 Rev 2, HCB-101-1 Rev 4, DBB-213-1 Rev 2, DBB-213-2 Rev 1, DCA-207-1 Rev 1, DCA-207-2 Rev 1,
DCA-204-1 Rev 1, DCA-209-2 Rev 1, GBB-201-1 Rev 2, GBB-201-2 Rev 3, GBB-201-3 Rev 2, GBB-201-4 Rev 2,
GBB-202-1 Rev 4, GBB-202-2 Rev 3, GBB-202-3 Rev 3, GBB-203-1 Rev 3, GBB-203-2 Rev 3, CONT NEXT PAGE

SOURCES OF FORMULAE & REFERENCES (1) CRANE TECHNICAL PAPER No. 410 (1965)
(2) G. E. PROCESS DIAGRAM, PROCESS DATA 8856-MI-E21-15-2 ✓
(3) GLOVER, TRAVIS F., "UNDERSTANDING NPSH FOR PUMPS" PLANT ENGINEERING, DEC. 24, 1975.
(4) PUMP PERFORMANCE CURVE 8856-MI-E21-30-1 ✓ (VPF No. 3308-149-1)
(5) DANIEL STEAM-LIQUID ORIFICE FLOW CALCULATOR
(6) PIPING SPECIFICATION M-199 Rev. 30
(7) POSTA, BENJENY, "BASIC GUIDANCE TO AVOID CAVITATION OF ORIFICES & VALVES" JUNE 21, 1974.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NOS. 152-5
152-4, 152-3, 152-2, 152-1

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
	6/21/79	G. KALINAUSKAS / <i>H. Kalinauskas</i>	<i>Ed Brown</i>	8/20/79	R. M. Jackson	8/21/79
C	3/27/79	G. KALINAUSKAS / <i>H. Kalinauskas</i>	<i>J. C. McCune</i>	3-30-79	R. M. Jackson	4/6/79
A	11/8/78	G. KALINAUSKAS / <i>H. Kalinauskas</i>	<i>E. Cornell</i>	12-2-78	R. M. Jackson	1/2/79

*Preliminary calcs checked only at group supervisor's request.

**Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.



SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

JOB NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. B OF A-B
CALC. NO. 152-6
NO. OF SHEETS 1
Q NO. 510

TITLE CORE SPRAY CALCULATIONS

SUSQUEHANNA STATION UNITS 1 & 2
PENNSYLVANIA P & L JOB 8856

CALC. SHEET CONTROL:

SUBJECT

STATEMENT OF PROBLEM

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA CON'T FROM PAGE 1: HBB-204-1 Rev 4, HBB-204-2 Rev 5, HBD-283-1 Rev 2,
HBD-283-2 Rev 1, HCB-201-1 Rev 5, HCD-211-1 Rev 3, HCD-215-1 Rev 6
VALVE Cr: 8856-P10A-1B-6 Rev D, P12A-15-4 Rev B, P12A-19-4 Rev C, P12A-22-7 Rev E
P12A-25-5 Rev C, P12A-56-3 Rev A, P12A-63-5 Rev C, P12BC-15-6 Rev D, P12A-17-4 Rev B
P17A-21-6 Rev D, P17A-26-5 Rev D, P18AC-2-6 Rev 4.
ORIFICE SIZES - J-30-39 Rev 0

SOURCES OF FORMULAE & REFERENCES

- (8) P. & I. D. - CORE SPRAY - M-152 Rev 9
- (9) AREA DRAWING - M-35-2 Rev 9
- (10) EQUIPMENT LOCATION DRAWING - M-247 Rev 8.
- (11) G.E. P. & I. D. - M1-E21-14-2
- (12) G.E. DESIGN SPECIFICATION & DATA SHEETS - DOC. NO. 22A3053 Rev 0
- (13) P. & I. D. - M-108 Rev 12

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV	DATE	BY	DATE	BY	DATE	BY
1	6/21/79	A. Kalinauskas				
3	3/27/79	A. Kalinauskas	J.C. McCague	3-30-79	B.M. Jackson	4/6/79
A	11/8/78	A. Kalinauskas	E. Connolly	12-2-78	B.M. Jackson	1/2/79



CALCULATION SHEET

CALC. NO. 152-6 REV. NO. 0
 CHECKED ECC DATE 12-2-78
 JOB NO. 8856
 SHEET NO. 79

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2
 SUBJECT PENNSYLVANIA P & L SPRAY CALCULATIONS JOB 8856

1 SECTION 3

2 NPSH CALCULATIONS

3 MODE A

$$5 \text{ NPSHA} = h_s - h_f + h_a - h_{vpa} \quad (\text{ref 3})$$

$$6 \text{ } h_f (120^\circ \text{F})$$

TABLE A-1

NODE	Eq. LENGTH on Cr	d (in.)	d ⁵ (in ⁵)	v (ft/sec)	ΔP (psi)
12 STRAINER - 2.1	ΔP = 2 psi C _v = 20,700	15.25	8.25 × 10 ⁵	11.14	2.0
13		15.25	8.25 × 10 ⁵	11.14	0.09
14	136'	15.25	8.25 × 10 ⁵	11.14	1.15
15 2.1 - 2.2	36'	15.25	8.25 × 10 ⁵	11.14	0.30
16 2.2 - 3 B	127'	15.25	8.25 × 10 ⁵	5.57	0.28
TOTAL ΔP =					3.82 psi

$$17 \rho (120^\circ \text{F}) = 61.73 \text{ lb/ft}^3 \quad (\text{ref 1 pg A-6})$$

$$18 \mu (120^\circ \text{F}) = 0.51 \text{ cp.} \quad (\text{ref 1 pg A-3})$$

20 STRAINER - 2.1 FOR VALVE FOOLB

$$21 \Delta P = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2 \quad (\text{ref 1 pg 2.9})$$

$$22 \Delta P = \frac{61.73}{62.4} \left(\frac{6350}{20,700} \right)^2$$

$$23 \Delta P = 0.09 \text{ psi}$$

26 FOR PIPE + FITTINGS:

$$27 v = 0.408 \frac{Q}{d^2} = 0.408 \frac{(6350)}{(15.25)^2} = 11.14 \text{ ft/sec.}$$

$$28 Re = 123.9 \frac{d v \rho}{\mu} = 123.9 \frac{(15.25)(11.14)(61.73)}{(0.51)} = 2.55 \times 10^6$$

$$30 f = 0.013 \quad (\text{from ref 1 pg A-25})$$

$$31 \Delta P = 0.000216 \frac{f L \rho Q^2}{d^5} = 0.000216 \frac{(0.013)(136)(61.73)(6350)^2}{8.25 \times 10^5}$$

$$32 \Delta P = 1.15 \text{ psi}$$





(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 1
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA PUMP & ACTIONS JOB 8856 SHEET NO. 80

1 2.1 - 2.2

2 FOR PIPE + FITTINGS:

$$3 \quad \Delta P = 0.000216 \frac{f L Q^2}{d^5} = 0.000216 \frac{(0.013)(36)(61.73)(6350)^2}{8.25 \times 10^5}$$

$$4 \quad \Delta P = 0.30 \text{ psi}$$

5 2.1 - 3B

6 FOR PIPE + FITTINGS:

$$7 \quad v = 0.408 \frac{Q}{d^2} = 0.408 \frac{(3175)}{(15.25)^2} = 5.57 \text{ ft/sec} \rightarrow Q = 3175 \text{ gpm (ref 2)}$$

$$8 \quad Re = 123.9 \frac{d v \rho}{\mu} = 123.9 \frac{(15.25)(5.57)(61.73)}{(0.51)} = 1.27 \times 10^6$$

$$9 \quad f = 0.0135 \text{ (from ref 1 pg A-25)}$$

$$10 \quad \Delta P = 0.000216 \frac{f L Q^2}{d^5} = 0.000216 \frac{(0.0135)(127)(61.73)(3175)^2}{8.25 \times 10^5}$$

$$11 \quad \Delta P = 0.28 \text{ psi}$$

$$12 \quad h_f = 3.82 \text{ psi} \left(\frac{1}{61.73} \frac{\text{ft}^3}{\text{hr}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

$$13 \quad h_f = 8.91 \text{ ft}$$

$$14 \quad z_2 = 670' \text{ (min. water level in pool - assumed 1' below normal M-247 Rev 8)}$$

$$15 \quad z_1 = 646' 10^{5/8} \text{ (inlet level to pump - iso HBB-104-2 Rev 6)}$$

$$16 \quad h_s = (670' - 646' 10^{5/8})$$

$$17 \quad h_s = 23.11 \text{ ft}$$

$$18 \quad h_a = 33.16 \text{ ft (by calculation from ref 3 Table I)}$$

$$19 \quad h_{vpa} = 1.692 \frac{\text{hr}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{61.73 \text{ hr}} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 3.95 \text{ ft (ref 1 pg A-6)}$$

$$20 \quad \therefore \text{NPSHA} = h_s - h_f + h_a - h_{vpa} = 23.11 - 8.91 + 33.16 - 3.95$$

$$21 \quad \text{NPSHA} = 43.41 \text{ ft} \quad \text{NPSHR} = 2 \text{ ft (ref 4) or pg 13}$$



● CALCULATION SHEET ●

CALC. NO. 152-6 REV. NO. 0

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1970 CHECKED ECC DATE 12-2-78

PROJECT SUSQUEHANNA STATION UNITS 1 & 2 JOB NO. 8856

SUBJECT CORE SPRAY CALCULATIONS JOB 8856 SHEET NO. 81

1 MODE B

2

3 $NPSHA = h_s - h_f + h_a - h_{vpa}$

4

5 h_f

6

NODE

TABLE B.1

TABLE B.1

ΔP

7

OR C_r

(psi)

ENTRANCE

62'

0.27

15-16

250'

1.10

$C_r = 18,470$

0.21

124'

0.72

$C_r = 20,700$

0.16

108'

1.63

2.1-2.2

136'

0.54

2.2-3B

127'

0.51

TOTAL $\Delta P = 6.14$ psi

18 $h_f = 6.14 \text{ psi} \left(\frac{1 \text{ ft}^3}{62.27 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{1 \text{ ft}^2} \right)$

20 $h_f = 14.20 \text{ ft}$

23 $h_s = z_2 - z_1$ $z_2 = 673' 9''$ (outlet level from tank - see HCB-1-2 Rev 4)

24 $h_s = (673' 9'' - 646' 10\frac{5}{8}'')$ $z_1 = 646' 10\frac{5}{8}''$ (inlet level to pump - see HBB-104-1 Rev 6)

25 $h_s = 26.86 \text{ ft}$

27 $h_a (674') = 33.16 \text{ ft}$ (by calculation from ref 3 Table I)

29 $h_{vpa} (70^\circ F) = 0.363 \frac{\text{ft}}{\text{in}} \times \frac{1 \text{ ft}^3}{62.27 \text{ lb}} \times \frac{144 \text{ in}^2}{1 \text{ ft}^2} = 0.84 \text{ ft}$ (ref 1 pg A-6)

31 $NPSHA = h_s - h_f + h_a - h_{vpa}$

33 $NPSHA = 26.86 - 14.20 + 33.16 - 0.84$

34 $NPSHA = 44.98 \text{ ft.}$

36 $NPSHR = 19 \text{ ft}$ (ref 2).



(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA P&S CALCULATIONS JOB 8856 SHEET NO. 82

1 MODE C

2

3 $NPSHA = h_s - h_f + h_a - h_{upa}$

4

5 TABLE C.1

6

NODE	EQ. LENGTH or C_v	ΔP (psi)
STRAINER - 2.1	$\Delta P = 2 \text{ psi}$ $C_v = 20,700$	2.0
	136'	9.2×10^{-4}
2.1 - 2.2	36'	1.32×10^{-2}
2.2 - 3B	127'	3.5×10^{-3}
		3.35×10^{-3}
		TOTAL $\Delta P = 2.02 \text{ psi}$

7

8

9

10

11 $h_f = 2.02 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ ft}^3} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$

12 $h_f = 4.84 \text{ ft}$

13

14

15 $h_s = z_2 - z_1$

16 $h_s = 23.11 \text{ ft}$

17 $z_2 = 670' \text{ (as before)}$

18 $z_1 = 646' 10^{5/8}'' \text{ (as before)}$

19

20 $h_a (670') = 33.16 \text{ ft}$

21

22

23 $h_{upa} (200^\circ \text{F}) = 11.53 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.13 \text{ ft}^3} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 27.61 \text{ ft} \text{ (ref 1 pg A-6)}$

24

25 $\therefore NPSHA = h_s - h_f + h_a - h_{upa}$

26

27 $NPSHA = 23.11 - 4.84 + 33.16 - 27.61$

28 $NPSHA = 23.82 \text{ ft}$

29

30

31 $NPSHR = 2 \text{ ft} \text{ (ref 4) or pg 13}$

32

33

34

35

36



(CALCULATION SHEET)

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-6-78
 SUBJECT CORE SPRAY CALCULATIONS JOB NO. 8856 SHEET NO. 83

1 MODE D

2

3
$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

4

5 TABLE D-1

6 NODE	7 EQ. LENGTH OR C_v	8 ΔP (psi)
9 STRAINER - 2-1	10 $\Delta P = 2 \text{ psi}$	11 2.0
	12 $C_v = 20,700$	13 0.09
	14 136'	15 1.09
16 2-1 - 2-2	17 36'	18 0.29
19 2-2 - 3B	20 127'	21 0.27
		22 TOTAL $\Delta P = 3.74 \text{ psi}$

23

24
$$h_f = 3.74 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

25

26
$$h_f = 8.86 \text{ ft}$$

27

28
$$h_s = z_2 - z_1$$

29
$$z_2 = 670' \text{ (as before)}$$

30

31
$$h_s = 23.11 \text{ ft}$$

32
$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

33

34
$$h_a (670') = 33.16 \text{ ft}$$

35

36
$$h_{vpa} (170^\circ \text{F}) = 5.99 \frac{\text{ft}}{\text{in}^2} \times \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}} \right) \times \frac{144 \text{ in}^2}{\text{ft}^2} = 14.19 \text{ ft} \quad (\text{ref 1 pg A-6})$$

37

38
$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

39

40
$$NPSHA = 23.11 - 8.86 + 33.16 - 14.19$$

41

42
$$NPSHA = 33.22 \text{ ft}$$

43

44
$$NPSHR = 2 \text{ ft (ref 4) or pg 13}$$





(CALCULATION SHEET)

CALC. NO. 15A-6 REV. NO. 0

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CHECKED ECC DATE 12-2-78

PROJECT SUSQUEHANNA STATION UNITS 1 & 2 JOB NO. 8856

SUBJECT CORE PENNSYLVANIA P & L SPRAY CALCULATIONS JOB 8856 SHEET NO. 84

1 MODE E

2

3

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

4

5

TABLE E-1

6

NODE

EQ. LENGTH

ΔP

7

or C_v

(psi)

STRAINER - 2.1

$$\Delta P = 2 \text{ psi}$$

2.0

5'

$$C_v = 20,700$$

0.09

136'

1.08

2.1 - 2.2

36'

0.28

2.2 - 3B

127'

0.26

$$\text{TOTAL } \Delta P = 3.71 \text{ psi}$$

$$h_f = 3.71 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ ft}} \right) \left(\frac{144 \text{ in}^2}{1 \text{ ft}^2} \right)$$

$$h_f = 8.88 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$z_2 = 670' \text{ (as before)}$$

$$h_s = 23.11 \text{ ft}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a (670') = 33.16 \text{ ft}$$

$$h_{vpa} (200^\circ \text{F}) = 11.53 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.13 \text{ ft}} \times 144 \frac{\text{in}^2}{\text{ft}^2} = 27.61 \text{ ft (ref 1 pg A-6)}$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 8.88 + 33.16 - 27.61$$

$$NPSHA = 19.78 \text{ ft}$$

$$NPSHR = 11 \text{ ft. (ref 2)}$$





(CALCULATION SHEET)

ORIGINATOR G. KALINDIASKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ECC DATE 12-2-78
 SUBJECT CORE SPRAY CALCULATIONS JOB NO. 8856 SHEET NO. 85

MODE F

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

TABLE F.1

NODE	EQ. LENGTH or C_r	ΔP (psi)
STRAINER - 2.1	$\Delta P = 2 \text{ psi}$	2.0
	$C_r = 20,700$	0.12
	136'	1.50
2.1 - 2.2	36'	0.40
2.2 - 3B	127'	0.36
TOTAL $\Delta P =$		4.38 psi

$$h_f = 4.38 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.79 \text{ ft}^3} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

$$h_f = 10.38 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$h_s = 23.11 \text{ ft}$$

$$z_2 = 670' \text{ (as before)}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a(670') = 33.16 \text{ ft}$$

$$h_{vpa}(170^\circ\text{F}) = 5.99 \frac{\text{ft}}{\text{in}^2} \times \frac{1 \text{ ft}^3}{60.79 \text{ ft}^3} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 14.19 \text{ ft} \text{ (ref 1 pg A-6)}$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 10.38 + 33.16 - 14.19$$

$$NPSHA = 31.70 \text{ ft}$$

$$NPSHR = 2.5 \text{ ft. (ref 4) or pg 13}$$



CALCULATION SHEET

ORIGINATOR G. KALINAUSKAS DATE NOV 08 1978 CALC. NO. 152-6 REV. NO. 0
 PROJECT SUSQUEHANNA STATION UNITS 1 & 2 CHECKED ΣCC DATE 12-2-78
 SUBJECT CORE PENNSYLVANIA P&B'S JOB NO. 8856 SHEET NO. 86

MODE G

$$NPSHA = h_s - h_f + h_a - h_{vpa}$$

TABLE G.1

NODE	ED. LENGTH OR C_v	ΔP (psi)
STRAINER - 2.1	$\Delta P = 2 \text{ psi}$	2.0
	$C_v = 20,700$	0.14
	136'	1.68
2.1 - 2.2	36'	0.44
2.2 - 3B	127'	0.41

$$\text{TOTAL } \Delta P = 4.67 \text{ psi.}$$

$$h_f = 4.67 \text{ psi} \left(\frac{1}{60.57} \frac{\text{ft}^3}{\text{hr}} \right) \left(144 \frac{\text{in}^2}{\text{ft}^2} \right)$$

$$h_f = 11.10 \text{ ft}$$

$$h_s = z_2 - z_1$$

$$h_s = 23.11 \text{ ft}$$

$$z_2 = 670' \text{ (as before)}$$

$$z_1 = 646' 10 \frac{5}{8}" \text{ (as before)}$$

$$h_a(670') = 33.16 \text{ ft}$$

$$h_{vpa}(180^\circ\text{F}) = 7.51 \frac{\text{ft}}{\text{hr}} \times \frac{1 \text{ ft}^3}{60.57 \text{ hr}} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 17.85 \text{ ft} \quad (\text{ref 1 pg A-6})$$

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa}$$

$$NPSHA = 23.11 - 11.10 + 33.16 - 17.85$$

$$NPSHA = 27.32 \text{ ft}$$

$$NPSHR = 16 \text{ ft} \quad (\text{ref 2})$$

REPORT OF PERFORMANCE TEST FOR PUMP S/N 107384

2356-M1-E21-30-1

A performance test was conducted 8 September 1976 for a pump on order 006-36051 (AE 231). All necessary data associated with the hydraulic performance was obtained. The serial numbers for the impeller and casings are as follows:

<u>Stage No.</u>	<u>Casings</u>	<u>Impellers</u>
1	66044	57303
2	64953	68422
3	64946	68449
4	64957	55611
5	64703	69496
6	70976	68404

Vibration was found to be satisfactory as indicated by the data sheets. The NPSH points for a flow of 3004 GPM towards shut-off have been plotted on Curve N-831, Rev. 0 and fall on the head capacity curve. The NPSH data from 3625 GPM to runout is also plotted on N-831, Rev. 0.

SUSQUEHANNA 1,2
MPL # E21-C001

FF128510

TAG - 1P206 A, B, C & D

GENERAL ELECTRIC	
NUCLEAR ENERGY DIVISION	
☐	Disapproved per comments. Revise and resubmit for approval.
☐	Approved with Comments. Revise and resubmit IN FINAL FORM.
☐	Refer to EDS No. _____
☐	Approved. No further action req'd.
☐	Approved. Submit certified copy.
☒	Certified by Seller and Approved by Buyer.
Reviewed by <u>R. Lemp</u>	
Date <u>25 Oct 1976</u>	
VPF No. <u>3308-149-1</u>	

CERTIFICATE OF COMPLAINE

The performance test on Pump S/N 107384 on order 006-36051 (AE 231) was conducted in accordance with Procedure QCP-1085, Rev. 4 except the test was conducted in the Cameron shell.


R. Lemp / D. Shalman
R. Lemp.
Cameron Test Dept.

CUSTOMER **G.F.A.P.E.D.**PROPOSAL NO. **006-3606/ITEM-2**

SPECIAL NOTES

**PUMP SN 107384
TESTED IN CAMERON SHELL**

DESIGN CONDITIONS

**GPM 3175 EFF -
T.H. (FT.) 668 BHP - SG. 1.0
RPM 1780 DRIVER HP
700 HP MOTOR
WITH 1.0 S.F.****Ingersoll-Rand****DRAWN
BY D.P.W.****9-14-76
DATE**CURVE **N-831, REV. 0.**PUMP **25APHD-6**CURVE **N-831, REV. 0**


PUMP SN 107384

PART OF PERFORMANCE CURVE N-831, REV. 0

NOTE:

- ⊙ PERFORMANCE DATA FOR HEAD, FLOW, EFFICIENCY & BHP
- △ NPSH TEST BASIS NPSH HELD CONSTANT AT APPROXIMATELY 6.4 FT. REF. TO C.L. SUCTION NOZZLE (2.3 FT. CORRECTION INCLUDED).
- ▣ NPSHA FROM 3625 GPM TOWARDS RUN-OUT, REF. TO C.L. SUCTION NOZZLE (2.3 FT. CORRECTION INCLUDED).

5

CAMERON PUMP DIVISION		INGERSOLL-RAND COMPANY								TEST RECORD		
HEAD 3.56 @ 300 GPM	DISCHARGE HEAD	AS READ	479	651	727	807	845	891	927	948		
		CORRECTED ELEVATION	479	652	729	809	847	893	929	950		
	SUCTION LIFT FT. ZERO DEPRESSED	0.120 FT.	61	61	62	62	62	63	63	63		
	CHANGE IN VELOCITY HEAD IN FEET	24 x 12	3	2	1	1	0	0	0	0		
	TOTAL HEAD		421	594	669	749	786	831	867	888		
CAPACITY	VENTURI TUBES	18" TUBE	4380	0	0	0	0	0	0	0		
		CORRECTED	4411	0	0	0	0	0	0	0		
	SIZES AND READINGS	10" TUBE	0	3647	3218	2581	1804	1084	375	0		
		CORRECTED	0	3632	3182	2491	1715	1098	395	0		
	TOTAL G.P.M.		4411	3632	3182	2491	1715	1098	395	0		
WATER H.P.			468.9	543.9	536.8	470.5	340.0	230.1	86.4	0		
POWER	WATTMETER	AS READ	.732	.727	.702	.649	.570	.526	.479	.477		
		CORRECTED KW	512.4	508.9	491.4	454.3	399.0	368.2	335.3	333.9		
		TOP OF MOTOR VIB.	1.1	1.0	1.0	1.0	1.0	1.0	1.0	1.0		
		MOTOR VIB.	1.6	1.7	1.7	1.7	1.7	1.7	1.7	1.7		
	BRAKE H. P.		644	640	618	572	506	465	417	415		
SHAFT VIB.		H ₂ O °F	1.7	1.7	2.1	1.7	1.7	1.7	1.7	1.7		
SEAL LEAKAGE		SPECIFIC GRAVITY	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE		
PUMP EFFICIENCY %			72.8	85.0	86.7	82.3	67.2	49.5	20.7	0		
DRIVER 700 HP MOTOR			FULL LOAD SPEED			R.P.M.	PUMP NO. 107384	SIZE 25	TYPE APKD	STAGES 6		
LIQUID H ₂ O			NOTES: T-R SHELL			G.P.M. 3175	TOTAL HEAD IN FT. 668	SUCT.	R.P.M. 1780	EFF. %		
TEMP.			SHUTDOWN TIME: 30 SEC.			IMPELLER	DIA.	VANE DIA	DIFFUSOR			
VISCOS.			WITNESSED BY [Signature]			SUCTION CONNECTION TO C.L. PUMP			C.L. PUMP TO C.L. DISC. GAUGE			
GRAVITY 1.0						TEST PROCEDURE CQCP - 1085 REV. 4						
TEST STAND #16						CUSTOMER G.E.A.P.E.D.						
TESTED BY R. LEMP						ORDER NO. 006-36051			ITEM NO. 2			
APP. BY						DATE SEPT. 8, 1976			TEST NO.			

7



PUMP S/N 107384	SIZE 25	TYPE APKD-6	DATE SEPT. 8, 1976	TEST STAND #16	NPSH+ (BARO-VPY) 1.133 - SUC.+LIFT + VEL. HD SP. GR.
PELLER	DIA	CUSTOMER G.E.A.P.E.D.	DATA BY R. LEMP	2.2 SUBMERGENCE + 2.3 CORRECTION	
I-R SHELL		ORDER NO. 006-36051	ITEM NO. 2	TOTAL HEAD= CORR. DISCH HD + VEL. HD + SUCT. HD	

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION +15.8 FT. ELEV.	VELOCITY HEAD 24 to 12	VACUUM AT C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (°F)	10+18" TUBE GPM	CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER ..(INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG)	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. CUST. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
1	822	837.8	0	21.5	860	80	430	450	485	340	999	27.83	NONE	3.6	0	1.03	28.80	32.63	6.4	21.4	424	23.0
2	795	810.8	.1	21.5	833	80	970	988	520	364				3.3	.01	1.03	28.80	32.63	6.4	21.4	460	45.1
3	760	775.8	.4	21.5	798	80	1665	1580	557	390				3.2	.02	1.03	28.80	32.63	6.4	21.4	495	61.3
4	726	741.8	.7	21.6	765	80	2350	2272	619	433				2.9	.05	1.03	28.80	32.63	6.3	21.5	547	80.1
5	657	671.8	1.3	21.7	695	81	3068	3004	685	480	↓	↓	↓	2.8	.08	1.07	28.76	32.59	6.2	21.6	604	87.3
6	558	572.8	1.9	19.9	596	82	3585	3625	722	505	998	27.83	NONE	2.8	.12	1.10	28.73	32.55	8.1	19.7	635	85.7
	555	569.8	1.9	22.9	596	82			722	505				2.8	.12	1.10	28.73	32.55	5.0	22.8	635	85.7
	553	567.8	1.9	23.9	595	82			722	505				2.7	.12	1.10	28.73	32.55	4.0	23.8	635	85.6
	549	563.8	1.9	25.9	593	83			725	508				2.7	.12	1.14	28.69	32.51	1.9	25.9	638	84.9
	521	535.8	1.9	26.4	565	83	↓	↓	719	503	↓	↓	↓	2.5	.12	1.14	28.69	32.51	1.4	26.4	633	81.6

FF/26510

Comments -

1. Page 6 of 6 is missing

DEC 08 1976

APED DRAWING REVIEW									
COMMENTS AS CHECKED BELOW									
E ☐ NO COMMENTS. F ☐ COMMENTS AS INDICATED, FOR APED'S INFORMATION AND USE ONLY. NO REPLY REQUIRED. G ☒ COMMENTS AS INDICATED, WHEN DIRECTLY AFFECTING BECHTEL RESPONSIBILITY. REPLY REQUIRED IF NOT INCORPORATED BY APED.									
FORWARDED BY <i>W. J. Schell</i>						DATE <i>1/24/77</i>			
REVIEWED		C	E	I	L	M <i>ML</i>			
BECHTEL SAN FRANCISCO						JOB NO. <i>7</i> 8856			

DISTRIBUTION			S
	NO.	DATE	
VENDOR	2P		DESCRIPTION—DRAWING
CLIENT	1T		
FIELD	2F		
Q.E.			
CIVIL			
ELECT.			
PLT. DES.			
MECH.	1		
CON. SYS.			
ARCH.			
PURCH.			
EXPED.			
INSPECT			
SCHED.			
START-UP			
RECORD	11F10R14		LOCATION
BECHTEL SAN FRANCISCO			





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

9346

JOB NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. A OF A-D
CALC. NO. 151-26
NO. OF SHEETS 263
Q NO. 49.0

FILE R.H.R. 4P CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

REVISION 1:

REVISED PAGES:
4, 6, 21, 34, 54, 66, 83, 86,
109, 174, 199, 209, 218,
223, 224, 226

ADDED PAGES:
4A, 5A

SUBJECT PRESSURE DROPS IN THE R.H.R. SYSTEM
OF UNITS 1 AND 2 FOR VARIOUS MODES (A-J) OF
OPERATION

REVISION 2:

REVISED PAGES:
131-153
ADDED PAGES:
153 A, B, C, D, E

STATEMENT OF PROBLEM COMPUTE PRESSURE DROPS IN THE
R.H.R. SYSTEM FOR UNITS 1 AND 2 UNDER
VARIOUS MODES OF OPERATION IN ORDER TO SIZE
FLOW ORIFICES AND TO VERIFY LINE SIZES.

SAR CHECKED ☒

SAR CHANGE REQ'D. ☒

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA ISOMETRICS: 8856-DBB-107-1 Rev 3, DBB-107-2 Rev 3, DBB-115-1 Rev 7, DCA-108-1 Rev 7,
DCA-110-1 Rev 6, DCA-110-2 Rev 9, DCA-111-1 Rev 8, DCA-111-2 Rev 5, DCB-102-1 Rev 4, GBA-104-1 Rev 7,
GBB-104-2 Rev 4, GBB-104-3 Rev 7, GBB-104-4 Rev 4, GBB-105-1 Rev 5, GBB-105-2 Rev 5, GBB-106-1 Rev 7,
GBB-106-2 Rev 7, GBB-107-1 Rev 4, GBB-107-2 Rev 4, GBB-108-1 Rev 5, GBB-109-1 Rev 6, GBB-109-2 Rev 7,
GBB-110-1 Rev 7, GBB-110-2 Rev 6, GBB-111-1 Rev 7, GBB-111-2 Rev 4, GBB-112-1 Rev 7, GBB-112-2 Rev 5,
GBB-115-1 Rev 4, GBB-116-1 Rev 5, GBB-116-2 Rev 5, GBB-117-1 Rev 2, GBB-118-1 Rev 5, GBB-118-2 Rev 2,
GBB-118-3 Rev 1, GBB-118-4 Rev 2, GBB-120-1 Rev 3, HBB-110-1 Rev 8, HBB-110-2 Rev 6, CON'T: EXT PAGE

SOURCES OF FORMULAE & REFERENCES: ① CRANE TECHNICAL PAPER No. 410 (1965)
② G.E. PROCESS DIAGRAM & PROCESS DATA 8856-M1-E11-3(1)-8 ✓
③ FLOW ORIFICE CURVE 8856-M1-E11-25-1
④ PUMP PERFORMANCE CURVE 8856-M1-E11-53-1 - see
⑤ DANIEL STEAM-LIQUID ORIFICE FLOW CALCULATOR
⑥ GLOVER, TRAVIS, F., "UNDERSTANDING NPSH FOR PUMPS", PLANT ENGINEERING, DEC. 24, 1975.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. 151-23,

151-22, 151-19, 151-16, 151-14, 151-13, 151-12 (CON'T NEXT PG.)

REV. NO.	DATE	CALCULATION BY	CHECKED BY	DATE	APPROVED BY	DATE
	12/11/79	G. KALINAUSKAS / H. Kalinauskas	J. Brown	1/25/80	M. Jackson	1/29/80
	6/20/79	G. KALINAUSKAS / H. Kalinauskas	J. Brown	8/20/79	B.M. Jackson	8/21/79
0	1/16/79	G. KALINAUSKAS / H. Kalinauskas	JCM	4-4-79	B.M. Jackson	5/10/79

*Preliminary calcs checked only at group supervisor's request.
*Considers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

COVER SH. B OF A-D
CALC. NO. 151-26
NO. OF SHEETS —
Q NO. 49.0

NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

TITLE R.H.R. AP CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

SUBJECT _____

STATEMENT OF PROBLEM _____

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA HBB-110-3 Rev 6, HBB-110-4 Rev 6, HBB-111-1 Rev 5, HBB-111-2 Rev 3, HBB-113-1 Rev 6,
HBB-113-3 Rev 3, HBD-185-1 Rev 1, HBD-186-1 Rev 4, DBB-207-1 Rev 1, DBB-207-2 Rev 2, DBB-215-1 Rev 5,
DCA-208-1 Rev 1, DCA-210-1 Rev 2, DCA-210-2 Rev 2, DCA-211-1 Rev 2, DCA-211-2 Rev 2, DCA-211-3 Rev 2,
DCB-202-1 Rev 2, GBB-204-1 Rev 6, GBB-204-2 Rev 5, GBB-204-3 Rev 6, GBB-204-4 Rev 4, GBB-205-1 Rev 4,
GBB-205-2 Rev 4, GBB-206-1 Rev 5, GBB-206-2 Rev 4, GBB-207-1 Rev 6, GBB-207-2 Rev 4, GBB-208-1 Rev 2,
GBB-209-1 Rev 4, GBB-209-2 Rev 5, GBB-210-1 Rev 3, GBB-210-2 Rev 3, GBB-211-1 Rev 2, GBB-211-2 Rev 3,
GBB-212-1 Rev 4, GBB-212-2 Rev 3, GBB-215-1 Rev 4, GBB-216-1 Rev 3, GBB-216-2 Rev 3, CONT NEXT PAGE

SOURCES OF FORMULAE & REFERENCES _____

- ⑦ POSTA, BEKENY, "BASIC GUIDANCE TO AVOID CAVITATION OF ORIFICES, VALVES" JUNE 21, 1974.
- ⑧ SPRAY ENGINEERING COMPANY - CATALOG # 73 - BURLINGTON, MASS. 01803.
- ⑨ ASME STEAM TABLES (1967)
- ⑩ P.I.D. - RESIDUAL HEAT REMOVAL - M-151 Rev 12
- ⑪ G.E. - P.I.D. - RESIDUAL HEAT REMOVAL - M1-E11-2 Rev 6

⑫ AREA DRAWING - M-257 Rev 3

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. 151-11,

151-10, 151-9, 151-8, 151-6, 151-5, 151-4, 151-3, 151-2, 151-1

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE

*Preliminary calcs checked only at group supervisor's request.

**Consider PSAB codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.



SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

NO. 8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. C OF A-D
CALC. NO. 151-26
NO. OF SHEETS —
Q NO. 49.0

TITLE R.H.R. OP CALCULATIONS

**SUSQUEHANNA STEAM
ELECTRIC STATION**

SUBJECT _____

STATEMENT OF PROBLEM _____

CALC. SHEET CONTROL:

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA G8B-217-1 Rev 2, G8B-218-1 Rev 1, G8B-218-2 Rev 2, G8B-218-3 Rev 2, G8B-218-4 Rev 2,
G8B-220-1 Rev 3, H8B-210-1 Rev 5, H8B-210-2 Rev 5, H8B-210-3 Rev 5, H8B-210-4 Rev 5, H8B-211-1 Rev 3,
H8B-211-2 Rev 3, H8B-213-1 Rev 4, H8B-213-2 Rev 1, H8D-285-1 Rev 1, H8D-285-2 Rev 1, H8D-286-1 Rev 3,
8856-M1-B31-16(2) Rev 10.

VALVE Cv: 8856-P1DA-74-5 Rev C, P12A-11-7 Rev D, P12A-12-6 Rev C, P12A-13-5 Rev C, P12A-18-7 Rev D,
P12A-20-10 Rev G, P12A-24-7 Rev E, P12A-60-6 Rev D, P12A-61-5 Rev D, P12A-62-6 Rev D, P12A-71-4 Rev B,
P12A-72-1 Rev C, P12A-74-4 Rev B, P12A-75-5 Rev C, P12A-80-3 Rev B, P12BC-14-9 Rev G, P12A-14-5 Rev C

SOURCES OF FORMULAE & REFERENCES _____

CON'T NEXT PAGE

(13) G.E. REACTOR VESSEL DRAWING - M1-B11-234 Rev 7.

(14) CALCULATIONS - M-111-17 Rev 0

(15) GB-76-171 (4/22/76)

(16) GB-79-72 (3/29/79) and BWG-1999 (1/24/79)

(17) CALCULATIONS - C-11-A Rev 6

(18) SPRAY NOZZLE PURCHASE ORDER - 8856-M154-10-1

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
----------	------	----------------	--------------	------	-------------	------

*Preliminary calcs checked only at group supervisor's request.

**Consider PSAR codes and standards redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity





SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
CALCULATION COVER SHEET

8856

DISCIPLINE MECHANICAL / NUCLEAR

COVER SH. D OF A-D
CALC. NO. 151-26
NO. OF SHEETS —
Q NO. 49.0

TITLE R.H.R. ΔP CALCULATIONS
SUSQUEHANNA STEAM
ELECTRIC STATION

CALC. SHEET CONTROL:

SUBJECT _____

STATEMENT OF PROBLEM _____

SAR CHECKED ☐

SAR CHANGE REQ'D. ☐

SAR CHANGE
NOTICE INITIATED ☐

SOURCES OF DATA P17A-15-4 Rev B, P17A-16-4 Rev C, P17A-17-4 Rev B, P17A-18-6 Rev E
P17A-23-5 Rev D, P17A-27-4 Rev C, P17A-62-3 Rev A, P17BC-2,
J-28 Rev 1

SOURCES OF FORMULAE & REFERENCES (19) SPRAY NOZZLE P.O. - 8856-MISH-2-2
(20) PIPING SPECIFICATION M-199 Rev 31.
(21) R.H.R. PUMPS - M1-E11-21-1
(22) R.H.R. HEAT EXCHANGER - M1-E11-23-2
(23) EMC-4262 (6/28/79)
(24) EQUIPMENT LOCATION DRAWING M-247 Rev 8.

*PRELIMINARY CALC. ☐

FINAL CALC. ☒

SUPERSEDES CALC. NO. _____

REV. NO.	DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE

*Preliminary calcs checked only at group supervisor's request.

**Consider PSAR, codes and standards, redundancy and engineering, operability and maintainability, technical data, as applicable, and their



CALCULATION SHEET

CALC. NO. 151-26 REV. NO. 1

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CHECKED JCM DATE 4-4-79

PROJECT SUSQUEHANNA STEAM JOB NO. 8856

SUBJECT R.H.R. AP CALCULATIONS SHEET NO. 223

SECTION 3 - NPSH CALCULATIONS

2

3 MODE C-2

4

$$NPSHA = h_s - h_f + h_a - h_{vpa} \quad (\text{ref 6})$$

6

7 h_f

TABLE C-2.1			
NODE	EQ. LENGTH or Cr	$\Delta P_{9260 \text{ gpm}}$ (psi)	
2B-3B	$\Delta P = 2 \text{ psi}$	2.0	
3B-41B	$Cr = 49,000$	0.03	
	299'	0.59	
41B-5B	90'	0.18	
	3'	1.79×10^{-3}	

17

$$\Delta P = 2.80 \text{ psi}$$

19

$$h_f = 2.80 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

21

$$h_f = 6.70 \text{ ft}$$

23

$$h_s = z_2 - z_1 \quad z_2 = 670' \text{ (min. water level - assumed 1' below normal - M-247 Rev 8)} \quad \Delta$$

$$h_s = (670' - 648' 0 \frac{1}{2} ") \quad z_1 = 648' 0 \frac{1}{2} " \text{ (inlet level to pump - iso HBB-110-2 Rev 6)} \quad \frac{7}{15}$$

$$h_s = 21.96 \text{ ft}$$

26

$$h_a (670') = 33.16 \text{ ft} \quad (\text{by calculation from ref 6 Table I})$$

29

$$h_{vpa} (200^\circ \text{F}) = 11.53 \text{ psi} \left(\frac{1 \text{ ft}^3}{60.13 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right) = 27.61 \text{ ft} \quad (\text{ref 1 pg A-6})$$

32

$$\therefore NPSHA = h_s - h_f + h_a - h_{vpa} = 21.96 - 6.70 + 33.16 - 27.61$$

$$= 20.81 \text{ ft.}$$

34

$$NPSHR = 3 + 4 = 7 \text{ ft} \quad (\text{ref. 2 and ref 4 - G.E. requires additional 4 ft.})$$

36



() CALCULATION SHEET ()

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CALC. NO. 151-26 REV. NO. 1
 PROJECT SUSQUEHANNA STEAM CHECKED JCM DATE 4-4-79
 SUBJECT R.H.R. ΔP CALCULATIONS JOB NO. 8856 SHEET NO. 224

1 NPSH CALCULATION

2

3 MODE G

4

5
$$NPSHA = h_s - h_f + h_a - h_{vpa} \quad (\text{ref } 6)$$

6

7 h_f

8	9	10	11	12	13	14
	MODE	TABLE G-1	EQ. LENGTH		ΔP	
			OR Cr		(psi)	
	2A-3A	ΔP = 2 psi			2.0	
	3A-41A	Cr = 49,000			0.07	
		380'			1.56	
	41A-5A	90'			0.37	
		3'			3.80×10^{-3}	

15

16
$$\Delta P = 4.00 \text{ psi}$$

17
$$h_f = 4.00 \text{ psi} \left(\frac{1 \text{ ft}^3}{61.54 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right)$$

18
$$h_f = 9.36 \text{ ft}$$

20

21 $h_s = z_2 - z_1$ $z_2 = 670'$ (min. water level - assumed 1' below normal - H-247 Rev. 8) $\frac{9/8/79}{\Delta z}$

22 $h_s = (670' - 648' 0\frac{1}{2}')$ $z_1 = 648' 0\frac{1}{2}''$ (inlet level to pump - iso HBB-110-1 Rev. 8)

23 $h_s = 21.96 \text{ ft}$

24

25 $h_a (670') = 33.16 \text{ ft}$ (by calculation from ref 6 Table I)

26

27 $h_{vpa} (130^\circ) = 2.22 \text{ psi} \left(\frac{1 \text{ ft}^3}{61.54 \text{ lb}} \right) \left(\frac{144 \text{ in}^2}{\text{ft}^2} \right) = 5.19 \text{ ft}$ (ref 1 pg A-6)

28

30
$$\begin{aligned} \text{NPSHA} &= h_s - h_f + h_a - h_{vpa} = 21.96 - 9.36 + 33.16 - 5.19 \\ &= 40.57 \text{ ft} \end{aligned}$$

31

33
$$NPSHR = 5 + 4 = 9 \text{ ft}$$
 (ref 2. and ref. 4 - G.E. requires additional 4 ft)

35

36



CALCULATION SHEET

ORIGINATOR G. KALINAUSKAS DATE JAN 16 1979 CALC. NO. 151-26 REV. NO. 0
PROJECT SUSQUEHANNA STEAM CHECKED JCM DATE 4-4-79
SUBJECT R.H.R. AP CALCULATIONS JOB NO. 8856 SHEET NO. 225

In a similar fashion, the following table was constructed for the other modes of operation with suction from the suppression pool.

TABLE 1

MODE	h_s (ft)	h_f (ft)	h_a (ft)	h_{upa} (ft)	NPSH A (ft)	NPSH R (ft)
A	21.96	8.78	33.16	5.19	41.25	3
B	21.96	7.85	33.16	5.19	42.08	3
C ₁	21.96	5.48	33.16	12.69	36.95	2
C ₂	21.96	6.70	33.16	27.61	20.81	7
D ₂	21.96	6.95	33.16	3.94	44.23	3
G	21.96	9.36	33.16	5.19	40.57	9
H	21.96	8.76	33.16	0.84	45.52	3

FF/24510

APED DRAWING REVIEW									
COMMENTS AS CHECKED BELOW									
E ☒ No comments.									
F ☐ Comments as Indicated, for APED's Information and use only. No reply required.									
G ☐ Comments as Indicated, when directly affecting Bechtel responsibility. Reply required if not Incorporated by APED.									
FORWARDED BY					DATE				
					12-6-76				
Reviewed					C	E	I	L	M
								W	Th
BECHTEL					JOB NO.				
SAN FRANCISCO					8856				

REPORT OF PERFORMANCE TEST FOR PUMP S/N 0573314

A performance test was conducted 26 July 1976 for a pump on order 006-36049 (AE 234). All necessary data associated with the hydraulic performance was obtained. The serial numbers for the impeller and casings are as follows:

<u>Stage</u>	<u>Casings</u>	<u>Impellers</u>
1	59910	66465
2	58664	66235
3	58665	68009
4	59882	65490

The vibration was found to be satisfactory as indicated by the Data Sheets. The NPSH points for a flow of 9898 GPM towards shut-off have been plotted on Curve N-810, Rev. 0 and fall on the head capacity curve. The NPSH data from 12081 GPM to runout is also plotted on N-810, Rev: 0.

 GENERAL ELECTRIC NUCLEAR ENERGY DIVISION	
☐	Disapproved per comments. Revise and resubmit for approval.
☐	Approved with Comments. Revise and resubmit IN FINAL FORM.
☐	Refer to EDS No. _____
☐	Approved. No further action req'd.
☐	Approved. Submit certified copy.
☒	Certified by Seller and Approved by Buyer.
Reviewed by <i>R. Lemp</i>	
Date <u>12 Aug 1976</u>	
VPF No. <u>3307-73-1</u>	

CERTIFICATE OF COMPLIANCE

The performance test of pump S/N 0573314 on order 006-36049 (AE 234) was conducted in accordance with Procedure CQCP-1085, Rev. 4.


R. Lemp / [Signature]

R. Lemp
Cameron Test Department

SUSQUEHANNA 1,2
MPL #E11C002

REC'D
2026
N.Y.

CUSTOMER G.E.A.P.E.D.	DESIGN CONDITIONS		 Ingersoll-Rand	CURVE N-810, REV.0
	PROPOSAL NO. 006-36049 ITEM 2	GPM 10,000 EFF		PUMP 34 APKO-4
SPECIAL NOTES PUMP SN 0573314 PUMP TESTED IN CAMERON SHELL	T.H. (FT.) 600	BHP	SG. 1.0	DRAWN BY D.P.W. DATE 7-27-76
	RPM 1180	DRIVER HP 2000 HP MOTOR WITH 1.0 S.F.		



PUMP SN 0573314

PART OF CURVE N-810, REV. 0

NOTE:

- ⊙ PERFORMANCE DATA FOR HEAD, FLOW, EFFICIENCY & BHP,
- △ NPSH TEST BASIS NPSH HELD CONSTANT AT APPROXIMATELY 9.5 FT., REF. TO C.L. SUCTION NOZZLE (0.9 FT. CORRECTION INCLUDED)
- ▣ NPSHR DATA FROM 12081 GPM TOWARDS RUNOUT, REF. TO C.L. SUCTION NOZZLE (0.9 FT. CORRECTION INCLUDED)




ON PUMP DIVISION

INGERSOLL-RAND COMPANY

TEST RECORD.

HEAD 1.67 @ 10,000	DISCHARGE HEAD	050% AS READ	506	598	683	739	770	816	852	875			
		CORRECTED 1.2 CLEAN	507	599	686	742	774	820	854	878			
	SUCTION LIFT FT. ZERO DEPRESSED	FT.	65	67	69	70	71	72	73	74			
	CHANGE IN VELOCITY HEAD IN FEET	24"x18"	3	2	2	1	1	0	0	0			
	TOTAL HEAD			446	536	621	676	707	751	784	807		
CAPACITY	VENTURI TUBES	18" TUBE "Hg	12459	11049	8948	6973	5712	0	0	0			
		GPM	12261	11033	8970	6915	5595	0	0	0			
	SIZES AND READINGS	10" TUBE "Hg	12.9	5.65	5.80	5.70	0	51.9	108.2	0			
		GPM	1681	1113	1127	1118	0	3372	1087	0			
	TOTAL G.P.M.			13942	12146	10097	8033	5595	3372	1087	0		
WATER H.P.			1567	1638	1578	1365	995	637	214	0			
POWER	METER WATT R.P. 2800/1 CS	AS READ	562	548	518	470	419	378	348	350			
		KW	1574	1534	1450	1316	1173	1058	974	980			
		R.P.M.											
	BRAKE H. P.			1935	1885	1775	1605	1424	1275	1170	1175		
SHAFT VIB. MILS			2.1	1.1	1.3	1.4	1.5	1.6	1.8	1.7			
SEAL LEAKAGE			NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE			
SP. GR.			997	996	996	996	996	996	996	996			
PUMP EFFICIENCY %			81.0	86.9	88.9	85.1	69.9	50.0	18.3	0			

DRIVER 2000 HP MOTOR		FULL LOAD SPEED		R.P.M.	PUMP NO. 0573314	SIZE 34	TYPE APKD	STAGES 4
LIQUID H ₂ O		NOTES: I-R SHELL			G.P.M. 10,000	TOTAL HEAD IN FT. 600	SUCT.	R.P.M. 1180
TEMP.		SHUTDOWN TIME: 70 SEC.			IMPELLER	DIA.	VANE DIA	DIFFUSOR
VISCOS.		WITNESS BY:			SUCTION CONNECTION TO C.L. PUMP		C.L. PUMP TO C.L. DISC. GAUGE	
GRAVITY 1.0				TEST PROCEDURE C&CP-1085 REV. 4				
TEST STAND #16				CUSTOMER G.E.A.P.E.D.				
TESTED BY R. LEMP		ORDER NO. 006-36049					ITEM NO. 2	
APP. BY		DATE JULY 26 1976					TEST NO.	



PUMP S/N 0573314	SIZE 34	TYPE AP15D-4	DATE JULY 26, 1976	TEST STAND #16	NPSH (BARO-VPY1.133) SP. GR.	SUC. + DIFT + VEL. HD SP. GR.
PELLER	DIA	CUSTOMER G.F.A.P.E.D.	DATA BY R.H. PH. LEMP	7.2 SUBMERGENCE + 9 CORRECTION		
I-R SHELL		ORDER NO. 006-36049	ITEM NO. 2	WITNESSED BY	TOTAL HEAD= CORR. DISCH. HD + VEL. HD + SUCTION	

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION + 5.6 FT. ELEV.	VELOCITY HEAD 24 to 18" VACUUM AT C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (OF)	10" TUBE CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER (INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG)	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
1	743	760.1	0	781	106	1004	1016	317	972	994	ABW	3.9	0	2.31	27.59	31.26	9.4	15.9	114.8	17.0
2	710	726.9	2	748	108	49.8	7302	372	1056	993	ABW	3.7	1	2.45	27.45	31.10	9.4	15.9	1273	48.7
3	666	682.3	5	704	109	5718	417	1168	993	ABW	3.6	3	2.52	27.37	31.02	9.5	15.9	1419	71.2	
4	642	655.8	1.0	678	110	7793	467	1308	993	ABW	3.6	5	2.60	27.30	30.93	9.6	15.9	1597	82.9	
5	588	602.9	1.6	626	112	7817	512	1134	992	ABW	3.3	9	2.75	27.15	30.76	9.8	16.0	1759	88.2	
6	503	519.6	2.4	541	113	12081	543	1520	992	79.9	ABW	2.8	1.3	2.82	27.07	30.67	11.2	14.9	1865	87.8
	503	516.6	2.4	540	114		543	1520	992			2.7	1.3	2.91	26.99	30.58	9.1	16.9	1865	87.7
	501	515.6	2.4	541	115		543	1520	992			2.8	1.3	3.00	26.90	30.49	7.7	18.2	1865	87.7
	495	512.6	2.4	540	116		543	1520	992			2.6	1.3	3.08	26.82	30.37	5.5	20.3	1865	87.5
	473	507.6	2.4	537	117		543	1520	991			2.8	1.3	3.17	26.72	30.29	3.5	22.3	1865	87.0
	481	503.6	2.4	534	118		543	1520	991			2.7	1.3	3.26	26.64	30.18	2.6	23.1	1865	86.5
	430	494.6	2.4	525	118		546	1512	991			2.8	1.3	3.26	26.64	30.18	2.4	23.3	1857	85.4
	411	425.1	2.4	456	119		485	1365	991			2.4	1.3	3.35	26.55	30.06	1.9	23.7	16.72	82.4




2 2 2 2 2



PUMP S/N 0573314	SIZE 34	TYPE AP10-4	DATE JULY 26, 1976	TEST STAND #16	NPSH+ [(BARO-VP)/1.133] 2.0	SUC. LIFT SP. GR. 1.0	VEL. HD CORRECTION .9
IMPELLER	DIA	CUSTOMER G.E.A.P.E.D.		DATA BY RALPH LEMP	SUBMERGENCE + CORRECTION		
I-R SHELL		ORDER NO. 006-36049	ITEM NO. 2	WITNESSED BY	TOTAL HEAD= CORR. DISCH HD + VEL. HD + SUCTION HD		

RUN NO.	DISCH. HEAD AS RUN	DISCH. HEAD CORRECTED TO C.L. OF SUCTION + 15.6 FT. ELEV.	VELOCITY HEAD 24 to 18 VACUUM AT	C.L. SUCTION (FT. OF H ₂ O)	TOTAL HEAD (FT. OF H ₂ O)	TEMP. AT PUMP SUCTION (OF)	1/2" TUBE GPM	CORRECTED GPM	WATT METER (AS READ)	KW	SPECIFIC GRAVITY	BAROMETER (INCHES HG)	SEAL LEAKAGE	VIBRATION (MILS)	SUCTION VELOCITY HEAD	VAPOR PRESSURE (INCHES HG)	RUNNING VACUUM (INCHES HG)	RUNNING VACUUM (FT. H ₂ O)	NPSH C.L. SUCTION	CORRECTED SUCTION HEAD	BRAKE HP	EFFICIENCY
7	416	477.6	2.8	15.9	503	121	12913	12913	551	1543	990	29.9	1.5	2.7	1.5	3.45	28.45	29.97	7.8	15.9	1895	85.7
	414	478.6	2.8	16.0	504	121			551	1543	990			2.7	1.5	3.54	28.36	29.87	7.6	18.0	1895	85.9
		477.6	2.8	19.2	505	122			551	1543	990			2.6	1.5	3.64	26.36	29.75	6.2	19.3	1895	86.0
	457	471.6	2.8	20.4	500	123			551	1546	990			2.6	1.5	3.74	26.16	29.64	4.8	20.5	1892	85.3
	439	453.6	2.7	21.1	482	123			547	1532	990			2.7	1.5	3.74	26.16	29.64	4.1	21.2	1881	82.8
	409	423.6	2.7	21.3	452	124	↓	↓	527	1469	990	↓	↓	2.5	1.5	3.85	26.05	29.51	3.8	21.4	1795	81.3
8	415	429.6	3.2	15.4	453	125	1376	1376	553	1548	989	29.9	1.7	2.5	1.7	3.95	25.95	29.40	9.9	15.4	1900	82.0
	414	428.6	3.2	16.4	453	126			553	1549	989			2.6	1.7	4.06	25.84	29.28	8.8	16.4	1900	82.0
	410	424.6	3.2	17.7	450	127			553	1541	989			2.5	1.7	4.18	25.72	29.14	7.4	17.7	1895	81.6
	405	419.6	3.2	18.3	446	128			551	1543	988			2.5	1.7	4.29	25.61	29.02	6.7	18.3	1895	80.9
	374	388.6	3.2	18.5	415	128	↓	↓	543	1520	988	↓	↓	2.5	1.7	4.29	25.61	29.02	6.5	18.5	1866	76.4




7-26 76



This drawing and the design it covers are the property of BSCYTEL. They are hereby loaned and as the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or in any way disclosed to the public without the express written permission of BSCYTEL.

27 L.F.



REFERENCE DRAWINGS

M-151 REV. 8 P I T D
M-31-2 : 7 PIPING PLAN AREA 31
M-31-3 : 6 : 31
M-34-3 : 6 : 34



COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8858-G-9 APPLIES

NO.	DATE	REVISION	BY	CHKD.	APPD.
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

PENNSYLVANIA POWER & LIGHT COMPANY
ALLENTOWN, PENNSYLVANIA
BUSSYHARRIS STEAM ELECTRIC STATION - UNIT 1, UNIT 2
BSCYTEL - SAN FRANCISCO


ISOMETRIC - REACTOR BUILDING
RESIDUAL HEAT REMOVAL UNIT 2

REACTOR BLDG. UNIT 2

51-20 DRAWING NO. 2
DCB-202-1 2

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and purpose permitted by the lender to the borrower.

ALL DIMENSIONS ARE TO
CONTACT SURFACES
OF FLANGES.



REFERENCE DRAWINGS

M - 141 REV. C. P. 1. D.
M - 181 1. 8.
M - 81-12 1. 5. PIPING PLAN - AREA - 31
M - 81-14 1. 5.

COMPONENTS ON
THIS DWG. ARE Q-LISTED.
SPEC. 8858-G-9 APPLIES

NO.	DATE	REVISION	BY	CHKD.	APPD.
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					


PENNSYLVANIA POWER & LIGHT COMPANY
ALL LANTON, PENNSYLVANIA
BURLINGAME STEAM ELECTRIC STATION - UNIT 1, UNIT 2
BECHTEL - SAN FRANCISCO

ISOMETRIC - REACTOR BLDG
RHR. UNIT - 2

NO.	DATE	REVISION	BY	CHKD.	APPD.
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

Q LISTED ISOMETRIC REACTOR BLDG RHR



[illegible]

M - 141 REV.G P & I.D.
M - 151 : : B
M - 31-4 : : S PLANS PLAN AREA 21
M - 31-72 : : S P : : : : 21

10/1	SEE RPT FOR NOTE	MR	10/1						
10/2	SEE RPT FOR NOTE	MR	10/2						
10/3	SEE RPT FOR NOTE	MR	10/3						
10/4	SEE RPT FOR NOTE	MR	10/4						
10/5	SEE RPT FOR NOTE	MR	10/5						
10/6	SEE RPT FOR NOTE	MR	10/6						
10/7	SEE RPT FOR NOTE	MR	10/7						
10/8	SEE RPT FOR NOTE	MR	10/8						
10/9	SEE RPT FOR NOTE	MR	10/9						
10/10	SEE RPT FOR NOTE	MR	10/10						
10/11	SEE RPT FOR NOTE	MR	10/11						
10/12	SEE RPT FOR NOTE	MR	10/12						
10/13	SEE RPT FOR NOTE	MR	10/13						
10/14	SEE RPT FOR NOTE	MR	10/14						
10/15	SEE RPT FOR NOTE	MR	10/15						
10/16	SEE RPT FOR NOTE	MR	10/16						
10/17	SEE RPT FOR NOTE	MR	10/17						
10/18	SEE RPT FOR NOTE	MR	10/18						
10/19	SEE RPT FOR NOTE	MR	10/19						
10/20	SEE RPT FOR NOTE	MR	10/20						
10/21	SEE RPT FOR NOTE	MR	10/21						
10/22	SEE RPT FOR NOTE	MR	10/22						
10/23	SEE RPT FOR NOTE	MR	10/23						
10/24	SEE RPT FOR NOTE	MR	10/24						
10/25	SEE RPT FOR NOTE	MR	10/25						
10/26	SEE RPT FOR NOTE	MR	10/26						
10/27	SEE RPT FOR NOTE	MR	10/27						
10/28	SEE RPT FOR NOTE	MR	10/28						
10/29	SEE RPT FOR NOTE	MR	10/29						
10/30	SEE RPT FOR NOTE	MR	10/30						
10/31	SEE RPT FOR NOTE	MR	10/31						
11/1	SEE RPT FOR NOTE	MR	11/1						
11/2	SEE RPT FOR NOTE	MR	11/2						
11/3	SEE RPT FOR NOTE	MR	11/3						
11/4	SEE RPT FOR NOTE	MR	11/4						
11/5	SEE RPT FOR NOTE	MR	11/5						
11/6	SEE RPT FOR NOTE	MR	11/6						
11/7	SEE RPT FOR NOTE	MR	11/7						
11/8	SEE RPT FOR NOTE	MR	11/8						
11/9	SEE RPT FOR NOTE	MR	11/9						
11/10	SEE RPT FOR NOTE	MR	11/10						
11/11	SEE RPT FOR NOTE	MR	11/11						
11/12	SEE RPT FOR NOTE	MR	11/12						
11/13	SEE RPT FOR NOTE	MR	11/13						
11/14	SEE RPT FOR NOTE	MR	11/14						
11/15	SEE RPT FOR NOTE	MR	11/15						
11/16	SEE RPT FOR NOTE	MR	11/16						
11/17	SEE RPT FOR NOTE	MR	11/17						
11/18	SEE RPT FOR NOTE	MR	11/18						
11/19	SEE RPT FOR NOTE	MR	11/19						
11/20	SEE RPT FOR NOTE	MR	11/20						
11/21	SEE RPT FOR NOTE	MR	11/21						
11/22	SEE RPT FOR NOTE	MR	11/22						
11/23	SEE RPT FOR NOTE	MR	11/23	</					

WELDING REQUIREMENTS		Pipe Class	DLA
☐ P1-A-C-14	0.706-2	☐ Pre Heat: 60°F	
☐ P1-A7-14	0.6018	☐ Pre Heat: 700°F	
☐ P1-A	0.7018	☐ Preheat: 250°F	
☐ P1-A7-A	18.360	☐ Pre-Heat: 275°F	
☐ P1-A-A	18.360	☐ Pre Heat: 550°F	
☐ P1-A7-A	18.360-14	☐ Preheat:	
☐ P1-A7-14	0.7038-16	☐ Inlet Pipe: 350°F	
☐ P1-A7-14	0.8048-2	☐ Existing Ring Band	
☐ P1-A7	0.8048-8	☐ Argon Tung Band	
☐ P1-A7-A	0.8115	☐ Pre Welding Temp	
	NDT 100% 16-2	1.25-50-1.5mm	

Along Welding Requirements And Control Curves: 1774-1784

21	306	21	NOTE	JAN	1968	1	CL
22	307	22	NOTE	JAN	1968	1	CL


1156 RELEASE UNDER E.O. 14176

ISOMETRIC - REACTOR BLDG
R.H.R. UNIT - 2

MM	DCA-211-2	2
----	-----------	---

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below

This drawing and the designs it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and private use permitted by any written consent given by the lender to the borrower.



B = 3/8" DIA. BEND.


REFERENCE DRAWINGS

M-141 REV. C P & L D.
M-151 : D.
M-21-3 : B. PIPING PLAN - AREA-B1
M-21-4 : E.

COMPONENTS ON
THIS DWG. ARE Q-LISTED
SPEC. 8858-G-9 APPLIES

DATE	REVISED	BY	CHKD	APPD
10/1/54		REL		
PENNSYLVANIA POWER & LIGHT COMPANY ALL STATE, PENNSYLVANIA BUCKLEUPHARIA STEAM ELECTRIC STATION - UNIT 1, UNIT 2 BECHTEL - SAN FRANCISCO				
ISOMETRIC - REACTOR BLDG R.H.R. - UNIT-2				
41-13	41-13	41-13	41-13	41-13
8858	DCA-211-1	2		

ISO REACTOR BLDG R.H.R.





M-2151 REV. 0 P#10
M-31-2 " 2 PIPING PLAN - AREA 31
M-31-3 " 2 " " " "
M-34-3 " 6 " " " " 34.

[illegible]



ISOMETRIC-REACTOR BLDG.
R.H.R. - UNIT # 2

	100 No.	51-25 000000 No.	01
	8858	DCA-210-1	4

G2 150 REACTOR BLDG RHR









M-151 REV. 2 P.E.I.D.
M-26-12 " 2 PIPING PLAN-AREA 26

[illegible]



SPRAY NOZZLE CONNECTIONS



REFERENCE DRAWINGS

M-151 REV. 2 P.E.I.D.
M-265 " 3 PIPING PLAN-AREA 26

**COMPONENTS ON
THIS DWG: ARE Q-LISTED
SPEC. 8858-G-9 APPLIES**

[illegible]

161 1150 REACTING RNR 111111 M

