


CONTAINMENT STEAM BYPASS

OBJECTIVE: Assuming a small break accident with steam being completely bypassed directly into the wetwell air space, determine how much time is available without operator action before the wetwell design pressure of 53 psig is reached. Time $t=0$ is defined at the moment wetwell air space pressure reaches 30 psig.

NOTE: The fact that no credit was taken for heat sinks in this calculation is very conservative. An analysis similar to this calculation was performed by Robert Lundy for LaSalle*. The Robert Lundy analysis used the COMTEMPT computer code and investigated the sensitivity of the heat sink parameter. For LaSalle, a 50% reduction in heat sink capacity resulted in an 11 minute reduction (35%) in time allowed without operator action. It is safe to assume, therefore, that because of the similar Mark II geometries, SUSQUEHANNA would gain 10 to 20 minutes by taking credit for 100% of its heat sink capacity.

8104210467

* Reference to the PSA question C21.1



Dept. NPE MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981

Designed by HRC


PROJECT SUSQUEHANNA SES

Sht. No. 1 of 9

Approved by _____

MARK II ASSUMPTIONS

1. The steam that leaks into the wetwell air space does not mix with the air already there.
2. No portion of the steam that has leaked into the wetwell air space condenses.
3. Only steam leaks into the wetwell; any air moving from the drywell into the wetwell goes through the vents.
4. For this small break analysis, all of the air initially in the drywell is cleared into the wetwell before the moment when the operator is alerted.
5. The flow of steam through leakage paths is considered incompressible.
6. The pressure differential across the leakage path is assumed constant and equal to the vent submergence hydrostatic pressure difference.
7. The wetwell air temperature when the operator is alerted to the occurrence of bypass leakage is assumed to be equal to the initial wetwell temperature. At the time the drywell pressure is reduced due to operator action, the wetwell air temperature is assumed to be 50°F greater than the initial wetwell temperature.



Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET


ER No. _____

Date 4/1 19 81Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 2 of 9

Approved by _____

INPUT PARAMETERS

- $M_{NC} \equiv$ mass of non-condensable gas in drywell and wetwell 26,986 lbm
 $V_{DW} \equiv$ drywell volume (including vents) 259,337 ft³
 $V_{WW} \equiv$ wetwell airspace volume (high water level) 148,590 ft³
 $T_{DW} \equiv$ initial drywell temperature 135°F
 $T_{WW} \equiv$ initial wetwell temperature 90°F
 $\phi_{DW} \equiv$ initial drywell relative humidity (minimum normal) 0.2
 $\phi_{WW} \equiv$ initial wetwell relative humidity (minimum normal) 1.0
 $P_{SAT}(T_{DW}) \equiv$ pressure of saturated steam at T_{DW} 2.5375 psia
 $P_{SAT}(T_{WW}) \equiv$ pressure of saturated steam at T_{WW} 0.69813 psia
 $P_{DW} \equiv$ initial drywell pressure (maximum normal) 15.45 psia
 $P_{WW} \equiv$ initial wetwell pressure (maximum normal) 15.45 psia
 $\Delta P_v \equiv$ pressure differential drywell/wetwell (high water level) 5.18 psi
 $P_{50} \equiv$ initial wetwell pressure (NRC operator action analysis) 44.7 psia (30 psia)
 $V_{50} \equiv$ volume of steam leaked into wetwell when pressure has reached P_{50} 23,639 ft³
 $P_{53} \equiv$ final wetwell pressure (NRC operator action analysis - SSES design) 67.7 psia (53 psia)
 $T_{WF} \equiv$ final wetwell temperature (when P_{53} is reached) 140°F
 $V_{53} \equiv$ volume of steam leaked into wetwell when pressure has reached P_{53} 56,652 ft³
 $P_{SAT}(T_{WF}) \equiv$ pressure of saturated steam at T_{WF} 2.8892 psia
 $V_g(P_{53}) \equiv$ specific volume of saturated steam at P_{53} 6.4036 ft³/lbm
 $V_g(P_{50}) \equiv$ specific volume of saturated steam at P_{50} 9.4417 ft³/lbm
 $R \equiv$ gas constant 53.34 $\frac{\text{ft}^3 \text{ lbf}}{\text{lbm} \text{ } ^\circ\text{R}}$
 $t_p \equiv$ time delay, between P_{50} and P_{53} (30 psia to 53 psia)



Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 3 of 9

Approved by _____

MNC


$$M_{NC} = \frac{(P_{DW} - \phi_{DW} P_{SAT}(T_{DW})) V_{DW}}{R T_{DW}} + \frac{(P_{WW} - \phi_{WW} P_{SAT}(T_{WW})) V_{WW}}{R T_{WW}}$$

$$M_{NC} = \frac{(15.45 \frac{\text{lb}_f}{\text{in}^2} - 0.2(2.5375 \frac{\text{lb}_f}{\text{in}^2})) (239,337 \text{ ft}^3) (144 \frac{\text{in}^2}{\text{ft}^2})}{(53.34 \frac{\text{ft} \cdot \text{lb}_f}{\text{lb}_m \cdot ^\circ\text{R}}) (135+460) ^\circ\text{R}} +$$

$$\frac{(15.45 \frac{\text{lb}_f}{\text{in}^2} - 1.0(0.69813 \frac{\text{lb}_f}{\text{in}^2})) (148,590 \text{ ft}^3) (144 \frac{\text{in}^2}{\text{ft}^2})}{(53.34 \frac{\text{ft} \cdot \text{lb}_f}{\text{lb}_m \cdot ^\circ\text{R}}) (90+460) ^\circ\text{R}}$$

$$M_{NC} = 16227 + 10,759$$

$$\underline{M_{NC} = 26,986 \text{ lb}_m}$$



Dept. NPE MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981

Designed by HRC

PROJECT SUSQUEHANNA SES

Sht. No. 4 of 9

Approved by _____

ΔP_v

$$\Delta P_v = \rho H \left(\frac{g}{g_c} \right)$$

ρ = density of water at $T_{ow} = 90^\circ F$

$$\rho = 62.12 \text{ lbm} / \text{ft}^3$$

$$\frac{g}{g_c} = \text{constant} \quad 1.0 \frac{\text{lb}_f}{\text{lb}_m}$$

H = vent submergence

$$H = 12 \text{ ft}$$

$$\Delta P_v = \left(62.12 \frac{\text{lb}_m}{\text{ft}^3} \right) (12 \text{ ft}) \left(1.0 \frac{\text{lb}_f}{\text{lb}_m} \right) \left(\frac{1.0 \text{ ft}^2}{144 \text{ in}^2} \right)$$

$$\underline{\Delta P_v = 5.18 \text{ psi}}$$

Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 5 of 9

Approved by _____


P₅₀, V₅₀ $P_{50} = 30 \text{ psig}$ per NRC assumption $P_{50} = 44.7 \text{ psia}$

$$V_{50} = V_w - \frac{M_{NC} R T_{ww}}{P_{50} - P_{SAT}(T_{ww})}$$

$$V_{50} = 148,590 \text{ ft}^3 - \frac{(26986 \text{ lbm}) \left(53.34 \frac{\text{ft} \cdot \text{lb}_f}{\text{lbm} \cdot \text{R}} \right) (90 + 460) \text{ R}}{\left(44.7 \frac{\text{lb}_f}{\text{in}^2} - 0.69813 \frac{\text{lb}_f}{\text{in}^2} \right) \left(\frac{144 \text{ in}^2}{1.0 \text{ ft}^2} \right)}$$

$$V_{50} = 148,590 - 124,945$$

$$V_{50} = 23645 \text{ ft}^3$$



Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 6 of 9

Approved by _____

P_{SF} , T_{WF} , V_{SF}

P_{SF} = final wetwell pressure = SES wetwell design pressure

$$P_{SF} = 53 \text{ psig}$$

$$\underline{P_{SF} = 67.7 \text{ psia}}$$

T_{WF} = final assumed wetwell airspace temperature

$$T_{WF} = T_{WW} + 50^\circ\text{F}$$

$$T_{WF} = 90^\circ\text{F} + 50^\circ\text{F}$$

$$\underline{T_{WF} = 140^\circ\text{F}}$$

$$V_{SF} = V_{WW} - \frac{(26786 \text{ lbm}) \left(53.34 \frac{\text{ft} \cdot \text{lb}_f}{\text{lbm} \cdot ^\circ\text{R}} \right) (140 + 460) ^\circ\text{R}}{\left(67.7 \frac{\text{lb}_f}{\text{in}^2} - 2.8872 \frac{\text{lb}_f}{\text{in}^2} \right) \left(144 \frac{\text{in}^2}{\text{ft}^2} \right)}$$

$$V_{SF} = 148,570 - 92,541$$

$$\underline{V_{SF} = 56,049 \text{ ft}^3}$$

Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1961Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 7 of 9

Approved by _____

 A/\sqrt{K} , \dot{m}_{SB}

$$\frac{A}{\sqrt{K}} = \dot{m}_{SB} \sqrt{\frac{V_g(P_{sf}) + V_g(P_{sa})}{4 g_c \Delta P_v}}$$


$$\frac{A}{\sqrt{K}} = \dot{m}_{SB} \sqrt{\frac{6.4036 \frac{ft^3}{lbm} + 9.4417 \frac{ft^3}{lbm}}{4 \left(32.2 \frac{ft}{sec^2}\right) \left(5.18 \frac{lb_f}{in^2}\right) \left(\frac{144 in^2}{1 ft^2}\right) \left(\frac{lbm}{lb_f}\right)}}$$

$$\frac{A}{\sqrt{K}} = \dot{m}_{SB} \sqrt{.00016493}$$

$$\frac{A}{\sqrt{K}} = .01284 \dot{m}_{SB} \quad \underline{\text{OR}} \quad \dot{m}_{SB} = 77.88 \frac{A}{\sqrt{K}}$$

$$\frac{A}{\sqrt{K}} \quad ft^2$$

$$\dot{m}_{SB} \quad \frac{lbm}{sec}$$



Dept. NPE MECHPENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 4/1 1981Designed by HRCPROJECT SUSQUEHANNA SESSht. No. 8 of 9

Approved by _____

 \bar{m}_{sb} , t_D $\bar{m}_{sb} \equiv$ average steam mass flow for a small break accident $t_D \equiv$ time delay between P_{so} and P_{sf} (30psig and 53 psig)

$$\bar{m}_{sb} = \frac{1}{t_D} \left(\frac{V_{sf}}{V_g(P_{sf})} - \frac{V_{so}}{V_g(P_{so})} \right)$$

$$\bar{m}_{sb} = \frac{1}{t_D} \left(\frac{56,052 \text{ ft}^3}{6.4036 \text{ ft}^3/\text{lbm}} - \frac{23,639 \text{ ft}^3}{9.4417 \text{ ft}^3/\text{lbm}} \right)$$

$$\bar{m}_{sb} = \frac{1}{t_D} (8753 \text{ lbm} - 2504 \text{ lbm})$$

$$\bar{m}_{sb} = \frac{1}{t_D} (6249) \quad \underline{\text{OR}} \quad t_D = \frac{1}{\bar{m}_{sb}} (6249)$$

$$\bar{m}_{sb} \quad \frac{\text{lbm}}{\text{sec}}$$

$$t_D \quad \text{sec}$$

t_D CASE 1

$$\frac{A}{VK} = .05 \text{ ft}^2 \quad \text{NRC Standard Review Plan}$$

$$\bar{m}_{SB} = 77.88 \frac{A}{VK} = 77.88 (.05)$$

$$\bar{m}_{SB} = 3.894 \text{ lbm/sec}$$

$$t_D = \frac{1}{\bar{m}_{SB}} (6249) = \frac{1}{3.894} (6249)$$

$$t_D = 1605 \text{ sec}$$

$$\underline{t_D = 26.75 \text{ minutes}}$$

CASE 2

$$\frac{A}{VK} = .0535 \text{ ft}^2 \quad \text{Calculation for SSES by GE}$$

$$\bar{m}_{SE} = 77.88 \frac{A}{VK} = 77.88 (.0535)$$

$$\bar{m}_{SE} = 4.167 \text{ lbm/sec}$$

$$t_D = \frac{1}{\bar{m}_{SE}} (6249) = \frac{1}{4.167} (6249)$$

$$t_D = 1500 \text{ sec}$$

$$t_D = 25 \text{ minutes}$$

CONTAINMENT HIGH PRESSURE
BY PASS LEAKAGE TEST

ATTACHEMENT 2 TO PLA 742



1