

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION Nbr: 8105190240 DUC. DATE: 81/05/15 NOTARIZED: NO DOCKET #
 FACIL: 50-367 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: YOUNGBLOOD, B.J. RECIPIENT AFFILIATION: Licensing Branch 1

SUBJECT: Forwards calculations which indicate adequate flow capacity for piping & valves required in alternate shutdown path & show that requirements for worst path resistances are met. Calculations close SER Outstanding Issue 38.

DISTRIBUTION CODE: 80015 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 12
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RID) 05000387
 Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RID) 05000388


ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	A/O LICENSNG	1	0	LIC BR #2 BC	1	0
	RUSHBROOK, M.	1	0	STARK, R. 04	1	1
INTERNAL:	ACCID EVAL BR25	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR 12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR 13	3	3
	GEOSCIENCES 14	1	1	HUM FACI ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 09	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	DELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAN ASSESS BR 22	1	1	REAC SYS BR 23	1	1
	REG FILE 01	1	1	SIT ANAL BR 24	1	1
	STRUCT ENG BR 25	1	1			
EXTERNAL:	ACKS 27	16	16	LPDR 03	1	1
	NSIC 05	1	1			

MAY

MAY 21 1987

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 51


LJ



PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 821-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction
821-5381



May 15, 1981

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos. 50-387
50-388

SUSQUEHANNA STEAM ELECTRIC STATION
SER OUTSTANDING ITEM 38
ER 100450 FILE 841-2
PLA-782

Dear Mr. Youngblood:

Attached are the Susquehanna SES calculations to show sufficient flow capacity for all piping and valves required in the alternate shutdown path and which show that the pump head-flow requirements for the worst path resistances are met.

These calculations complete our action to close SER Outstanding Issue 38.

Very truly yours,

N. W. Curtis
Vice President-Engineering and Construction-Nuclear

CTC/mks

Attachment

cc: R. M. Stark - NRC

Boo!
s
///

E

8105190240



CALCULATION COVER SHEET

COVER SH. A OF A
CALC. NO. M152-7
NO. OF SHEETS 10
Q NO. 510

NO. 8856

DISCIPLINE MECHANICAL

TITLE ALTERNATE SHUTDOWN COOLING MAY -4 '61

CALC. SHEET CONTROL:
138930

SUBJECT CORE SPRAY PUMP OPERATION IN THE ALTERNATE SHUTDOWN COOLING MODE.

STATEMENT OF PROBLEM DETERMINE CORE SPRAY PUMP OPERATING POINTS IN ALTERNATE SHUTDOWN COOLING MODE WITH ONE OR MORE MAINSTEAM RELIEF VALVES OPEN.

SAR CHECKED SAR CHANGE REQ'D. SAR CHANGE NOTICE INITIATED

SOURCES OF DATA ISOMETRICS: HBB-104-1, REV. 8, GBB-101-2, REV. 3, DGB-113-1 REV. 3, DCA-109-1 REV. 5, DCA-107-1, REV. 11.

SOURCES OF FORMULAE & REFERENCES 1) CORE SPRAY PUMP CALCS M152-6, REV. 1
2) CRANE TECHNICAL PAPER NO. 410, 1979 EDITION
3) CORE SPRAY PUMP PERFORMANCE CURVE 8856-M1-E21-30-1
4) CORE SPRAY PROCESS DIAGRAM 8856-M1-E21-15-2
5) CROSBY VALVE ENGINEERING AND CAPACITY DATA, CAT. #302, SUP. 1
6) PSU OUTLINE DWG. 8856-M1-B21-64-2

PRELIMINARY CALC. FINAL CALC. SUPERSEDES CALC. NO. _____

DATE	CALCULATION BY	**CHECKED BY	DATE	APPROVED BY	DATE
4/23/81	J. J. Brunner / [Signature]	David Yang	5/4/81	[Signature]	5/4/81

Primary calcs checked only at group supervisor's request. Covers PSAR, codes and standards, redundancy and separation, operability and maintainability, technical adequacy, accuracy and clarity.



(CALCULATION SHEET)

MAY -4 '81 138930

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M 152-7 REV. NO. 0
 PROJECT SUSQUEHANNA CHECKED G. Yang DATE 5-4-81
 SUBJECT CORE SPRAY PUMPS IN JOB NO. 8856
ALTERNATE SHUTDOWN COOLING MADE SHEET NO. 1 of 10

ASSUMPTIONS

1. Based on vendor catalog information the C_v value for fully open main steam relief valve (PSV F013) is assumed to be within the range of 400 to 500 gpm. Both values (400 & 500) were used in these calculations. An estimate of the C_v value is presented in Appendix A of this calculation.
2. Backpressure in PSV discharge line is neglected because of large line diameter (12").
3. Friction losses in main steam piping are negligible and thus are omitted.
4. Calculation reflects a steady state condition. Inlet flow is equal to outlet flow. Water level in RPV is assumed to be 3 ft above center line of main steam nozzle.
5. No venting of RPV dome occurs.

SUMMARY AND CONCLUSIONS

- a) With only one PSV open, pumps will pressurize RPV above shutdown initiation pressure of 98 psig. This could be prevented by throttling with core spray valve. It is preferable, however, that a second PSV be opened to lower reactor pressure below shutdown initiation pressure.
- b) Calculations show (see page 9) that with 4 PSV open, runout flow of 7900 gpm will be reached with a valve C_v of 500.



(CALCULATION SHEET)

ORIGINATOR J. J. Brunner DATE 4/23/81

CALC. NO. M152-7 REV. NO. 0

PROJECT SUSQUEHANNA

CHECKED JWJ DATE 5-4-81

SUBJECT Core Spray Pumps in Alt. Shutdown Cooling Mode

JOB NO. 8856


SHEET NO. 2 OF 10

MAY -4 '81 138930

Use Core Spray Mode D

$P_{RPV} = 105 \text{ psig}$ (use 98 psig for shutdown coolg. initiation)
 $T_{RPV} = 332 \text{ } ^\circ\text{F}$
 $T_{pool} = 170 \text{ } ^\circ\text{F}$
 $P_{pool} = 14.7 \text{ psia}$ } (Ref. 4)

Assume water level ~ 3 ft above M.S. nozzle $\frac{1}{2}$



CORE SPRAY PUMP (TWIN SET)



CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
 PROJECT SUSQUEHANNA CHECKED DWG DATE 5-4-81
 SUBJECT CORE SPRAY PUMPS IN JOB NO. 8856
ALTERNATE SHUTDOWN COOLING MODE SHEET NO. 3 of 10

MAY -4 '81 138930

TOTAL SYSTEM'S RESISTANCE

$$H_T = H_s + H_p + H_f$$

Static Head - with water level at approx. 3 ft above main steam nozzle ϕ

$$H_s = 790' - 670' = 120'$$

Pressure Head

$$H_p = \frac{144}{\rho} P_{psv} - H_0$$

where:

$$\Delta P_{psv} = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2 \quad (\text{Ref. 2})$$

with zero back pressure $\Delta P_{psv} = P_{psv}$
 $H_0 = \text{stat. head at psv } \phi = 45.9' \text{ (see page 9)}$

Friction Head

$$H_f = \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

condition calculated for Mode D
 (see Ref 1 sht. 78)

$$Q_c \text{ (2 pumps)} = 6350 \text{ gpm}$$

$$H_{fc} = 277.3 \text{ ft}$$

$$H_T = H_s + \frac{144}{\rho} \left(\frac{Q}{C_v} \right)^2 - H_0 + \left(\frac{Q}{Q_c} \right)^2 H_{fc}$$

$$\text{RPV Pressure} = P_{psv} = \frac{\rho}{144} H_0$$



CALCULATION SHEET

CALC. NO. M152-7 REV. NO. 0ORIGINATOR J. J. Brimmer DATE 4/23/81 CHECKED JWA DATE 5-4-81PROJECT SUSQUEHANNA JOB NO. 8856SUBJECT Core Spray Pumps in Alternate Shutdown Mode SHEET NO. 4 of 10ONE PSV IS OPEN

$C_v = 400$

MAY -4 '81 138930

Q	2000	4000	6000	8000
H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{400}\right)^2 - 45.9$	11.8	184.9	473.3	877
H _f = $\left(\frac{Q}{6350}\right)^2 \times 277.3$	27.5	110	247.5	440
H _{tot}	159.3	414.9	840.8	1437

$C_v = 500$

Q	2000	4000	6000	8000
H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{500}\right)^2 - 45.9$	9	101.8	286	545
H _f	27.5	110	247.5	440
H _{tot}	N/A	331.8	653.5	1105

PRPV with 1 PSV @ C_v = 400 Q = 5,450 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{5450}{400} \right)^2 - 45.9 \right] = 149.3 \text{ psig}$$

PRPV with 1 PSV @ C_v = 500 Q = 6,130 gpm

$$P = \frac{56.2}{144} \left[\frac{144}{62.4} \left(\frac{6130}{500} \right)^2 - 45.9 \right] = 117.4 \text{ psig}$$



CALCULATION SHEET

CALC. NO. M152-7 REV. NO. 0ORIGINATOR J. J. Brunner DATE 4/23/81 CHECKED QWJ DATE 5-4-81PROJECT SUSQUEHANNA JOB NO. 8856SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode SHEET NO. 5 of 10TWO PSU OPEN

MAY -4 '81 138930

$$CV = 400$$

Q TOTAL	2000	4000	6000	8000
---------	------	------	------	------

Q PSU	1000	2000	3000	4000
-------	------	------	------	------

H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{400}\right)^2 - 45.9$	-31.5	11.8	83.9	184.9
H _f = $\left(\frac{Q}{6350}\right)^2 \cdot 277.3$	27.5	110	247.5	440
H _{tot}	N/A	241.8	451.4	744.9

$$CV = 500$$

H _s	120	120	120	120
H _p = $\frac{144}{62.4} \left(\frac{Q}{500}\right)^2 - 45.9$	-36.7	-9	37.2	101.8
H _f = $\left(\frac{Q}{6350}\right)^2 \cdot 277.3$	27.5	110	247.5	440
	N/A	N/A	404.7	661.8

PRPV @ CV = 400

$$Q_{PSU} = 7,150/2 = 3,575 \text{ gpm}$$

$$P_{RPV} = \frac{57.2}{144} \left[\frac{144}{62.4} \left(\frac{3575}{400}\right)^2 - 45.9 \right] = 55 \text{ psig}$$

PRPV @ CV = 500

$$Q_{PSU} = 7420/2 = 3,710 \text{ gpm}$$

$$P_{RPV} = \frac{58}{144} \left[\frac{144}{62.4} \left(\frac{3710}{500}\right)^2 - 45.9 \right] = 32.7 \text{ psig}$$



CALCULATION SHEET

CALC. NO. M152-7 REV. NO. 0ORIGINATOR J. J. Brunner DATE 4/23/81 CHECKED Jung DATE 5-4-81PROJECT Susquehanna JOB NO. 8856SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode SHEET NO. 6 of 10THREE PSV OPEN

MAY -4 '81 138930

$$C_V = 400$$

Q_{TOTAL}	3000	6000	9000
-------------	------	------	------

Q_{PSV}	1000	2000	3000
-----------	------	------	------

H_s	120	120	120
$H_p = \frac{144}{62.4} \left(\frac{Q_V}{400} \right)^2 - 45.9$	-31.5	11.8	83
$H_f = (Q_V/6350)^2 \cdot 277.3$	61.9	247.5	557
H_{tot}	N/A	379.3	760

$$C_V = 500$$

H_s	120	120
$H_p = \frac{144}{62.4} \left(\frac{Q_V}{500} \right)^2 - 45.9$	-9	37
$H_f = (Q_V/6350)^2 \cdot 277.3$	247.8	557
H_{tot}	N/A	714

$$PRPV @ C_V = 400 \quad Q_{PSV} = 7600/3 = 2,533 \text{ gpm}$$

$$P_{RPV} = \frac{58.4}{144} \left[\frac{144}{62.4} \left(\frac{2,533}{400} \right)^2 - 45.9 \right] = 18.9 \text{ psig}$$

$$PRPV @ C_V = 500 \quad Q_{PSV} = 7720/3 = 2,590 \text{ gpm}$$

$$P_{RPV} = \frac{59.5}{144} \left[\frac{144}{62.4} \left(\frac{2,590}{500} \right)^2 - 45.9 \right] = 6.6 \text{ psig}$$



CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81

CALC. NO. M152-7 REV. NO. 0

PROJECT Susquehanna

CHECKED Quj DATE 5-4-81

SUBJECT Core Spray Pumps in Alternate Shutdown Cooling Mode

JOB NO. 8856

SHEET NO. 7 of 10

MAY -4 '81 138930

FOUR PSV OPEN

$C_v = 400$

Q_{TOT}

6000 8000 9000

Q_v

1500 2000 2250

$H_s = \frac{144}{62.4} \left(\frac{Q_v}{400} \right)^2 - 45.9$

120 120 120

$H_p = \frac{144}{62.4} \left(\frac{Q_v}{400} \right)^2 - 45.9$

-13.4 11.8 27.1

$H_f = (Q_v/6350)^2 \cdot 277.3$

247.8 440 557

H_{tot}

N/A 571.8 704.1

$C_v = 500$

$H_s = \frac{144}{62.4} \left(\frac{Q_v}{500} \right)^2 - 45.9$

120 120

$H_p = \frac{144}{62.4} \left(\frac{Q_v}{500} \right)^2 - 45.9$

-9 0.0

$H_f = (Q_v/6350)^2 \cdot 277.3$

440 557

H_{tot}

N/A 677.0

$PRPV @ C_v = 400$

$Q_{psv} = 7780/4 = 1945$

$PRPV = \frac{59.6}{144} \left[\frac{144}{62.4} \left(\frac{1945}{400} \right)^2 - 45.9 \right] = 3.5 \text{ psig}$

9P

$PRPV @ C_v = 500$

$Q_{psv} = 7900/4 = 1975$

$PRPV = \frac{59.8}{144} \left[\frac{144}{62.4} \left(\frac{1975}{500} \right)^2 - 45.9 \right] =$

9P.

atmospheric

(NEG)



CALCULATION SHEET

ORIGINATOR J. J. Brunner DATE 4/23/81 CALC. NO. M152-7 REV. NO. 0
 PROJECT SUPERUEHANNA CHECKED DWJ DATE 5-4-81
 SUBJECT CORE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE JOB NO. 8856
 SHEET NO. 8 of 10

MAY -4 '81 138930

Determine Amount of Throttling Required to Match Initiation Pressure of 98 psig with one PCV open.

With 0 back pressure:

$$P_{PSV} = P_{RPV} + \frac{P_{H_2O}}{144} = 98 + \frac{56.2 \cdot 45.9}{144} = 115.9 \text{ psi}$$

Flow through PSV

$$P_{PSV} = \frac{P}{62.4} \left(\frac{Q}{C_V} \right)^2$$


$$\therefore Q = \left(P_{PSV} \cdot \frac{62.4}{P} \cdot C_V^2 \right)^{0.5} = C_V \cdot \left(P_{PSV} \cdot \frac{62.4}{P} \right)^{0.5}$$

$$\text{For } C_V = 400: Q = 400 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 4,528$$

$$\text{For } C_V = 500: Q = 500 \cdot \left(115.9 \cdot \frac{62.4}{56.2} \right)^{0.5} = 5,660 \text{ gpm}$$

Amount of throttling for above flows are shown on sht. 9.

BY: ~~SA~~ 4/22/81 CHECKD: JWG E-48



CORE SPRAY PUMP OPERATION
IN ALTERNATE SHUTDOWN COOLING MODE

PURE PUMPS

HEAD (FT)

FLOW (1000 GPM)

PRESSURES RPV INDICATED IN PSIG

VAPOR LINE

THROTTLING

THROTTLE

RPV=98

RPV=147.3

RPV=179

RPV=179.9

RPV=189

RPV=32.7

MAY 1981 138931



(CALCULATION SHEET)

ORIGINATOR J. J. Brunner DATE 4/30/81 CHECKED gung DATE 5-4-81
 PROJECT SISSQUEHANNA JOB NO. 8856
 SUBJECT COKE SPRAY PUMPS IN ALTERNATE SHUTDOWN COOLING MODE SHEET NO. 10 OF 10

MAY -4 '81 138930

APPENDIX A

ESTIMATE OF VALVE FLOW COEFFICIENT CV

Valve capacity (per Ref. 5 for liquid)

$$Q = 27.2 C_A A K_{sg} \sqrt{\frac{P - P_b}{\Delta P}}$$

(gpm)

where: C_A = correction factor for accum. press. assume 1

$K_{sg} = 1$ (for water)

$P_b = 0$ assuming no back pressure.

$A = 16$ orifice area for Crosby style 6 R10HB-65-BP (see Ref. 5 & 6)

$$Q = 27.2 \cdot 16 \cdot \sqrt{\Delta P} = 435.2 \sqrt{\Delta P}$$

From flow equation $\Delta P = \frac{\rho}{62.4} \left(\frac{Q}{C_v} \right)^2$

or: $Q = C_v \sqrt{\frac{62.4}{\rho} \Delta P}$

By substitution:

$$435.2 \sqrt{\Delta P} = C_v \sqrt{\frac{62.4}{\rho} \Delta P}$$

$$\therefore C_v = \frac{435.2}{\sqrt{\frac{62.4}{\rho}}}$$

for: $\rho = 59.8 \text{ lb/ft}^3$
 $P = 14.7 \text{ psia}$
 $T = 212^\circ F$

$$C_v = \frac{435.2}{\sqrt{\frac{62.4}{59.8}}} = \underline{\underline{427}}$$