

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8106120170 DOC. DATE: 81/06/10 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania ~~05000387~~
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Forwards response to NRC question on SER Open Item 33 re flashing in ECCS pump suction lines. NPSH for ECCS pumps is adequate to preclude local flashing in suction piping. 3

DISTRIBUTION CODE: 8001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: _____
 TITLE: PSAR/FSAR AMDTs and Related Correspondence.

NOTES: Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000387
 Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000388

| ACTION: | RECIPIENT | COPIES | | RECIPIENT | COPIES | |
|-----------|-----------------|--------|------|------------------------|--------------|-----|
| | ID CODE/NAME | LTR | ENCL | | ID CODE/NAME | LTR |
| ACTION: | A/D LICENSNG | 1 | 0 | LIC BR #2 BC | 1 | 0 |
| | LIC BR #2 LA | 1 | 0 | STARK, R. 04 | 1 | 1 |
| INTERNAL: | ACCID EVAL BR26 | 1 | 1 | AUX SYS BR 27 | 1 | 1 |
| | CHEM ENG BR 11 | 1 | 1 | CONT SYS BR 09 | 1 | 1 |
| | CORE PERF BR 10 | 1 | 1 | EFF TR SYS BR12 | 1 | 1 |
| | EMERG. PREP 22 | 1 | 0 | EMRG PRP DEV 35 | 1 | 1 |
| | EMRG PRP LIC 36 | 3 | 3 | EQUIP QUAL BR13 | 3 | 3 |
| | FEMA-REP DIV 39 | 1 | 1 | GEOSCIENCES 28 | 2 | 2 |
| | HUM FACT ENG 40 | 1 | 1 | HYD/GEO BR 30 | 2 | 2 |
| | I&C SYS BR 16 | 1 | 1 | I&E 06 | 3 | 3 |
| | LIC GUID BR 33 | 1 | 1 | LIC QUAL BR 32 | 1 | 1 |
| | MATL ENG BR 17 | 1 | 1 | MECH ENG BR 18 | 1 | 1 |
| | MPA | 1 | 0 | NRC PDR 02 | 1 | 1 |
| | OELD | 1 | 0 | OP LIC BR 34 | 1 | 1 |
| | POWER SYS BR 19 | 1 | 1 | PROC/TST REV 20 | 1 | 1 |
| | QA BR 21 | 1 | 1 | RAD ASSESS BR22 | 1 | 1 |
| | REAC SYS BR 23 | 1 | 1 | REG FILE 01 | 1 | 1 |
| | SIT ANAL BR 24 | 1 | 1 | STRUCT ENG BR25 | 1 | 1 |
| EXTERNAL: | ACRS 41 | 16 | 16 | LPDR 03 | 1 | 1 |
| | NSIC 05 | 1 | 1 | | | |

JUN 16 1981

ECCS

TOTAL NUMBER OF COPIES REQUIRED: LTR

63
62 ENCL 57
56

3/4

188 0 100




TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

June 10, 1981

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



SUSQUEHANNA STEAM ELECTRIC STATION
RESPONSE TO NRC QUESTION 211.296
ER 100450 FILE 841-1
PLA-834

Dear Mr. Schwencer:

Attached please find our response to the Commission's question on SER Open Item #33 regarding flashing in the ECCS pump suction lines.

We believe that this response indicates that there is adequate NPSH available to the ECCS pumps to preclude local flashing in the suction piping.

Very truly yours,

N. W. Curtis
Vice President-Engineering and Construction-Nuclear

Attachment.

Boo 5/11

8106120 170

E

211.296.

We have reviewed the suction piping for all ECCS pumps to determine if adequate NPSH is available to preclude local flashing in the pipe. Local flashing can occur if the absolute pressure at that point (h_A) is less than the vapor pressure (h_{vpa}) of the fluid in the pipe. ($h_A = h_{stat} + h_{ata} - h_{frc} > h_{vpa}$)

The suction piping for the core spray system is horizontal from the suction strainer to the outside of the suppression pool penetration and thereafter it slopes down continuously to the pumps without any vertical rises. Therefore taking the location outside of the penetration (Elevation 658'-1") as the highest point in the system. (Refer to Mode "E" of the CS NPSH calculations presented as a response to SER Open Item 33 by letter PLA-779.) For simplicity, conservatively assume that all 8.88 feet of friction loss (h_f) is between the suction strainer inlet and the first drop right outside of the suppression pool penetration. Using the NPSHA numbers from that calculation, the available h_A would be:

$$h_A = (670 - 658.08) + 33.16 - 8.88 = 36.2 \text{ feet}$$

The required pressure is the vapor pressure at 200°F: $h_{vpa} = 27.61$ feet. Since the $h_A > h_{vpa}$ there is adequate pressure at this point to prevent local flashing. The remainder of the piping from this point to the pump does not go upward, therefore we can conclude that there is no local flashing.

Similarly the suction piping for the RHR system is horizontal from the suction strainers to the outside of the suppression pool penetration and thereafter it slopes down continuously to the pump without any vertical rises. Therefore taking the location outside of the penetration (Elevation 658'-1") as the highest point in the system. (Refer to Mode "C-2" of the RHR NPSH calculations presented as a response to SER Open Item 33 via letter PLA-779).

For simplicity, conservatively assume that all 6.7 feet of friction loss (h_f) is between the suction strainer inlet and the first drop right outside of suppression pool penetration. Using the NPSHA numbers from that calculation, the available h_A would be:

$$h_A = (670 - 658.08) + 33.16 - 6.7 = 38.38 \text{ feet}$$

The required pressure is the vapor pressure at 200°F: $h_{vpa} = 27.61$ feet. Since the $h_A > h_{vpa}$ there is adequate pressure at this point to prevent local flashing. The remainder of the piping from this point to the pump does not go upward, therefore we can conclude that there is no local flashing.

However, the suction pipe for the HPCI pump takes a vertical rise of four feet inside the suppression pool, to the elevation of the suppression pool penetration, elevation 658'-1". Refer to the NPSH calculation presented in the FSAR section 6.3.2.2.1.2. For simplicity, conservatively assume that all 16 feet of friction loss (h_f) is between the suction strainer inlet and the high point.


Using the NPSHA numbers from this section, the available h_g would be:

$$h_g = (670 - 658.08) + 33.16 - 16 = 29.08 \text{ feet}$$

The required pressure is the vapor pressure at 140°F: $h_{vpa} = 6.8$ feet. Since the $h_g > h_{vpa}$ there is adequate pressure at this high point to prevent local flashing. The remainder of the piping from containment isolation valve to the pump does not go upward and therefore there is no local flashing.

Conclusion: There is adequate NPSH available to preclude local flashing in the ECCS suction piping.

- * Please note that FSAR will be revised to state that minimum low water level elevation inside the suppression pool is 670 feet.



**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 6284

FILE: _____

| | | | | | | | |
|--|------------------|-----------------------|----------------------|-------------------|---------------------------------|-----|-------|
| FROM: Pennsylvania Pwr & Light Allentown, Pa. N W Curtis | | DATE OF DOC 6-5-75 | DATE REC'D 6-9-75 | LTR XX | TWX | RPT | OTHER |
| TO: Mr. W A Butler | | ORIG 1 signed | CC | OTHER | SENT NRC PDR <u>XXXX</u> | | |
| | | | | | SENT LOCAL PDR <u>XXXX</u> | | |
| CLASS | UNCLASS XXXXX | PROP INFO | INPUT | NO CYS REC'D 1 | DOCKET NO: <u>50-387/388</u> | | |

DESCRIPTION: Ltr with attachment re our letters of 4-17-75, and 4-23-75, provides add. info with regards to the LOCA related suppression pool hydrodynamic phenomena...

PLANT NAME: Susquehanna 1 & 2

ENCLOSURES:

ACKNOWLEDGED
DO NOT REMOVE

FOR ACTION/INFORMATION WTM 6-10-75

- | | | | |
|--------------------------|----------------------------|-----------------------------|------------------------|
| BUTLER (L) W/6 Copies | SCHWENCER (L) W/ Copies | ZIEMANN (L) W/ Copies | REGAN (E) W/ Copies |
| CLARK (L) W/ Copies | STOLZ (L) W/ Copies | DICKER (E) W/ Copies | LEAR (L) W/ Copies |
| PARR (L) W/ Copies | VASSALLO (L) W/ Copies | KNIGHTON (E) W/ Copies | SPIES W/ Copies |
| KNIEL (L) W/ Copies | PURPLE (L) W/ Copies | YOUNGBLOOD (E) W/ Copies | LPM W/ Copies |

INTERNAL DISTRIBUTION


- | | | | | |
|--|--|---|---|--|
| <u>REG FILE</u> NRC-PDR OGC, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE REG OPR (2) FILE & REGION (2) MIFC | <u>TECH REVIEW</u> SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK (3) ROSS IPPOLITO TEDESCO LONG LAINAS BENAROYA VOLLMER | DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR <u>BEVIN</u> HARLESS | <u>LIC ASST</u> R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. MAIGRET (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L) M. DUNCAN | <u>A/T IND.</u> BRAITMAN SALTZMAN MELTZ <u>PLANS</u> MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON <u>VARGA</u> |
|--|--|---|---|--|

EXTERNAL DISTRIBUTION

- | | | |
|---|--------------------------------|------------------------|
| 1 - LOCAL PDR <u>Wilkes Barre, Pa</u> | 1 - NATIONAL LABS _____ | 1 - PDR-SAN/LA/NY |
| 1 - TIC. (ABERNATHY) (1)(2)(10) | 1 - W. PENNINGTON, Rm E-201 GT | 1 - BROOKHAVEN NAT LAB |
| 1 - NSIC (BUCHANAN) | 1 - CONSULTANTS | 1 - G. ULRIKSON ORNL |
| 1 - ASLB | NEWMARK/BLUME/AGBABI'AN | |
| 1 - Newton Anderson | | |
| 1 - ACRS 1-2-75 / SENT TO <u>MAIGRET.</u> | | |


June 5, 1975

Dr. Walter R. Butler, Chief
Light Water Reactors Branch 1-2
Division of Reactor Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Docket Nos. 50-387
50-388

SUSQUEHANNA SES
ADDITIONAL INFORMATION-CONTAINMENT DESIGN
ER 100450 FILES 840-2, 170
PLA-69



Dear Dr. Butler:

Your letter of April 17, 1975 indicated that the NRC requires additional information relative to the design of the containment for the Susquehanna Steam Electric Station, Units 1 and 2. You requested that we submit to you within thirty days our program and schedule for prompt resolution of the potential problems associated with the LOCA related suppression pool hydrodynamic phenomena identified by General Electric during Mark III testing.

Your letter of April 23, 1975 requested additional information related to the effects of main steam relief valve operation. You requested that we respond within 90 days or that we advise you within 15 days if we cannot meet this schedule. Subsequently, we informed you that we would submit our proposed program and schedule for resolving these issues the week of June 2, 1975. Since the investigations of the phenomena discussed in your letters are interrelated, we have chosen to respond to both subjects together.

Prior to receipt of your letters, we had begun a program to evaluate certain suppression pool phenomena. These phenomena, as identified in our April 4, 1975 letter to Mr. J. P. O'Reilly, are:

1. Suppression Pool Swell
2. Containment Vent Pipe Horizontal Loads from Steam Condensation.
3. Main Steam Safety/Relief Valve discharge pipe air clearing.

[The text in this section is extremely faint and illegible due to the quality of the scan. It appears to be a large block of text, possibly a list or a series of entries, but the individual characters and words cannot be discerned.]

The program to investigate these three phenomena, and the other phenomena mentioned in your letter, is described in the attachment and reflects our long-term approach to resolution of these problems. The program and schedule were developed in conjunction with General Electric by the utilities owning plants with Mark II containments.

As part of our near term efforts to permit restart of containment construction, we have done a substantial amount of work in terms of defining bounding loads, based on information supplied by General Electric, and determining the capability of the existing structures. Based on this work, we have concluded that some of the "holds" placed on containment construction activities can be lifted. We have scheduled a meeting for June 17 with the NRC to discuss the bounding loads, methods of structural analysis used to determine structural capability, and our plans for the resumption of containment construction.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction

CTC:MAS

c-Messrs.
Mr. J. P. O'Reilly - US Nuc. Reg. Com.
Director-Region I
U.S. Nuclear Regulatory Commission
931 Park Avenue
King of Prussia, PA 19406



10/10/10

[The main body of the page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and does not form any recognizable words or sentences.]

ATTACHMENT
MARK II CONTAINMENT PROGRAM & SCHEDULE

| <u>Program</u> | <u>Schedule</u> | <u>LOCA Questions**</u> | <u>SRV Questions**</u> |
|--|--------------------|-------------------------|------------------------|
| 1. Submit suppression pool and relief valve drawings reflecting current design. | July, 1975 | 1 | 1, 5* |
| 2. Submit a generic "Forcing Function Report" which will provide the time history of pool dynamic forcing functions and the methods for relating these functions to the containment structures and components. | Sept., 1975 | 2, 7* | 1*, 2, 4*6 |
| 3. Submit a description of suppression pool temperature monitoring system. (Temperature limits and transients will be described in the Final Safety Analysis Report.) | Oct., 1975 | Not Appl. | 7, 8, 9, 10 |
| 5. Submit a preliminary assessment of containment structures and components based on the Forcing Function Report. | Nov., 1975 | 3, 4, 5, 6, 7*, 8 | 3, 4*, 5 |
| 5. Submit a schedule for the generic test program and mathematical models which justify the forcing functions used to assess containment structures and components. | Dec., 1975 | 7 | 4 |
| 6. Submit a schedule for the final assessment of containment structures and components. | First Quarter 1976 | - | - |

* Partial Answer

** Question Numbers correspond to the additional information requests contained in NRC letters dated April 17 and April 23, 1975.



Handwritten scribbles and marks in the top right corner.

