



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 101
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated November 7, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 101, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8407090152 840625
PDR ADOCK 05000259
P PDR

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 25, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 101

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

305

311

2. The marginal lines on these pages denote the area being changed.
3. Add the following new page:

305A

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.10.A Refueling Interlocks

being withdrawn may be bypassed on a withdrawn control rod after the fuel assemblies in the cell containing (controlled by) that control rod have been removed from the reactor core. All other refueling interlocks shall be operable.

B. Core Monitoring

1. During core alterations, except as in 3.10.B.2, two SRM's shall be operable, in or adjacent to any quadrant where fuel or control rods are being moved. For an SRM to be considered operable, the following shall be satisfied:
 - a. The SRM shall be inserted to the normal operating level. (Use of special moveable, dunking type detectors during initial fuel loading and major core alterations in place of normal detectors is permissible as long as the detector is connected to the normal SRM circuit.)
 - b.1 The SRM shall have a minimum of 3 cps with all rods fully inserted in the core, if one or more fuel assemblies are in the core, or,
 - b.2 During a full core reload where both irradiated and fresh fuel is being loaded, SRM's (FLC's) may have a count rate of <3 cps provided that the SRM's are response checked at least once every 8 hours with a neutron source until >3 cps can be maintained, and provided also that the core is loaded in a spiral sequence only, or

4.10.A Refueling Interlocks

3. Core Monitoring

Prior to making any alterations to the core the SRM's shall be functionally tested and checked for neutron response. Thereafter, while required to be operable, the SRM's will be checked daily for response except as specified in 3.10.B.1.b.2.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.10.B

b.3 During a full core reload where both irradiated and fresh fuel are being loaded, four (4) irradiated fuel assemblies will be placed adjacent to each SRM to establish a count rate of >3 cps, provided each SRM is functionally tested prior to adjacent fuel loading, a neutron response is observed as the adjacent fuel is loaded, and the core is loaded in a spiral sequence only after the SRM adjacent fuel loading.

3.10 BASES

REFERENCES

1. Refueling interlocks (BFNP FSAR Subsection 7.6)

B. Core Monitoring

The SRM's are provided to monitor the core during periods of station shutdown and to guide the operator during refueling operations and station startup. Requiring two operable SRM's in or adjacent to any core quadrant where fuel or control rods are being moved assures adequate monitoring of that quadrant during such alterations. The requirement of 3 counts per second provides assurance that neutron flux is being monitored and ensures that startup is conducted only if the source range flux level is above the minimum assumed in the control rod drop accident.

During a full core reload SRM/FLC (Fuel Loading Chamber) operability will be verified using a portable external source at least once every 8 hours until sufficient fuel has been loaded to maintain 3 cps. A large number of fuel assemblies will not be required to maintain 3 cps. This increased surveillance rate assures proper detector operability until that time.

During a full core reload, irradiated fuel may be placed adjacent to each SRM to maintain a count rate >3 cps. Four (4) irradiated fuel assemblies will be placed in the four adjacent fuel locations to each SRM to establish the >3 cps count rate. The response of each SRM to the adjacent fuel loading will demonstrate neutron response. Each SRM will be functionally tested prior to loading the adjacent fuel assemblies. This precludes the use of FLC's as mandatory for a full core reload.

Under the special condition of removing the full core with all control rods inserted and electrically disarmed, it is permissible to allow SRM count rate to decrease below 3 cps. All fuel moves during core unloading will reduce reactivity. It is expected that the SRM's will drop below 3 cps before all of the fuel is unloaded. Since there will be no reactivity additions during this period, the low number of counts will not present a hazard. When all of the fuel has been removed to the spent fuel storage pool, SRM's will no longer be required. Requiring the SRM's to be functionally tested prior to fuel removal assures that the SRM's will be operable at the start of fuel removal. The daily response check of the SRM's ensures their continued operability until the count rate diminishes due to fuel removal. Control rods in cells from which all fuel has been removed and which are outside the periphery of the then existing fuel matrix may be armed electrically and moved for maintenance purposes during full core removal, provided all rods that control fuel are fully inserted and electrically disarmed.

REFERENCES

1. Neutron Monitoring System (BFNP FSAR Subsection 7.5)
2. Morgan, W. R., "In-Core Neutron Monitoring System for General Electric Boiling Water Reactors," General Electric Company, Atomic Power Equipment Department, November 1968, revised April 1969 (APED-5706)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 95
License No. DPR-52


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated November 7, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 95, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 25, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 95

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

305

311

2. The marginal lines on these pages denote the area being changed.
3. Add the following new page:

305A

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.10.A Refueling Interlocks

being withdrawn may be bypassed on a withdrawn control rod after the fuel assemblies in the cell containing (controlled by) that control rod have been removed from the reactor core. All other refueling interlocks shall be operable.

B. Core Monitoring

1. During core alterations, except as in 3.10.B.2, two SRM's shall be operable, in or adjacent to any quadrant where fuel or control rods are being moved. For an SRM to be considered operable, the following shall be satisfied:
 - a. The SRM shall be inserted to the normal operating level. (Use of special moveable, dunking type detectors during initial fuel loading and major core alterations in place of normal detectors is permissible as long as the detector is connected to the normal SRM circuit.)
 - b.1 The SRM shall have a minimum of 3 cps with all rods fully inserted in the core, if one or more fuel assemblies are in the core, or,
 - b.2 During a full core reload where both irradiated and fresh fuel is being loaded, SRM's (FLC's) may have a count rate of <3 cps provided that the SRM's are response checked at least once every 8 hours with a neutron source until >3 cps can be maintained, and provided also that the core is loaded in a spiral sequence only, or

4.10.A Refueling Interlocks

B. Core Monitoring

Prior to making any alterations to the core the SRM's shall be functionally tested and checked for neutron response. Thereafter, while required to be operable, the SRM's will be checked daily for response except as specified in 3.10.B.1.b.2.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.10.B

b.3 During a full core reload where both irradiated and fresh fuel are being loaded, four (4) irradiated fuel assemblies will be placed adjacent to each SRM to establish a count rate of >3 cps, provided each SRM is functionally tested prior to adjacent fuel loading, a neutron response is observed as the adjacent fuel is loaded, and the core is loaded in a spiral sequence only after the SRM adjacent fuel loading.

3.10 BASES

REFERENCES

1. Refueling interlocks (BFNP FSAR Subsection 7.6)

B. Core Monitoring

The SRM's are provided to monitor the core during periods of station shutdown and to guide the operator during refueling operations and station startup. Requiring two operable SRM's in or adjacent to any core quadrant where fuel or control rods are being moved assures adequate monitoring of that quadrant during such alterations. The requirement of 3 counts per second provides assurance that neutron flux is being monitored and ensures that startup is conducted only if the source range flux level is above the minimum assumed in the control rod drop accident.

During a full core reload SRM/FLC (Fuel Loading Chamber) operability will be verified using a portable external source at least once every 8 hours until sufficient fuel has been loaded to maintain 3 cps. A large number of fuel assemblies will not be required to maintain 3 cps. This increased surveillance rate assures proper detector operability until that time.

During a full core reload, irradiated fuel may be placed adjacent to each SRM to maintain a count rate >3 cps. Four (4) irradiated fuel assemblies will be placed in the four adjacent fuel locations to each SRM to establish the >3 cps count rate. The response of each SRM to the adjacent fuel loading will demonstrate neutron response. Each SRM will be functionally tested prior to loading the adjacent fuel assemblies. This precludes the use of FLC's as mandatory for a full core reload.

Under the special condition of removing the full core with all control rods inserted and electrically disarmed, it is permissible to allow SRM count rate to decrease below 3 cps. All fuel moves during core unloading will reduce reactivity. It is expected that the SRM's will drop below 3 cps before all of the fuel is unloaded. Since there will be no reactivity additions during this period, the low number of counts will not present a hazard. When all of the fuel has been removed to the spent fuel storage pool, SRM's will no longer be required. Requiring the SRM's to be functionally tested prior to fuel removal assures that the SRM's will be operable at the start of fuel removal. The daily response check of the SRM's ensures their continued operability until the count rate diminishes due to fuel removal. Control rods in cells from which all fuel has been removed and which are outside the periphery of the then existing fuel matrix may be armed electrically and moved for maintenance purposes during full core removal, provided all rods that control fuel are fully inserted and electrically disarmed.

REFERENCES

1. Neutron Monitoring System (BFNP FSAR Subsection 7.5)
2. Morgan, W. R., "In-Core Neutron Monitoring System for General Electric Boiling Water Reactors," General Electric Company, Atomic Power Equipment Department, November 1968, revised April 1969 (APED-5706)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 68
License No. DPR-68


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated November 7, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 68, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 25, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 68

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

336

342

2. The marginal lines on these pages denote the area being changed.
3. Add the following new page:

336A

3.10 CORE ALTERATIONSB. Core Monitoring

1. During core alterations, except as in 3.10.B.2, two SRM's shall be operable, in or adjacent to any quadrant where fuel or control rods are being moved. For an SRM to be considered operable, the following shall be satisfied: -
 - a. The SRM shall be inserted to the normal operating level. (Use of special moveable, dunking type detectors during initial fuel loading and major core alterations in place of normal detectors is permissible as long as the detector is connected to the normal SRM circuit.)
 - b.1 The SRM shall have a minimum of 1 cps with all rods fully inserted in the core, if one or more fuel assemblies are in the core, or
 - b.2 During a full core reload where both irradiated and fresh fuel is being loaded, SRM's (FLC's) may have a count rate of <3 cps provided that the SRM's are response checked at least once every 8 hours with a neutron source until >3 cps can be maintained, and provided also that the core is loaded in a spiral sequence only, or

4.10 CORE ALTERATIONSB. Core Monitoring

Prior to making any alterations to the core the SRM's shall be functionally tested and checked for neutron response. Thereafter, while required to be operable, the SRM's will be checked daily for response except as specified in 3.10.B.1.b.2.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.10.B.

b.3 During a full core reload where both irradiated and fresh fuel are being loaded, four (4) irradiated fuel assemblies will be placed adjacent to each SRM to establish a count rate of >3 cps, provided each SRM is functionally tested prior to adjacent fuel loading, a neutron response is observed as the adjacent fuel is loaded, and the core is loaded in a spiral sequence only after the SRM adjacent fuel loading.

provided primary reactivity control for the fuel assemblies in the cell associated with that control rod.

Thus, removal of an entire cell (fuel assemblies plus control rod) results in a lower reactivity potential of the core. The requirements for SRM operability during these core alterations assure sufficient core monitoring.

REFERENCES

1. Refueling interlocks (BFNP FSAR Subsection 7.6)

B. Core Monitoring

The SRM's are provided to monitor the core during periods of station shutdown and to guide the operator during refueling operations and station startup. Requiring two operable SRM's in or adjacent to any core quadrant where fuel or control rods are being moved assures adequate monitoring of that quadrant during such alterations. The requirement of 3 counts per second provides assurance that neutron flux is being monitored and insures that startup is conducted only if the source range flux level is above the minimum assumed in the control rod drop accident.

- During a full core reload SRM/FLC (Fuel Loading Chamber) operability will be verified using a portable external source at least once every 8 hours until sufficient fuel has been loaded to maintain 3 cps. A large number of fuel assemblies will not be required to maintain 3 cps. This increased surveillance rate assures proper detector operability until that time.

During a full core reload, irradiated fuel may be placed adjacent to each SRM to maintain a count rate >3 cps. Four (4) irradiated fuel assemblies will be placed in the four adjacent fuel locations to each SRM to establish the >3 cps count rate. The response of each SRM to the adjacent fuel loading will demonstrate neutron response. Each SRM will be functionally tested prior to loading the adjacent fuel assemblies. This precludes the use of FLC's as mandatory for a full core reload.

Under the special condition of removing the full core with all control rods inserted and electrically disarmed, it is permissible to allow SRM count rate to decrease below 3 cps. All fuel moves during core unloading will reduce reactivity. It is expected that the SRM's will drop below 3 cps before all of the fuel is unloaded. Since there will be no reactivity additions during this period, the low number of counts will not present a hazard. When all of the fuel has been removed to the spent fuel storage pool, SRM's will no longer be required. Requiring the SRM's to be functionally tested prior to fuel removal assures that the SRM's will be operable at the start of fuel removal. The daily response check of the SRM's ensures their continued operability until the count rate diminishes due to fuel removal. Control rods in cells from which all fuel has been removed may be armed electrically and moved for maintenance purposes during full core removal, provided all rods that control fuel are fully inserted and electrically disarmed.