* **** *** *** ***	REGUL	ATORY	INFORM	ATION	DISTRIBUTION :	SYSTA	M (ŔID	S)	
ACCESSIO FACIL:5 AUTH.N DOMER.J RECIP. DENTON,	N NBR:8502010 0=259 Browns AME AU •A• Ten NAMEI RE H•R• Off	434 Ferry THOR A nessee CIPIEN ice of	DOC:D Nuclea AFFILIA Valle VT AFFI F Nucle	ATE: 8 r Powe TION y Auth LIATIO ar Rea	5/01/28 NOTA r Station, Un ority N ctor Regulation	RIZED it 1,	i YES, Tenne i recto	ssee*	DOCKET`# 05000259
SUBJECT	Forwards, ad containment to, peactor performed o	d) ini vent branch n 10-i	fo re N & purg chief Inch Fi	RČ con e valv s & 84 sher v	cerns, on struc es discussed 0810 & 1009t alve:adequate	ctura in, NR elcon	1 adeq C; 8309 s.Ana1	uacy (13, mer ysis [,]	o f no
DISTRIB TITLE:	UTION CODE: A OR Submittal:	034D Conte	COPIES sinment	RECEI	VEDILTR C ENO		' SIZE		
NOTES:N O	MSS/ECAF 1cy. L:06/26/73	1cy M	MŠ SŽFČ	AF/PM'					05000259
NOTES:N O	MSS/ECAF 1cy. L:06/26/73 Recipient ID codeynam NRR orb2 BC	1 cy M E: 01,	NMSSJFC Copies Lttr e 7	AF/PM. NCL: 7	RECIPIENT ID CODE/NAME	E'	COPÎ LTTR	EŞ ENCL'	05000259÷
NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NOTES:NO	MSS/ECAF 1cy. L:06/26/73 ID CODE/NAM NRR ORB2 BC ACRS NRR FIELDS.M NRB/DE/EQB REG FILE	1 cy M E: 01: 12: 09: 04	NMSSJFC Copies LTTR E 7 6 1 1 1	AF/PM. NCL: 7 6 1 1	RECIPIENT ID CODE/NAME ADM/LFMB NRR REEVES,E NRR/DSI/AEB RGN2	E' 14	COPÎ LTTR 1 1 1	E\$ ENCL [•] 0 1, 1 1	05000259÷
NOTES:N O INTERNAL: EXTERNAL:	MSS/ECAF 1cy. L:06/26/73 ID CODE/NAM NRR ORB2 BC ACRS NRR FIELDS.M N <u>RB/DE/EOB</u> REG FILE LPDR NSIC	1 cy M E: 01, 12, 09, 04, 03, 05,	NMSSJFC COPIES LTTR E 7 6 1 1 1 1 1	AF/PM. NCL: 7 6 1 1 1 1	RECIPIENT ID CODE/NAME ADM/LFMB NRR REEVES,E NRR/DSI/AEB RGN2 NRC PDR	E' 14 02'	COPI LTTR 1 1 1 1 1	ES ENCL ⁴ 0 1, 1, 1, 1, 1,	0500259÷

•

1

****.

TOTAL NUMBER OF COPIES REQUIRED: UTTR 25. ENCL 24

•



ארארי דייייי ארארי דיייי ארארי דיייי ארארי דיייי ארארי דייייי ארארי דיייי

#

	۰	, ' I K '	● 3 · · · · · · · · · · · · · · · · · ·
₹ , H	к	י ד איי רי א	א די. . יי ג
і Р	₩ •• • • • • • • •	і и Ф. с. Б. р.	н, н , ж , , , , , , , , , , , , , , , , , , ,
٩		b h	, ' ≰ _# '

в н

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 25, 1985

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Denton:

In the Matter of the) Docket No. 50-259 Tennessee Valley Authority)

Enclosed is additional information regarding the structural adequacy of containment vent and purge valves in the Browns Ferry Nuclear Plant. The enclosed information is being submitted in response to verbal requests from your staff made during telephone conferences with TVA on August 10 and October 9, 1984. We believe the enclosed information demonstrates the structural integrity of the subject valves and acceptability of the valves for continued use in Browns Ferry.

If you have any questions or need additional clarification, please get in touch with us through the Browns Ferry Project Manager.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

mis-Mmn. James A. Domer

Nuclear Engineer

Subscribed and sworn to before day of mé'this ann Notary Public My Commission Expires

Enclosures cc (Enclosures): U.S. Nuclear Regulatory Commission Region II ATTN: James P. O'Reilly, Regional Administrator 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

Mr. R. J. Clark Browns Ferry Project Manager U.S. Nuclear Regulatory Commission 7920 Norfolk Avenue Bethesda, Maryland 20814

02010434 850125

An Equal Opportunity Employer

The the state of the state of the state

A Provide State State State

ار می از ۲۰۰۸ از بال کاری ۲۰ میرد بایی ۲۰۰۶ اور به توکی ۲۰۰ ۲۹ از میران ۲۰۰۱ ترکیز ۲۰۰۱ میران ۲۰۰۶ ترکی از ۲۰۰۰ ترکی از ۲۰۰۰ ۲۰۰۱ ۲۰۰۰ ۲۰۰۱ می ۲۰۰۲ ۲۵۵۵ ۲۰۰۱ کو ۲۰۰۷ از ۲۰۰۵ آزد. ۲۰ ۲۰۰۱ ۲۰۰۰ ۲۰۰۹ می ۲۰۰۲ ماری کارون در ۲۰

attraction and

「そうな」」が、「そうな」では、「「」」」。 「そうな」「そう」を見ていた。 「そうな」「そう」を見ていた。

المراقعة الما المراجعة في المحتودة المحتولية في المركز والمراور والمراور والمحتودي المحتودي المحتودة المحتودة ا المحتولة في المحتود المحتولية المحتولية المحتودية المحتودية والمحتودين المحتودين المحتود المحتودين المحتودين ال المحتولة المحتودين المحتولية المحتودين المحتودين المحتود المحتودين المحتود المحتويين المحتودين المحتودين المحتو المحتولة المحتودين المحتولية المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين ال المحتولة المحتودين المحتولية المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين المحتودين ا المحتولة المحتودين المحت المحتولة المحتودين الم

and and a start of the second sec A start second second

المراجعة المحمد الم

: ► :/1 • n n 10 a a train a tr e ⁿ j i • ····· of The Sec. at the set of the set 15 T 199 ತಿ ಬಿಡಿಕೆ ಕೊಟ್ಟಿಗೆ ಸಂಗೀತ ಮಾಡಿದ್ದಲ್ಲಿ ಎಂದು ತೊಡಿಸಿದ್ದ ಬೇಕೆ ತಾಗಿ ತಾಲಿಸಿದ್ದು ಕೊಟ್ಟಿಗೆ ಸಂಗೀತ ಮಾಡಿ ಮಾಡಿ ಮಾಡಿ ತಾಲ್ಲಿ ಗೆಲ್ಲಿ ತಾಲಿ ಎಡಿಗೆ ಸಂಗೀತ ಸೇರಿಗೆ ಮಾಡಿ ಮಾಡಿ н тран с о^ле Серект и у с общ • P and the second a state of the second e. S. C. C. C. C. C. S. अस्ति स्टब्स् मिन्द्र 🖓 🖓 Sec.

ENCLOSURE

BROWNS FERRY NUCLEAR PLANT RESPONSE TO NRC CONCERNS ON CONTAINMENT PURGE VALVE OPERABILITY

Listed below are NRC's outstanding concerns on the Browns Ferry Nuclear Plant (BFN) containment purge valve operability analysis as detailed in the NRC memorandum from G. C. Lainas and J. P. Knight to Operating Reactor Branch Chiefs dated September 13, 1983 and TVA's responses. These concerns were further clarified in telephone conferences with the NRC staff on August 10, 1984 and October 9, 1984.

Concern 1

The Staff concurs with the approach stated in the licensee's response. However, confirmation in the form of drawings, meeting minutes, or other verification is required to demonstrate the similarity of valve design.

Response 1

Drawings of our BFN 18- and 20-inch Rockwell Edwards and 10-inch Fisher purge valves as well as comparative drawings of a symmetrical disc Henry Pratt valve were provided under separate cover. The drawings provided were: (1) Rockwell drawing No. 225449; (2) Fisher Controls Company drawing No. F-39237; and (3) Henry Pratt Company drawing No. E-3347. The Henry Pratt valve is the same type of valve from which the torque coefficients used in our analysis were derived. As can be seen from the referenced drawings, the valve dics are very similar in shape.

The cover letter from the Henry Pratt Company which transmitted the torque coefficient data is provided as attachment A. This letter illustrates the nature of the conversations which took place between TVA and the Henry Pratt Valve Company that led to the determination of the correct torque coefficient data to utilize.

Finally on this concern, an aspect ratio comparison was made with the Henry Pratt Mk II valve. That comparison is provided as attachment B. As can be seen from that attachment, they compare favorably.

Concern 2

The Licensee's response on this item is acceptable to the staff.

Response

No response required.

Concern 3

In order for the Staff to confirm the structural adequacy of the valve assembly under the postulated accident condition as claimed by the licensee, supporting documentation should include as a minmum a summary of stress analysis results with calculated stresses and code allowable stresses to demonstrate that the allowable stresses in the valve-operator extended structure and associated interfacing hardware are not exceeded.

<u>Response</u> 3

and the second s

Table 1 provides a breakdown of the calculated stresses of the pertinent valve components as compared to the allowables. As can be seen, a large margin exists between the calculated and the allowable stresses. Similar results can be expected for the pertinent components of the operator and the interfacing hardware. This is based upon the fact that the design torque for these components exceeds the maximum operating torque, (design basis loss of coolant accident (LOCA) plus seismic event) by a comfortable margin.

Concern 4

Operator spring torque curves are required as part of the evaluation to assure that adequate torque margin exists for the entire valve stroke when compared to the calculated dynamic and seating torques.

Table 1 included in the June 3, 1981, response includes the spring torques for valve angles of 0 and 90 only (full open and full closed). This is unacceptable to the Staff since it does not include the region of peak dynamic torques encountered during closure. If a table is submitted instead of a curve, it should be set up in angular increments of valve stroke no less than 10 degress.

Response 4

Figures 1, 2 and 3 provide spring torque data for all 18-inch and 20inch Rockwell Edwards containment purge valves installed at Browns Ferry.

Concern 5

The staff finds the Licensee's response to this item acceptable.

Response

No response required.

Concern 6

Until the data pertaining to the Fisher values is received and evaluated, the Staff has no basis on which to draw conclusions with regard to either the ability or inability of the 10-inch values to close during a DBA/LOCA at BFN 1-3. These circumstances have existed for several years now.

Response 6

As stated in TVA letter dated June 7, 1983 from L. M. Mills to H. R. Denton, we entered into negotiations with Fisher Valve Company to obtain an operability analysis of our 10-inch Fisher N_2 supply valve. The Fisher Valve Company indicated that an analysis could be obtained for a valve similar to our BFN valve. Because of the fact that the analysis was not for our specific valve and also, because we had considered this issue closed when no response had been received after several months from our June 7, 1983, submittal to your 50.54(f) request, it was determined that a contract for analysis of our 10-inch Fisher valves would be inappropriate.

It should be pointed out that the 10-inch Fisher valve has a symmetrical disc. By inspection of the Henry Pratt drawing No. E-3347 referenced in the response to question 1, it can be seen that the disc is similar in shape to the Henry Pratt valve disc, indicating that the torque coefficients used in the TVA analysis of the Fisher valve are appropriate. This position is further justified by the aspect ratios calculated for this valve disc as shown in attachment B.

Ĵ

. 11

The adequacy of this analysis can be further demonstrated by pointing out some of the conservatisms that it contains. (1) Although this valve is used only during the 24-hour period, limited by our technical specifications, when the unit is being re-inerted, the analysis assumes that an instantaneous large break in combination with a seismic event is occurring during this period of operation. (2) Even though this valve is over 130 feet from the drywell, the associated line losses and other losses from the upstream debris screen, purge valves, and flow directional changes were not accounted for in this analysis. Furthermore; no credit was taken for the increased back pressure from the N₂ supply which would serve to reduce the flow through the valve. Finally, this valve is in series with and secondary to the upstream Rockwell Edwards containment isolation purge valves.

The 10-inch Fisher vavle seismic qualification is addressed by Fisher Controls report "Seismic Analysis of 10-inch Butterfly Valve Assemblies," dated December 14, 1973. The report is available within TVA.

In summary, we believe that the analysis performed on our 10-inch Fisher valve is completely adequate and the available conservatisms should more than offset any oustanding concerns.

•

. .

•

•

2. 9. 41.12 (P

. Table 1

BUTTERELY VALVES วราหีสมพ.ศภ 70,663 and F.D INci

5/25

YAYE

ノドドレ

/8

COMPONENTS MATERIAL: 17-4 PH STEEL MIN TIETS STRENGTU ~ Fty = 125 X51 ואוא טוד. לפטגונב שופיאלא - F = 145XSI

REPLEDITS VALVE SIDELC	VALYE COMFONENT	CONFONENT SIZE	LOADS MAPOSED	CRITICUL STRESSES IN CONFOUNT	ALLOUNDE STRZSS	STRUCTUM	COMVICUTS / REFERENCES
18 = 20	Shaft	13- inest DIA	MAX. OFER. CITEST TORADE of 15,000 Inclis + 3c SEISME + MAX 284-604	20,360 (SHEAR)	62,500 (0.5Fm)	3.1	MAX, DEA-LOCA TORQUE IS LESS THAN MEX, OFER, TORQUE
	* 1 <u>1</u>		ΔP n 41 PSI Across Disc	11,150 (BEDAWAG)	112,500 (0.957)	10.1	HSSIME PINNED SINDS AT BUSHINGS.CLITICAL LOCATION AT OUTER DUE 9 DSC.
	* v * *	- 4 Å - 4 Å - 4 Å	DBA-LOA MARINUM ROTATIOUAL ENEEGY OF DISCY CLOUED POIDU	10,400 (s'нема)	62500 (0.5Fm)	<i>6.</i> 0	ASSUME KWERL EMERT DISC = TOESIONAL STRAND DNORGY IN DHAFT. SEE NOTE 3.
18 420	Disc	199 INA DA 32 E= 29,111	DBA-LOCA MAX^AP A fIBI Access Disc + 3g Seisme	3035 (ВЕЛДИКУ	112,500 (19,547)	VZY LAKE	
16"42.5"	CHERE PINS (CONVERS DISC (SUUT)	5/6 m24 DA	MAZ, OPER OUTROT TREASE of 15,000 ILLES + 3,555MC	27950 (s#E72)	67,500 (0.5 Fty)	2.2	MAX DBA-LOCA TORQUE IS LES THAT MAX.OFEL TORQUE *
18 [°] \$20'	SHAFT FUSHINGS (UFTER {lough	13 welt Dit by I welt but	MAX DBA-LOCA AP 13,41 PSI Access Disc + 34 SESMIC	3520 (557,1106)	ο / πουφιατίας ματαγίας ματαγί	VERY LARGE	
' <i>10</i> "	SHAFT.	linen DiA	DBA-LOCA MAX FLUID TCLQUE (2-1400 IN-485) + 39 Second	,7135 (sharz)	62500 (015 Fig).	8,8	MAX DBA-LOCA TOLSUE IS LEES THAN YENDR'S (FISHER) HLOWED TOZOUE OR OPERTER TOLSUE
10"	DISC	10 мен	MAX JEA-LOCA DP of 44PSI ACROSS DISC + 3g Sellmic	NOT CULWIKN SEF COMMUNS	112,500 (0.9F47)	VERY LARGE	FUENISIED VALVE ASSY RATED AT 150 LBS,

NOTES (1) THIS STRUCTURAL EVALUATION HAD TWO PRIMARY CONSIDERATIONS, 1.0;

(2) WHAT IS THE COMPARISON BETWEEN THE MAXIMUM DBA-LOCA FLUID TORQUE VERSUS THE COMPONENTS DELIGN OR OPERATOR COTENT TORQUE?

(b) WHAT IS THE MAXIMUM DISC KINETIC ENERGY AT CLOSED PESTION WITH JBA-LOCA?

(2) FOR EACY SIZE VALVE, THE MAXIMUM DBA-LOCA RUID TORGUE IS LESS THAN THE DESIGN OR OPERATER OUTPUT TORQUE. AS NOTED IN THELE, THE MAK OPERATOR OUTPUT TORQUE IS 15,000 IN.LEL WHEREAS THE MAX DBA-LOCA FLUD TOLOVES ARE 9100 \$ 9800 IN-LAS REFERENCES FOR THE IS E 20 MAH SIZES. ALSO THE ID WHAN VALVE DESISN OR OPERATOR TOLODOS ARE GREATER THAN THE MAR DEA-LOCA FLUID TORQUE OF APPROXIMATELY 1400 IN-LES,

(3) PR EACH SIZE VALUE, THE DISC TORQUE IS VERY SMALL OR AT A MINIMUM DLUNG APPLOVIMATELY THE USST 3rd on DISC CLOSING MOVEMENT AND THEREFOLD THE CURLESPONDING DISC ROTATIONAL VELOCITY (W) AND KINETC ENERGY IS MINIMUM, AS IN ABOUE EXAMPLE FOR IS & ZO INLISTES, THE SHAFT STRESS RESULTS FROM ASSUMING A CONSERVITIVE AND CONSTANT DISC NET TOUDE OF 100 INLES WITH AN ACTUAL DISC CHECKATED RETATIONAL MASS MODIFEUT & INERTIA (Im) OF 0.344 SLUG-FT? THE DISC KINER ENERGY (C. 5 Imw?) WAS THEN CHICULATED TO ZE 13 FT-LBS WHICH WAS ASSUMED EQUIL TO THE SHAPP. TOUSWIT STRAW BUDG OF 0.5T2 , TRIANG RELITING SHIFT REQUE FROM WHICH STRESS (IP) WAS CALCULATED.

El ser



. •

.

, • • •

v • , •

VALVE OPERATOR NO.

(20-INCH ROCKWELL EDWARDS VALVE)

YOKE ARM ANGLE' (degrees)	SPRING TORQUE (in 16)	PRESSURE TORQUE (50)ps1 (PRESSURE TORQUE (60)p=1	PRESSURE TORQUE (70)psi	PRESSURE TORQUE (80)psi
0	8576	101.77	13927	17678	21428
15 -	7266	6187	8878	11568	14259
30	6757	4491 .	6741	8991 *	11240
45 1	6941 -	3685	5811	7936	10061
60	7937	3311	5560	7810	10060
75.	10309	3145	5835	8526	11216
'90	15922 🐩	2831	6581	10332	14082

PRESSURE OR SPRING TOROUE

YOKE ARH ANGLE

FIGURE 1

VALVE OPERATOR NO.

(18-INCH ROCKWELL EDWARDS VALVE)

YOKE ARM Angle (degrees	SPRING TORQUE (in 1b)	PRESSURE TORQUE (70)ps1	PRESSURE TORQUE (80)psi	PRESSURE TORQUE	PRESSURE TORQUE (100)psi
0	9776	16478	20228	23979	27729
15	8494	10340	13031	15721	18412
30	8009	7739	9988	12238	14488
45	83,08	.6569	8694	10820	12945
60	9579	· 6168	8418	10668	12917
, 75	12541	6293	8981	11674	14365
, 90	19546	6707	10458	14208	17959



YOKE ARH ANGLE

.

۰

κ. .

. . . .

.

.

)

. .

in Stati

*****.

LAND STREET STREET STREET STREET STREET

(18-INCH ROCKWELL EDWARDS VALVE)

VALVE OPERATOR N	ю. 722 (18-INCH	2-SR8 ROCKWELL EDW	ARDS VALVE)			
YOKE ARM Angle (degrees)	SPRING TORQUE (in 16)	PRESSURE TORQUE: (70)p=1	PRESSURE TORQUE (80)psi	PRESSURE. TORQUE : (90)ps1	PRESSURE TORQUE (100)p=1	۳. او
- 0	7470	12444	15289	18134 💈	20979	
15	6496	7790	9831 、	11872	13913	
30	6127	5818	7524	9231	10937	
45	6358	4927	6539	8151	9763	
60.	7333	4612	6319	· 6025	9732	
75	9603 🔭	4684	6725	8766	10807	
90. ;	14970 -	4944	7789 🚛	10634	13479	



YOKE ARH ANGLE

FIGURE 3

NT ** (Fre W SVE WY SY 10

ħ.



Henry Pratt Company

AUI SOUTH HIGHLAND AVENUE AURORA, ILLINOIS

GREGORY A. KURKJIAN, JR. VICE PRESIDENT AND MANAGER-MARKETING

844-4020

April 25, 1980

Tennessee Valley Authority 400 Commerce Avenue W9C155 Knoxville, TN 37901

Attention: R. Bryon

Dear Mr. Bryon:

In response to our recent phone conversation, enclosed herewith are two (2) copies of various coefficients associated with Pratt valves that can be used in determining the pressure drop and torque for the Rockwell valves you described.

For the value size you indicated, I would expect the maximum fluidynamic torque to occur somewhere from the 40° to 50° position range. Torques are calculated as noted in the Appendix, page 13 of AWWA - C504, copy enclosed.

If you have any questions regarding the use of this 'material, please feel free to contact me.

Very truly yours,

Kurkijan

GAK:jb

Enclosure's,



. .

• • •

•

.

- · · · · · ·

n

. .

ATTACHMENT B

s.^^ .

1. The aspect ratio data for the Rockwell-Edwards 18- and 20-inch butterfly valves and Fisher Controls 10-inch valve for comparison with a Henry Pratt valve with a geometrically similar disk was obtained. The flow coefficient data used in TVA's operability analysis for the Fisher and Rockwell-Edwards valves is representative of this particular Henry Pratt valve.

Aspect ratio is defined as the ratio of disk thickness at a particular position to the overall disk diameter. The tabulation
below shows aspect ratios at two positions (the disk center and the disk edge) for TVA's Fisher and Rockwell-Edwards valve types and the representative Henry Pratt valve.

Aspect Ratio		
Center.	Edge	
0.212	0.025	
0.209	0.022	
0.228	0.000*	
0.232	0.022	
	Aspect I Center 0.212 0.209 0.228 0.232	

*The edge is rounded based on data provided by the site, making determination of this value difficult.

• •

-

•

•

•

۰۰ سو ۲۰۰۰ میں ۲۰۰۰ میں

* • • •

. ۲

• •