



MAY 20 1980

Mr. Norman W. Curtis

cc: Mr. Earle M. Mead  
Project Engineering Manager  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Jay Silberg, Esq.  
Shaw, Pittman, Potts &  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. William E. Barberich,  
Nuclear Licensing Group Supervisor  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Edward M. Nagel, Esquire  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Bryan Snapp, Esq.  
Pennsylvania Power & Light Company  
901 Hamilton Street  
Allentown, Pennsylvania 18101

Robert M. Gallo  
Resident Inspector  
P. O. Box 52  
Shickshinny, Pennsylvania 18655

Susquehanna Environmental Advocates  
c/o Gerald Schultz, Esq.  
500 South River Street  
Wilkes-Barre, PA 18702

John L. Anderson  
Oak Ridge National Laboratory  
Union Carbide Corporation  
Bldg. 3500, P. O. Box X  
Oak Ridge, Tennessee 37830

Mr. Robert J. Shovlin  
Project Manager  
Pennsylvania Power and Light Co.  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Matias F. Travieso-Diaz, Esq.  
Shaw, Pittman, Potts &  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Dr. Judith H. Johnsrud  
Co-Director  
Environmental Coalition on  
Nuclear Power  
433 Orlando Avenue  
State College, PA 16801

Mr. Thomas M. Gerusky, Director  
Bureau of Radiation Protection  
Department of Environmental  
Resources  
Commonwealth of Pennsylvania  
P. O. Box 2063  
Harrisburg, PA 17120

Ms. Colleen Marsh  
Box 538A, RD#4  
Mountain Top, PA 18707

Mrs. Irene Lemanowicz, Chairperson  
The Citizens Against Nuclear  
Dangers  
P. O. Box 377  
RD#1  
Berwick, PA 18503

ENCLOSURE

010.22

The Standard Review Plan, Section 9.1.4, part II provides guidelines for a fuel handling system. The fuel handling platform bridge and its subcomponents such as crane rails, clamps and clips are not excluded from a system's approach. They perform a safety related function, i.e. position fuel and limit the displacement of the fuel handling platform during a seismic event. Your FSAR Volume II, page 9.1-17 identifies the fuel handling platform as a safety Class 2, seismic category 1 piece of equipment and discusses its seismic requirements. There are no departures or exceptions identified in the FSAR.

On the basis of the above, please indicate your intent to upgrade the crane rails, rail clips and clip plates to meet the requirements of 10 CFR Part 50 Appendix B or provide your justification for retaining your present design. Your justification should include the consequences of the failure of these items or show that failure of any of these items will not result in damage to the fuel.

MAY 20 1980