

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103270686 DOC. DATE: 81/03/25 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 YOUNGBLOOD, B.J. Licensing Branch 1

SUBJECT: Forwards util response to FSAR Questions 230.5, 230.6 & 230.7. Units will not be operated in natural circulation mode or w/only one recirculation pump in operation. Stability analysis will be performed for second cycle.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 05000387
 Send I&E 3 copies FSAR & all amends. 05000388

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	A/D LICENSNG	1	0	YOUNGBLOOD, B	1	0
	RUSHBROOK, M.	1	0	STARK, R. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	REG FILE 01	1	1	SIT ANAL BR 24	1	1
	STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1
EXTERNAL:	ACRS 27	16	16	LPDR 03	1	1
	NSIC 05	1	1			

MAR 30 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 51

MA 4


JF

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101

PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381



March 25, 1981

Mr. B.J. Youngblood, Chief
Licensing Branch 1
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Susquehanna Steam Electric Station
Response to Questions 230.5, 230.6 and 230.7
ER 100450 File 841-2
PLA-678

Docket Nos. 50-387
and 50-388

Dear Mr. Youngblood:

Attached are the responses to FSAR Questions 230.5, 230.6
and 230.7.

Very truly yours,

N. W. Curtis

N.W. Curtis
Vice-President-Engineering
and Construction-Nuclear

cc: R.M. Stark

bcc: N.W. Curtis
W.E. Barberich
B.A. Snapp
C.T. Coddington
R.J. Shovlin

8001
S
1/1

PENNSYLVANIA POWER & LIGHT COMPANY

8103270686
A

QUESTION 230.5:

The staff is performing a generic study of the hydrodynamic stability characteristics of LWRs under normal operation, anticipated transients, and accident conditions. The results of this study will be applied to the staff review and acceptance of stability analyses and analytical methods now in use by the reactor vendors. In the interim, the staff concludes that past operating experience, stability tests, and the inherent thermal-hydraulic characteristics of LWRs provide a basis for accepting the Susquehanna stability evaluation for normal operation and anticipated transient events. However, in order to provide additional margin to stability limits, natural circulation operation of Susquehanna will be prohibited until the staff review of these conditions is complete. Any action resulting from the staff study will be applied to Susquehanna.

RESPONSE:

PP&L does not plan to operate the Susquehanna units in the natural circulation mode. The plant technical specifications are consistent with your position, and require that appropriate actions be taken if no recirculation loops are in operation.

SSES-FSAR

QUESTION 230.6:

Because the Susquehanna stability analysis is for the first cycle only, a new analysis must be reviewed and approved by the staff prior to second cycle operation.

RESPONSE:

PP&L will perform a stability analysis for the second cycle of operation.

SSES-FSAR

QUESTION 230.7:

No analysis has been presented for MCPR limits or stability characteristics for one loop operation. One loop operation will not be permitted until supporting analyses are provided and are approved by the staff.

RESPONSE:

PP&L does not plan to operate the Susquehanna units with only one recirculation loop in operation, therefore, no additional analysis are required. The plant technical specifications are consistent with your position, and require that appropriate actions be taken with one recirculation loop not in operation.