

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8104070342 DOC. DATE: 81/04/03 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: YOUNGBLOOD, B.J. RECIPIENT AFFILIATION: Licensing Branch 1

SUBJECT: Forwards response to Containment Sys Branch 810309-10 questions re FSAR review. COPDA was used for subcompartment pressurization analysis. Blowdown data was generated by hand calculations.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5.2
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 05000387
 Send I&E 3 copies FSAR & all amends. 05000388

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES		
	ID. CODE/NAME	LTR	ENCL		ID. CODE/NAME	LTR	ENCL
ACTION:	A/D LICENSNG	1	0	YOUNGBLOOD, B	1	0	
	RUSHBROOK, M.	1	0	STARK, R. 04	1	1	
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 07	1	1	
	CHEM ENG BR 08	1	1	CONT SYS BR 09	1	1	
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1	
	EMERG PREP 22	1	0	EQUIP QUAL BR13	3	3	
	GEOSCIENCES 14	1	1	HUM FACT ENG BR	1	1	
	HYD/GEO BR 15	2	2	I&C SYS BR 16	1	1	
	I&E 06	3	3	LIC GUID BR	1	1	
	LIC QUAL BR	1	1	MATL ENG BR 17	1	1	
	MECH ENG BR 18	1	1	MPA	1	0	
	NRC PDR 02	1	1	OELD	1	0	
	OP LIC BR	1	1	POWER SYS BR 19	1	1	
	PROC/TST REV 20	1	1	QA BR 21	1	1	
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1	
	REG FILE 01	1	1	SIT ANAL BR 24	1	1	
	STRUCT ENG BR25	1	1	SYS INTERAC BR	1	1	
	EXTERNAL:	ACRS 27	16	16	LPDR 03	1	1
		NSIC 05	1	1			

APR 9 1981

MAY

ff

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 51

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

April 3, 1981


Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
NRC MEETING -- MARCH 9-10 1981
FSAR REVIEW -- CONTAINMENT BRANCH
ER 100450 FILE 841-1
PLA-710

Dear Mr. Youngblood:

The attached responds to concerns expressed by the Containment Systems Branch at the March 9 and 10, 1981 meeting between NRC and PP&L.


Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction-Nuclear

TEG/mks

Attachment



*Boo
5/11*

8104070 342
A

ATTACHMENT TO PLA-710

Question #1

Does PP&L meet the NRC position on WCAP 7709L for H₂ recombiners? (Reference memo Rosa to Kintner dated 5/11/78.)

Response

Yes. PP&L utilizes the automatic temperature controller. However, we do not use the cold reference junction box with this type of penetration. We use chromel-alumel penetrations (not copper) for the hydrogen recombiner thermocouples.

Question #2

Will the H₂ recombiner work in an inerted atmosphere?

Response

Westinghouse has documented that the H₂ recombiners will work in an inerted atmosphere.

Question #3

P&ID M-157 shows group alarms on the inboard and outboard vacuum breakers. Is there position indication on the individual valves?

Response

Yes. There is position indication in the main control room for each valve. (Ref. P&ID M-100, sht. 2, notes 1 thru 4.)

Question #4

NRC did not receive a copy of table 6.2-23.

Response

Table 6.2-23 is included in Revision 22 to the Susquehanna FSAR. A copy is attached.

Question #5

What codes were used for subcompartment pressurization analysis and for blowdown data for this analysis?

Response

COPDA was used for subcompartment pressurization analysis. Blowdown data was generated by hand calculations.

Question #6

For 0-60 and 0-250 psig drywell pressure monitors:

- a. Is manual action needed to provide indication in each range?
- b. What is accuracy?
- c. What is response time?

Response

- a. No. Each is recorded on a separate channel.
- b. Minimum accuracy is +3% of full scale.
- c. Less than three seconds for full scale deflection.

Question #7

What is accuracy for suppression pool water level indication and hydrogen analyzer?

Response

Minimum accuracy is +2% of full scale.

Question #8

Change the description of penetration X-88 in Tables 6.2-12 and 6.2-22 to agree with the description given in paragraph 6.2.4.3.2.2 of the FSAR.

Response

The FSAR will be corrected.

Question #9

How far is the outboard isolation valve for penetration X-217 from the containment?

Response

Two and a half feet.

Question #10

What is the free volume of the secondary containment?

Response

Zone I	1,560,000 ft. ³
Zone II	1,670,000 ft. ³
Zone III, Unit 1	1,428,000 ft. ³
Zone III, Unit 2	1,300,000 ft. ³

Question #11

How many vacuum breakers are assumed to open in the containment pressure analysis? (To relieve pressure from wetwell.)

Response

Four.

TABLE 6.2-23INITIAL AND BOUNDARY CONDITIONS FOR INADVERTENT
SPRAY ACTUATION STUDY

	t -00	Time Zero to
<u>Drywell</u>		
Volume (Ft ³)	239600	239600
Pressure (PSIA)	14.8	34.83
Temperature (F)	150	259
Relative Humidity (%)	100	100
Spray Rate (GPM/ TRANS)	0/0	1.0700/1
<u>Wetwell</u>		
Volume - Vapor Region (Ft ³)	148590	145900
- Suppression Pool (Ft ³)	131550	131550
Pressure (PSIA)	14.8	30.28
Temperature (F)	50	50
Relative Humidity (%)	100	100
Suppression Pool Free Surface Area (Ft ²)	5277	5277
<u>Wetwell-to-Drywell Vacuum Breakers</u>		
Number of Valve Assemblies		4 of 5
Flow Area Per Assembly (Ft ²)		2.05
Flow Coefficient		0.35
Assumed Vacuum Breaker Lifting Pressure (psid)		3
<u>RHR System - Drywell Spray Mode</u>		
Service Water Flow Rate (GPM)		9000
Service Water Temperature (F)		32
Heat Exchange Effectiveness		0.245

