

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8104140409 DOC. DATE: 81/04/01 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: YOUNGBLOOD, B.J. RECIPIENT AFFILIATION: Licensing Branch 1

SUBJECT: Notifies that util will provide fully qualified purge & vent valves per verbal committment at 810326 meeting w/NRC. Valves to be analyzed for S-s closure under full LOCA pressure. Full qualification by startup following outage.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR ENCL SIZE:
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 05000387
 Send I&E 3 copies FSAR & all amends. 05000388

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTTR	ENCL		LTTR	ENCL
ACTION:	A/D LICENSNG		1	0	YOUNGBLOOD, B	1	0
	RUSHBROOK, M.		1	0	STARK, R. 04	1	0
INTERNAL:	ACCID EVAL BR26		1	1	AUX SYS BR 07	1	1
	CHEM ENG BR 08		1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10		1	1	EFF TR SYS BR12	1	1
	EMERG PREP 22		1	1	EQUIP QUAL BR13	3	1
	GEOSCIENCES 14		1	1	HUM FACT ENG BR	1	1
	HYD/GEO BR 15		2	2	I&C SYS BR 16	1	1
	I&E 06		3	3	LIC GUID BR	1	1
	LIC QUAL BR		1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18		1	1	MPA	1	0
	NRC PDR 02		1	1	OELD	1	0
	OP LIC BR		1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20		1	1	QA BR 21	1	1
	RAD ASSESS BR22		1	1	REAC SYS BR 23	1	1
	REG FILE 01		1	1	SIT ANAL BR 24	1	1
	STRUCT ENG BR25		1	1	SYS INTERAC BR	1	1
EXTERNAL:	ACRS 27		16	16	LPDR 03	1	1
	NSIC 05		1	1			

APR 15 1981


MAY

TOTAL NUMBER OF COPIES REQUIRED: LTTR 57 ENCL

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381



April 1, 1981

Mr. B.J. Youngblood, Chief
Licensing Branch No. 1
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Susquehanna Steam Electric Station
Containment Purge and Vent Valves
ER100450 File 841-2
PLA-700

Docket Nos. 50-387 and 50-388

Dear Mr. Youngblood:

This is to confirm a verbal committment given in a meeting with the NRC Staff on March 26, 1981.

PP&L will provide fully qualified purge and vent valves. The valves will be analyzed for a five second closure under full LOCA pressure. Analysis, testing, valve modification or system modification are being explored in the applicants program. If any physical modifications are required, a detailed implementation schedule will be transmitted to the NRC by November 26, 1981. PP&L will comply with the interim position given in Attachment 1 to paragraph II.E.4.2 of NUREG-0737 by fuel load if it is not possible to complete the physical modifications by that time. In any event PP&L commits to full qualification of the valves no later than the start up following the first refueling outage.

Very truly yours,

N.W. Curtis
Vice-President-Engineering and Construction-Nuclear

Boo's/0

810.4140

409

A