

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8107280597 DOC. DATE: 81/07/21 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.L. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Advises of mods to common water level ref point re SER
 Outstanding Issue 99. Operator training on revised ref level
 will be completed. Mimics will not be installed beside level
 indicators.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000387
 Send I&E 3 copies FSAR & all amends. 1 cy: BWR-LRG PM(L.RIB) 05000388

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
ACTION:	A/D LICENSNG	1	0	LIC BR #2 BC	1	0
	LIC BR #2 LA	1	0	STARK, R. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMRG PRP DEV 35	1	1	EMRG. PRP LIC 36	3	3
	EQUIP QUAL BR13	3	3	FEMA-REP DIV 39	1	1
	GEOSCIENCES 28	2	2	HUM FACT ENG 40	1	1
	HYD/GEO. BR 30	2	2	I&C SYS BR 16	1	1
	I&E. 06	3	3	LIC GUID BR 33	1	1
	LIC QUAL BR 32	1	1	MATL. ENG. BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDR 02	1	1	OELD	1	0
	OP LIC BR. 34	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA. BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
REG. FILE 01	1	1	SIT ANAL BR 24	1	1	
STRUCT ENG BR25	1	1				
EXTERNAL:	ACRS 41	16	1	LPDR 03	1	1
	NSIC 05	1	1	NTIS	1	1

MAY

TOTAL NUMBER OF COPIES REQUIRED: LTR 63/62 ENCL 0/7

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

July 21, 1981

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



SUSQUEHANNA STEAM ELECTRIC STATION
SER OUTSTANDING ISSUE 99
ER 100450 FILE 841-2
PLA-888

Dear Mr. Schwencer:

In response to your concern on common water level reference point, PP&L will make the following modifications prior to fuel load:.

1. LR-1R615 and LI-1R610 will be converted to an instrument zero reference point. After this change, all RPV level indication will use instrument zero as the reference point.
2. Technical specifications and procedures will be altered as necessary to reflect the common reference point.
3. Operator training on the revised reference level will be completed.

As a result of this change, PP&L will not be installing the mimics, previously suggested, next to the level indicators.

Very truly yours,

A handwritten signature in cursive that reads "N.W. Curtis".

N. W. Curtis
Vice President-Engineering and Construction-Nuclear

CTC/mks

*Boal
8/10*