

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION-NBR: 9308170354      DOC. DATE: 93/08/16      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva      05000387  
           50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva      05000388  
 AUTH. NAME                      AUTHOR AFFILIATION  
 BYRAM, R.G.                      Pennsylvania Power & Light Co.  
 RECIP. NAME                      RECIPIENT AFFILIATION  
 MILLER, C.L.                      Project Directorate I-2

SUBJECT: Forwards rept entitled, "PP&L Response to NRC Concerns re  
 Loss of Spent Fuel Pool Cooling Following LOCA, SSES, Units 1  
 & 2," per 930708 meeting.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+27  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD1-2 LA	1	1		PD1-2 PD	1	1	
	CLARK, R	2	2					
INTERNAL:	ACRS	6	6		NRR/DE/EELB	1	1	
	NRR/DRCH/HICB	1	1		NRR/DRPW/OTSB	1	1	
	NRR/DSSA/SPLB	1	1		NRR/DSSA/SRXB	1	1	
	NUDOCS-ABSTRACT	1	1		OC/LEDCB	1	0	
	OGC/HDS2	1	0		<u>REG FILE</u> 01	1	1	
EXTERNAL:	NRC PDR	1	1		NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR    21    ENCL    19

*MAF*



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

Robert G. Byram  
Senior Vice President-Nuclear  
215/774-7502

AUG 16 1993

Director of Nuclear Reactor Regulation  
Attention: Mr. C. L. Miller, Project Director  
Project Directorate I-2  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION  
INFORMATION ON SPENT FUEL POOL COOLING  
PLA-4012**

**FILE A17-8**

**Docket Nos. 50-387  
and 50-388**

- References:
1. PLA-3978, R.G. Byram to C.L. Miller, "Request for Additional Information on the Effects of a Loss of Spent Fuel Pool Cooling Event Following a Loss of Coolant Accident", dated May 24, 1993.
  2. PLA-3996, R.G. Byram to C.L. Miller, "Information on Licensing Basis of Spent Fuel Pool Cooling System", dated July 6, 1993.

Dear Mr. Miller:

On July 8, 1993, PP&L met with the NRC to discuss the design and operation of the Spent Fuel Pool Cooling systems installed in Susquehanna SES Units 1 and 2. During the course of this presentation, we provided updated technical information since the Reference 1 submittal, and discussed PP&L's position on the SSES licensing basis as documented in Reference 2. Our major conclusions regarding the postulated accident scenario (design basis LOCA coupled with an extended loss of Spent Fuel Pool Cooling) were as follows:

- Time to boil is much greater than 25 hours at any point when the conditions presented by the accident scenario become a concern. Immediate operator actions are not required to restore spent fuel pool cooling. Sufficient time will be available to take appropriate operator actions to restore spent fuel pool cooling and prevent boiling.
- Cooling can be restored prior to boiling by either restoration of the normal Spent Fuel Pool Cooling system, or the safety-related, diesel-backed RHR system in Fuel Pool Cooling Mode.

170065

9308170354 930816  
PDR ADOCK 05000387  
P PDR



ADD 1/1

1950


- The Emergency Service Water valves that support makeup to the Spent Fuel Pool have been determined to be accessible (i.e.  $< 5$  Rem), even if a Regulatory Guide 1.3 source term is assumed.
- Emergency Service Water makeup to one Spent Fuel Pool will eventually fill both pools. Therefore, access to the accident unit is not required to provide makeup water to its Spent Fuel Pool.
- Access to the non-LOCA unit is always assured due to the capability to isolate its ventilation system from the accident unit using controls that exist in the main control room.
- Removing the cask storage pit gates will provide capability to utilize the non-LOCA unit Spent Fuel Pool Cooling system if available, or the RHR Fuel Pool Cooling Mode if it is not.
- Even if the Spent Fuel Pool is assumed to boil and no operator action to restore cooling occurs for 30 days, the resultant environmental impacts will not prevent adequate long term core cooling from being maintained.
- Procedures have been improved and operators have been trained to assure the proper response to a loss of Spent Fuel Pool Cooling. Modifications to install improved level and temperature indication to the Spent Fuel Pools, although not required to meet the Licensing Basis of Susquehanna SES, are being pursued in order to further strengthen the operator response to this event. These modifications also address previous recommendations made by our internal assessment group to add level and temperature indication to assist the operators in daily operation of the fuel pool cooling system.
- The Licensing Basis of Susquehanna SES considers loss of spent fuel pool cooling resulting in pool boiling to be initiated from a seismic event, not a LOCA, and this is in compliance with regulatory requirements.
- The SSES Licensing Basis is acceptable due to the lack of a need for immediate operator action to restore spent fuel pool cooling, the extremely low probability of a DBA LOCA coupled with an extended loss of pool cooling (per the SSES IPE this is on the order of  $10E-15$ ), and the fact that ensuring that the spent fuel is kept water covered is an operator priority.

27.1.1

27.1.1

The attached report provides further documentation of the details behind the above conclusions, and is provided in response to your request at the July 8 meeting. If you should have any questions on this material, please contact us.

Very truly yours,



R. G. Byram

Attachment

cc: NRC Document Control Desk (original)  
NRC Region I  
Mr. G. S. Barber, NRC Sr. Resident Inspector - SSES  
Mr. R. J. Clark, NRC Sr. Project Manager - Rockville