

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103200571 DOC. DATE: 81/03/13 NOTARIZED: NO  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania  
 AUTH. NAME AUTHUR AFFILIATION  
 CURTIS, N.W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 TEDESCO, R.L. Assistant Director for Licensing

DOCKET #  
 05000387  
05000388

SUBJECT: Responds to 810220 request. Verification of operability of security sys not required prior to issuance of SER. Design of sys evaluated in SER & verification of operability & completion is audited prior to fuel load.

DISTRIBUTION CODE: S003S COPIES RECEIVED: LTR 1 ENCL 2 SIZE: 1  
 TITLE: Non-Proprietary Info re Security Plans

NOTES: Send I&E 3 copies FSAR & all amends.  
 Send I&E 3 copies FSAR & all amends.

05000387  
 05000388

ACTION:	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
ACTION:	YOUNGBLOOD, B		1	0	RUSHBROOK, M.		1	0
	STARK, R.		1	0				
INTERNAL:	I&E	05	2	2	MCCORKLE, G.		1	
	NRC PDR	02	1	1	<del>REG. ENCL</del>	01	1	
	SIT ANAL BR	04	1	1	SSPB	08	1	
EXTERNAL:	ACRS	07	1		LPDR	03	1	

MA 4

4/1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 2


0

Docket Nos. 50-387  
50-388

NORMAN W. CURTIS  
Vice President-Engineering & Construction-Nuclear  
770-5381

March 13, 1981

Mr. Robert L. Tedesco  
Assistant Director for Licensing  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555



SUSQUEHANNA STEAM ELECTRIC STATION  
FINAL RESPONSES FOR THE SER  
ER 100450 FILE 841-2  
PLA-658

Dear Mr. Tedesco:

In your letter of February 20, 1981, you requested confirmation that the plant security system has been essentially completed and is ready for the NRC security inspection prior to completing the Susquehanna Safety Evaluation Report (SER). This is contrary to our understanding of normal practice which is that the design of a system is evaluated in the SER and the verification of operability and completion is audited prior to fuel load. We believe that the verification of operability of the security system is not required prior to issuance of the SER.

We would be pleased to discuss this further at your convenience.

Very truly yours,

N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

CTC:mcb  
cc: Mr. R. M. Stark - NRC  
Mr. B. J. Youngblood - NRC

5003  
5  
110



11-11-68