

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8105050463. DOC. DATE: 81/04/30 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 YOUNGBLOOD, B.J. Licensing Branch 1

SUBJECT: Advises that util will revise facility senior executive svc
 Tech Specs to include level 8 trip & turbine bypass sys, per
 SER Outstanding Issue 67.

DISTRIBUTION CODE: 8001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send I&E 3 copies FSAR & all amends. 05000387
 Send I&E 3 copies FSAR & all amends. 05000388

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
ACTION:	A/D LICENSNG	1		LIC BR #2 BC	1	
	RUSHBROOK, M.	1		STARK, R. 04	1	
INTERNAL:	ACCID EVAL BR26	1		AUX SYS BR 07	1	
	CHEM ENG BR 08	1		CONT SYS BR 09	1	
	CORE PERF BR 10	1		EFF TR SYS BR12	1	
	EMERG PREP 22	1		EQUIP QUAL BR13	3	
	GEOSCIENCES 14	1		HUM FACT ENG BR	1	
	HYD/GEO BR 15	2		I&C SYS BR 16	1	
	I&E 06	3		LIC GUID BR	1	
	LIC QUAL BR	1		MATL ENG BR 17	1	
	MECH ENG BR 18	1		MPA	1	
	NRC PDR 02	1		OELD	1	
	OP LIC BR	1		POWER SYS BR 19	1	
	PROC/TST REV 20	1		QA BR 21	1	
	RAD ASSESS BR22	1		REAC SYS BR 23	1	
	REG FILE 01	1		SIT ANAL BR 24	1	
STRUCT ENG BR25	1					
EXTERNAL:	ACRS 27	16	14	LPDR 03	1	
	NSIC 05	1				

MAY 06 1981

MHY

TOTAL NUMBER OF COPIES REQUIRED: LTR 56 ENCL 0

5

PP&L

TWO NORTH NINTH STREET, ALLENTOWN, PA. 18101 PHONE: (215) 770-5151

NORMAN W. CURTIS
Vice President-Engineering & Construction-Nuclear
770-5381

April 30, 1981

Mr. B.J. Youngblood
Licensing Branch No. 1
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Susquehanna Steam Electric Station
SER Outstanding Issue 67
ER100450 File 841-2
PLA-740

Dear Mr. Youngblood:

Pennsylvania Power and Light Company will revise the Susquehanna
SES Technical Specifications to include the level 8 trip and turbine
bypass system. This addresses SER Outstanding Issue 67.

Very truly yours,

N. W. Curtis

N.W. Curtis
Vice President-Engineering and Construction-Nuclear

cc: R.M. Stark

*Boo
s/o*

8105050 463
A