

PRELIMINARY DATA SHEET FOR
 NUREG-0737 S/RV TEST
 WYLE LABS, HUNTSVILLE, ALA.

DATE TESTED 3-24-81

RUN/TEST NO. 404

S/RV MODEL NO. HB-65-BP-FN

S/RV MANUFACTURER CROSBY

S/RV SERIAL NO. N63580-00-0019

6R10

TYPE OF TEST

STEAM, SATURATED

LOADS I SUPPORTS

TEST RESULTS

S/RV OPENED ON COMMAND

YES

S/RV CLOSED ON COMMAND

YES

S/RV FLUID TEST CONDITIONS

FLUID TEMPERATURE

555°F

INLET PRESSURE

1080 PSIG

S/RV FLOW RATE

LATER

S/RV OPENING TIME (MAIN DISK LIFT TIME)

25mSec

VALVE INTEGRITY DEMONSTRATED BY:

VISUAL INSPECTION

YES

POST-TEST HYDRO⁺

N/A*

POST-TEST DISASSEMBLY INSPECTION⁺

N/A

FACILITY INTEGRITY DEMONSTRATED

YES

+ ONLY ONCE PER VALVE AT END OF TEST SEQUENCE

* NOT APPLICABLE