



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 127
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 21, 1984, as superseded November 5, 1985 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:


8603120334 860226
PDR ADDCK 05000259
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 127, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective ninety days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 26, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 127

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

338

2. The marginal lines on these pages denote the area being changed.



6.0 ADMINISTRATIVE CONTROLS

6.3 Procedures

- A. Detailed written procedures, including applicable checkoff lists covering items listed below shall be prepared, approved and adhered to.
1. Normal startup, operation and shutdown of the reactor and of all systems and components involving nuclear safety of the facility.
 2. Refueling operations.
 3. Actions to be taken to correct specific and foreseen potential malfunctions of systems or components, including responses to alarms, suspected primary system leaks and abnormal reactivity changes.
 4. Emergency conditions involving potential or actual release of radioactivity.
 5. Preventive or corrective maintenance operations which could have an effect on the safety of the reactor.
 6. Surveillance and testing requirements.
 7. Radiation control procedures.
 8. Radiological Emergency Plan implementing procedures.
 9. Plant security program implementing procedures.
 10. Fire protection and prevention procedures.
 11. -Limitations on the amount of overtime worked by individuals performing safety-related functions in accordance with the NRC policy statement on working hours (Generic Letter No. 82-12).
- B. Written procedures pertaining to those items listed above shall be reviewed by PORC and approved by the plant superintendent prior to implementation. Temporary changes to a procedure which do not change the intent of the approved procedure may be made by a member of the plant staff knowledgeable in the area affected by the procedure except that temporary changes to those items listed above except item 5 require the additional approval of a member of the plant staff who holds a Senior Reactor Operator license on the unit affected. Such changes shall be documented and subsequently reviewed by PORC and approved by the plant superintendent."



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 122
License No. DPR-52


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 21, 1984, as superseded November 5, 1985 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 122, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective ninety days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 26, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 122

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

338

2. The marginal lines on these pages denote the area being changed.

6.0 ADMINISTRATIVE CONTROLS

6.3 Procedures

- A. Detailed written procedures, including applicable checkoff lists covering items listed below shall be prepared, approved and adhered to.
1. Normal startup, operation and shutdown of the reactor and of all systems and components involving nuclear safety of the facility.
 2. Refueling operations.
 3. Actions to be taken to correct specific and foreseen potential malfunctions of systems or components, including responses to alarms, suspected primary system leaks and abnormal reactivity changes.
 4. Emergency conditions involving potential or actual release of radioactivity.
 5. Preventive or corrective maintenance operations which could have an effect on the safety of the reactor.
 6. Surveillance and testing requirements.
 7. Radiation control procedures.
 8. Radiological Emergency Plan implementing procedures.
 9. Plant security program implementing procedures.
 10. Fire protection and prevention procedures.
 11. Limitations on the amount of overtime worked by individuals performing safety-related functions in accordance with the NRC policy statement on working hours (Generic Letter No. 82-12).
- B. Written procedures pertaining to those items listed above shall be reviewed by PORC and approved by the plant superintendent prior to implementation. Temporary changes to a procedure which do not change the intent of the approved procedure may be made by a member of the plant staff knowledgeable in the area affected by the procedure except that temporary changes to those items listed above except item 5 require the additional approval of a member of the plant staff who holds a Senior Reactor Operator license on the unit affected. Such changes shall be documented and subsequently reviewed by PORC and approved by the plant superintendent."



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 98
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 21, 1985, as superseded November 5, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:




(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 98, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective ninety days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 26, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 98

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

368

2. The marginal lines on these pages denote the area being changed.

6.0 ADMINISTRATIVE CONTROLS

6.3 Procedures

- A. Detailed written procedures, including applicable checkoff lists covering items listed below shall be prepared, approved and adhered to.
1. Normal startup, operation and shutdown of the reactor and of all systems and components involving nuclear safety of the facility.
 2. Refueling operations.
 3. Actions to be taken to correct specific and foreseen potential malfunctions of systems or components, including responses to alarms, suspected primary system leaks and abnormal reactivity changes.
 4. Emergency conditions involving potential or actual release of radioactivity.
 5. Preventive or corrective maintenance operations which could have an effect on the safety of the reactor.
 6. Surveillance and testing requirements.
 7. Radiation control procedures.
 8. Radiological Emergency Plan implementing procedures.
 9. Plant security program implementing procedures.
 10. Fire protection and prevention procedures.
 11. Limitations on the amount of overtime worked by individuals performing safety-related functions in accordance with the NRC policy statement on working-hours (Generic Letter No. 82-12).
- B. Written procedures pertaining to those items listed above shall be reviewed by PORC and approved by the plant superintendent prior to implementation. Temporary changes to a procedure which do not change the intent of the approved procedure may be made by a member of the plant staff knowledgeable in the area affected by the procedure except that temporary changes to those items listed above except item 5 require the additional approval of a member of the plant staff who holds a Senior Reactor Operator license on the unit affected. Such changes shall be documented and subsequently reviewed by PORC and approved by the plant superintendent.