

ENCLOSURE

Request for Additional Information  
Susquehanna Steam Electric Station  
Units 1 and 2  
Docket Numbers 50/387/388

371.28  
(2.4.2)

You have not documented that the pressure resisting doors described on page 2.4-10 will prevent water from reaching safety-related equipment, nor have you indicated what procedures will be used to ensure that the doors will be properly closed during a flood event. You state that "prototype assemblies are tested to insure their conformance to specified performance criteria . . ." Describe the performance criteria relevant to flood protection. Identify and locate on appropriate maps and figures those doors that provide flood protection. Identify the practices, technical specifications or other procedures that will insure that the doors will be properly closed during a flood event. Alternately, if you can document that the maximum water level will be below the sill level of the doors to all safety related buildings, it may not be necessary to keep the doors shut.

7908200084

ALL INFORMATION CONTAINED  
HEREIN IS UNCLASSIFIED  
DATE 11/19/01 BY 60322 UCBAW/STP

JUL 26 1979