

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8207080366 DOC. DATE: 82/07/07 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Justifies need for footnote "not accessible" on Tech Spec Table 3.3.7.9-1. Instruments are under raised floor & above false ceiling of control room.

DISTRIBUTION CODE: B002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: Fire Protection (Prior to Issuance of OL).

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME	LIC BR #2 BC	LTR	ENCL	ID CODE/NAME		LTR	ENCL
			1	1	PERCH, R.	01	1	1
INTERNAL:	ELD/HDS4		1	0	IE FILE	07	1	1
	NRR/DE/ADMQE		1	0	NRR/DE/CEB	06	4	4
	NRR/DSI/ASB		1	1	<u>REG FILE</u>	04	1	1
	RGN1		1	1				
EXTERNAL:	ACRS	10	10	10	LPDR	03	2	2
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

July 7, 1982

Mr. A. Schwencer, Chief
Licensing Branch No., 2
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
INACCESSIBLE FIRE DETECTION
ER 100450
PLA-1172

FILE 841-2

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

Pursuant to an NRC staff request, the purpose of this letter is to justify the need for the footnote "Not accessible" on Technical Specification Table 3.3.7.9-1. As mentioned in PLA-1123, dated June 15, 1982, "Susquehanna SES has several fire detection instruments installed which, because of their locations, are especially difficult to access. These areas are under the raised floor and above the false ceiling of the Control Room." These instruments, which are accurately referenced in the June 24, 1982 draft of the Susquehanna SES Unit 1 Tech Specs will be demonstrated OPERABLE per SURVEILLANCE REQUIREMENT 4.3.7.9.1.

For the reasons mentioned above, Pennsylvania Power and Light Company requests that the referenced parts of Specification 3/4.3.7.9 remain unchanged.

Very Truly yours,

N. W. Curtis
Vice President - Engineering & Construction - Nuclear

RRS

cc: R. L. Perch - NRC
R. R. Bottimore - NRC
R. Eberly - NRC

13002