

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8207150389 DOC. DATE: 82/07/09 NOTARIZED: NO
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania
 AUTH. NAME: AUTHUR AFFILIATION: Pennsylvania Power & Light Co.
 CLERK: TIS, N.W. RECIPIENT AFFILIATION: Licensing Branch 2
 RECIP. NAME: SCHWENCKER, A.


DOCKET # 05000387
05000388

SUBJECT: Responds to 820707 request re walkdown of masonry walls in control bldg. No safety-related items found attached to or in vicinity of subj walls.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	A/D LICENSNG		1	0	LIC BR #2 BC		1	0	
	LIC BR #2 LA		1	0	PERCH, R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3	
	NRR/DE/CEB	11	1	1	NRR/DE/EQB	13	3	3	
	NRR/DE/GB	28	2	2	NRR/DE/HGEB	30	2	2	
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1	
	NRR/DE/QAB	21	1	1	NRR/DE/SAB	24	1	1	
	NRR/DE/SEB	25	1	1	NRR/DHFS/HFEB40		1	1	
	NRR/DHFS/LQB	32	1	1	NRR/DHFS/OLB	34	1	1	
	NRR/DHFS/PIRB20		1	1	NRR/DSI/AEB	26	1	1	
	NRR/DSI/ASB	27	1	1	NRR/DSI/CPB	10	1	1	
	NRR/DSI/CSB	09	1	1	NRR/DSI/ETSB	12	1	1	
	NRR/DSI/ICSB	16	1	1	NRR/DSI/PSB	19	1	1	
	NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1	
	NRR/DST/LGB	33	1	1	REG FILE	04	1	1	
	RGN1		2	2	RM/DDAMI/MIS		1	0	
EXTERNAL:	ACRS	41	10	10	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	2	2	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215 / 770-5381

July 9, 1982

Mr. A. Schwencer, Chief
Licensing Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
CONTROL BUILDING MASONRY WALLS
ER 100450 FILE 841-2
PLA-1179

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

As per the request of Mr. N. Romney on July 7, 1982, the two masonry walls in the Control Building have been walked down to verify that there are no safety-related items attached to or in the vicinity of these walls. The walls are located on elevation 656'-0" in the Chemical Waste Room (#C-11) and on elevation 676'-0" in the Demineralizer Vessel Rooms (#J-117 and #J-118 - the wall is between these rooms).

The Bechtel Resident Engineering Safety Impact Walkdown Team performed the walkdown since they are the most familiar with all systems in these areas. Prior to this walkdown, these areas were walked down and found to have no safety-related items. This was done as part of the Safety Impact Program for all areas prior to turnover to Pennsylvania Power & Light Company.

Very truly yours,

N.W. Curtis
Vice President - Engineering & Construction - Nuclear

DPM

cc: R.L. Perch - NRC

13001