



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 130
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated April 8, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

8611210254 861117
PDR ADOCK 05000259
P PDR




(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 130, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 90 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 17, 1986



ATTACHMENT TO LICENSE AMENDMENT NO. 130

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

Pages

56
86

2. The marginal lines on these pages denote the area being changed.



Amendment No. 88, 114, 130

TABLE 3.2.A
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip S:s(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
2 (12)	Instrument Channel - Main Steam Line Tunnel High Temperature	≤ 200°F	B	1. Above trip setting initiates Main Steam Line Isolation.
2 (14)	Instrument Channel - Reactor Water Cleanup System Floor Drain High Temperature	160 - 180°F	C	1. Above trip setting initiates Isolation of Reactor Water Cleanup Lin. from Reactor and Reactor Water Return Line.
2	Instrument Channel - Reactor Water Cleanup System Space High Temperature	160 - 180°F	C	1. Same as above
1	Instrument Channel - Reactor Building Ventilation High Radiation - Reactor Zone	≤ 100 mR/hr or downscale	G	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate reactor zone and refueling floor. c. Close atmosphere control system.
1	Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	≤ 100 mR/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate refueling floor. c. Close atmosphere control system.
2 (7) (8)	Instrument Channel SGTS Flow - Train A Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train B Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train C Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.




TABLE 4.2.A
SURVEILLANCE REQUIREMENTS FOR PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

<u>Function</u>	<u>Functional Test</u>	<u>Calibration Frequency</u>	<u>Instrument Check</u>
Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	(1) (14) (22)	once/3 months	once/day (8)
Instrument Channel - SGTS Train A Heater	(9)	(9)	N/A
Instrument Channel - SGTS Train B Heater	(9)	(9)	N/A
Instrument Channel - SGTS Train C Heater	(9)	(9)	N/A
Reactor Building Isolation Timer (refueling floor)	(9)	once/operating cycle	N/A
Reactor Building Isolation Timer (reactor zone)	(9)	once/operating cycle	N/A



100

100

100

100

100



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 126
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated April 8, 1986 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:



3
1
2
3
4


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.126 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 90 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 17, 1986



[Faint, illegible text or markings in the center of the page]

ATTACHMENT TO LICENSE AMENDMENT NO. 126

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

Pages

56
86

2. The marginal lines on these pages denote the area being changed.



TABLE 3.2.A
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
2 (12)	Instrument Channel - Main Steam Line Tunnel High Temperature	$\leq 200^{\circ}\text{F}$	B	1. Above trip setting initiates Main Steam Line Isolation.
2 (14)	Instrument Channel - Reactor Water Cleanup System Floor Drain High Temperature	160 - 180 $^{\circ}\text{F}$	C	1. Above trip setting initiates Isolation of Reactor Water Cleanup Lin. from Reactor and Reactor Water Return Line.
2	Instrument Channel - Reactor Water Cleanup System Space High Temperature	160 - 180 $^{\circ}\text{F}$	C	1. Same as above
1	Instrument Channel - Reactor Building Ventilation High Radiation - Reactor Zone	≤ 100 mr/hr or downscale	G	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate reactor zone and refueling floor. c. Close atmosphere control system.
1	Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	≤ 100 mr/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate refueling floor. c. Close atmosphere control system.
2 (7) (8)	Instrument Channel SGTS Flow - Train A Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train B Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train C Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.



[Faint, illegible text spanning the width of the page, possibly bleed-through from the reverse side.]

TABLE 4.2.A
SURVEILLANCE REQUIREMENTS FOR PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

<u>Function</u>	<u>Functional Test</u>	<u>Calibration Frequency</u>	<u>Instrument Check</u>
Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	(1) (14) (22)	once/3 months	once/day (8)
Instrument Channel - SGTS Train A Heater	(9)	(9)	N/A
Instrument Channel - SGTS Train B Heater	(9)	(9)	N/A
Instrument Channel - SGTS Train C Heater	(9)	(9)	N/A
Reactor Building Isolation Timer (refueling floor)	(9)	once/operating cycle	N/A
86			
Reactor Building Isolation Timer (reactor zone)	(9)	once/operating cycle	N/A





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 101
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated April 8, 1986 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:




(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 101, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 90 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Müller, Director
BWR Project Directorate #2
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 17, 1986



ATTACHMENT TO LICENSE AMENDMENT NO. 101

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

Pages

58

89

2. The marginal lines on these pages denote the area being changed.



TABLE 3.2.A
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No.
Instrument
Channels Operable
per Trip Sys(1)(11)

	Function	Trip Level Setting	Action (1)	Remarks
2 (14)	Instrument Channel - Reactor Water Cleanup System Floor Drain High Temperature	160 - 180°F	C	1. Above trip setting initiates isolation of Reactor Water Cleanup Lin. from Reactor and Reactor Water Return Line.
2	Instrument Channel - Reactor Water Cleanup System Space High Temperature	160 - 180°F	C	1. Same as above
1	Instrument Channel - Reactor Building Venti- lation High Radiation - Reactor Zone	≤ 100 nr/hr or downscale	G	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate reactor zone and refueling floor. c. Close atmosphere control system.
1	Instrument Channel - Reactor Building Venti- lation High Radiation - Refueling Zone	≤ 100 nr/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate refueling floor. c. Close atmosphere control system.
2 (7) (8)	Instrument Channel SGTS Flow - Train A Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train B Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.
2 (7) (8)	Instrument Channel SGTS Flow - Train C Heater	R.H. Heater ≤ 2000 cfm	H and (A or F)	Below 2000 cfm, trip setting R.H. heater will shut off.



TABLE 4.2.A
SURVEILLANCE REQUIREMENTS FOR PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

<u>Function</u>	<u>Functional Test</u>	<u>Calibration Frequency</u>	<u>Instrument Check</u>
Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	(1) (14) (22)	once/3 months	once/day (8)
Instrument Channel - SGTS Train A Heater	(4)	(9)	N/A
Instrument Channel - SGTS Train B Heater	(4)	(9)	N/A
Instrument Channel - SGTS Train C Heater	(4)	(9)	N/A
Reactor Building Isolation Timer (refueling floor)	(4)	once/operating cycle	N/A
Reactor Building Isolation Timer (reactor zone)	(4)	once/operating cycle	N/A



11-11-11

11-11-11

11-11-11