

WELDING PROJECT  
SPECIFIC EMPLOYEE CONCERN  
EVALUATION REPORT

REPORT NUMBER: WP-18-SQN, R1

DATE 08-26-86

SUBJECT: EFFECTS OF LAMINATIONS ON WELD QUALITY

CONCERN CONSIDERED: XX-85-098-001

PREPARED BY J.E. Rose 8/25/86, OC, WP

REVIEWED BY R.M. Bateman 8/25/86, OC, WP

REVIEWED BY G.P. Lynskey 8/25/86, QA, WP

REVIEWED BY J.E. Martin 9/3/86, CEG-H, WELDING

APPROVED BY W.R. Brown 9/3/86, PROGRAM MANAGER

Revision 1 to this report incorporates comments made by the Senior Review Panel on 8/19/86.

8611120078 861105  
PDR ADDCK 05000259  
P PDR

SPECIFIC EMPLOYEE CONCERN

SUMMARY SHEET

Report Number: WP-18-SQN, R1

Report Title: EFFECTS OF LAMINATIONS ON WELD QUALITY

I. CONCERNS CONSIDERED: XX-85-098-001

II. ISSUES INVOLVED

Laminations in pipe prevented making an acceptable weld in unit 2 condenser.

III. STATEMENT OF CONCERN/ISSUE VALIDITY

Validity: Y X, N \_\_\_\_\_, Substantiated: Y \_\_\_\_\_, N X

IV. EFFECT ON HARDWARE AND/OR PROGRAM

None

V. JUSTIFICATION

Laminations in pipe are parallel to principal stress direction. Welds terminate the lamination at the weld joint.

VI. RECOMMENDATION AND/OR CORRECTIVE ACTION NEEDED

None

VII. REINSPECTION NEEDED: Y \_\_\_\_\_, N X

VIII. ISSUE CLOSURE

By this report.

IX. ATTACHMENT

1. Text of Employee Concerns





ASME Section III which defines requirements for nuclear pressure piping in safety systems which are designed to much more stringent requirements than those used for condenser construction accepts laminations with qualifications. ASME Section III, NB-5130 does not require weld repair of weld prep laminations which are one-inch and less in length. Those which exceed one-inch in length are customarily ground back three eighths-inch and sealed-off by welding. This sealing-off simply moves the lamination a distance from the weld joint which will prevent small porosity from appearing in the weld joint during subsequent welding. This is done as a convenience for subsequent nondestructive testing, if required. The net effect of welding over a lamination is simply to stop it and seal it off. Welding over laminations will usually evolve a small amount of oxides or gases into the molten weld puddle which will appear as porosity. This porosity is bothersome to the welder, but if repaired, is acceptable.

| R1  
|

In summary, the issue voiced in this concern is valid but not substantiated. It has been determined not to be detrimental for the following reasons:

1. ASME Class 1 rules state that weld prep laminations one-inch and less in length are acceptable material conditions which do not require weld repair. Those greater than one-inch are allowed to be weld repaired after grinding to a specified depth.
2. Condensers are constructed to requirements less stringent than ASME Class 1 which do not address laminations as injurious defects.
3. Laminations are commonly occurring discontinuities in wrought steel products and are not prohibited by material specifications.
4. The effect of a lamination in a pipe subjected to internal pressure is of no concern.
5. Laminations pose no problem to weld joint integrity.

Based on the foregoing analysis, this concern is closed.

(EMPLOYEE CONCERNS)

03/24/86

11:43:17

LOC	STATUS	RESP	-QIC-	PPP	CFR	INSP	TC	-----CONCERN-----	PROBLEM ID
								NR XX-85-098-001	WCMHC

KEYWORDS: WELDMENT QUALITY SPECIFIC

X: S Y: C Z: Y

SEQUOYAH: THERE WAS A LAMINATED PIPE 12" OR 14" DIAMETER COMING OUT OF THE CONDENSER IN UNIT 2 TURBINE BUILDING. THE CRAFT COULD NOT GET A GOOD WELD DUE TO LAMINATION. OCCURRED IN 1977. DETAILS KNOWN TO QIC, WITHHELD DUE TO CONFIDENTIALITY. CONST. DEPARTMENT CONCERN. C/I HAS NO ADDITIONAL INFORMATION.

TECHNICAL COMMENTARY:

ISSUE CONSIDERED: LAMINATION IN PIPE PREVENTED MAKING A GOOD BUTT WELD IN THE UNIT TWO CONDENSER.

