

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707210652 DOC. DATE: 87/07/14 NOTARIZED: NO DOCKET #  
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259  
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260  
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296


AUTH. NAME AUTHORITY AFFILIATION  
 GRIDLEY, R. Tennessee Valley Authority  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards 90 day rept on secondary containment leak rate testing. All three reactor zones & common refuel zone tested on 870504. Secondary containment capability of maintaining less than .25 inches H2O w/less than 12,000 CFM inleakage.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: DR Submittal: Append J Containment Leak Rate Testing

NOTES: Zwolinski 3 cy. 1 cy ea to: Axelrad, Ebnetter, S. Richardson, 05000259  
 Liaw, G. Zech, OI, DIA.  
 Zwolinski 3 cy. 1cy ea to: Axelrad, Ebnetter, S. Richardson, 05000260  
 Liaw, G. Zech, OI, DIA.  
 Zwolinski 3 cy. 1cy ea to: Axelrad, Ebnetter, S. Richardson, 05000296  
 Liaw, G. Zech, OI, DIA.

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	JAMERSON, C	1 0	PD	5 5
	GEARS, G	1 1	STANG, J	1 1
INTERNAL:	ACRS	10 10	ARM/DAF/LFMB	1 0
	NRR/DEST/PSB	1 1	OGC/HDS2	1 1
	<u>REG FILE</u> 01	1 1	RES DEPY GI	1 1
	RES TELFORD, J	1 1	RES/DE/EIB	1 1
	RES/DE/SSEB	1 1	RES/DRAA/SAIB	1 1
	RES/DRPS/RPSIB	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		
NOTES:		12 12		



TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

JUL 14 1987

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of	)	Docket Nos. 50-259
Tennessee Valley Authority	)	50-260
		50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - REACTOR BUILDING CONTAINMENT LEAK RATE TEST  
90-DAY REPORT

Enclosed is the report on secondary containment leak rate testing for the Browns Ferry Nuclear Plant. The secondary containment for all three reactor zones and the common refuel zone was leak rate tested on May 4, 1987. This report is submitted pursuant to Browns Ferry technical specifications section 6.7.3.C.1.a. If you have any questions, please call G. W. Morris at (205) 729-3583.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Adair*  
 for R. Gridley, Director  
 Nuclear Safety and Licensing

Enclosure  
cc: See page 2

8707210652 870714  
 PDR ADDCK 05000259  
 R PDR

*A017  
1/1*

JUL 14 1987

U.S. Nuclear Regulatory Commission

cc (Enclosure):

Mr. G. G. Zech, Assistant Director  
Regional Inspections  
Division of TVA Projects  
Office of Special Projects  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., NW, Suite 2900  
Atlanta, Georgia 30323

Mr. J. A. Zwolinski, Assistant Director  
for Projects  
Division of TVA Projects  
Office of Special Projects  
U.S. Nuclear Regulatory Commission  
4350 East West Highway  
EWW 322  
Bethesda, Maryland 20814

Browns Ferry Resident Inspector  
Browns Ferry Nuclear Plant  
P.O. Box 311  
Athens, Alabama 35611

1950

...

...  
...  
...  
...  
...  
...  
...  
...

...  
...  
...  
...  
...  
...  
...  
...

...  
...  
...  
...  
...

ENCLOSURE  
SECONDARY CONTAINMENT LEAK-RATE TEST  
BROWNS FERRY NUCLEAR PLANT (BFN)

1.0 Browns Ferry Nuclear Plant (BFN) Secondary Containment Leak Rate Test Report per technical specification 6.7.3.C.1.a.

2.0 Purpose

This report describes the results and analysis of the test data taken during leak rate testing of the BFN secondary containment system. The test was performed to verify the status of the secondary containment before commencement of outage activities conducted in and around the fuel pool.

3.0 Procedure

Surveillance Instruction (SI) 4.7.C outlines the procedure followed during secondary containment leak rate testing.

4.0 Data

The SI was performed concurrently on all zones. SI 4.7.C data sheets list the following test data:

1. Standby Gas Treatment  
System flowrate: 9986 CFM
  
2. Reactor Building differential pressures

Unit 1 Reactor Zone	.29 in H <sub>2</sub> O
Unit 2 Reactor Zone	.31 in H <sub>2</sub> O
Unit 3 Reactor Zone	.29 in H <sub>2</sub> O
Unit 1 Refuel Zone	.29 in H <sub>2</sub> O
Unit 2 Refuel Zone	.30 in H <sub>2</sub> O
Unit 2 Refuel Zone	.29 in H <sub>2</sub> O
  
3. Wind Speed 3.0 MPH
  
4. Wind Direction 332°

5. Analysis and Interpretation

Technical specification 3.7.C.3. requires that secondary containment integrity be maintained in the refueling zone when performing operations over spent fuel pools. SI 4.7.C demonstrates secondary containment integrity by assessing the capability of the secondary containment system to maintain 1/4" water vacuum under calm wind ( $\leq 5$  MPH) conditions with a system leakage rate of not more than 12,000 CFM (specified in BFN technical specification 4.7.C.1.a).

The secondary containment (all three reactor zones and the common refuel zone) was leak-rate tested per BFN SI 4.7.C on May 4, 1987. The test was satisfactorily performed. The results proved the secondary containment capability of maintaining less than -.25 inches H<sub>2</sub>O with less than 12,000 CFM inleakage.