

February 1, 2018

PG&E Letter DCL-18-004

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

EA-12-049  
10 CFR 50.54(f)

Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
Errata for the Diablo Canyon Power Plant Mitigating Strategies Assessment (MSA)  
for Flooding Report

References:

1. PG&E Letter to NRC, DCL-17-024, "Submittal of the Diablo Canyon Power Plant Mitigating Strategies Assessment for Flooding Report," April 6, 2017

Dear Commissioners and Staff:

Pacific Gas and Electric Company (PG&E) submitted the MSA for Flooding Report to the NRC in April 2017 (Reference 1). During subsequent reviews of this submittal, it was discovered that Table 1 of the report referenced an incorrect elevation datum. As previously discussed with your staff, the following changes were made to correct the table:

- The datum referenced in the second column of Table 1 entitled "Stillwater Elevation and Reevaluated Hazard Elevation (ft NAVD88)" was incorrectly shown as "(ft NAVD88);" whereas, the values shown in the table are calculated based on "(local PG&E datum)." To correct this error, the column datum was changed from (ft NAVD88) to (ft local PG&E datum).
- The relationship between "local PG&E datum" and "NAVD88 datum" was clarified within Note 3 of the table to state that 0.687 feet should be added to the "local PG&E datum" to convert these values to "NAVD88 datum."
- The first entry in column 2 for Door A1.1 was changed from 87.48 (ft NAVD88) to 86.79 (ft local PG&E datum) to be consistent with the datum clarification.

No other changes were made in Table 1 of the MSA for Flooding Report. Further, the evaluations and conclusions provided in Reference 1 remain unchanged.



PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

If you have any questions or require additional information, please contact Mr. Hossein Hamzehee at 805-545-4720.

I state under penalty of perjury that the foregoing is true and correct.

Executed on February 1, 2018.

Sincerely,

James M. Welsch  
*Vice President Nuclear Generation and Chief Nuclear Officer*

mem6/4539/50465780

cc: Diablo Distribution  
Brian E. Holian, Acting NRC/NRR Director  
Kriss M. Kennedy, NRC Region IV Administrator  
Christopher W. Newport, NRC Senior Resident Inspector  
Joseph M. Sebrosky, NRC Project Manager  
Balwant K. Singal, NRR Senior Project Manager